

August 03, 2018

Rob King
Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

RE: Project: DIST BACT-8/1
Pace Project No.: 7060114

Dear Rob King:

Enclosed are the analytical results for sample(s) received by the laboratory on August 01, 2018. The results relate only to the samples included in this report. Results reported herein conform to the most current, applicable TNI/NELAC standards and the laboratory's Quality Assurance Manual, where applicable, unless otherwise noted in the body of the report.

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Stu Murrell
stu.murrell@pacelabs.com
(631)694-3040
Project Manager

Enclosures

cc: Warren Booth, Hampton Bays Water District
John Collins, H2M Group
Stella Michaels, Hampton Bays Water District
Paul Ponturo, H2M Group



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: DIST BACT-8/1

Pace Project No.: 7060114

Long Island Certification IDs

575 Broad Hollow Rd, Melville, NY 11747

New York Certification #: 10478 Primary Accrediting Body

New Jersey Certification #: NY158

Pennsylvania Certification #: 68-00350

Connecticut Certification #: PH-0435

Maryland Certification #: 208

Rhode Island Certification #: LAO00340

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE SUMMARY

Project: DIST BACT-8/1

Pace Project No.: 7060114

Lab ID	Sample ID	Matrix	Date Collected	Date Received
7060114001	HB27	Drinking Water	08/01/18 08:20	08/01/18 16:45
7060114002	HB2	Drinking Water	08/01/18 07:45	08/01/18 16:45
7060114003	HB3	Drinking Water	08/01/18 08:00	08/01/18 16:45
7060114004	HB4	Drinking Water	08/01/18 08:35	08/01/18 16:45
7060114005	HB5	Drinking Water	08/01/18 08:50	08/01/18 16:45
7060114006	HB6	Drinking Water	08/01/18 09:05	08/01/18 16:45
7060114007	HB7	Drinking Water	08/01/18 09:20	08/01/18 16:45
7060114008	HB8	Drinking Water	08/01/18 09:40	08/01/18 16:45
7060114009	HB9	Drinking Water	08/01/18 07:30	08/01/18 16:45
7060114010	HB10	Drinking Water	08/01/18 10:00	08/01/18 16:45
7060114011	HB11	Drinking Water	08/01/18 10:20	08/01/18 16:45

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE ANALYTE COUNT

Project: DIST BACT-8/1

Pace Project No.: 7060114

Lab ID	Sample ID	Method	Analysts	Analytes Reported
7060114001	HB27	SM22 9223B Colilert	NML	2
7060114002	HB2	SM22 9223B Colilert	NML	2
7060114003	HB3	SM22 9223B Colilert	NML	2
7060114004	HB4	SM22 9223B Colilert	NML	2
7060114005	HB5	SM22 9223B Colilert	NML	2
7060114006	HB6	SM22 9223B Colilert	NML	2
7060114007	HB7	SM22 9223B Colilert	NML	2
7060114008	HB8	SM22 9223B Colilert	NML	2
7060114009	HB9	SM22 9223B Colilert	NML	2
7060114010	HB10	SM22 9223B Colilert	NML	2
7060114011	HB11	SM22 9223B Colilert	NML	2

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: DIST BACT-8/1

Pace Project No.: 7060114

Sample: HB27		Lab ID: 7060114001		Collected: 08/01/18 08:20	Received: 08/01/18 16:45	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual	
Field Chlorine and pH		Analytical Method:								
Field Residual Chlorine	0.82	mg/L			1		08/01/18 08:20		N3	
MBIO Total Coliform DW		Analytical Method: SM22 9223B Colilert Preparation Method: SM22 9223B Colilert								
Total Coliforms	Absent				1	08/01/18 18:45	08/02/18 12:45			
E.coli	Absent				1	08/01/18 18:45	08/02/18 12:45			

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: DIST BACT-8/1

Pace Project No.: 7060114

Sample: HB2		Lab ID: 7060114002		Collected: 08/01/18 07:45	Received: 08/01/18 16:45	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual	
Field Chlorine and pH		Analytical Method:								
Field Residual Chlorine	0.83	mg/L			1		08/01/18 07:45		N3	
MBIO Total Coliform DW		Analytical Method: SM22 9223B Colilert Preparation Method: SM22 9223B Colilert								
Total Coliforms	Absent				1	08/01/18 18:45	08/02/18 12:45			
E.coli	Absent				1	08/01/18 18:45	08/02/18 12:45			

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: DIST BACT-8/1

Pace Project No.: 7060114

Sample: HB3		Lab ID: 7060114003		Collected: 08/01/18 08:00	Received: 08/01/18 16:45	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual	
Field Chlorine and pH		Analytical Method:								
Field Residual Chlorine	0.63	mg/L			1		08/01/18 08:00		N3	
MBIO Total Coliform DW		Analytical Method: SM22 9223B Colilert Preparation Method: SM22 9223B Colilert								
Total Coliforms	Absent				1	08/01/18 18:45	08/02/18 12:45			
E.coli	Absent				1	08/01/18 18:45	08/02/18 12:45			

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: DIST BACT-8/1

Pace Project No.: 7060114

Sample: HB4		Lab ID: 7060114004		Collected: 08/01/18 08:35	Received: 08/01/18 16:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
Field Chlorine and pH		Analytical Method:							
Field Residual Chlorine	0.66	mg/L			1		08/01/18 08:35		N3
MBIO Total Coliform DW		Analytical Method: SM22 9223B Colilert Preparation Method: SM22 9223B Colilert							
Total Coliforms	Absent				1	08/01/18 18:45	08/02/18 12:45		
E.coli	Absent				1	08/01/18 18:45	08/02/18 12:45		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: DIST BACT-8/1

Pace Project No.: 7060114

Sample: HB5		Lab ID: 7060114005		Collected: 08/01/18 08:50	Received: 08/01/18 16:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
Field Chlorine and pH		Analytical Method:							
Field Residual Chlorine	0.57	mg/L			1		08/01/18 08:50		N3
MBIO Total Coliform DW		Analytical Method: SM22 9223B Colilert Preparation Method: SM22 9223B Colilert							
Total Coliforms	Absent				1	08/01/18 18:45	08/02/18 12:45		
E.coli	Absent				1	08/01/18 18:45	08/02/18 12:45		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: DIST BACT-8/1

Pace Project No.: 7060114

Sample: HB6		Lab ID: 7060114006		Collected: 08/01/18 09:05	Received: 08/01/18 16:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
Field Chlorine and pH		Analytical Method:							
Field Residual Chlorine	0.93	mg/L			1		08/01/18 09:05		N3
MBIO Total Coliform DW		Analytical Method: SM22 9223B Colilert Preparation Method: SM22 9223B Colilert							
Total Coliforms	Absent				1	08/01/18 18:45	08/02/18 12:45		
E.coli	Absent				1	08/01/18 18:45	08/02/18 12:45		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: DIST BACT-8/1

Pace Project No.: 7060114

Sample: HB7		Lab ID: 7060114007		Collected: 08/01/18 09:20	Received: 08/01/18 16:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
Field Chlorine and pH		Analytical Method:							
Field Residual Chlorine	0.55	mg/L			1		08/01/18 10:20		N3
MBIO Total Coliform DW		Analytical Method: SM22 9223B Colilert Preparation Method: SM22 9223B Colilert							
Total Coliforms	Absent				1	08/01/18 18:45	08/02/18 12:45		
E.coli	Absent				1	08/01/18 18:45	08/02/18 12:45		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: DIST BACT-8/1

Pace Project No.: 7060114

Sample: HB8		Lab ID: 7060114008		Collected: 08/01/18 09:40	Received: 08/01/18 16:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
Field Chlorine and pH		Analytical Method:							
Field Residual Chlorine	0.55	mg/L			1		08/01/18 09:40		N3
MBIO Total Coliform DW		Analytical Method: SM22 9223B Colilert Preparation Method: SM22 9223B Colilert							
Total Coliforms	Absent				1	08/01/18 18:45	08/02/18 12:45		
E.coli	Absent				1	08/01/18 18:45	08/02/18 12:45		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: DIST BACT-8/1

Pace Project No.: 7060114

Sample: HB9		Lab ID: 7060114009		Collected: 08/01/18 07:30	Received: 08/01/18 16:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
Field Chlorine and pH		Analytical Method:							
Field Residual Chlorine	0.73	mg/L			1		08/01/18 07:30		N3
MBIO Total Coliform DW		Analytical Method: SM22 9223B Colilert Preparation Method: SM22 9223B Colilert							
Total Coliforms	Absent				1	08/01/18 18:45	08/02/18 12:45		
E.coli	Absent				1	08/01/18 18:45	08/02/18 12:45		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: DIST BACT-8/1

Pace Project No.: 7060114

Sample: HB10		Lab ID: 7060114010		Collected: 08/01/18 10:00	Received: 08/01/18 16:45	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual	
Field Chlorine and pH		Analytical Method:								
Field Residual Chlorine	0.82	mg/L			1		08/01/18 10:00		N3	
MBIO Total Coliform DW		Analytical Method: SM22 9223B Colilert Preparation Method: SM22 9223B Colilert								
Total Coliforms	Absent				1	08/01/18 18:45	08/02/18 12:45			
E.coli	Absent				1	08/01/18 18:45	08/02/18 12:45			

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: DIST BACT-8/1

Pace Project No.: 7060114

Sample: HB11 **Lab ID: 7060114011** Collected: 08/01/18 10:20 Received: 08/01/18 16:45 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
Field Chlorine and pH									
Analytical Method:									
Field Residual Chlorine	0.61	mg/L			1		08/01/18 10:20		N3
MBIO Total Coliform DW									
Analytical Method: SM22 9223B Colilert Preparation Method: SM22 9223B Colilert									
Total Coliforms	Absent				1	08/01/18 18:45	08/02/18 12:45		
E.coli	Absent				1	08/01/18 18:45	08/02/18 12:45		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: DIST BACT-8/1

Pace Project No.: 7060114

QC Batch: 77651 Analysis Method: SM22 9223B Colilert
 QC Batch Method: SM22 9223B Colilert Analysis Description: TotColDW MBIO Total Coliform
 Associated Lab Samples: 7060114001, 7060114002, 7060114003, 7060114004, 7060114005, 7060114006, 7060114007, 7060114008, 7060114009, 7060114010, 7060114011

METHOD BLANK: 356869 Matrix: Drinking Water
 Associated Lab Samples: 7060114001, 7060114002, 7060114003, 7060114004, 7060114005, 7060114006, 7060114007, 7060114008, 7060114009, 7060114010, 7060114011

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
E.coli		Absent		08/02/18 12:45	
Total Coliforms		Absent		08/02/18 12:45	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: DIST BACT-8/1

Pace Project No.: 7060114

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

ANALYTE QUALIFIERS

N3 Accreditation is not offered by the relevant laboratory accrediting body for this parameter.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: DIST BACT-8/1

Pace Project No.: 7060114

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
7060114001	HB27		77593		
7060114002	HB2		77593		
7060114003	HB3		77593		
7060114004	HB4		77593		
7060114005	HB5		77593		
7060114006	HB6		77593		
7060114007	HB7		77593		
7060114008	HB8		77593		
7060114009	HB9		77593		
7060114010	HB10		77593		
7060114011	HB11		77593		
7060114001	HB27	SM22 9223B Colilert	77651	SM22 9223B Colilert	77652
7060114002	HB2	SM22 9223B Colilert	77651	SM22 9223B Colilert	77652
7060114003	HB3	SM22 9223B Colilert	77651	SM22 9223B Colilert	77652
7060114004	HB4	SM22 9223B Colilert	77651	SM22 9223B Colilert	77652
7060114005	HB5	SM22 9223B Colilert	77651	SM22 9223B Colilert	77652
7060114006	HB6	SM22 9223B Colilert	77651	SM22 9223B Colilert	77652
7060114007	HB7	SM22 9223B Colilert	77651	SM22 9223B Colilert	77652
7060114008	HB8	SM22 9223B Colilert	77651	SM22 9223B Colilert	77652
7060114009	HB9	SM22 9223B Colilert	77651	SM22 9223B Colilert	77652
7060114010	HB10	SM22 9223B Colilert	77651	SM22 9223B Colilert	77652
7060114011	HB11	SM22 9223B Colilert	77651	SM22 9223B Colilert	77652

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

WO#: 7060114



11747
16

Sample Request Form PUBLIC WATER SUPPLIER

Date: 8-1-18

Collected By: K. Tytwill

Accepted By: *[Signature]*

Cooler Temp: 3.7 °C

OK
8/1/18 WELL OFF LINE

1310 WELL RUN TO SYSTEM

YES NO VOC'S PRESERVED WITH HCl

Back 1045

Sample Types
 PW - Potable Water
 GW - Groundwater
 SW - Surface Water
 WW - Waste Water
 AQ - Aqueous
 S - Soil

Purpose
 RO - Routine
 RE - Resample
 S - Special

Origin
 D - Distribution
 RW - Raw Well
 TW - Treated Well
 T - Tank
 MW - Monitoring Well
 I - Influent
 E - Effluent

Treatment Types
 AST - Air Stripper
 GAC - Granular Activated Charcoal
 N - Nitrate Removal Plant
 FE - Iron Removal Plant
 O - Other

Client Info:

Name or Code: HAMPTON BAYS WATER DISTRICT

Address: P.O. BOX 1013
HAMPTON BAYS, NEW YORK 11946

(631) 728-0179

Phone #: _____
 Attn: _____
 Proj. # or (Name): _____
 Bill To: _____
 Copies To: _____

Sample Info:

Date/Time Collected:	Sample Type	Location	Origin	Treatment Type	Purpose	Field Readings Cl ₂ pH/Temp	Analysis	Lab No.
8:30 AM 8-1-18	PW	#27	D	-	RO	.87 7.20	BACT w/c	001
7:45 AM 8-1-18	PW	#2	D	-	RO	.83 7.36	BACT w/c	002
8:00 AM 8-1-18	PW	#3	D	-	RO	.63 7.34	BACT w/c	003
8:35 AM 8-1-18	PW	#4	D	-	RO	.66 7.37	BACT w/c	004
8:50 AM 8-1-18	PW	#5	D	-	RO	.57 7.42	BACT w/c	005
9:05 AM 8-1-18	PW	#6	D	-	RO	.93 7.30	BACT w/c	006
9:20 AM 8-1-18	PW	#7	D	-	RO	.55 7.29	BACT w/c	007
9:40 AM 8-1-18	PW	#8	D	-	RO	.55 7.57	BACT w/c	008
8:30 AM 8-1-18	PW	#9	D	-	RO	.73 7.01	BACT w/c	009
10:00 AM 8-1-18	PW	#10	D	-	RO	.82 7.25	BACT w/c	010
10:20 AM 8-1-18	PW	#11	D	-	RO	.61 7.36	BACT w/c	011

Remarks:

Client Name: HBW

WO#: 7060114
 PM: SWM Due Date: 08/31/18
 CLIENT: HBW

Courier: Fed Ex UPS USPS Client Commercial Pace Other

Tracking #: _____
 Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No

Packing Material: Bubble Wrap Bubble Bags Ziploc None Other

Thermometer Used: TH091 Correction Factor: 0.0
 Cooler Temperature (°C): 3.7 Cooler Temperature Corrected (°C): 3.7

Temp should be above freezing to 6.0°C
 USDA Regulated Soil (N/A, water sample)

Temperature Blank Present: Yes No

Type of Ice: Wet Blue None

Samples on ice, cooling process has begun
 Date/Time 5035A kits placed in freezer

Date and Initials of person examining contents: 8/31/18

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? YES NO

Did samples originate from a foreign source (internationally, including Hawaii and Puerto Rico)? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

			COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	2.
Chain of Custody Relinquished:	<input type="checkbox"/> Yes	<input type="checkbox"/> No	3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr):	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD)	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
Containers Intact:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	12.
-Includes date/time/ID/Analysis Matrix <u>SW</u> <u>WT</u> <u>OIL</u>			
All containers needing preservation have been checked	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot #			Sample #
All containers needing preservation are found to be in compliance with EPA recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH > 9 Sulfide, NaOH > 12 Cyanide)	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	Initial when completed: Lot # of added preservative: Date/Time preservative added
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis			
Samples checked for dechlorination:	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14.
KI starch test strips Lot #			Positive for Res. Chlorine? Y N
Residual chlorine strips Lot #			
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15.
Trip Blank Present:	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable):			

Client Notification/ Resolution: _____ Field Data Required? Y / N
 Person Contacted: _____ Date/Time: _____

Comments/ Resolution: _____

