

TABLE 2

GROUNDWATER REMEDIAL ACTION  
 ROWE INDUSTRIES SUPERFUND SITE  
 SAG HARBOR, NEW YORK

Effluent Water Quality Results

Date Sampled <sup>2/</sup>	pH <sup>1/</sup>	TDS (mg/l)	PCE (ug/l)	1,1,1-TCA (ug/l)	TCE (ug/l)	1,1-DCA (ug/l)	1,1-DCE (ug/l)	cis-1,2-DCE (ug/l)	trans-1,2-DCE (ug/l)	Xylene (ug/l)	Toluene (ug/l)	Ethylbenzene (ug/l)	Methylene Chloride (ug/l)	Freon 113 (ug/l)	Naphthalene (ug/l)	Chloroform (ug/l)	Total Iron (mg/l)	Dissolved Iron (mg/l)
<b>SPDES Limits</b>	<b>6.5 to 8.5</b>	<b>---</b>	<b>5</b>	<b>5</b>	<b>5</b>	<b>5</b>	<b>5</b>	<b>5</b>	<b>5</b>	<b>5</b>	<b>5</b>	<b>5</b>	<b>5</b>	<b>---</b>	<b>10</b>	<b>7</b>	<b>---</b>	<b>---</b>
1-Sep-16	6.5	157	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<1.5	ND<0.5	ND<0.5	ND<2	ND<0.5	ND<0.5	ND<0.5	1.65	0.044
16-Sep-16	6.5	146	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<1.5	ND<0.5	ND<0.5	ND<2	ND<0.5	ND<0.5	ND<0.5	0.92	0.336
17-Oct-16 <sup>4/</sup>	6.5	141	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<1.5	ND<0.5	ND<0.5	ND<2	ND<0.5	ND<0.5	ND<0.5	1.27	0.455
1-Nov-16	6.5	224	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<1.5	ND<0.5	ND<0.5	ND<2	ND<0.5	ND<0.5	ND<0.5	3.50	0.100
1-Dec-16	6.5	191	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<1.5	ND<0.5	ND<0.5	ND<2	ND<0.5	ND<0.5	ND<0.5	2.17	0.042
3-Jan-17	6.5	123	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<1.5	ND<0.5	ND<0.5	ND<2	ND<0.5	ND<0.5	ND<0.5	2.24	0.030
1-Feb-17	6.5	120	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<1.5	ND<0.5	ND<0.5	ND<2	ND<0.5	ND<0.5	ND<0.5	2.17	0.051
1-Mar-17	6.5	149	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<1.5	ND<0.5	ND<0.5	ND<2	ND<0.5	ND<0.5	ND<0.5	0.69	0.063
7-Apr-17	6.5	157	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<1.5	ND<0.5	ND<0.5	ND<2	ND<0.5	ND<0.5	ND<0.5	3.62	0.060
3-May-17	6.5	121	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<1.5	ND<0.5	ND<0.5	ND<2	ND<0.5	ND<0.5	ND<0.5	0.90	0.079
1-Jun-17	6.5	127	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<1.5	ND<0.5	ND<0.5	ND<2	ND<0.5	ND<0.5	ND<0.5	0.10	0.097
6-Jul-17	6.5	159	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<1.5	ND<0.5	ND<0.5	ND<2	ND<0.5	ND<0.5	ND<0.5	0.46	ND<0.02
1-Aug-17	6.8	143	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<1.5	ND<0.5	ND<0.5	ND<2	ND<0.5	ND<0.5	ND<0.5	3.00	0.193

SPDES: State Pollutant Discharge Elimination System

mg/l: Milligrams per liter

ug/l: Micrograms per liter

---: Not established

J: Analyte detected below quantitation limits, value shown is a laboratory estimate.

B: Analyte was found in the associated analysis batch blank. For volatiles, methylene chloride and acetone are common lab contaminants.

ND: Not detected

NM: Not Measured

TDS: Total dissolved solids

PCE: Tetrachloroethylene

1,1,1-TCA: 1,1,1-Trichloroethane

TCE: Trichloroethene

1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene

cis-1,2-DCE: cis-1,2-Dichloroethene

trans-1,2,-DCE: trans-1,2-Dichloroethene

Notes:

1. Based on the SPDES criteria from an NYSDEC letter dated on May 6, 2016, the allowable pH range for the Rowe Site is between 6.5 and 8.5. The pH on August 15, 2017, was 6.9.


2. "Effluent" samples were collected from sample port labeled NP2-10 unless otherwise noted.

3. LBG suspects the PCE and TCE detections from the water sample collected from the effluent sample port (NP2-10) on July 7, 2016, were most likely caused by: a) reversing the sample label on the influent and effluent laboratory bottles; or b) a mis-labeling of the results by the laboratory, because the "ND" (non-detect below the laboratory reporting limit) results for PCE and TCE are typically observed in the effluent water sample and low concentrations of these compounds are normally observed in the influent water sample. The reverse was true for the July 7, 2016 sampling event.

4. Starting in October 2016, FSP&T system samples will be collected monthly instead of once every two weeks.

**GRAPH 1**  
**GROUNDWATER REMEDIAL ACTION**  
**ROWE INDUSTRIES SUPERFUND SITE**  
**SAG HARBOR, NEW YORK**

**Effluent Flow Data**  
**(August 1, 2017 to August 31, 2017)**



**APPENDIX I**  
**AUGUST 2017 LABORATORY ANALYTICAL REPORTS**  
**FOR FSP&T SYSTEM**



# Technical Report

prepared for:

**Leggette Brashears & Graham Shelton Office**

4 Research Drive, Suite 204

Shelton CT, 06484

**Attention: Tunde Komuves-Sandor**

Report Date: 08/10/2017

**Client Project ID: Rowe Industries**

York Project (SDG) No.: 17H0152

CT Cert. No. PH-0723

New Jersey Cert. No. CT005 and NY037



New York Cert. Nos. 10854 and 12058

PA Cert. No. 68-04440

120 RESEARCH DRIVE  
[www.YORKLAB.com](http://www.YORKLAB.com)

STRATFORD, CT 06615  
(203) 325-1371



132-02 89th AVENUE  
FAX (203) 357-0166

RICHMOND HILL, NY 11418  
[ClientServices@yorklab.com](mailto:ClientServices@yorklab.com)

Report Date: 08/10/2017  
Client Project ID: Rowe Industries  
York Project (SDG) No.: 17H0152

**Leggette Brashears & Graham Shelton Office**  
4 Research Drive, Suite 204  
Shelton CT, 06484  
Attention: Tunde Komuves-Sandor

---

## Purpose and Results

This report contains the analytical data for the sample(s) identified on the attached chain-of-custody received in our laboratory on August 03, 2017 and listed below. The project was identified as your project: **Rowe Industries**.

The analyses were conducted utilizing appropriate EPA, Standard Methods, and ASTM methods as detailed in the data summary tables.

All samples were received in proper condition meeting the customary acceptance requirements for environmental samples except those indicated under the Sample and Analysis Qualifiers section of this report.

All analyses met the method and laboratory standard operating procedure requirements except as indicated by any data flags, the meaning of which are explained in the Sample and Data Qualifiers Relating to This Work Order section of this report and case narrative if applicable.

The results of the analyses, which are all reported on dry weight basis (soils) unless otherwise noted, are detailed in the following pages.

Please contact Client Services at 203.325.1371 with any questions regarding this report.

<u>York Sample ID</u>	<u>Client Sample ID</u>	<u>Matrix</u>	<u>Date Collected</u>	<u>Date Received</u>
17H0152-01	WQ080117:1300NP2-6	Water	08/01/2017	08/03/2017
17H0154-01	WQ080117:1305NP2-10	Water	08/01/2017	08/03/2017

## **General Notes for York Project (SDG) No.: 17H0152**

1. The RLs and MDLs (Reporting Limit and Method Detection Limit respectively) reported are adjusted for any dilution necessary due to the levels of target and/or non-target analytes and matrix interference. The RL(REPORTING LIMIT) is based upon the lowest standard utilized for the calibration where applicable.
2. Samples are retained for a period of thirty days after submittal of report, unless other arrangements are made.
3. York's liability for the above data is limited to the dollar value paid to York for the referenced project.
4. This report shall not be reproduced without the written approval of York Analytical Laboratories, Inc.
5. All analyses conducted met method or Laboratory SOP requirements. See the Sample and Data Qualifiers Section for further information.
6. It is noted that no analyses reported herein were subcontracted to another laboratory, unless noted in the report.
7. This report reflects results that relate only to the samples submitted on the attached chain-of-custody form(s) received by York.
8. Analyses conducted at York Analytical Laboratories, Inc. Stratford, CT are indicated by NY Cert. No. 10854; those conducted at York Analytical Laboratories, Inc., Richmond Hill, NY are indicated by NY Cert. No. 12058.

**Approved By:**



Benjamin Gulizia  
Laboratory Director

**Date:** 08/10/2017





### Sample Information

**Client Sample ID:** WQ080117:1300NP2-6

**York Sample ID:** 17H0152-01

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
17H0152	Rowe Industries	Water	August 1, 2017 1:00 pm	08/03/2017

**Volatile Organics, 8260 List - Low Level**

**Log-in Notes:**

**Sample Notes:**

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
630-20-6	1,1,1,2-Tetrachloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
71-55-6	1,1,1-Trichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
79-34-5	1,1,2,2-Tetrachloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
76-13-1	1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
79-00-5	1,1,2-Trichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
75-34-3	1,1-Dichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
75-35-4	1,1-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
563-58-6	1,1-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:15	SS
87-61-6	1,2,3-Trichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:15	SS
96-18-4	1,2,3-Trichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:15	SS
120-82-1	1,2,4-Trichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:15	SS
95-63-6	1,2,4-Trimethylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
96-12-8	1,2-Dibromo-3-chloropropane	ND		ug/L	0.20	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
106-93-4	1,2-Dibromoethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
95-50-1	1,2-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
107-06-2	1,2-Dichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
78-87-5	1,2-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
108-67-8	1,3,5-Trimethylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
541-73-1	1,3-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
142-28-9	1,3-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:15	SS
106-46-7	1,4-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
594-20-7	2,2-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:15	SS



### Sample Information

**Client Sample ID:** WQ080117:1300NP2-6

**York Sample ID:** 17H0152-01

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17H0152

Rowe Industries

Water

August 1, 2017 1:00 pm

08/03/2017

**Volatile Organics, 8260 List - Low Level**

**Log-in Notes:**

**Sample Notes:**

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
95-49-8	2-Chlorotoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
591-78-6	2-Hexanone	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
106-43-4	4-Chlorotoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
67-64-1	Acetone	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
71-43-2	Benzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
108-86-1	Bromobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:15	SS
74-97-5	Bromochloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:15	SS
75-27-4	Bromodichloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
75-25-2	Bromoform	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
74-83-9	Bromomethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
56-23-5	Carbon tetrachloride	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
108-90-7	Chlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
75-00-3	Chloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
67-66-3	<b>Chloroform</b>	<b>0.25</b>	J	ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
74-87-3	Chloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
156-59-2	cis-1,2-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
10061-01-5	cis-1,3-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
124-48-1	Dibromochloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
74-95-3	Dibromomethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:15	SS
75-71-8	Dichlorodifluoromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:15	SS
100-41-4	Ethyl Benzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS
87-68-3	Hexachlorobutadiene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:15	SS
98-82-8	Isopropylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:15	SS



### Sample Information

**Client Sample ID:** WQ080117:1300NP2-6

**York Sample ID:** 17H0152-01

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17H0152

Rowe Industries

Water

August 1, 2017 1:00 pm

08/03/2017

**Volatile Organics, 8260 List - Low Level**

**Log-in Notes:**

**Sample Notes:**

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
1634-04-4	Methyl tert-butyl ether (MTBE)	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 14:15	SS
75-09-2	Methylene chloride	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 14:15	SS
91-20-3	Naphthalene	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:15	SS
104-51-8	n-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 14:15	SS
103-65-1	n-Propylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 14:15	SS
95-47-6	o-Xylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:15	SS
179601-23-1	p- & m- Xylenes	ND		ug/L	0.50	1.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:15	SS
99-87-6	p-Isopropyltoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 14:15	SS
135-98-8	sec-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 14:15	SS
100-42-5	Styrene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 14:15	SS
98-06-6	tert-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 14:15	SS
127-18-4	<b>Tetrachloroethylene</b>	<b>0.32</b>	J	ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 14:15	SS
108-88-3	Toluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 14:15	SS
156-60-5	trans-1,2-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 14:15	SS
10061-02-6	trans-1,3-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 14:15	SS
79-01-6	<b>Trichloroethylene</b>	<b>0.23</b>	J	ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 14:15	SS
75-69-4	Trichlorofluoromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 14:15	SS
75-01-4	Vinyl Chloride	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 14:15	SS
1330-20-7	Xylenes, Total	ND		ug/L	0.60	1.5	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 14:15	SS

	Surrogate Recoveries	Result	Acceptance Range
17060-07-0	Surrogate: 1,2-Dichloroethane-d4	102 %	69-130
2037-26-5	Surrogate: Toluene-d8	97.7 %	81-117
460-00-4	Surrogate: p-Bromofluorobenzene	110 %	79-122



### Sample Information

**Client Sample ID:** WQ080117:1305NP2-10

**York Sample ID:** 17H0154-01

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17H0154

Rowe Industries

Water

August 1, 2017 1:05 pm

08/03/2017

**Volatile Organics, 8260 List - Low Level**

**Log-in Notes:**

**Sample Notes:**

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
630-20-6	1,1,1,2-Tetrachloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
71-55-6	1,1,1-Trichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
79-34-5	1,1,2,2-Tetrachloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
76-13-1	1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
79-00-5	1,1,2-Trichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
75-34-3	1,1-Dichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
75-35-4	1,1-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
563-58-6	1,1-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:47	SS
87-61-6	1,2,3-Trichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:47	SS
96-18-4	1,2,3-Trichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:47	SS
120-82-1	1,2,4-Trichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:47	SS
95-63-6	1,2,4-Trimethylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
96-12-8	1,2-Dibromo-3-chloropropane	ND		ug/L	0.20	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
106-93-4	1,2-Dibromoethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
95-50-1	1,2-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
107-06-2	1,2-Dichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
78-87-5	1,2-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
108-67-8	1,3,5-Trimethylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
541-73-1	1,3-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
142-28-9	1,3-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:47	SS
106-46-7	1,4-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
594-20-7	2,2-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:47	SS
95-49-8	2-Chlorotoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS



### Sample Information

**Client Sample ID:** WQ080117:1305NP2-10

**York Sample ID:** 17H0154-01

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17H0154

Rowe Industries

Water

August 1, 2017 1:05 pm

08/03/2017

**Volatile Organics, 8260 List - Low Level**

**Log-in Notes:**

**Sample Notes:**

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
591-78-6	2-Hexanone	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
106-43-4	4-Chlorotoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
67-64-1	Acetone	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
71-43-2	Benzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
108-86-1	Bromobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:47	SS
74-97-5	Bromochloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:47	SS
75-27-4	Bromodichloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
75-25-2	Bromoform	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
74-83-9	Bromomethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
56-23-5	Carbon tetrachloride	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
108-90-7	Chlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
75-00-3	Chloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
67-66-3	Chloroform	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
74-87-3	Chloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
156-59-2	cis-1,2-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
10061-01-5	cis-1,3-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
124-48-1	Dibromochloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
74-95-3	Dibromomethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:47	SS
75-71-8	Dichlorodifluoromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:47	SS
100-41-4	Ethyl Benzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
87-68-3	Hexachlorobutadiene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:47	SS
98-82-8	Isopropylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS
1634-04-4	Methyl tert-butyl ether (MTBE)	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/09/2017 17:33	08/10/2017 14:47	SS



### Sample Information

**Client Sample ID:** WQ080117:1305NP2-10

**York Sample ID:** 17H0154-01

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17H0154

Rowe Industries

Water

August 1, 2017 1:05 pm

08/03/2017

**Volatile Organics, 8260 List - Low Level**

**Log-in Notes:**

**Sample Notes:**

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
75-09-2	Methylene chloride	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:47	SS
91-20-3	Naphthalene	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:47	SS
104-51-8	n-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:47	SS
103-65-1	n-Propylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:47	SS
95-47-6	o-Xylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:47	SS
179601-23-1	p- & m- Xylenes	ND		ug/L	0.50	1.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:47	SS
99-87-6	p-Isopropyltoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:47	SS
135-98-8	sec-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:47	SS
100-42-5	Styrene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:47	SS
98-06-6	tert-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:47	SS
127-18-4	Tetrachloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:47	SS
108-88-3	Toluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:47	SS
156-60-5	trans-1,2-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:47	SS
10061-02-6	trans-1,3-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:47	SS
79-01-6	Trichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:47	SS
75-69-4	Trichlorofluoromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:47	SS
75-01-4	Vinyl Chloride	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:47	SS
1330-20-7	Xylenes, Total	ND		ug/L	0.60	1.5	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 14:47	SS
<b>Surrogate Recoveries</b>		<b>Result</b>			<b>Acceptance Range</b>						
17060-07-0	Surrogate: 1,2-Dichloroethane-d4	97.8 %			69-130						
2037-26-5	Surrogate: Toluene-d8	98.2 %			81-117						
460-00-4	Surrogate: p-Bromofluorobenzene	117 %			79-122						

**Iron by EPA 200.7**

**Log-in Notes:**

**Sample Notes:**

Sample Prepared by Method: EPA 200.7

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
120 RESEARCH DRIVE	STRATFORD, CT 06615						132-02 89th AVENUE			RICHMOND HILL, NY 11418
www.YORKLAB.com	(203) 325-1371						FAX (203) 357-0166			ClientServices@



**Sample Information**

**Client Sample ID:** WQ080117:1305NP2-10

**York Sample ID:** 17H0154-01

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17H0154

Rowe Industries

Water

August 1, 2017 1:05 pm

08/03/2017

**Iron by EPA 200.7**

**Log-in Notes:**

**Sample Notes:**

Sample Prepared by Method: EPA 200.7

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-89-6	Iron	3.00	B	mg/L	0.0222	1	EPA 200.7	08/09/2017 09:02	08/09/2017 21:51	KML
							Certifications:	CTDOH,NELAC-NY10854,NJDEP,PADEP		

**Iron, Dissolved by EPA 6010**

**Log-in Notes:**

**Sample Notes:**

Sample Prepared by Method: EPA 3015A

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-89-6	Iron	0.193	B	mg/L	0.0222	1	EPA 6010C	08/09/2017 13:26	08/10/2017 14:34	KML
							Certifications:	CTDOH,NELAC-NY10854,NJDEP,PADEP		

**Total Dissolved Solids**

**Log-in Notes:**

**Sample Notes:**

Sample Prepared by Method: % Solids Prep

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
	Total Dissolved Solids	143		mg/L	10.0	1	SM 2540C	08/03/2017 20:35	08/03/2017 20:35	AA
							Certifications:	NELAC-NY10854,CTDOH,NJDEP,PADEP		



### Analytical Batch Summary

**Batch ID:** BH70215                      **Preparation Method:** % Solids Prep                      **Prepared By:** AA

YORK Sample ID	Client Sample ID	Preparation Date
17H0154-01	WQ080117:1305NP2-10	08/03/17
BH70215-BLK1	Blank	08/03/17

**Batch ID:** BH70402                      **Preparation Method:** EPA 200.7                      **Prepared By:** SY

YORK Sample ID	Client Sample ID	Preparation Date
17H0154-01	WQ080117:1305NP2-10	08/09/17
BH70402-BLK1	Blank	08/09/17
BH70402-SRM1	Reference	08/09/17

**Batch ID:** BH70478                      **Preparation Method:** EPA 3015A                      **Prepared By:** SY

YORK Sample ID	Client Sample ID	Preparation Date
17H0154-01	WQ080117:1305NP2-10	08/09/17
BH70478-BLK1	Blank	08/09/17
BH70478-DUP1	Duplicate	08/09/17
BH70478-MS1	Matrix Spike	08/09/17
BH70478-SRM1	Reference	08/09/17

**Batch ID:** BH70484                      **Preparation Method:** EPA 5030B                      **Prepared By:** RDS

YORK Sample ID	Client Sample ID	Preparation Date
17H0152-01	WQ080117:1300NP2-6	08/09/17
17H0154-01	WQ080117:1305NP2-10	08/09/17
BH70484-BLK1	Blank	08/09/17
BH70484-BS1	LCS	08/09/17
BH70484-BSD1	LCS Dup	08/09/17



**Volatile Organic Compounds by GC/MS - Quality Control Data**  
**York Analytical Laboratories, Inc.**

Analyte	Result	Reporting	Units	Spike Level	Source*	%REC	%REC	Flag	RPD	RPD	Limit	Flag
		Limit			Result	Limits	Limit					

**Batch BH70484 - EPA 5030B**

**Blank (BH70484-BLK1)**

Prepared: 08/09/2017 Analyzed: 08/10/2017

1,1,1,2-Tetrachloroethane	ND	0.50	ug/L
1,1,1-Trichloroethane	ND	0.50	"
1,1,2,2-Tetrachloroethane	ND	0.50	"
1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	ND	0.50	"
1,1,2-Trichloroethane	ND	0.50	"
1,1-Dichloroethane	ND	0.50	"
1,1-Dichloroethylene	ND	0.50	"
1,1-Dichloropropylene	ND	0.50	"
1,2,3-Trichlorobenzene	0.30	0.50	"
1,2,3-Trichloropropane	ND	0.50	"
1,2,4-Trichlorobenzene	ND	0.50	"
1,2,4-Trimethylbenzene	ND	0.50	"
1,2-Dibromo-3-chloropropane	ND	0.50	"
1,2-Dibromoethane	ND	0.50	"
1,2-Dichlorobenzene	ND	0.50	"
1,2-Dichloroethane	ND	0.50	"
1,2-Dichloropropane	ND	0.50	"
1,3,5-Trimethylbenzene	ND	0.50	"
1,3-Dichlorobenzene	ND	0.50	"
1,3-Dichloropropane	ND	0.50	"
1,4-Dichlorobenzene	ND	0.50	"
2,2-Dichloropropane	ND	0.50	"
2-Chlorotoluene	ND	0.50	"
2-Hexanone	ND	0.50	"
4-Chlorotoluene	ND	0.50	"
Acetone	ND	2.0	"
Benzene	ND	0.50	"
Bromobenzene	ND	0.50	"
Bromochloromethane	ND	0.50	"
Bromodichloromethane	ND	0.50	"
Bromoform	ND	0.50	"
Bromomethane	ND	0.50	"
Carbon tetrachloride	ND	0.50	"
Chlorobenzene	ND	0.50	"
Chloroethane	ND	0.50	"
Chloroform	ND	0.50	"
Chloromethane	ND	0.50	"
cis-1,2-Dichloroethylene	ND	0.50	"
cis-1,3-Dichloropropylene	ND	0.50	"
Dibromochloromethane	ND	0.50	"
Dibromomethane	ND	0.50	"
Dichlorodifluoromethane	ND	0.50	"
Ethyl Benzene	ND	0.50	"
Hexachlorobutadiene	0.20	0.50	"
Isopropylbenzene	ND	0.50	"
Methyl tert-butyl ether (MTBE)	ND	0.50	"
Methylene chloride	ND	2.0	"
Naphthalene	ND	2.0	"
n-Butylbenzene	ND	0.50	"
n-Propylbenzene	ND	0.50	"



Volatile Organic Compounds by GC/MS - Quality Control Data

York Analytical Laboratories, Inc.

Analyte	Result	Reporting Limit	Units	Spike Level	Source* Result	%REC	%REC Limits	Flag	RPD	RPD Limit	Flag
---------	--------	-----------------	-------	-------------	----------------	------	-------------	------	-----	-----------	------

Batch BH70484 - EPA 5030B

Blank (BH70484-BLK1)

Prepared: 08/09/2017 Analyzed: 08/10/2017

o-Xylene	ND	0.50	ug/L								
p- & m- Xylenes	ND	1.0	"								
p-Isopropyltoluene	ND	0.50	"								
sec-Butylbenzene	ND	0.50	"								
Styrene	ND	0.50	"								
tert-Butylbenzene	ND	0.50	"								
Tetrachloroethylene	ND	0.50	"								
Toluene	ND	0.50	"								
trans-1,2-Dichloroethylene	ND	0.50	"								
trans-1,3-Dichloropropylene	ND	0.50	"								
Trichloroethylene	ND	0.50	"								
Trichlorofluoromethane	ND	0.50	"								
Vinyl Chloride	ND	0.50	"								
Xylenes, Total	ND	1.5	"								
Surrogate: 1,2-Dichloroethane-d4	10.1		"	10.0		101	69-130				
Surrogate: Toluene-d8	9.74		"	10.0		97.4	81-117				
Surrogate: p-Bromofluorobenzene	11.6		"	10.0		116	79-122				

LCS (BH70484-BS1)

Prepared: 08/09/2017 Analyzed: 08/10/2017

1,1,1,2-Tetrachloroethane	10.1		ug/L	10.0		101	82-126				
1,1,1-Trichloroethane	10.3		"	10.0		103	78-136				
1,1,2,2-Tetrachloroethane	10.3		"	10.0		103	76-129				
1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	9.79		"	10.0		97.9	54-165				
1,1,2-Trichloroethane	9.56		"	10.0		95.6	82-123				
1,1-Dichloroethane	9.88		"	10.0		98.8	82-129				
1,1-Dichloroethylene	19.0		"	10.0		190	68-138	High Bias			
1,1-Dichloropropylene	10.0		"	10.0		100	83-133				
1,2,3-Trichlorobenzene	2.78		"	10.0		27.8	76-136	Low Bias			
1,2,3-Trichloropropane	10.6		"	10.0		106	77-128				
1,2,4-Trichlorobenzene	3.88		"	10.0		38.8	76-137	Low Bias			
1,2,4-Trimethylbenzene	11.2		"	10.0		112	82-132				
1,2-Dibromo-3-chloropropane	8.21		"	10.0		82.1	45-147				
1,2-Dibromoethane	9.68		"	10.0		96.8	83-124				
1,2-Dichlorobenzene	10.1		"	10.0		101	79-123				
1,2-Dichloroethane	10.2		"	10.0		102	73-132				
1,2-Dichloropropane	9.34		"	10.0		93.4	78-126				
1,3,5-Trimethylbenzene	11.5		"	10.0		115	80-131				
1,3-Dichlorobenzene	10.9		"	10.0		109	86-122				
1,3-Dichloropropane	9.50		"	10.0		95.0	81-125				
1,4-Dichlorobenzene	10.7		"	10.0		107	85-124				
2,2-Dichloropropane	8.87		"	10.0		88.7	56-150				
2-Chlorotoluene	11.4		"	10.0		114	79-130				
2-Hexanone	9.39		"	10.0		93.9	51-146				
4-Chlorotoluene	11.6		"	10.0		116	79-128				
Acetone	8.24		"	10.0		82.4	14-150				
Benzene	10.0		"	10.0		100	85-126				
Bromobenzene	10.8		"	10.0		108	78-129				
Bromochloromethane	9.77		"	10.0		97.7	77-128				
Bromodichloromethane	9.73		"	10.0		97.3	79-128				
Bromoform	9.22		"	10.0		92.2	78-133				
Bromomethane	6.56		"	10.0		65.6	43-168				



**Volatile Organic Compounds by GC/MS - Quality Control Data**

**York Analytical Laboratories, Inc.**

Analyte	Result	Reporting	Spike	Source*	%REC	%REC	Limits	Flag	RPD	RPD	
		Limit								Units	Level

**Batch BH70484 - EPA 5030B**

**LCS (BH70484-BS1)**

Prepared: 08/09/2017 Analyzed: 08/10/2017

Carbon tetrachloride	10.2		ug/L	10.0		102	77-141				
Chlorobenzene	10.1		"	10.0		101	88-120				
Chloroethane	9.81		"	10.0		98.1	65-136				
Chloroform	10.2		"	10.0		102	82-128				
Chloromethane	8.04		"	10.0		80.4	43-155				
cis-1,2-Dichloroethylene	10.0		"	10.0		100	83-129				
cis-1,3-Dichloropropylene	9.34		"	10.0		93.4	80-131				
Dibromochloromethane	9.94		"	10.0		99.4	80-130				
Dibromomethane	9.37		"	10.0		93.7	72-134				
Dichlorodifluoromethane	8.27		"	10.0		82.7	44-144				
Ethyl Benzene	10.1		"	10.0		101	80-131				
Hexachlorobutadiene	2.72		"	10.0		27.2	67-146	Low Bias			
Isopropylbenzene	12.0		"	10.0		120	76-140				
Methyl tert-butyl ether (MTBE)	10.4		"	10.0		104	76-135				
Methylene chloride	7.57		"	10.0		75.7	55-137				
Naphthalene	4.11		"	10.0		41.1	70-147	Low Bias			
n-Butylbenzene	10.2		"	10.0		102	79-132				
n-Propylbenzene	11.9		"	10.0		119	78-133				
o-Xylene	10.2		"	10.0		102	78-130				
p- & m- Xylenes	20.8		"	20.0		104	77-133				
p-Isopropyltoluene	11.1		"	10.0		111	81-136				
sec-Butylbenzene	11.8		"	10.0		118	79-137				
Styrene	9.14		"	10.0		91.4	67-132				
tert-Butylbenzene	12.0		"	10.0		120	77-138				
Tetrachloroethylene	10.7		"	10.0		107	82-131				
Toluene	9.94		"	10.0		99.4	80-127				
trans-1,2-Dichloroethylene	9.82		"	10.0		98.2	80-132				
trans-1,3-Dichloropropylene	9.43		"	10.0		94.3	78-131				
Trichloroethylene	9.72		"	10.0		97.2	82-128				
Trichlorofluoromethane	10.0		"	10.0		100	67-139				
Vinyl Chloride	9.05		"	10.0		90.5	58-145				
<i>Surrogate: 1,2-Dichloroethane-d4</i>	<i>10.2</i>		<i>"</i>	<i>10.0</i>		<i>102</i>	<i>69-130</i>				
<i>Surrogate: Toluene-d8</i>	<i>9.83</i>		<i>"</i>	<i>10.0</i>		<i>98.3</i>	<i>81-117</i>				
<i>Surrogate: p-Bromofluorobenzene</i>	<i>11.4</i>		<i>"</i>	<i>10.0</i>		<i>114</i>	<i>79-122</i>				



Volatile Organic Compounds by GC/MS - Quality Control Data

York Analytical Laboratories, Inc.

Analyte	Result	Reporting		Spike Level	Source*		%REC Limits	Flag	RPD	
		Limit	Units		Result	%REC			RPD	Limit
<b>Batch BH70484 - EPA 5030B</b>										
<b>LCS Dup (BH70484-BSD1)</b>										
Prepared: 08/09/2017 Analyzed: 08/10/2017										
1,1,1,2-Tetrachloroethane	10.1		ug/L	10.0	101	82-126			0.297	30
1,1,1-Trichloroethane	10.3		"	10.0	103	78-136			0.00	30
1,1,2,2-Tetrachloroethane	10.5		"	10.0	105	76-129			1.74	30
1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	9.74		"	10.0	97.4	54-165			0.512	30
1,1,2-Trichloroethane	9.46		"	10.0	94.6	82-123			1.05	30
1,1-Dichloroethane	9.69		"	10.0	96.9	82-129			1.94	30
1,1-Dichloroethylene	19.3		"	10.0	193	68-138	High Bias		1.25	30
1,1-Dichloropropylene	9.60		"	10.0	96.0	83-133			4.38	30
1,2,3-Trichlorobenzene	3.03		"	10.0	30.3	76-136	Low Bias		8.61	30
1,2,3-Trichloropropane	10.8		"	10.0	108	77-128			2.52	30
1,2,4-Trichlorobenzene	3.93		"	10.0	39.3	76-137	Low Bias		1.28	30
1,2,4-Trimethylbenzene	11.1		"	10.0	111	82-132			1.08	30
1,2-Dibromo-3-chloropropane	8.38		"	10.0	83.8	45-147			2.05	30
1,2-Dibromoethane	9.68		"	10.0	96.8	83-124			0.00	30
1,2-Dichlorobenzene	9.91		"	10.0	99.1	79-123			1.50	30
1,2-Dichloroethane	10.0		"	10.0	100	73-132			1.78	30
1,2-Dichloropropane	9.26		"	10.0	92.6	78-126			0.860	30
1,3,5-Trimethylbenzene	11.3		"	10.0	113	80-131			1.93	30
1,3-Dichlorobenzene	10.7		"	10.0	107	86-122			2.41	30
1,3-Dichloropropane	9.54		"	10.0	95.4	81-125			0.420	30
1,4-Dichlorobenzene	10.6		"	10.0	106	85-124			0.656	30
2,2-Dichloropropane	8.67		"	10.0	86.7	56-150			2.28	30
2-Chlorotoluene	11.2		"	10.0	112	79-130			2.03	30
2-Hexanone	9.75		"	10.0	97.5	51-146			3.76	30
4-Chlorotoluene	11.4		"	10.0	114	79-128			1.39	30
Acetone	7.88		"	10.0	78.8	14-150			4.47	30
Benzene	9.92		"	10.0	99.2	85-126			1.10	30
Bromobenzene	10.6		"	10.0	106	78-129			1.12	30
Bromochloromethane	9.70		"	10.0	97.0	77-128			0.719	30
Bromodichloromethane	9.60		"	10.0	96.0	79-128			1.35	30
Bromoform	9.49		"	10.0	94.9	78-133			2.89	30
Bromomethane	6.64		"	10.0	66.4	43-168			1.21	30
Carbon tetrachloride	10.1		"	10.0	101	77-141			1.38	30
Chlorobenzene	10.0		"	10.0	100	88-120			0.993	30
Chloroethane	9.78		"	10.0	97.8	65-136			0.306	30
Chloroform	10.2		"	10.0	102	82-128			0.491	30
Chloromethane	7.91		"	10.0	79.1	43-155			1.63	30
cis-1,2-Dichloroethylene	9.84		"	10.0	98.4	83-129			1.91	30
cis-1,3-Dichloropropylene	9.24		"	10.0	92.4	80-131			1.08	30
Dibromochloromethane	10.1		"	10.0	101	80-130			1.20	30
Dibromomethane	9.40		"	10.0	94.0	72-134			0.320	30
Dichlorodifluoromethane	7.98		"	10.0	79.8	44-144			3.57	30
Ethyl Benzene	10.0		"	10.0	100	80-131			0.992	30
Hexachlorobutadiene	2.81		"	10.0	28.1	67-146	Low Bias		3.25	30
Isopropylbenzene	11.8		"	10.0	118	76-140			1.67	30
Methyl tert-butyl ether (MTBE)	10.4		"	10.0	104	76-135			0.288	30
Methylene chloride	7.55		"	10.0	75.5	55-137			0.265	30
Naphthalene	4.28		"	10.0	42.8	70-147	Low Bias		4.05	30
n-Butylbenzene	9.89		"	10.0	98.9	79-132			2.89	30
n-Propylbenzene	11.6		"	10.0	116	78-133			2.56	30
o-Xylene	10.1		"	10.0	101	78-130			0.885	30



Volatile Organic Compounds by GC/MS - Quality Control Data

York Analytical Laboratories, Inc.

Analyte	Result	Reporting	Units	Spike Level	Source*	%REC	Limits	Flag	RPD	
		Limit			Result	%REC			RPD	Limit

Batch BH70484 - EPA 5030B

LCS Dup (BH70484-BSD1)

Prepared: 08/09/2017 Analyzed: 08/10/2017

p- & m- Xylenes	20.5		ug/L	20.0		102	77-133		1.69	30
p-Isopropyltoluene	10.9		"	10.0		109	81-136		2.00	30
sec-Butylbenzene	11.6		"	10.0		116	79-137		1.79	30
Styrene	9.05		"	10.0		90.5	67-132		0.990	30
tert-Butylbenzene	11.7		"	10.0		117	77-138		2.03	30
Tetrachloroethylene	10.4		"	10.0		104	82-131		2.47	30
Toluene	9.87		"	10.0		98.7	80-127		0.707	30
trans-1,2-Dichloroethylene	9.88		"	10.0		98.8	80-132		0.609	30
trans-1,3-Dichloropropylene	9.47		"	10.0		94.7	78-131		0.423	30
Trichloroethylene	9.59		"	10.0		95.9	82-128		1.35	30
Trichlorofluoromethane	9.77		"	10.0		97.7	67-139		2.53	30
Vinyl Chloride	8.92		"	10.0		89.2	58-145		1.45	30
<i>Surrogate: 1,2-Dichloroethane-d4</i>	<i>10.2</i>		<i>"</i>	<i>10.0</i>		<i>102</i>	<i>69-130</i>			
<i>Surrogate: Toluene-d8</i>	<i>9.86</i>		<i>"</i>	<i>10.0</i>		<i>98.6</i>	<i>81-117</i>			
<i>Surrogate: p-Bromofluorobenzene</i>	<i>11.4</i>		<i>"</i>	<i>10.0</i>		<i>114</i>	<i>79-122</i>			



**Metals by ICP - Quality Control Data**  
**York Analytical Laboratories, Inc.**

Analyte	Result	Reporting Limit	Units	Spike Level	Source* Result	%REC	%REC Limits	Flag	RPD	RPD Limit	Flag
<b>Batch BH70402 - EPA 200.7</b>											
<b>Blank (BH70402-BLK1)</b>											Prepared & Analyzed: 08/09/2017
Iron	0.320	0.0222	mg/L								
<b>Reference (BH70402-SRM1)</b>											Prepared & Analyzed: 08/09/2017
Iron	1.11		ug/mL	0.759		146	84.9-115	High Bias			
<b>Batch BH70478 - EPA 3015A</b>											
<b>Blank (BH70478-BLK1)</b>											Prepared: 08/09/2017 Analyzed: 08/10/2017
Iron - Dissolved	0.571	0.0222	mg/L								
<b>Duplicate (BH70478-DUP1)</b>											*Source sample: 17H0154-01 (WQ080117:1305NP2-10) Prepared: 08/09/2017 Analyzed: 08/10/2017
Iron - Dissolved	0.466	0.0222	mg/L		0.193				82.6	20	Non-dir.
<b>Matrix Spike (BH70478-MS1)</b>											*Source sample: 17H0154-01 (WQ080117:1305NP2-10) Prepared: 08/09/2017 Analyzed: 08/10/2017
Iron - Dissolved	2.00	0.0222	mg/L	1.11	0.193	163	75-125	High Bias			
<b>Reference (BH70478-SRM1)</b>											Prepared: 08/09/2017 Analyzed: 08/10/2017
Iron - Dissolved	0.700		ug/mL	0.759		92.3	84.9-115				



Miscellaneous Physical Parameters - Quality Control Data  
York Analytical Laboratories, Inc.

Analyte	Result	Reporting Limit	Units	Spike Level	Source* Result	%REC	%REC Limits	Flag	RPD	RPD Limit	Flag
<b>Batch BH70215 - % Solids Prep</b>											
<b>Blank (BH70215-BLK1)</b>										Prepared & Analyzed: 08/03/2017	
Total Dissolved Solids	ND	10.0	mg/L								



### Volatile Analysis Sample Containers

Lab ID	Client Sample ID	Volatile Sample Container
17H0152-01	WQ080117:1300NP2-6	40mL Clear Vial (pre-pres.) HCl; Cool to 4° C
17H0154-01	WQ080117:1305NP2-10	40mL Clear Vial (pre-pres.) HCl; Cool to 4° C



## Sample and Data Qualifiers Relating to This Work Order

- QL-02 This LCS analyte is outside Laboratory Recovery limits due the analyte behavior using the referenced method. The reference method has certain limitations with respect to analytes of this nature.
- J Detected below the Reporting Limit but greater than or equal to the Method Detection Limit (MDL/LOD) or in the case of a TIC, the result is an estimated concentration.
- B Analyte is found in the associated analysis batch blank. For volatiles, methylene chloride and acetone are common lab contaminants.

### Definitions and Other Explanations

- \* Analyte is not certified or the state of the samples origination does not offer certification for the Analyte.
- ND NOT DETECTED - the analyte is not detected at the Reported to level (LOQ/RL or LOD/MDL)
- RL REPORTING LIMIT - the minimum reportable value based upon the lowest point in the analyte calibration curve.
- LOQ LIMIT OF QUANTITATION - the minimum concentration of a target analyte that can be reported within a specified degree of confidence. This is the lowest point in an analyte calibration curve that has been subjected to all steps of the processing/analysis and verified to meet defined criteria. This is based upon NELAC 2009 Standards and applies to all analyses.
- LOD LIMIT OF DETECTION - a verified estimate of the minimum concentration of a substance in a given matrix that an analytical process can reliably detect. This is based upon NELAC 2009 Standards and applies to all analyses conducted under the auspices of EPA SW-846.
- MDL METHOD DETECTION LIMIT - a statistically derived estimate of the minimum amount of a substance an analytical system can reliably detect with a 99% confidence that the concentration of the substance is greater than zero. This is based upon 40 CFR Part 136 Appendix B and applies only to EPA 600 and 200 series methods.
- Reported to This indicates that the data for a particular analysis is reported to either the LOD/MDL, or the LOQ/RL. In cases where the "Reported to" is located above the LOD/MDL, any value between this and the LOQ represents an estimated value which is "J" flagged accordingly. This applies to volatile and semi-volatile target compounds only.
- NR Not reported
- RPD Relative Percent Difference
- Wet The data has been reported on an as-received (wet weight) basis
- Low Bias Low Bias flag indicates that the recovery of the flagged analyte is below the laboratory or regulatory lower control limit. The data user should take note that this analyte may be biased low but should evaluate multiple lines of evidence including the LCS and site-specific MS/MSD data to draw bias conclusions. In cases where no site-specific MS/MSD was requested, only the LCS data can be used to evaluate such bias.
- High Bias High Bias flag indicates that the recovery of the flagged analyte is above the laboratory or regulatory upper control limit. The data user should take note that this analyte may be biased high but should evaluate multiple lines of evidence including the LCS and site-specific MS/MSD data to draw bias conclusions. In cases where no site-specific MS/MSD was requested, only the LCS data can be used to evaluate such bias.
- Non-Dir. Non-dir. flag (Non-Directional Bias ) indicates that the Relative Percent Difference (RPD) (a measure of precision) among the MS and MSD data is outside the laboratory or regulatory control limit. This alerts the data user where the MS and MSD are from site-specific samples that the RPD is high due to either non-homogeneous distribution of target analyte between the MS/MSD or indicates poor reproducibility for other reasons.

If EPA SW-846 method 8270 is included herein it is noted that the target compound N-nitrosodiphenylamine (NDPA) decomposes in the gas chromatographic inlet and cannot be separated from diphenylamine (DPA). These results could actually represent 100% DPA, 100% NDPA or some combination of the two. For this reason, York reports the combined result for n-nitrosodiphenylamine and diphenylamine for either of these compounds as a combined concentration as Diphenylamine.

If Total PCBs are detected and the target aroclors reported are "Not detected", the Total PCB value is reported due to the presence of either or both Aroclors 1262 and 1268 which are non-target aroclors for some regulatory lists.

2-chloroethylvinyl ether readily breaks down under acidic conditions. Samples that are acid preserved, including standards will exhibit breakdown. The data user should take note.

Certification for pH is no longer offered by NYDOH ELAP.

Semi-Volatile and Volatile analyses are reported down to the LOD/MDL, with values between the LOD/MDL and the LOQ being "J" flagged as estimated results.



For analyses by EPA SW-846-8270D, the Limit of Quantitation (LOQ) reported for benzidine is based upon the lowest standard used for calibration and is not a verified LOQ due to this compound's propensity for oxidative losses during extraction/concentration procedures and non-reproducible chromatographic performance.

---







**APPENDIX II**  
**AUGUST 2017 LABORATORY ANALYTICAL REPORTS**  
**FOR FSP&T AND FP&T RECOVERY WELLS**



# Technical Report

prepared for:

**Leggette Brashears & Graham Shelton Office**

4 Research Drive, Suite 204

Shelton CT, 06484

**Attention: Tunde Komuves-Sandor**

Report Date: 08/10/2017

**Client Project ID: Rowe Industries**

York Project (SDG) No.: 17H0158

CT Cert. No. PH-0723

New Jersey Cert. No. CT005 and NY037



New York Cert. Nos. 10854 and 12058

PA Cert. No. 68-04440

120 RESEARCH DRIVE  
[www.YORKLAB.com](http://www.YORKLAB.com)

STRATFORD, CT 06615  
(203) 325-1371

132-02 89th AVENUE  
FAX (203) 357-0166

RICHMOND HILL, NY 11418  
[ClientServices@yorklab.com](mailto:ClientServices@yorklab.com)

Report Date: 08/10/2017  
Client Project ID: Rowe Industries  
York Project (SDG) No.: 17H0158

**Leggette Brashears & Graham Shelton Office**  
4 Research Drive, Suite 204  
Shelton CT, 06484  
Attention: Tunde Komuves-Sandor

## Purpose and Results

This report contains the analytical data for the sample(s) identified on the attached chain-of-custody received in our laboratory on August 03, 2017 and listed below. The project was identified as your project: **Rowe Industries**.

The analyses were conducted utilizing appropriate EPA, Standard Methods, and ASTM methods as detailed in the data summary tables.

All samples were received in proper condition meeting the customary acceptance requirements for environmental samples except those indicated under the Sample and Analysis Qualifiers section of this report.

All analyses met the method and laboratory standard operating procedure requirements except as indicated by any data flags, the meaning of which are explained in the Sample and Data Qualifiers Relating to This Work Order section of this report and case narrative if applicable.

The results of the analyses, which are all reported on dry weight basis (soils) unless otherwise noted, are detailed in the following pages.

Please contact Client Services at 203.325.1371 with any questions regarding this report.

<u>York Sample ID</u>	<u>Client Sample ID</u>	<u>Matrix</u>	<u>Date Collected</u>	<u>Date Received</u>
17H0158-01	WQ080117:1340NP1-1-2	Water	08/01/2017	08/03/2017

## General Notes for York Project (SDG) No.: 17H0158

1. The RLs and MDLs (Reporting Limit and Method Detection Limit respectively) reported are adjusted for any dilution necessary due to the levels of target and/or non-target analytes and matrix interference. The RL(REPORTING LIMIT) is based upon the lowest standard utilized for the calibration where applicable.
2. Samples are retained for a period of thirty days after submittal of report, unless other arrangements are made.
3. York's liability for the above data is limited to the dollar value paid to York for the referenced project.
4. This report shall not be reproduced without the written approval of York Analytical Laboratories, Inc.
5. All analyses conducted met method or Laboratory SOP requirements. See the Sample and Data Qualifiers Section for further information.
6. It is noted that no analyses reported herein were subcontracted to another laboratory, unless noted in the report.
7. This report reflects results that relate only to the samples submitted on the attached chain-of-custody form(s) received by York.
8. Analyses conducted at York Analytical Laboratories, Inc. Stratford, CT are indicated by NY Cert. No. 10854; those conducted at York Analytical Laboratories, Inc., Richmond Hill, NY are indicated by NY Cert. No. 12058.

Approved By:



Benjamin Gulizia  
Laboratory Director

Date: 08/10/2017





### Sample Information

**Client Sample ID:** WQ080117:1340NP1-1-2

**York Sample ID:** 17H0158-01

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
17H0158	Rowe Industries	Water	August 1, 2017 1:40 pm	08/03/2017

**Volatile Organics, 8260 List - Low Level**

**Log-in Notes:**

**Sample Notes:**

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
630-20-6	1,1,1,2-Tetrachloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
71-55-6	1,1,1-Trichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
79-34-5	1,1,2,2-Tetrachloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
76-13-1	1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
79-00-5	1,1,2-Trichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
75-34-3	1,1-Dichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
75-35-4	1,1-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
563-58-6	1,1-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 15:53	SS
87-61-6	1,2,3-Trichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 15:53	SS
96-18-4	1,2,3-Trichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 15:53	SS
120-82-1	1,2,4-Trichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 15:53	SS
95-63-6	1,2,4-Trimethylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
96-12-8	1,2-Dibromo-3-chloropropane	ND		ug/L	0.20	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
106-93-4	1,2-Dibromoethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
95-50-1	1,2-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
107-06-2	1,2-Dichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
78-87-5	1,2-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
108-67-8	1,3,5-Trimethylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
541-73-1	1,3-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
142-28-9	1,3-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 15:53	SS
106-46-7	1,4-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
594-20-7	2,2-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 15:53	SS



### Sample Information

**Client Sample ID:** WQ080117:1340NP1-1-2

**York Sample ID:** 17H0158-01

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17H0158

Rowe Industries

Water

August 1, 2017 1:40 pm

08/03/2017

**Volatile Organics, 8260 List - Low Level**

**Log-in Notes:**

**Sample Notes:**

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
95-49-8	2-Chlorotoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
591-78-6	2-Hexanone	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
106-43-4	4-Chlorotoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
67-64-1	Acetone	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
71-43-2	Benzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
108-86-1	Bromobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 15:53	SS
74-97-5	Bromochloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 15:53	SS
75-27-4	Bromodichloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
75-25-2	Bromoform	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
74-83-9	Bromomethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
56-23-5	Carbon tetrachloride	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
108-90-7	Chlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
75-00-3	Chloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
67-66-3	<b>Chloroform</b>	<b>0.24</b>	J	ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
74-87-3	Chloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
156-59-2	cis-1,2-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
10061-01-5	cis-1,3-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
124-48-1	Dibromochloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
74-95-3	Dibromomethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 15:53	SS
75-71-8	Dichlorodifluoromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 15:53	SS
100-41-4	Ethyl Benzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS
87-68-3	Hexachlorobutadiene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 15:53	SS
98-82-8	Isopropylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	08/09/2017 17:33	08/10/2017 15:53	SS



### Sample Information

**Client Sample ID:** WQ080117:1340NP1-1-2

**York Sample ID:** 17H0158-01

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17H0158

Rowe Industries

Water

August 1, 2017 1:40 pm

08/03/2017

**Volatile Organics, 8260 List - Low Level**

**Log-in Notes:**

**Sample Notes:**

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
1634-04-4	Methyl tert-butyl ether (MTBE)	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 15:53	SS
75-09-2	Methylene chloride	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 15:53	SS
91-20-3	Naphthalene	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 15:53	SS
104-51-8	n-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 15:53	SS
103-65-1	n-Propylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 15:53	SS
95-47-6	o-Xylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 15:53	SS
179601-23-1	p- & m- Xylenes	ND		ug/L	0.50	1.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NELAC-NY10854-Que	08/09/2017 17:33	08/10/2017 15:53	SS
99-87-6	p-Isopropyltoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 15:53	SS
135-98-8	sec-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 15:53	SS
100-42-5	Styrene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 15:53	SS
98-06-6	tert-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 15:53	SS
127-18-4	<b>Tetrachloroethylene</b>	<b>0.23</b>	<b>J</b>	ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 15:53	SS
108-88-3	Toluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 15:53	SS
156-60-5	trans-1,2-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 15:53	SS
10061-02-6	trans-1,3-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 15:53	SS
79-01-6	<b>Trichloroethylene</b>	<b>0.26</b>	<b>J</b>	ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 15:53	SS
75-69-4	Trichlorofluoromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 15:53	SS
75-01-4	Vinyl Chloride	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 15:53	SS
1330-20-7	Xylenes, Total	ND		ug/L	0.60	1.5	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854	08/09/2017 17:33	08/10/2017 15:53	SS
<b>Surrogate Recoveries</b>		<b>Result</b>	<b>Acceptance Range</b>								
17060-07-0	Surrogate: 1,2-Dichloroethane-d4	99.5 %	69-130								
2037-26-5	Surrogate: Toluene-d8	98.1 %	81-117								
460-00-4	Surrogate: p-Bromofluorobenzene	117 %	79-122								



## Analytical Batch Summary

**Batch ID:** BH70484

**Preparation Method:** EPA 5030B

**Prepared By:** RDS

YORK Sample ID	Client Sample ID	Preparation Date
17H0158-01	WQ080117:1340NP1-1-2	08/09/17
BH70484-BLK1	Blank	08/09/17
BH70484-BS1	LCS	08/09/17
BH70484-BSD1	LCS Dup	08/09/17



**Volatile Organic Compounds by GC/MS - Quality Control Data**  
**York Analytical Laboratories, Inc.**

Analyte	Result	Reporting	Units	Spike Level	Source*	%REC	%REC	Flag	RPD	RPD	Limit	Flag
		Limit			Result	Limits	Limit					

**Batch BH70484 - EPA 5030B**

**Blank (BH70484-BLK1)**

Prepared: 08/09/2017 Analyzed: 08/10/2017

1,1,1,2-Tetrachloroethane	ND	0.50	ug/L
1,1,1-Trichloroethane	ND	0.50	"
1,1,2,2-Tetrachloroethane	ND	0.50	"
1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	ND	0.50	"
1,1,2-Trichloroethane	ND	0.50	"
1,1-Dichloroethane	ND	0.50	"
1,1-Dichloroethylene	ND	0.50	"
1,1-Dichloropropylene	ND	0.50	"
1,2,3-Trichlorobenzene	0.30	0.50	"
1,2,3-Trichloropropane	ND	0.50	"
1,2,4-Trichlorobenzene	ND	0.50	"
1,2,4-Trimethylbenzene	ND	0.50	"
1,2-Dibromo-3-chloropropane	ND	0.50	"
1,2-Dibromoethane	ND	0.50	"
1,2-Dichlorobenzene	ND	0.50	"
1,2-Dichloroethane	ND	0.50	"
1,2-Dichloropropane	ND	0.50	"
1,3,5-Trimethylbenzene	ND	0.50	"
1,3-Dichlorobenzene	ND	0.50	"
1,3-Dichloropropane	ND	0.50	"
1,4-Dichlorobenzene	ND	0.50	"
2,2-Dichloropropane	ND	0.50	"
2-Chlorotoluene	ND	0.50	"
2-Hexanone	ND	0.50	"
4-Chlorotoluene	ND	0.50	"
Acetone	ND	2.0	"
Benzene	ND	0.50	"
Bromobenzene	ND	0.50	"
Bromochloromethane	ND	0.50	"
Bromodichloromethane	ND	0.50	"
Bromoform	ND	0.50	"
Bromomethane	ND	0.50	"
Carbon tetrachloride	ND	0.50	"
Chlorobenzene	ND	0.50	"
Chloroethane	ND	0.50	"
Chloroform	ND	0.50	"
Chloromethane	ND	0.50	"
cis-1,2-Dichloroethylene	ND	0.50	"
cis-1,3-Dichloropropylene	ND	0.50	"
Dibromochloromethane	ND	0.50	"
Dibromomethane	ND	0.50	"
Dichlorodifluoromethane	ND	0.50	"
Ethyl Benzene	ND	0.50	"
Hexachlorobutadiene	0.20	0.50	"
Isopropylbenzene	ND	0.50	"
Methyl tert-butyl ether (MTBE)	ND	0.50	"
Methylene chloride	ND	2.0	"
Naphthalene	ND	2.0	"
n-Butylbenzene	ND	0.50	"
n-Propylbenzene	ND	0.50	"



Volatile Organic Compounds by GC/MS - Quality Control Data

York Analytical Laboratories, Inc.

Analyte	Result	Reporting	Units	Spike	Source*	%REC	%REC	Limits	Flag	RPD	Flag
		Limit			Result					Limit	

Batch BH70484 - EPA 5030B

Blank (BH70484-BLK1)

Prepared: 08/09/2017 Analyzed: 08/10/2017

o-Xylene	ND	0.50	ug/L								
p- & m- Xylenes	ND	1.0	"								
p-Isopropyltoluene	ND	0.50	"								
sec-Butylbenzene	ND	0.50	"								
Styrene	ND	0.50	"								
tert-Butylbenzene	ND	0.50	"								
Tetrachloroethylene	ND	0.50	"								
Toluene	ND	0.50	"								
trans-1,2-Dichloroethylene	ND	0.50	"								
trans-1,3-Dichloropropylene	ND	0.50	"								
Trichloroethylene	ND	0.50	"								
Trichlorofluoromethane	ND	0.50	"								
Vinyl Chloride	ND	0.50	"								
Xylenes, Total	ND	1.5	"								
Surrogate: 1,2-Dichloroethane-d4	10.1		"	10.0		101	69-130				
Surrogate: Toluene-d8	9.74		"	10.0		97.4	81-117				
Surrogate: p-Bromofluorobenzene	11.6		"	10.0		116	79-122				

LCS (BH70484-BS1)

Prepared: 08/09/2017 Analyzed: 08/10/2017

1,1,1,2-Tetrachloroethane	10.1		ug/L	10.0		101	82-126				
1,1,1-Trichloroethane	10.3		"	10.0		103	78-136				
1,1,2,2-Tetrachloroethane	10.3		"	10.0		103	76-129				
1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	9.79		"	10.0		97.9	54-165				
1,1,2-Trichloroethane	9.56		"	10.0		95.6	82-123				
1,1-Dichloroethane	9.88		"	10.0		98.8	82-129				
1,1-Dichloroethylene	19.0		"	10.0		190	68-138	High Bias			
1,1-Dichloropropylene	10.0		"	10.0		100	83-133				
1,2,3-Trichlorobenzene	2.78		"	10.0		27.8	76-136	Low Bias			
1,2,3-Trichloropropane	10.6		"	10.0		106	77-128				
1,2,4-Trichlorobenzene	3.88		"	10.0		38.8	76-137	Low Bias			
1,2,4-Trimethylbenzene	11.2		"	10.0		112	82-132				
1,2-Dibromo-3-chloropropane	8.21		"	10.0		82.1	45-147				
1,2-Dibromoethane	9.68		"	10.0		96.8	83-124				
1,2-Dichlorobenzene	10.1		"	10.0		101	79-123				
1,2-Dichloroethane	10.2		"	10.0		102	73-132				
1,2-Dichloropropane	9.34		"	10.0		93.4	78-126				
1,3,5-Trimethylbenzene	11.5		"	10.0		115	80-131				
1,3-Dichlorobenzene	10.9		"	10.0		109	86-122				
1,3-Dichloropropane	9.50		"	10.0		95.0	81-125				
1,4-Dichlorobenzene	10.7		"	10.0		107	85-124				
2,2-Dichloropropane	8.87		"	10.0		88.7	56-150				
2-Chlorotoluene	11.4		"	10.0		114	79-130				
2-Hexanone	9.39		"	10.0		93.9	51-146				
4-Chlorotoluene	11.6		"	10.0		116	79-128				
Acetone	8.24		"	10.0		82.4	14-150				
Benzene	10.0		"	10.0		100	85-126				
Bromobenzene	10.8		"	10.0		108	78-129				
Bromochloromethane	9.77		"	10.0		97.7	77-128				
Bromodichloromethane	9.73		"	10.0		97.3	79-128				
Bromoform	9.22		"	10.0		92.2	78-133				
Bromomethane	6.56		"	10.0		65.6	43-168				



**Volatile Organic Compounds by GC/MS - Quality Control Data**

**York Analytical Laboratories, Inc.**

Analyte	Result	Reporting	Spike	Source*	%REC	%REC	Limits	Flag	RPD	RPD	
		Limit								Units	Level

**Batch BH70484 - EPA 5030B**

**LCS (BH70484-BS1)**

Prepared: 08/09/2017 Analyzed: 08/10/2017

Carbon tetrachloride	10.2		ug/L	10.0	102	102	77-141				
Chlorobenzene	10.1		"	10.0	101	101	88-120				
Chloroethane	9.81		"	10.0	98.1	98.1	65-136				
Chloroform	10.2		"	10.0	102	102	82-128				
Chloromethane	8.04		"	10.0	80.4	80.4	43-155				
cis-1,2-Dichloroethylene	10.0		"	10.0	100	100	83-129				
cis-1,3-Dichloropropylene	9.34		"	10.0	93.4	93.4	80-131				
Dibromochloromethane	9.94		"	10.0	99.4	99.4	80-130				
Dibromomethane	9.37		"	10.0	93.7	93.7	72-134				
Dichlorodifluoromethane	8.27		"	10.0	82.7	82.7	44-144				
Ethyl Benzene	10.1		"	10.0	101	101	80-131				
Hexachlorobutadiene	2.72		"	10.0	27.2	27.2	67-146	Low Bias			
Isopropylbenzene	12.0		"	10.0	120	120	76-140				
Methyl tert-butyl ether (MTBE)	10.4		"	10.0	104	104	76-135				
Methylene chloride	7.57		"	10.0	75.7	75.7	55-137				
Naphthalene	4.11		"	10.0	41.1	41.1	70-147	Low Bias			
n-Butylbenzene	10.2		"	10.0	102	102	79-132				
n-Propylbenzene	11.9		"	10.0	119	119	78-133				
o-Xylene	10.2		"	10.0	102	102	78-130				
p- & m- Xylenes	20.8		"	20.0	104	104	77-133				
p-Isopropyltoluene	11.1		"	10.0	111	111	81-136				
sec-Butylbenzene	11.8		"	10.0	118	118	79-137				
Styrene	9.14		"	10.0	91.4	91.4	67-132				
tert-Butylbenzene	12.0		"	10.0	120	120	77-138				
Tetrachloroethylene	10.7		"	10.0	107	107	82-131				
Toluene	9.94		"	10.0	99.4	99.4	80-127				
trans-1,2-Dichloroethylene	9.82		"	10.0	98.2	98.2	80-132				
trans-1,3-Dichloropropylene	9.43		"	10.0	94.3	94.3	78-131				
Trichloroethylene	9.72		"	10.0	97.2	97.2	82-128				
Trichlorofluoromethane	10.0		"	10.0	100	100	67-139				
Vinyl Chloride	9.05		"	10.0	90.5	90.5	58-145				
<i>Surrogate: 1,2-Dichloroethane-d4</i>	<i>10.2</i>		<i>"</i>	<i>10.0</i>	<i>102</i>	<i>102</i>	<i>69-130</i>				
<i>Surrogate: Toluene-d8</i>	<i>9.83</i>		<i>"</i>	<i>10.0</i>	<i>98.3</i>	<i>98.3</i>	<i>81-117</i>				
<i>Surrogate: p-Bromofluorobenzene</i>	<i>11.4</i>		<i>"</i>	<i>10.0</i>	<i>114</i>	<i>114</i>	<i>79-122</i>				



Volatile Organic Compounds by GC/MS - Quality Control Data

York Analytical Laboratories, Inc.

Analyte	Result	Reporting Limit	Units	Spike Level	Source* Result	%REC	%REC Limits	Flag	RPD	RPD Limit	Flag
<b>Batch BH70484 - EPA 5030B</b>											
<b>LCS Dup (BH70484-BSD1)</b>											
Prepared: 08/09/2017 Analyzed: 08/10/2017											
1,1,1,2-Tetrachloroethane	10.1		ug/L	10.0		101	82-126		0.297	30	
1,1,1-Trichloroethane	10.3		"	10.0		103	78-136		0.00	30	
1,1,2,2-Tetrachloroethane	10.5		"	10.0		105	76-129		1.74	30	
1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	9.74		"	10.0		97.4	54-165		0.512	30	
1,1,2-Trichloroethane	9.46		"	10.0		94.6	82-123		1.05	30	
1,1-Dichloroethane	9.69		"	10.0		96.9	82-129		1.94	30	
1,1-Dichloroethylene	19.3		"	10.0		193	68-138	High Bias	1.25	30	
1,1-Dichloropropylene	9.60		"	10.0		96.0	83-133		4.38	30	
1,2,3-Trichlorobenzene	3.03		"	10.0		30.3	76-136	Low Bias	8.61	30	
1,2,3-Trichloropropane	10.8		"	10.0		108	77-128		2.52	30	
1,2,4-Trichlorobenzene	3.93		"	10.0		39.3	76-137	Low Bias	1.28	30	
1,2,4-Trimethylbenzene	11.1		"	10.0		111	82-132		1.08	30	
1,2-Dibromo-3-chloropropane	8.38		"	10.0		83.8	45-147		2.05	30	
1,2-Dibromoethane	9.68		"	10.0		96.8	83-124		0.00	30	
1,2-Dichlorobenzene	9.91		"	10.0		99.1	79-123		1.50	30	
1,2-Dichloroethane	10.0		"	10.0		100	73-132		1.78	30	
1,2-Dichloropropane	9.26		"	10.0		92.6	78-126		0.860	30	
1,3,5-Trimethylbenzene	11.3		"	10.0		113	80-131		1.93	30	
1,3-Dichlorobenzene	10.7		"	10.0		107	86-122		2.41	30	
1,3-Dichloropropane	9.54		"	10.0		95.4	81-125		0.420	30	
1,4-Dichlorobenzene	10.6		"	10.0		106	85-124		0.656	30	
2,2-Dichloropropane	8.67		"	10.0		86.7	56-150		2.28	30	
2-Chlorotoluene	11.2		"	10.0		112	79-130		2.03	30	
2-Hexanone	9.75		"	10.0		97.5	51-146		3.76	30	
4-Chlorotoluene	11.4		"	10.0		114	79-128		1.39	30	
Acetone	7.88		"	10.0		78.8	14-150		4.47	30	
Benzene	9.92		"	10.0		99.2	85-126		1.10	30	
Bromobenzene	10.6		"	10.0		106	78-129		1.12	30	
Bromochloromethane	9.70		"	10.0		97.0	77-128		0.719	30	
Bromodichloromethane	9.60		"	10.0		96.0	79-128		1.35	30	
Bromoform	9.49		"	10.0		94.9	78-133		2.89	30	
Bromomethane	6.64		"	10.0		66.4	43-168		1.21	30	
Carbon tetrachloride	10.1		"	10.0		101	77-141		1.38	30	
Chlorobenzene	10.0		"	10.0		100	88-120		0.993	30	
Chloroethane	9.78		"	10.0		97.8	65-136		0.306	30	
Chloroform	10.2		"	10.0		102	82-128		0.491	30	
Chloromethane	7.91		"	10.0		79.1	43-155		1.63	30	
cis-1,2-Dichloroethylene	9.84		"	10.0		98.4	83-129		1.91	30	
cis-1,3-Dichloropropylene	9.24		"	10.0		92.4	80-131		1.08	30	
Dibromochloromethane	10.1		"	10.0		101	80-130		1.20	30	
Dibromomethane	9.40		"	10.0		94.0	72-134		0.320	30	
Dichlorodifluoromethane	7.98		"	10.0		79.8	44-144		3.57	30	
Ethyl Benzene	10.0		"	10.0		100	80-131		0.992	30	
Hexachlorobutadiene	2.81		"	10.0		28.1	67-146	Low Bias	3.25	30	
Isopropylbenzene	11.8		"	10.0		118	76-140		1.67	30	
Methyl tert-butyl ether (MTBE)	10.4		"	10.0		104	76-135		0.288	30	
Methylene chloride	7.55		"	10.0		75.5	55-137		0.265	30	
Naphthalene	4.28		"	10.0		42.8	70-147	Low Bias	4.05	30	
n-Butylbenzene	9.89		"	10.0		98.9	79-132		2.89	30	
n-Propylbenzene	11.6		"	10.0		116	78-133		2.56	30	
o-Xylene	10.1		"	10.0		101	78-130		0.885	30	



**Volatile Organic Compounds by GC/MS - Quality Control Data**

**York Analytical Laboratories, Inc.**

Analyte	Result	Reporting	Units	Spike Level	Source*	%REC	%REC Limits	Flag	RPD	RPD	Flag
		Limit			Result					Limit	

**Batch BH70484 - EPA 5030B**

**LCS Dup (BH70484-BSD1)**

Prepared: 08/09/2017 Analyzed: 08/10/2017

p- & m- Xylenes	20.5		ug/L	20.0		102	77-133		1.69	30	
p-Isopropyltoluene	10.9		"	10.0		109	81-136		2.00	30	
sec-Butylbenzene	11.6		"	10.0		116	79-137		1.79	30	
Styrene	9.05		"	10.0		90.5	67-132		0.990	30	
tert-Butylbenzene	11.7		"	10.0		117	77-138		2.03	30	
Tetrachloroethylene	10.4		"	10.0		104	82-131		2.47	30	
Toluene	9.87		"	10.0		98.7	80-127		0.707	30	
trans-1,2-Dichloroethylene	9.88		"	10.0		98.8	80-132		0.609	30	
trans-1,3-Dichloropropylene	9.47		"	10.0		94.7	78-131		0.423	30	
Trichloroethylene	9.59		"	10.0		95.9	82-128		1.35	30	
Trichlorofluoromethane	9.77		"	10.0		97.7	67-139		2.53	30	
Vinyl Chloride	8.92		"	10.0		89.2	58-145		1.45	30	
<i>Surrogate: 1,2-Dichloroethane-d4</i>	<i>10.2</i>		<i>"</i>	<i>10.0</i>		<i>102</i>	<i>69-130</i>				
<i>Surrogate: Toluene-d8</i>	<i>9.86</i>		<i>"</i>	<i>10.0</i>		<i>98.6</i>	<i>81-117</i>				
<i>Surrogate: p-Bromofluorobenzene</i>	<i>11.4</i>		<i>"</i>	<i>10.0</i>		<i>114</i>	<i>79-122</i>				



### Volatile Analysis Sample Containers

Lab ID	Client Sample ID	Volatile Sample Container
17H0158-01	WQ080117:1340NP1-1-2	40mL Clear Vial (pre-pres.) HCl; Cool to 4° C



## Sample and Data Qualifiers Relating to This Work Order

- QL-02 This LCS analyte is outside Laboratory Recovery limits due the analyte behavior using the referenced method. The reference method has certain limitations with respect to analytes of this nature.
- J Detected below the Reporting Limit but greater than or equal to the Method Detection Limit (MDL/LOD) or in the case of a TIC, the result is an estimated concentration.

### Definitions and Other Explanations

- \* Analyte is not certified or the state of the samples origination does not offer certification for the Analyte.
- ND NOT DETECTED - the analyte is not detected at the Reported to level (LOQ/RL or LOD/MDL)
- RL REPORTING LIMIT - the minimum reportable value based upon the lowest point in the analyte calibration curve.
- LOQ LIMIT OF QUANTITATION - the minimum concentration of a target analyte that can be reported within a specified degree of confidence. This is the lowest point in an analyte calibration curve that has been subjected to all steps of the processing/analysis and verified to meet defined criteria. This is based upon NELAC 2009 Standards and applies to all analyses.
- LOD LIMIT OF DETECTION - a verified estimate of the minimum concentration of a substance in a given matrix that an analytical process can reliably detect. This is based upon NELAC 2009 Standards and applies to all analyses conducted under the auspices of EPA SW-846.
- MDL METHOD DETECTION LIMIT - a statistically derived estimate of the minimum amount of a substance an analytical system can reliably detect with a 99% confidence that the concentration of the substance is greater than zero. This is based upon 40 CFR Part 136 Appendix B and applies only to EPA 600 and 200 series methods.
- Reported to This indicates that the data for a particular analysis is reported to either the LOD/MDL, or the LOQ/RL. In cases where the "Reported to" is located above the LOD/MDL, any value between this and the LOQ represents an estimated value which is "J" flagged accordingly. This applies to volatile and semi-volatile target compounds only.
- NR Not reported
- RPD Relative Percent Difference
- Wet The data has been reported on an as-received (wet weight) basis
- Low Bias Low Bias flag indicates that the recovery of the flagged analyte is below the laboratory or regulatory lower control limit. The data user should take note that this analyte may be biased low but should evaluate multiple lines of evidence including the LCS and site-specific MS/MSD data to draw bias conclusions. In cases where no site-specific MS/MSD was requested, only the LCS data can be used to evaluate such bias.
- High Bias High Bias flag indicates that the recovery of the flagged analyte is above the laboratory or regulatory upper control limit. The data user should take note that this analyte may be biased high but should evaluate multiple lines of evidence including the LCS and site-specific MS/MSD data to draw bias conclusions. In cases where no site-specific MS/MSD was requested, only the LCS data can be used to evaluate such bias.
- Non-Dir. Non-dir. flag (Non-Directional Bias ) indicates that the Relative Percent Difference (RPD) (a measure of precision) among the MS and MSD data is outside the laboratory or regulatory control limit. This alerts the data user where the MS and MSD are from site-specific samples that the RPD is high due to either non-homogeneous distribution of target analyte between the MS/MSD or indicates poor reproducibility for other reasons.

If EPA SW-846 method 8270 is included herein it is noted that the target compound N-nitrosodiphenylamine (NDPA) decomposes in the gas chromatographic inlet and cannot be separated from diphenylamine (DPA). These results could actually represent 100% DPA, 100% NDPA or some combination of the two. For this reason, York reports the combined result for n-nitrosodiphenylamine and diphenylamine for either of these compounds as a combined concentration as Diphenylamine.

If Total PCBs are detected and the target aroclors reported are "Not detected", the Total PCB value is reported due to the presence of either or both Aroclors 1262 and 1268 which are non-target aroclors for some regulatory lists.

2-chloroethylvinyl ether readily breaks down under acidic conditions. Samples that are acid preserved, including standards will exhibit breakdown. The data user should take note.

Certification for pH is no longer offered by NYDOH ELAP.

Semi-Volatile and Volatile analyses are reported down to the LOD/MDL, with values between the LOD/MDL and the LOQ being "J" flagged as estimated results.



For analyses by EPA SW-846-8270D, the Limit of Quantitation (LOQ) reported for benzidine is based upon the lowest standard used for calibration and is not a verified LOQ due to this compound's propensity for oxidative losses during extraction/concentration procedures and non-reproducible chromatographic performance.

---



# YORK

ANALYTICAL LABORATORIES, INC.  
120 RESEARCH DR. STRATFORD, CT 06615  
(203) 325-1371 FAX (203) 357-0166

# Field Chain-of-Custody Record

Page 1 of 1

NOTE: York's Std. Terms & Conditions are listed on the back side of this document. This document serves as your written authorization to York to proceed with the analyses requested and your signature binds you to York's Std. Terms & Conditions.

York Project No. 17H0158

<b>YOUR INFORMATION</b> Company: <u>LB6</u> Address: <u>4 Research Dr. Suite 301</u> <u>Shelton, CT 06484</u> Phone No. <u>203-929-8555</u> Contact Person: <u>Tunde Sander</u> E-Mail Address: <u>Tsander@LB6.com</u>		<b>Report To:</b> Company: <u>Same</u> Address: _____ Phone No. _____ Attention: _____ E-Mail Address: _____		<b>Invoice To:</b> Company: <u>Rowe Industries</u> Address: _____ Phone No. _____ Attention: _____ E-Mail Address: _____		<b>YOUR PROJECT ID</b> Project Name: _____ Purchase Order No.: <u>MABSA6</u> Samples from: CT _____ NY _____ X NJ _____		<b>Turn-Around Time</b> RUSH - Same Day <input type="checkbox"/> RUSH - Next Day <input type="checkbox"/> RUSH - Two Day <input type="checkbox"/> RUSH - Three Day <input type="checkbox"/> RUSH - Four Day <input type="checkbox"/> Standard (5-7 Days) <input checked="" type="checkbox"/>		<b>Report Type</b> Summary Report <input checked="" type="checkbox"/> <u>pdf</u> Summary w/ QA summary <input checked="" type="checkbox"/> <u>pdf</u> CT RCP Package <input type="checkbox"/> CT RCP DQA/DUE Pkg <input type="checkbox"/> NY ASP A Package <input type="checkbox"/> NY ASP B Package <input checked="" type="checkbox"/> <u>pdf</u> NIDEP Red. Deliv. <input type="checkbox"/> Electronic Data Deliverables (EDD) <input type="checkbox"/> Simple Excel <input checked="" type="checkbox"/> X NYSDEC EQULS _____ EQULS (std) _____ EZ-EDD (EQULS) _____ NIDEP SRP HazSite EDD _____ GIS/KEY (std) _____ Other _____ York Regulatory Comparison _____ Excel Spreadsheet _____ Compare to the following Regs. (please fill in): _____									
<b>Report To:</b> Company: _____ Address: _____ Phone No. _____ Attention: _____ E-Mail Address: _____		<b>Volatiles</b> 8260 full _____ 624 _____ STARS list _____ BTEX _____ MTBE _____ TCL list _____ TAGM list _____ CT RCP list _____ Arom. only _____ Halog. only _____ App. IX list _____ 8021B list _____		<b>Metals</b> RCRA8 _____ PP13 list _____ TAL _____ CT15 list _____ TAGM list _____ NIDEP list _____ Air TO14A _____ Air TO15 _____ Air STARS _____ Air VPH _____ Air TCS _____ Methane _____ Helium _____		<b>Misc. Org.</b> TPH GRO _____ TPH DRO _____ CT ETPH _____ TAL MACN _____ Full TCLP _____ Full App. IX _____ Part 360 Acute _____ Part 360 Residue _____ Part 360 Inorganic _____ Part 360 Aquatic Tox _____ NYCLP Sewer _____ NYCLP Sewer _____ NYCLP Sewer _____ TAGM _____ Silica _____		<b>Matrix Codes</b> S - soil _____ Other - specify (oil, etc.) _____ WW - wastewater _____ GW - groundwater _____ DW - drinking water _____ Air-A - ambient air _____ Air-SV - soil vapor _____		<b>Sample Matrix</b> <u>GW</u>		<b>Date Sampled</b> <u>8-1-17</u>		<b>Sample Identification</b> <u>10080117.1340NPI-1-2</u>		<b>Choose Analyses Needed from the Menu Above and Enter Below</b> <u>VOC 8260 full list (EPA 519-846-8260) plus from 113</u> <u>3 UO2</u>		<b>Container Description(s)</b> _____	
<b>Comments</b> Preservation <input type="checkbox"/> _____ Check those Applicable _____ Special Instructions <input type="checkbox"/> _____ Field Filtered <input type="checkbox"/> _____ Lab to Filter <input type="checkbox"/> _____		4°C <input checked="" type="checkbox"/> Frozen _____ ZnAc _____ HCl _____ MeOH _____ Acorbic Acid _____ Other _____ HNO <sub>3</sub> _____ H <sub>2</sub> SO <sub>4</sub> _____ NaOH _____		Samples Relinquished By: <u>[Signature]</u> Date/Time: <u>8/17 8:00</u> Samples Received By: <u>[Signature]</u> Date/Time: <u>8/2/17 8:00</u>		Samples Relinquished By: _____ Date/Time: _____ Samples Received in LAB by: _____ Date/Time: _____		Temperature on Receipt: <u>2.1</u> °C											

*Print Clearly and Legibly. All Information must be complete. Samples will NOT be logged in and the turn-around time clock will not begin until any questions by York are resolved.*

*[Signature]*  
 Samples Collected/Authorized By (Signature)  
Evan Foster  
 Name (printed)

*Dec'd at 8/3/17 12:35*

*(AW & FAW)*



# Technical Report

prepared for:

**Leggette Brashears & Graham Shelton Office**

4 Research Drive, Suite 204

Shelton CT, 06484

**Attention: Tunde Komuves-Sandor**

Report Date: 08/11/2017

**Client Project ID: Rowe Industries**

York Project (SDG) No.: 17H0156

CT Cert. No. PH-0723

New Jersey Cert. No. CT005 and NY037



New York Cert. Nos. 10854 and 12058

PA Cert. No. 68-04440

120 RESEARCH DRIVE  
[www.YORKLAB.com](http://www.YORKLAB.com)

STRATFORD, CT 06615  
(203) 325-1371

132-02 89th AVENUE  
FAX (203) 357-0166

RICHMOND HILL, NY 11418  
[ClientServices@yorklab.com](mailto:ClientServices@yorklab.com)

Report Date: 08/11/2017  
Client Project ID: Rowe Industries  
York Project (SDG) No.: 17H0156

**Leggette Brashears & Graham Shelton Office**  
4 Research Drive, Suite 204  
Shelton CT, 06484  
Attention: Tunde Komuves-Sandor

---

## Purpose and Results

This report contains the analytical data for the sample(s) identified on the attached chain-of-custody received in our laboratory on August 03, 2017 and listed below. The project was identified as your project: **Rowe Industries**.

The analyses were conducted utilizing appropriate EPA, Standard Methods, and ASTM methods as detailed in the data summary tables.

All samples were received in proper condition meeting the customary acceptance requirements for environmental samples except those indicated under the Sample and Analysis Qualifiers section of this report.

All analyses met the method and laboratory standard operating procedure requirements except as indicated by any data flags, the meaning of which are explained in the Sample and Data Qualifiers Relating to This Work Order section of this report and case narrative if applicable.

The results of the analyses, which are all reported on dry weight basis (soils) unless otherwise noted, are detailed in the following pages.

Please contact Client Services at 203.325.1371 with any questions regarding this report.

<u>York Sample ID</u>	<u>Client Sample ID</u>	<u>Matrix</u>	<u>Date Collected</u>	<u>Date Received</u>
17H0156-01	WQ080117: 1320 FRW-1	Water	08/01/2017	08/03/2017
17H0156-02	WQ080117: 1325 FRW-2	Water	08/01/2017	08/03/2017
17H0156-03	WQ080117: 1330 FRW-3	Water	08/01/2017	08/03/2017
17H0156-04	WQ080117: 1335 FRW-4	Water	08/01/2017	08/03/2017

## **General Notes for York Project (SDG) No.: 17H0156**

1. The RLs and MDLs (Reporting Limit and Method Detection Limit respectively) reported are adjusted for any dilution necessary due to the levels of target and/or non-target analytes and matrix interference. The RL(REPORTING LIMIT) is based upon the lowest standard utilized for the calibration where applicable.
2. Samples are retained for a period of thirty days after submittal of report, unless other arrangements are made.
3. York's liability for the above data is limited to the dollar value paid to York for the referenced project.
4. This report shall not be reproduced without the written approval of York Analytical Laboratories, Inc.
5. All analyses conducted met method or Laboratory SOP requirements. See the Sample and Data Qualifiers Section for further information.
6. It is noted that no analyses reported herein were subcontracted to another laboratory, unless noted in the report.
7. This report reflects results that relate only to the samples submitted on the attached chain-of-custody form(s) received by York.
8. Analyses conducted at York Analytical Laboratories, Inc. Stratford, CT are indicated by NY Cert. No. 10854; those conducted at York Analytical Laboratories, Inc., Richmond Hill, NY are indicated by NY Cert. No. 12058.

**Approved By:**



Benjamin Gulizia  
Laboratory Director

**Date:** 08/11/2017





### Sample Information

**Client Sample ID:** WQ080117: 1320 FRW-1

**York Sample ID:** 17H0156-01

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
17H0156	Rowe Industries	Water	August 1, 2017 1:20 pm	08/03/2017

**Volatile Organics, 8260 List - Low Level**

**Log-in Notes:**

**Sample Notes:**

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
630-20-6	1,1,1,2-Tetrachloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
71-55-6	1,1,1-Trichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
79-34-5	1,1,2,2-Tetrachloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
76-13-1	1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
79-00-5	1,1,2-Trichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
75-34-3	1,1-Dichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
75-35-4	1,1-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
563-58-6	1,1-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS
87-61-6	1,2,3-Trichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS
96-18-4	1,2,3-Trichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS
120-82-1	1,2,4-Trichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS
95-63-6	1,2,4-Trimethylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
96-12-8	1,2-Dibromo-3-chloropropane	ND		ug/L	0.20	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
106-93-4	1,2-Dibromoethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
95-50-1	1,2-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
107-06-2	1,2-Dichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
78-87-5	1,2-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
108-67-8	1,3,5-Trimethylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
541-73-1	1,3-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
142-28-9	1,3-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS
106-46-7	1,4-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
594-20-7	2,2-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS



### Sample Information

**Client Sample ID:** WQ080117: 1320 FRW-1

**York Sample ID:** 17H0156-01

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17H0156

Rowe Industries

Water

August 1, 2017 1:20 pm

08/03/2017

**Volatile Organics, 8260 List - Low Level**

**Log-in Notes:**

**Sample Notes:**

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
95-49-8	2-Chlorotoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
591-78-6	2-Hexanone	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
106-43-4	4-Chlorotoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
67-64-1	Acetone	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
71-43-2	Benzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
108-86-1	Bromobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS
74-97-5	Bromochloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS
75-27-4	Bromodichloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
75-25-2	Bromoform	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
74-83-9	Bromomethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
56-23-5	Carbon tetrachloride	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
108-90-7	Chlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
75-00-3	Chloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
67-66-3	Chloroform	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
74-87-3	Chloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
156-59-2	<b>cis-1,2-Dichloroethylene</b>	<b>0.44</b>	<b>J</b>	ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
10061-01-5	cis-1,3-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
124-48-1	Dibromochloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
74-95-3	Dibromomethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS
75-71-8	Dichlorodifluoromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS
100-41-4	Ethyl Benzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS
87-68-3	Hexachlorobutadiene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS
98-82-8	Isopropylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:07	SS



### Sample Information

**Client Sample ID:** WQ080117: 1320 FRW-1

**York Sample ID:** 17H0156-01

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17H0156

Rowe Industries

Water

August 1, 2017 1:20 pm

08/03/2017

**Volatile Organics, 8260 List - Low Level**

**Log-in Notes:**

**Sample Notes:**

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
1634-04-4	Methyl tert-butyl ether (MTBE)	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS
75-09-2	Methylene chloride	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS
91-20-3	Naphthalene	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS
104-51-8	n-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS
103-65-1	n-Propylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS
95-47-6	o-Xylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS
179601-23-1	p- & m- Xylenes	ND		ug/L	0.50	1.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS
99-87-6	p-Isopropyltoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS
135-98-8	sec-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS
100-42-5	Styrene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS
98-06-6	tert-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS
127-18-4	<b>Tetrachloroethylene</b>	<b>16</b>		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS
108-88-3	Toluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS
156-60-5	trans-1,2-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS
10061-02-6	trans-1,3-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS
79-01-6	<b>Trichloroethylene</b>	<b>0.41</b>	<b>J</b>	ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS
75-69-4	Trichlorofluoromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS
75-01-4	Vinyl Chloride	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS
1330-20-7	Xylenes, Total	ND		ug/L	0.60	1.5	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:07	SS
	<b>Surrogate Recoveries</b>	<b>Result</b>			<b>Acceptance Range</b>						
17060-07-0	Surrogate: 1,2-Dichloroethane-d4	103 %			69-130						
2037-26-5	Surrogate: Toluene-d8	96.4 %			81-117						
460-00-4	Surrogate: p-Bromofluorobenzene	108 %			79-122						



### Sample Information

**Client Sample ID:** WQ080117: 1325 FRW-2

**York Sample ID:** 17H0156-02

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17H0156

Rowe Industries

Water

August 1, 2017 1:25 pm

08/03/2017

**Volatile Organics, 8260 List - Low Level**

**Log-in Notes:**

**Sample Notes:**

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
630-20-6	1,1,1,2-Tetrachloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
71-55-6	1,1,1-Trichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
79-34-5	1,1,2,2-Tetrachloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
76-13-1	1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
79-00-5	1,1,2-Trichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
75-34-3	1,1-Dichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
75-35-4	1,1-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
563-58-6	1,1-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:38	SS
87-61-6	1,2,3-Trichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:38	SS
96-18-4	1,2,3-Trichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:38	SS
120-82-1	1,2,4-Trichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:38	SS
95-63-6	1,2,4-Trimethylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
96-12-8	1,2-Dibromo-3-chloropropane	ND		ug/L	0.20	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
106-93-4	1,2-Dibromoethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
95-50-1	1,2-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
107-06-2	1,2-Dichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
78-87-5	1,2-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
108-67-8	1,3,5-Trimethylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
541-73-1	1,3-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
142-28-9	1,3-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:38	SS
106-46-7	1,4-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
594-20-7	2,2-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:38	SS
95-49-8	2-Chlorotoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS



### Sample Information

**Client Sample ID:** WQ080117: 1325 FRW-2

**York Sample ID:** 17H0156-02

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17H0156

Rowe Industries

Water

August 1, 2017 1:25 pm

08/03/2017

**Volatile Organics, 8260 List - Low Level**

**Log-in Notes:**

**Sample Notes:**

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
591-78-6	2-Hexanone	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
106-43-4	4-Chlorotoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
67-64-1	<b>Acetone</b>	<b>2.1</b>	SCAL-E	ug/L	1.0	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
71-43-2	Benzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
108-86-1	Bromobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:38	SS
74-97-5	Bromochloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:38	SS
75-27-4	Bromodichloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
75-25-2	Bromoform	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
74-83-9	Bromomethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
56-23-5	Carbon tetrachloride	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
108-90-7	Chlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
75-00-3	Chloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
67-66-3	Chloroform	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
74-87-3	Chloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
156-59-2	cis-1,2-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
10061-01-5	cis-1,3-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
124-48-1	Dibromochloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
74-95-3	Dibromomethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:38	SS
75-71-8	Dichlorodifluoromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:38	SS
100-41-4	Ethyl Benzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
87-68-3	Hexachlorobutadiene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:38	SS
98-82-8	Isopropylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
1634-04-4	Methyl tert-butyl ether (MTBE)	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS



### Sample Information

**Client Sample ID:** WQ080117: 1325 FRW-2

**York Sample ID:** 17H0156-02

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17H0156

Rowe Industries

Water

August 1, 2017 1:25 pm

08/03/2017

**Volatile Organics, 8260 List - Low Level**

**Log-in Notes:**

**Sample Notes:**

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
75-09-2	Methylene chloride	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
91-20-3	Naphthalene	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:38	SS
104-51-8	n-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
103-65-1	n-Propylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
95-47-6	o-Xylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:38	SS
179601-23-1	p- & m- Xylenes	ND		ug/L	0.50	1.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NELAC-NY10854-Que	08/10/2017 15:38	08/10/2017 23:38	SS
99-87-6	p-Isopropyltoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
135-98-8	sec-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
100-42-5	Styrene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
98-06-6	tert-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
127-18-4	<b>Tetrachloroethylene</b>	<b>7.0</b>		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
108-88-3	Toluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
156-60-5	trans-1,2-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
10061-02-6	trans-1,3-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
79-01-6	Trichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
75-69-4	Trichlorofluoromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
75-01-4	Vinyl Chloride	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
1330-20-7	Xylenes, Total	ND		ug/L	0.60	1.5	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/10/2017 23:38	SS
	<b>Surrogate Recoveries</b>	<b>Result</b>			<b>Acceptance Range</b>						
17060-07-0	Surrogate: 1,2-Dichloroethane-d4	101 %			69-130						
2037-26-5	Surrogate: Toluene-d8	97.5 %			81-117						
460-00-4	Surrogate: p-Bromofluorobenzene	112 %			79-122						



### Sample Information

**Client Sample ID:** WQ080117: 1330 FRW-3

**York Sample ID:** 17H0156-03

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17H0156

Rowe Industries

Water

August 1, 2017 1:30 pm

08/03/2017

**Volatile Organics, 8260 List - Low Level**

**Log-in Notes:**

**Sample Notes:**

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
630-20-6	1,1,1,2-Tetrachloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
71-55-6	1,1,1-Trichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
79-34-5	1,1,2,2-Tetrachloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
76-13-1	1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
79-00-5	1,1,2-Trichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
75-34-3	1,1-Dichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
75-35-4	1,1-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
563-58-6	1,1-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/11/2017 00:11	SS
87-61-6	1,2,3-Trichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/11/2017 00:11	SS
96-18-4	1,2,3-Trichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/11/2017 00:11	SS
120-82-1	1,2,4-Trichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/11/2017 00:11	SS
95-63-6	1,2,4-Trimethylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
96-12-8	1,2-Dibromo-3-chloropropane	ND		ug/L	0.20	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
106-93-4	1,2-Dibromoethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
95-50-1	1,2-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
107-06-2	1,2-Dichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
78-87-5	1,2-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
108-67-8	1,3,5-Trimethylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
541-73-1	1,3-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
142-28-9	1,3-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/11/2017 00:11	SS
106-46-7	1,4-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
594-20-7	2,2-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/11/2017 00:11	SS
95-49-8	2-Chlorotoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS



### Sample Information

**Client Sample ID:** WQ080117: 1330 FRW-3

**York Sample ID:** 17H0156-03

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17H0156

Rowe Industries

Water

August 1, 2017 1:30 pm

08/03/2017

**Volatile Organics, 8260 List - Low Level**

**Log-in Notes:**

**Sample Notes:**

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
591-78-6	2-Hexanone	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
106-43-4	4-Chlorotoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
67-64-1	<b>Acetone</b>	<b>1.6</b>	SCAL-E, J	ug/L	1.0	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
71-43-2	Benzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
108-86-1	Bromobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/11/2017 00:11	SS
74-97-5	Bromochloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/11/2017 00:11	SS
75-27-4	Bromodichloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
75-25-2	Bromoform	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
74-83-9	Bromomethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
56-23-5	Carbon tetrachloride	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
108-90-7	Chlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
75-00-3	Chloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
67-66-3	Chloroform	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
74-87-3	Chloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
156-59-2	<b>cis-1,2-Dichloroethylene</b>	<b>1.9</b>		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
10061-01-5	cis-1,3-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
124-48-1	Dibromochloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
74-95-3	Dibromomethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/11/2017 00:11	SS
75-71-8	Dichlorodifluoromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/11/2017 00:11	SS
100-41-4	Ethyl Benzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
87-68-3	Hexachlorobutadiene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/11/2017 00:11	SS
98-82-8	Isopropylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
1634-04-4	Methyl tert-butyl ether (MTBE)	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS



### Sample Information

**Client Sample ID:** WQ080117: 1330 FRW-3

**York Sample ID:** 17H0156-03

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17H0156

Rowe Industries

Water

August 1, 2017 1:30 pm

08/03/2017

**Volatile Organics, 8260 List - Low Level**

**Log-in Notes:**

**Sample Notes:**

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
75-09-2	Methylene chloride	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
91-20-3	Naphthalene	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/11/2017 00:11	SS
104-51-8	n-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
103-65-1	n-Propylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
95-47-6	o-Xylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NELAC-NY10854-Que	08/10/2017 15:38	08/11/2017 00:11	SS
179601-23-1	p- & m- Xylenes	ND		ug/L	0.50	1.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NELAC-NY10854-Que	08/10/2017 15:38	08/11/2017 00:11	SS
99-87-6	p-Isopropyltoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
135-98-8	sec-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
100-42-5	Styrene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
98-06-6	tert-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
127-18-4	<b>Tetrachloroethylene</b>	<b>35</b>		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
108-88-3	Toluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
156-60-5	trans-1,2-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
10061-02-6	trans-1,3-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
79-01-6	<b>Trichloroethylene</b>	<b>1.9</b>		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
75-69-4	Trichlorofluoromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
75-01-4	Vinyl Chloride	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
1330-20-7	Xylenes, Total	ND		ug/L	0.60	1.5	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:11	SS
	<b>Surrogate Recoveries</b>	<b>Result</b>			<b>Acceptance Range</b>						
17060-07-0	Surrogate: 1,2-Dichloroethane-d4	102 %			69-130						
2037-26-5	Surrogate: Toluene-d8	96.8 %			81-117						
460-00-4	Surrogate: p-Bromofluorobenzene	112 %			79-122						



### Sample Information

**Client Sample ID:** WQ080117: 1335 FRW-4

**York Sample ID:** 17H0156-04

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17H0156

Rowe Industries

Water

August 1, 2017 1:35 pm

08/03/2017

**Volatile Organics, 8260 List - Low Level**

**Log-in Notes:**

**Sample Notes:**

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
630-20-6	1,1,1,2-Tetrachloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
71-55-6	1,1,1-Trichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
79-34-5	1,1,2,2-Tetrachloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
76-13-1	1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
79-00-5	1,1,2-Trichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
75-34-3	1,1-Dichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
75-35-4	1,1-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
563-58-6	1,1-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/11/2017 00:43	SS
87-61-6	1,2,3-Trichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/11/2017 00:43	SS
96-18-4	1,2,3-Trichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/11/2017 00:43	SS
120-82-1	1,2,4-Trichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/11/2017 00:43	SS
95-63-6	1,2,4-Trimethylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
96-12-8	1,2-Dibromo-3-chloropropane	ND		ug/L	0.20	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
106-93-4	1,2-Dibromoethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
95-50-1	1,2-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
107-06-2	1,2-Dichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
78-87-5	1,2-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
108-67-8	1,3,5-Trimethylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
541-73-1	1,3-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
142-28-9	1,3-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/11/2017 00:43	SS
106-46-7	1,4-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
594-20-7	2,2-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/11/2017 00:43	SS
95-49-8	2-Chlorotoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS



### Sample Information

**Client Sample ID:** WQ080117: 1335 FRW-4

**York Sample ID:** 17H0156-04

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17H0156

Rowe Industries

Water

August 1, 2017 1:35 pm

08/03/2017

**Volatile Organics, 8260 List - Low Level**

**Log-in Notes:**

**Sample Notes:**

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
591-78-6	2-Hexanone	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
106-43-4	4-Chlorotoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
67-64-1	<b>Acetone</b>	<b>1.6</b>	SCAL-E, J	ug/L	1.0	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
71-43-2	Benzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
108-86-1	Bromobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/11/2017 00:43	SS
74-97-5	Bromochloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/11/2017 00:43	SS
75-27-4	Bromodichloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
75-25-2	Bromoform	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
74-83-9	Bromomethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
56-23-5	Carbon tetrachloride	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
108-90-7	Chlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
75-00-3	Chloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
67-66-3	Chloroform	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
74-87-3	Chloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
156-59-2	cis-1,2-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
10061-01-5	cis-1,3-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
124-48-1	Dibromochloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
74-95-3	Dibromomethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/11/2017 00:43	SS
75-71-8	Dichlorodifluoromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/11/2017 00:43	SS
100-41-4	Ethyl Benzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
87-68-3	Hexachlorobutadiene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/11/2017 00:43	SS
98-82-8	Isopropylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
1634-04-4	Methyl tert-butyl ether (MTBE)	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS



### Sample Information

**Client Sample ID:** WQ080117: 1335 FRW-4

**York Sample ID:** 17H0156-04

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17H0156

Rowe Industries

Water

August 1, 2017 1:35 pm

08/03/2017

**Volatile Organics, 8260 List - Low Level**

**Log-in Notes:**

**Sample Notes:**

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
75-09-2	Methylene chloride	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
91-20-3	Naphthalene	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	08/10/2017 15:38	08/11/2017 00:43	SS
104-51-8	n-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
103-65-1	n-Propylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
95-47-6	o-Xylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NELAC-NY10854-Que	08/10/2017 15:38	08/11/2017 00:43	SS
179601-23-1	p- & m- Xylenes	ND		ug/L	0.50	1.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NELAC-NY10854-Que	08/10/2017 15:38	08/11/2017 00:43	SS
99-87-6	p-Isopropyltoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
135-98-8	sec-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
100-42-5	Styrene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
98-06-6	tert-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
127-18-4	<b>Tetrachloroethylene</b>	<b>0.80</b>		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
108-88-3	Toluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
156-60-5	trans-1,2-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
10061-02-6	trans-1,3-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
79-01-6	Trichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
75-69-4	Trichlorofluoromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
75-01-4	Vinyl Chloride	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
1330-20-7	Xylenes, Total	ND		ug/L	0.60	1.5	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	08/10/2017 15:38	08/11/2017 00:43	SS
<b>Surrogate Recoveries</b>		<b>Result</b>	<b>Acceptance Range</b>								
17060-07-0	Surrogate: 1,2-Dichloroethane-d4	102 %	69-130								
2037-26-5	Surrogate: Toluene-d8	97.4 %	81-117								
460-00-4	Surrogate: p-Bromofluorobenzene	111 %	79-122								



## Analytical Batch Summary

**Batch ID:** BH70512

**Preparation Method:** EPA 5030B

**Prepared By:** RDS

YORK Sample ID	Client Sample ID	Preparation Date
17H0156-01	WQ080117: 1320 FRW-1	08/10/17
17H0156-02	WQ080117: 1325 FRW-2	08/10/17
17H0156-03	WQ080117: 1330 FRW-3	08/10/17
17H0156-04	WQ080117: 1335 FRW-4	08/10/17
BH70512-BLK1	Blank	08/10/17
BH70512-BS1	LCS	08/10/17
BH70512-BSD1	LCS Dup	08/10/17



**Volatile Organic Compounds by GC/MS - Quality Control Data**  
**York Analytical Laboratories, Inc.**

Analyte	Result	Reporting Limit	Units	Spike Level	Source* Result	%REC	%REC Limits	Flag	RPD	RPD Limit	Flag
---------	--------	-----------------	-------	-------------	----------------	------	-------------	------	-----	-----------	------

**Batch BH70512 - EPA 5030B**

**Blank (BH70512-BLK1)**

Prepared & Analyzed: 08/10/2017

1,1,1,2-Tetrachloroethane	ND	0.50	ug/L								
1,1,1-Trichloroethane	ND	0.50	"								
1,1,2,2-Tetrachloroethane	ND	0.50	"								
1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	ND	0.50	"								
1,1,2-Trichloroethane	ND	0.50	"								
1,1-Dichloroethane	ND	0.50	"								
1,1-Dichloroethylene	ND	0.50	"								
1,1-Dichloropropylene	ND	0.50	"								
1,2,3-Trichlorobenzene	0.25	0.50	"								
1,2,3-Trichloropropane	ND	0.50	"								
1,2,4-Trichlorobenzene	ND	0.50	"								
1,2,4-Trimethylbenzene	ND	0.50	"								
1,2-Dibromo-3-chloropropane	ND	0.50	"								
1,2-Dibromoethane	ND	0.50	"								
1,2-Dichlorobenzene	ND	0.50	"								
1,2-Dichloroethane	ND	0.50	"								
1,2-Dichloropropane	ND	0.50	"								
1,3,5-Trimethylbenzene	ND	0.50	"								
1,3-Dichlorobenzene	ND	0.50	"								
1,3-Dichloropropane	ND	0.50	"								
1,4-Dichlorobenzene	ND	0.50	"								
2,2-Dichloropropane	ND	0.50	"								
2-Chlorotoluene	ND	0.50	"								
2-Hexanone	ND	0.50	"								
4-Chlorotoluene	ND	0.50	"								
Acetone	ND	2.0	"								
Benzene	ND	0.50	"								
Bromobenzene	ND	0.50	"								
Bromochloromethane	ND	0.50	"								
Bromodichloromethane	ND	0.50	"								
Bromoform	ND	0.50	"								
Bromomethane	ND	0.50	"								
Carbon tetrachloride	ND	0.50	"								
Chlorobenzene	ND	0.50	"								
Chloroethane	ND	0.50	"								
Chloroform	ND	0.50	"								
Chloromethane	ND	0.50	"								
cis-1,2-Dichloroethylene	ND	0.50	"								
cis-1,3-Dichloropropylene	ND	0.50	"								
Dibromochloromethane	ND	0.50	"								
Dibromomethane	ND	0.50	"								
Dichlorodifluoromethane	ND	0.50	"								
Ethyl Benzene	ND	0.50	"								
Hexachlorobutadiene	ND	0.50	"								
Isopropylbenzene	ND	0.50	"								
Methyl tert-butyl ether (MTBE)	ND	0.50	"								
Methylene chloride	ND	2.0	"								
Naphthalene	ND	2.0	"								
n-Butylbenzene	ND	0.50	"								
n-Propylbenzene	ND	0.50	"								



Volatile Organic Compounds by GC/MS - Quality Control Data

York Analytical Laboratories, Inc.

Analyte	Result	Reporting Limit	Units	Spike Level	Source* Result	%REC	%REC Limits	Flag	RPD	RPD Limit	Flag
---------	--------	-----------------	-------	-------------	----------------	------	-------------	------	-----	-----------	------

Batch BH70512 - EPA 5030B

Blank (BH70512-BLK1)

Prepared & Analyzed: 08/10/2017

o-Xylene	ND	0.50	ug/L								
p- & m- Xylenes	ND	1.0	"								
p-Isopropyltoluene	ND	0.50	"								
sec-Butylbenzene	ND	0.50	"								
Styrene	ND	0.50	"								
tert-Butylbenzene	ND	0.50	"								
Tetrachloroethylene	ND	0.50	"								
Toluene	ND	0.50	"								
trans-1,2-Dichloroethylene	ND	0.50	"								
trans-1,3-Dichloropropylene	ND	0.50	"								
Trichloroethylene	ND	0.50	"								
Trichlorofluoromethane	ND	0.50	"								
Vinyl Chloride	ND	0.50	"								
Xylenes, Total	ND	1.5	"								
Surrogate: 1,2-Dichloroethane-d4	9.95		"	10.0		99.5	69-130				
Surrogate: Toluene-d8	9.78		"	10.0		97.8	81-117				
Surrogate: p-Bromofluorobenzene	11.6		"	10.0		116	79-122				

LCS (BH70512-BS1)

Prepared & Analyzed: 08/10/2017

1,1,1,2-Tetrachloroethane	10.5		ug/L	10.0		105	82-126				
1,1,1-Trichloroethane	10.4		"	10.0		104	78-136				
1,1,2,2-Tetrachloroethane	11.1		"	10.0		111	76-129				
1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	9.86		"	10.0		98.6	54-165				
1,1,2-Trichloroethane	10.3		"	10.0		103	82-123				
1,1-Dichloroethane	10.2		"	10.0		102	82-129				
1,1-Dichloroethylene	19.2		"	10.0		192	68-138	High Bias			
1,1-Dichloropropylene	10.0		"	10.0		100	83-133				
1,2,3-Trichlorobenzene	3.76		"	10.0		37.6	76-136	Low Bias			
1,2,3-Trichloropropane	11.1		"	10.0		111	77-128				
1,2,4-Trichlorobenzene	4.93		"	10.0		49.3	76-137	Low Bias			
1,2,4-Trimethylbenzene	11.4		"	10.0		114	82-132				
1,2-Dibromo-3-chloropropane	9.06		"	10.0		90.6	45-147				
1,2-Dibromoethane	10.3		"	10.0		103	83-124				
1,2-Dichlorobenzene	10.4		"	10.0		104	79-123				
1,2-Dichloroethane	10.4		"	10.0		104	73-132				
1,2-Dichloropropane	10.0		"	10.0		100	78-126				
1,3,5-Trimethylbenzene	11.6		"	10.0		116	80-131				
1,3-Dichlorobenzene	11.1		"	10.0		111	86-122				
1,3-Dichloropropane	10.3		"	10.0		103	81-125				
1,4-Dichlorobenzene	11.0		"	10.0		110	85-124				
2,2-Dichloropropane	11.1		"	10.0		111	56-150				
2-Chlorotoluene	11.6		"	10.0		116	79-130				
2-Hexanone	10.9		"	10.0		109	51-146				
4-Chlorotoluene	11.8		"	10.0		118	79-128				
Acetone	8.72		"	10.0		87.2	14-150				
Benzene	10.5		"	10.0		105	85-126				
Bromobenzene	11.2		"	10.0		112	78-129				
Bromochloromethane	10.5		"	10.0		105	77-128				
Bromodichloromethane	10.1		"	10.0		101	79-128				
Bromoform	9.63		"	10.0		96.3	78-133				
Bromomethane	6.45		"	10.0		64.5	43-168				



**Volatile Organic Compounds by GC/MS - Quality Control Data**  
**York Analytical Laboratories, Inc.**

Analyte	Result	Reporting	Spike	Source*	%REC	%REC	Limits	Flag	RPD	RPD	Flag
		Limit								Units	

**Batch BH70512 - EPA 5030B**

**LCS (BH70512-BS1)**

Prepared & Analyzed: 08/10/2017

Carbon tetrachloride	10.2		ug/L	10.0		102	77-141				
Chlorobenzene	10.4		"	10.0		104	88-120				
Chloroethane	9.76		"	10.0		97.6	65-136				
Chloroform	10.4		"	10.0		104	82-128				
Chloromethane	7.90		"	10.0		79.0	43-155				
cis-1,2-Dichloroethylene	10.7		"	10.0		107	83-129				
cis-1,3-Dichloropropylene	10.3		"	10.0		103	80-131				
Dibromochloromethane	10.5		"	10.0		105	80-130				
Dibromomethane	9.96		"	10.0		99.6	72-134				
Dichlorodifluoromethane	6.72		"	10.0		67.2	44-144				
Ethyl Benzene	10.6		"	10.0		106	80-131				
Hexachlorobutadiene	3.61		"	10.0		36.1	67-146	Low Bias			
Isopropylbenzene	12.2		"	10.0		122	76-140				
Methyl tert-butyl ether (MTBE)	10.9		"	10.0		109	76-135				
Methylene chloride	8.06		"	10.0		80.6	55-137				
Naphthalene	5.20		"	10.0		52.0	70-147	Low Bias			
n-Butylbenzene	10.8		"	10.0		108	79-132				
n-Propylbenzene	12.1		"	10.0		121	78-133				
o-Xylene	10.7		"	10.0		107	78-130				
p- & m- Xylenes	21.5		"	20.0		108	77-133				
p-Isopropyltoluene	11.3		"	10.0		113	81-136				
sec-Butylbenzene	12.0		"	10.0		120	79-137				
Styrene	9.59		"	10.0		95.9	67-132				
tert-Butylbenzene	11.9		"	10.0		119	77-138				
Tetrachloroethylene	10.0		"	10.0		100	82-131				
Toluene	10.3		"	10.0		103	80-127				
trans-1,2-Dichloroethylene	10.2		"	10.0		102	80-132				
trans-1,3-Dichloropropylene	10.4		"	10.0		104	78-131				
Trichloroethylene	9.98		"	10.0		99.8	82-128				
Trichlorofluoromethane	9.56		"	10.0		95.6	67-139				
Vinyl Chloride	8.75		"	10.0		87.5	58-145				
<i>Surrogate: 1,2-Dichloroethane-d4</i>	<i>9.77</i>		<i>"</i>	<i>10.0</i>		<i>97.7</i>	<i>69-130</i>				
<i>Surrogate: Toluene-d8</i>	<i>9.76</i>		<i>"</i>	<i>10.0</i>		<i>97.6</i>	<i>81-117</i>				
<i>Surrogate: p-Bromofluorobenzene</i>	<i>11.0</i>		<i>"</i>	<i>10.0</i>		<i>110</i>	<i>79-122</i>				



Volatile Organic Compounds by GC/MS - Quality Control Data

York Analytical Laboratories, Inc.

Analyte	Result	Reporting Limit	Units	Spike Level	Source* Result	%REC	%REC Limits	Flag	RPD	RPD Limit	Flag
<b>Batch BH70512 - EPA 5030B</b>											
<b>LCS Dup (BH70512-BSD1)</b>											
Prepared & Analyzed: 08/10/2017											
1,1,1,2-Tetrachloroethane	10.6		ug/L	10.0		106	82-126		1.24	30	
1,1,1-Trichloroethane	10.5		"	10.0		105	78-136		0.671	30	
1,1,2,2-Tetrachloroethane	11.6		"	10.0		116	76-129		4.06	30	
1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	9.94		"	10.0		99.4	54-165		0.808	30	
1,1,2-Trichloroethane	10.3		"	10.0		103	82-123		0.485	30	
1,1-Dichloroethane	10.2		"	10.0		102	82-129		0.785	30	
1,1-Dichloroethylene	19.4		"	10.0		194	68-138	High Bias	1.35	30	
1,1-Dichloropropylene	10.1		"	10.0		101	83-133		1.19	30	
1,2,3-Trichlorobenzene	3.89		"	10.0		38.9	76-136	Low Bias	3.40	30	
1,2,3-Trichloropropane	11.4		"	10.0		114	77-128		2.58	30	
1,2,4-Trichlorobenzene	5.06		"	10.0		50.6	76-137	Low Bias	2.60	30	
1,2,4-Trimethylbenzene	11.9		"	10.0		119	82-132		4.31	30	
1,2-Dibromo-3-chloropropane	9.40		"	10.0		94.0	45-147		3.68	30	
1,2-Dibromoethane	10.4		"	10.0		104	83-124		1.06	30	
1,2-Dichlorobenzene	10.7		"	10.0		107	79-123		3.23	30	
1,2-Dichloroethane	10.4		"	10.0		104	73-132		0.481	30	
1,2-Dichloropropane	10.2		"	10.0		102	78-126		1.38	30	
1,3,5-Trimethylbenzene	12.2		"	10.0		122	80-131		4.37	30	
1,3-Dichlorobenzene	11.5		"	10.0		115	86-122		3.27	30	
1,3-Dichloropropane	10.3		"	10.0		103	81-125		0.291	30	
1,4-Dichlorobenzene	11.3		"	10.0		113	85-124		2.69	30	
2,2-Dichloropropane	10.9		"	10.0		109	56-150		1.18	30	
2-Chlorotoluene	12.1		"	10.0		121	79-130		3.88	30	
2-Hexanone	10.8		"	10.0		108	51-146		0.924	30	
4-Chlorotoluene	12.2		"	10.0		122	79-128		3.16	30	
Acetone	9.12		"	10.0		91.2	14-150		4.48	30	
Benzene	10.4		"	10.0		104	85-126		0.862	30	
Bromobenzene	11.4		"	10.0		114	78-129		2.30	30	
Bromochloromethane	10.4		"	10.0		104	77-128		1.72	30	
Bromodichloromethane	10.3		"	10.0		103	79-128		1.77	30	
Bromoform	9.81		"	10.0		98.1	78-133		1.85	30	
Bromomethane	6.46		"	10.0		64.6	43-168		0.155	30	
Carbon tetrachloride	10.3		"	10.0		103	77-141		0.293	30	
Chlorobenzene	10.6		"	10.0		106	88-120		0.952	30	
Chloroethane	9.63		"	10.0		96.3	65-136		1.34	30	
Chloroform	10.4		"	10.0		104	82-128		0.673	30	
Chloromethane	7.94		"	10.0		79.4	43-155		0.505	30	
cis-1,2-Dichloroethylene	10.6		"	10.0		106	83-129		0.656	30	
cis-1,3-Dichloropropylene	10.4		"	10.0		104	80-131		0.966	30	
Dibromochloromethane	10.6		"	10.0		106	80-130		0.0948	30	
Dibromomethane	9.98		"	10.0		99.8	72-134		0.201	30	
Dichlorodifluoromethane	6.72		"	10.0		67.2	44-144		0.00	30	
Ethyl Benzene	10.7		"	10.0		107	80-131		1.60	30	
Hexachlorobutadiene	3.70		"	10.0		37.0	67-146	Low Bias	2.46	30	
Isopropylbenzene	12.6		"	10.0		126	76-140		3.31	30	
Methyl tert-butyl ether (MTBE)	10.7		"	10.0		107	76-135		1.76	30	
Methylene chloride	8.05		"	10.0		80.5	55-137		0.124	30	
Naphthalene	5.18		"	10.0		51.8	70-147	Low Bias	0.385	30	
n-Butylbenzene	11.1		"	10.0		111	79-132		3.56	30	
n-Propylbenzene	12.6		"	10.0		126	78-133		4.37	30	
o-Xylene	10.8		"	10.0		108	78-130		1.30	30	



**Volatile Organic Compounds by GC/MS - Quality Control Data**  
**York Analytical Laboratories, Inc.**

Analyte	Result	Reporting	Units	Spike	Source*	%REC	%REC	Limits	Flag	RPD	
		Limit								RPD	Limit

**Batch BH70512 - EPA 5030B**

**LCS Dup (BH70512-BSD1)**

Prepared & Analyzed: 08/10/2017

p- & m- Xylenes	22.0		ug/L	20.0		110	77-133			2.02	30
p-Isopropyltoluene	11.8		"	10.0		118	81-136			3.99	30
sec-Butylbenzene	12.5		"	10.0		125	79-137			4.24	30
Styrene	9.68		"	10.0		96.8	67-132			0.934	30
tert-Butylbenzene	12.5		"	10.0		125	77-138			4.85	30
Tetrachloroethylene	10.3		"	10.0		103	82-131			2.46	30
Toluene	10.5		"	10.0		105	80-127			1.83	30
trans-1,2-Dichloroethylene	10.2		"	10.0		102	80-132			0.195	30
trans-1,3-Dichloropropylene	10.5		"	10.0		105	78-131			1.15	30
Trichloroethylene	10.2		"	10.0		102	82-128			2.28	30
Trichlorofluoromethane	9.54		"	10.0		95.4	67-139			0.209	30
Vinyl Chloride	8.81		"	10.0		88.1	58-145			0.683	30
<i>Surrogate: 1,2-Dichloroethane-d4</i>	<i>9.65</i>		<i>"</i>	<i>10.0</i>		<i>96.5</i>	<i>69-130</i>				
<i>Surrogate: Toluene-d8</i>	<i>9.86</i>		<i>"</i>	<i>10.0</i>		<i>98.6</i>	<i>81-117</i>				
<i>Surrogate: p-Bromofluorobenzene</i>	<i>11.3</i>		<i>"</i>	<i>10.0</i>		<i>113</i>	<i>79-122</i>				



### Volatile Analysis Sample Containers

Lab ID	Client Sample ID	Volatile Sample Container
17H0156-01	WQ080117: 1320 FRW-1	40mL Clear Vial (pre-pres.) HCl; Cool to 4° C
17H0156-02	WQ080117: 1325 FRW-2	40mL Clear Vial (pre-pres.) HCl; Cool to 4° C
17H0156-03	WQ080117: 1330 FRW-3	40mL Clear Vial (pre-pres.) HCl; Cool to 4° C
17H0156-04	WQ080117: 1335 FRW-4	40mL Clear Vial (pre-pres.) HCl; Cool to 4° C



## Sample and Data Qualifiers Relating to This Work Order

- SCAL-E The value reported is ESTIMATED. The value is estimated due to its behavior during initial calibration (average Rf>20%).
- QL-02 This LCS analyte is outside Laboratory Recovery limits due the analyte behavior using the referenced method. The reference method has certain limitations with respect to analytes of this nature.
- J Detected below the Reporting Limit but greater than or equal to the Method Detection Limit (MDL/LOD) or in the case of a TIC, the result is an estimated concentration.

### Definitions and Other Explanations

- \* Analyte is not certified or the state of the samples origination does not offer certification for the Analyte.
- ND NOT DETECTED - the analyte is not detected at the Reported to level (LOQ/RL or LOD/MDL)
- RL REPORTING LIMIT - the minimum reportable value based upon the lowest point in the analyte calibration curve.
- LOQ LIMIT OF QUANTITATION - the minimum concentration of a target analyte that can be reported within a specified degree of confidence. This is the lowest point in an analyte calibration curve that has been subjected to all steps of the processing/analysis and verified to meet defined criteria. This is based upon NELAC 2009 Standards and applies to all analyses.
- LOD LIMIT OF DETECTION - a verified estimate of the minimum concentration of a substance in a given matrix that an analytical process can reliably detect. This is based upon NELAC 2009 Standards and applies to all analyses conducted under the auspices of EPA SW -846.
- MDL METHOD DETECTION LIMIT - a statistically derived estimate of the minimum amount of a substance an analytical system can reliably detect with a 99% confidence that the concentration of the substance is greater than zero. This is based upon 40 CFR Part 136 Appendix B and applies only to EPA 600 and 200 series methods.
- Reported to This indicates that the data for a particular analysis is reported to either the LOD/MDL, or the LOQ/RL. In cases where the "Reported to" is located above the LOD/MDL, any value between this and the LOQ represents an estimated value which is "J" flagged accordingly. This applies to volatile and semi-volatile target compounds only.
- NR Not reported
- RPD Relative Percent Difference
- Wet The data has been reported on an as-received (wet weight) basis
- Low Bias Low Bias flag indicates that the recovery of the flagged analyte is below the laboratory or regulatory lower control limit. The data user should take note that this analyte may be biased low but should evaluate multiple lines of evidence including the LCS and site-specific MS/MSD data to draw bias conclusions. In cases where no site-specific MS/MSD was requested, only the LCS data can be used to evaluate such bias.
- High Bias High Bias flag indicates that the recovery of the flagged analyte is above the laboratory or regulatory upper control limit. The data user should take note that this analyte may be biased high but should evaluate multiple lines of evidence including the LCS and site-specific MS/MSD data to draw bias conclusions. In cases where no site-specific MS/MSD was requested, only the LCS data can be used to evaluate such bias.
- Non-Dir. Non-dir. flag (Non-Directional Bias ) indicates that the Relative Percent Difference (RPD) (a measure of precision) among the MS and MSD data is outside the laboratory or regulatory control limit. This alerts the data user where the MS and MSD are from site-specific samples that the RPD is high due to either non-homogeneous distribution of target analyte between the MS/MSD or indicates poor reproducibility for other reasons.

If EPA SW-846 method 8270 is included herein it is noted that the target compound N-nitrosodiphenylamine (NDPA) decomposes in the gas chromatographic inlet and cannot be separated from diphenylamine (DPA). These results could actually represent 100% DPA, 100% NDPA or some combination of the two. For this reason, York reports the combined result for n-nitrosodiphenylamine and diphenylamine for either of these compounds as a combined concentration as Diphenylamine.

If Total PCBs are detected and the target aroclors reported are "Not detected", the Total PCB value is reported due to the presence of either or both Aroclors 1262 and 1268 which are non-target aroclors for some regulatory lists.

2-chloroethylvinyl ether readily breaks down under acidic conditions. Samples that are acid preserved, including standards will exhibit breakdown. The data user should take note.

Certification for pH is no longer offered by NYDOH ELAP.

Semi-Volatile and Volatile analyses are reported down to the LOD/MDL, with values between the LOD/MDL and the LOQ being "J" flagged as estimated results.



For analyses by EPA SW-846-8270D, the Limit of Quantitation (LOQ) reported for benzidine is based upon the lowest standard used for calibration and is not a verified LOQ due to this compound's propensity for oxidative losses during extraction/concentration procedures and non-reproducible chromatographic performance.

---

# YORK

ANALYTICAL LABORATORIES, INC.  
120 RESEARCH DR. STRATFORD, CT 06615  
(203) 325-1371 FAX (203) 357-0166

# Field Chain-of-Custody Record

NOTE: York's Std. Terms & Conditions are listed on the back side of this document. This document serves as your written authorization to York to proceed with the analyses requested and your signature binds you to York's Std. Terms & Conditions.

Page 1 of 1  
York Project No. 17H0156

YOUR INFORMATION		Report To:		Invoice To:		YOUR PROJECT ID		Turn-Around Time		Report Type			
Company: <u>LBE</u>	Company: <u>Same</u>	Company: <u>Same</u>	Company: <u>Rowe Industries.</u>	8260 full	Volatiles	Semi-Vols. <input checked="" type="checkbox"/>	Metals	RUSH - Same Day <input type="checkbox"/>	Full Lists	Simple Excel <input checked="" type="checkbox"/>	Summary Report <input checked="" type="checkbox"/>		
Address: <u>4 Research Dr, Suite 301</u>	Address: <u>Same</u>	Address: <u>Same</u>	Address: <u>Rowe Industries.</u>	624	Site Spec.	8082 PCB	TPH GRO	RUSH - Next Day <input type="checkbox"/>	PH Foil	NYSDEC EQUIS <input type="checkbox"/>	Summary w/ QA Summary <input checked="" type="checkbox"/>		
Phone No. <u>86484</u>	Phone No. <u>Same</u>	Phone No. <u>Same</u>	Phone No. <u>NAASA6</u>	STARS list	Nassau Co.	BN Only	TPH DRO	RUSH - Two Day <input type="checkbox"/>	ICL Oganics	EQUIS (std)	CT RCP Package <input type="checkbox"/>		
Attention: <u>Tunde Sandor</u>	Attention: <u>Same</u>	Attention: <u>Same</u>	Attention: <u>NAASA6</u>	BTEX	Suffolk Co.	PAH list	CT ETPH	RUSH - Three Day <input type="checkbox"/>	TAL M&EN	EZ-EDD (EQUIS)	CTRCP DQA/DUE Pkg <input type="checkbox"/>		
E-Mail Address: <u>Tsandor@lbe.com</u>	E-Mail Address: <u>Same</u>	E-Mail Address: <u>Same</u>	E-Mail Address: <u>NAASA6</u>	MTBE	Ketones	TAGM list	NY 310-15	RUSH - Four Day <input type="checkbox"/>	Full TCLP	NI DEP SRP HazSite EDD	NY ASP A Package <input type="checkbox"/>		
<p><b>Print Clearly and Legibly. All information must be complete. Samples will NOT be logged in and the turn-around time clock will not begin until any questions by York are resolved.</b></p> <p><u>[Signature]</u> Samples Collected/Authorized By (Signature)</p> <p><u>Even Foster</u> Name (printed)</p>		<p>Matrix Codes</p> <p>S - soil Other - specify (oil, etc.) WW - wastewater GW - groundwater DW - drinking water Air-A - ambient air Air-SV - soil vapor</p>		<p>8270 or 625</p> <p>STARS list</p> <p>Acids Only</p> <p>App. IX</p> <p>TAGM list</p> <p>Site Spec.</p> <p>CT RCP list</p> <p>TCLP list</p> <p>Acrom. only</p> <p>502.2</p> <p>Halog. only</p> <p>NIDEF list</p> <p>App. IX list</p> <p>SPLP or TCLP</p> <p>802.1B list</p>		<p>8082 PCB</p> <p>815 Herb</p> <p>CT RCP</p> <p>App. IX</p> <p>Site Spec.</p> <p>SPLP or TCLP</p> <p>TCLP Herb</p> <p>Chlordane</p> <p>608 Pest</p> <p>SPLP or TCLP</p> <p>608 PCB</p>		<p>Misc. Org.</p> <p>TPH GRO</p> <p>TPH DRO</p> <p>CT ETPH</p> <p>NY 310-15</p> <p>TPH 1664</p> <p>Air TO14A</p> <p>Air TO15</p> <p>Air STARS</p> <p>Air VPH</p> <p>Air TK's</p> <p>Methane</p> <p>Helium</p>		<p>Misc</p> <p>Conservatory</p> <p>Reactivity</p> <p>Ignitability</p> <p>Flash Point</p> <p>Stev. Anal.</p> <p>Heteroatoms</p> <p>Part 360-Residue</p> <p>TOX</p> <p>BTU/lb.</p> <p>Part 360-Residue</p> <p>Part 360-Residue</p> <p>Part 360-Residue</p> <p>NYCDEP-Sox</p> <p>NYCDEP-Sox</p> <p>NYCDEP-Sox</p> <p>ASTOSIS</p> <p>Silica</p>		<p>Other</p> <p>York Regulatory Comparison</p> <p>Excel Spreadsheet</p> <p>Compare to the following (Reg. # please fill in)</p>	
<p>Container</p> <p>Description(s)</p> <p><u>300a</u></p>		<p>Choose Analyses Needed from the Menu Above and Enter Below</p> <p><u>VOC 8260 full list (EPA SW846-81606) plus from 113</u></p>											
<p>Sample Identification</p> <p>Date Sampled</p> <p>Sample Matrix</p>		<p>Preservation</p> <p>Check those Applicable</p> <p>Special Instructions</p> <p>Field Filtered <input type="checkbox"/></p> <p>Lab to Filter <input type="checkbox"/></p>											
<p>1320 FRW-1</p> <p>1325 FRW-2</p> <p>1330 FRW-3</p> <p>1335 FRW-4</p>		<p>8-1-17</p>		<p>GW</p>		<p>4°C <input checked="" type="checkbox"/></p> <p>Frozen <input checked="" type="checkbox"/></p> <p>HCl <input type="checkbox"/></p> <p>Zn Ac <input type="checkbox"/></p> <p>McOH <input checked="" type="checkbox"/></p> <p>Ascorbic Acid <input type="checkbox"/></p> <p>HNO<sub>3</sub> <input type="checkbox"/></p> <p>H<sub>2</sub>SO<sub>4</sub> <input type="checkbox"/></p> <p>NaOH <input type="checkbox"/></p> <p>Other <input type="checkbox"/></p>		<p>8/2/17 8:00</p> <p>8-3-17 12:35</p>		<p>8/2/17 8:00</p> <p>8-3-17 12:35</p>		<p>2.1 °C</p>	
<p>Comments</p>		<p><u>Rec'd at 8/3/17 12:35</u></p>											

(AW & FRW)