

TABLE 2

**GROUNDWATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

Effluent Water Quality Results

Date Sampled ^{2/}	pH ^{1/}	TDS (mg/l)	PCE (ug/l)	1,1,1-TCA (ug/l)	TCE (ug/l)	1,1-DCA (ug/l)	1,1-DCE (ug/l)	cis-1,2-DCE (ug/l)	trans-1,2-DCE (ug/l)	Xylene (ug/l)	Toluene (ug/l)	Ethylbenzene (ug/l)	Methylene Chloride (ug/l)	Freon 113 (ug/l)	Naphthalene (ug/l)	Chloroform (ug/l)	Total Iron (mg/l)	Dissolved Iron (mg/l)
SPDES Limits	6.5 to 8.5	---	5	5	5	5	5	5	5	5	5	5	5	---	10	7	---	---
1-Sep-16	6.5	157	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<1.5	ND<0.5	ND<0.5	ND<2	ND<0.5	ND<0.5	ND<0.5	1.65	0.044
16-Sep-16	6.5	146	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<1.5	ND<0.5	ND<0.5	ND<2	ND<0.5	ND<0.5	ND<0.5	0.92	0.336
17-Oct-16 ^{3/}	6.5	141	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<1.5	ND<0.5	ND<0.5	ND<2	ND<0.5	ND<0.5	ND<0.5	1.27	0.455
1-Nov-16	6.5	224	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<1.5	ND<0.5	ND<0.5	ND<2	ND<0.5	ND<0.5	ND<0.5	3.50	0.100
1-Dec-16	6.5	191	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<1.5	ND<0.5	ND<0.5	ND<2	ND<0.5	ND<0.5	ND<0.5	2.17	0.042
3-Jan-17	6.5	123	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<1.5	ND<0.5	ND<0.5	ND<2	ND<0.5	ND<0.5	ND<0.5	2.24	0.030
1-Feb-17	6.5	120	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<1.5	ND<0.5	ND<0.5	ND<2	ND<0.5	ND<0.5	ND<0.5	2.17	0.051
1-Mar-17	6.5	149	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<1.5	ND<0.5	ND<0.5	ND<2	ND<0.5	ND<0.5	ND<0.5	0.69	0.063
7-Apr-17	6.5	157	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<1.5	ND<0.5	ND<0.5	ND<2	ND<0.5	ND<0.5	ND<0.5	3.62	0.060
3-May-17	6.5	121	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<1.5	ND<0.5	ND<0.5	ND<2	ND<0.5	ND<0.5	ND<0.5	0.90	0.079
1-Jun-17	6.5	127	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<1.5	ND<0.5	ND<0.5	ND<2	ND<0.5	ND<0.5	ND<0.5	0.10	0.097
6-Jul-17	6.5	159	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<1.5	ND<0.5	ND<0.5	ND<2	ND<0.5	ND<0.5	ND<0.5	0.46	ND<0.02
1-Aug-17	6.8	143	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<1.5	ND<0.5	ND<0.5	ND<2	ND<0.5	ND<0.5	ND<0.5	3.00	0.193
5-Sep-17	6.8	298	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<0.5	ND<1.5	ND<0.5	ND<0.5	ND<2	ND<0.5	ND<0.5	ND<0.5	2.12	0.051

SPDES: State Pollutant Discharge Elimination System

mg/l: Milligrams per liter

ug/l: Micrograms per liter

----: Not established

J: Analyte detected below quantitation limits, value shown is a laboratory estimate.

B: Analyte was found in the associated analysis batch blank. For volatiles, methylene chloride and acetone are common lab contaminants

ND: Not detected

NM: Not Measured

TDS: Total dissolved solids

PCE: Tetrachloroethylene

1,1,1-TCA: 1,1,1-Trichloroethane

TCE: Trichloroethene

1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene

cis-1,2-DCE: cis-1,2-Dichloroethene


trans-1,2,-DCE: trans-1,2-Dichloroethene

Notes:

- Based on the SPDES criteria from an NYSDEC letter dated on May 6, 2016, the allowable pH range for the Rowe Site is between 6.5 and 8.5. The pH on September 19, 2017, was 6.8.
- "Effluent" samples were collected from sample port labeled NP2-10 unless otherwise noted.
- Starting in October 2016, FSP&T system samples are collected monthly instead of once every two weeks. The pH of the effluent water is measured two times per month.

GRAPH 1
GROUNDWATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

Effluent Flow Data
(September 1, 2017 to September 30, 2017)



APPENDIX I
SEPTEMBER 2017 LABORATORY ANALYTICAL REPORTS
FOR FSP&T SYSTEM



Technical Report

prepared for:

Leggette Brashears & Graham Shelton Office

4 Research Drive, Suite 204

Shelton CT, 06484

Attention: Tunde Komuves-Sandor

Report Date: 09/13/2017

Client Project ID: Rowe Industries

York Project (SDG) No.: 17I0189

CT Cert. No. PH-0723

New Jersey Cert. No. CT005 and NY037



New York Cert. Nos. 10854 and 12058

PA Cert. No. 68-04440

120 RESEARCH DRIVE
www.YORKLAB.com

STRATFORD, CT 06615
(203) 325-1371



132-02 89th AVENUE
FAX (203) 357-0166

RICHMOND HILL, NY 11418
ClientServices@yorklab.com

Report Date: 09/13/2017
Client Project ID: Rowe Industries
York Project (SDG) No.: 17I0189

Leggette Brashears & Graham Shelton Office
4 Research Drive, Suite 204
Shelton CT, 06484
Attention: Tunde Komuves-Sandor

Purpose and Results

This report contains the analytical data for the sample(s) identified on the attached chain-of-custody received in our laboratory on September 07, 2017 and listed below. The project was identified as your project: **Rowe Industries**.

The analyses were conducted utilizing appropriate EPA, Standard Methods, and ASTM methods as detailed in the data summary tables.

All samples were received in proper condition meeting the customary acceptance requirements for environmental samples except those indicated under the Sample and Analysis Qualifiers section of this report.

All analyses met the method and laboratory standard operating procedure requirements except as indicated by any data flags, the meaning of which are explained in the Sample and Data Qualifiers Relating to This Work Order section of this report and case narrative if applicable.

The results of the analyses, which are all reported on dry weight basis (soils) unless otherwise noted, are detailed in the following pages.

Please contact Client Services at 203.325.1371 with any questions regarding this report.

<u>York Sample ID</u>	<u>Client Sample ID</u>	<u>Matrix</u>	<u>Date Collected</u>	<u>Date Received</u>
17I0189-01	WQ090517:1100 NP2-6	Water	09/05/2017	09/07/2017
17I0191-01	WQ090517:1105 NP2-10	Water	09/05/2017	09/07/2017

General Notes for York Project (SDG) No.: 17I0189

1. The RLs and MDLs (Reporting Limit and Method Detection Limit respectively) reported are adjusted for any dilution necessary due to the levels of target and/or non-target analytes and matrix interference. The RL(REPORTING LIMIT) is based upon the lowest standard utilized for the calibration where applicable.
2. Samples are retained for a period of thirty days after submittal of report, unless other arrangements are made.
3. York's liability for the above data is limited to the dollar value paid to York for the referenced project.
4. This report shall not be reproduced without the written approval of York Analytical Laboratories, Inc.
5. All analyses conducted met method or Laboratory SOP requirements. See the Sample and Data Qualifiers Section for further information.
6. It is noted that no analyses reported herein were subcontracted to another laboratory, unless noted in the report.
7. This report reflects results that relate only to the samples submitted on the attached chain-of-custody form(s) received by York.
8. Analyses conducted at York Analytical Laboratories, Inc. Stratford, CT are indicated by NY Cert. No. 10854; those conducted at York Analytical Laboratories, Inc., Richmond Hill, NY are indicated by NY Cert. No. 12058.

Approved By:



Benjamin Gulizia
Laboratory Director

Date: 09/13/2017





Sample Information

Client Sample ID: WQ090517:1100 NP2-6

York Sample ID: 17I0189-01

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
17I0189	Rowe Industries	Water	September 5, 2017 11:00 am	09/07/2017

Volatile Organics, 8260 List - Low Level

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
630-20-6	1,1,1,2-Tetrachloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
71-55-6	1,1,1-Trichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
79-34-5	1,1,2,2-Tetrachloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
76-13-1	1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
79-00-5	1,1,2-Trichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
75-34-3	1,1-Dichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
75-35-4	1,1-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
563-58-6	1,1-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 18:23	SR
87-61-6	1,2,3-Trichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 18:23	SR
96-18-4	1,2,3-Trichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 18:23	SR
120-82-1	1,2,4-Trichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 18:23	SR
95-63-6	1,2,4-Trimethylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
96-12-8	1,2-Dibromo-3-chloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
106-93-4	1,2-Dibromoethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
95-50-1	1,2-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
107-06-2	1,2-Dichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
78-87-5	1,2-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
108-67-8	1,3,5-Trimethylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
541-73-1	1,3-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
142-28-9	1,3-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 18:23	SR
106-46-7	1,4-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
594-20-7	2,2-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 18:23	SR



Sample Information

Client Sample ID: WQ090517:1100 NP2-6

York Sample ID: 17I0189-01

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17I0189

Rowe Industries

Water

September 5, 2017 11:00 am

09/07/2017

Volatile Organics, 8260 List - Low Level

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
95-49-8	2-Chlorotoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
591-78-6	2-Hexanone	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
106-43-4	4-Chlorotoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
67-64-1	Acetone	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
71-43-2	Benzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
108-86-1	Bromobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 18:23	SR
74-97-5	Bromochloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 18:23	SR
75-27-4	Bromodichloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
75-25-2	Bromoform	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
74-83-9	Bromomethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
56-23-5	Carbon tetrachloride	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
108-90-7	Chlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
75-00-3	Chloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
67-66-3	Chloroform	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
74-87-3	Chloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
156-59-2	cis-1,2-Dichloroethylene	0.22	J	ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
10061-01-5	cis-1,3-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
124-48-1	Dibromochloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
74-95-3	Dibromomethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 18:23	SR
75-71-8	Dichlorodifluoromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 18:23	SR
100-41-4	Ethyl Benzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
87-68-3	Hexachlorobutadiene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 18:23	SR
98-82-8	Isopropylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR



Sample Information

Client Sample ID: WQ090517:1100 NP2-6

York Sample ID: 17I0189-01

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17I0189

Rowe Industries

Water

September 5, 2017 11:00 am

09/07/2017

Volatile Organics, 8260 List - Low Level

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
1634-04-4	Methyl tert-butyl ether (MTBE)	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
75-09-2	Methylene chloride	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
91-20-3	Naphthalene	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 18:23	SR
104-51-8	n-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
103-65-1	n-Propylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
95-47-6	o-Xylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 18:23	SR
179601-23-1	p- & m- Xylenes	ND		ug/L	0.50	1.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 18:23	SR
99-87-6	p-Isopropyltoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
135-98-8	sec-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
100-42-5	Styrene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
98-06-6	tert-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
127-18-4	Tetrachloroethylene	1.1		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
108-88-3	Toluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
156-60-5	trans-1,2-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
10061-02-6	trans-1,3-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
79-01-6	Trichloroethylene	0.30	J	ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
75-69-4	Trichlorofluoromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
75-01-4	Vinyl Chloride	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
1330-20-7	Xylenes, Total	ND		ug/L	0.60	1.5	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:23	SR
Surrogate Recoveries		Result	Acceptance Range								
17060-07-0	Surrogate: 1,2-Dichloroethane-d4	101 %	69-130								
2037-26-5	Surrogate: Toluene-d8	105 %	81-117								
460-00-4	Surrogate: p-Bromofluorobenzene	112 %	79-122								



Sample Information

Client Sample ID: WQ090517:1105 NP2-10

York Sample ID: 17I0191-01

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17I0191

Rowe Industries

Water

September 5, 2017 11:05 am

09/07/2017

Volatile Organics, 8260 List - Low Level

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
630-20-6	1,1,1,2-Tetrachloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
71-55-6	1,1,1-Trichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
79-34-5	1,1,2,2-Tetrachloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
76-13-1	1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
79-00-5	1,1,2-Trichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
75-34-3	1,1-Dichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
75-35-4	1,1-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
563-58-6	1,1-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 18:50	SR
87-61-6	1,2,3-Trichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 18:50	SR
96-18-4	1,2,3-Trichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 18:50	SR
120-82-1	1,2,4-Trichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 18:50	SR
95-63-6	1,2,4-Trimethylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
96-12-8	1,2-Dibromo-3-chloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
106-93-4	1,2-Dibromoethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
95-50-1	1,2-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
107-06-2	1,2-Dichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
78-87-5	1,2-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
108-67-8	1,3,5-Trimethylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
541-73-1	1,3-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
142-28-9	1,3-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 18:50	SR
106-46-7	1,4-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
594-20-7	2,2-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 18:50	SR
95-49-8	2-Chlorotoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR



Sample Information

Client Sample ID: WQ090517:1105 NP2-10

York Sample ID: 17I0191-01

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17I0191

Rowe Industries

Water

September 5, 2017 11:05 am

09/07/2017

Volatile Organics, 8260 List - Low Level

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
591-78-6	2-Hexanone	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
106-43-4	4-Chlorotoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
67-64-1	Acetone	2.3		ug/L	1.0	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
71-43-2	Benzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
108-86-1	Bromobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 18:50	SR
74-97-5	Bromochloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 18:50	SR
75-27-4	Bromodichloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
75-25-2	Bromoform	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
74-83-9	Bromomethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
56-23-5	Carbon tetrachloride	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
108-90-7	Chlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
75-00-3	Chloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
67-66-3	Chloroform	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
74-87-3	Chloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
156-59-2	cis-1,2-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
10061-01-5	cis-1,3-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
124-48-1	Dibromochloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
74-95-3	Dibromomethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 18:50	SR
75-71-8	Dichlorodifluoromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 18:50	SR
100-41-4	Ethyl Benzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
87-68-3	Hexachlorobutadiene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 18:50	SR
98-82-8	Isopropylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR
1634-04-4	Methyl tert-butyl ether (MTBE)	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 18:50	SR



Sample Information

Client Sample ID: WQ090517:1105 NP2-10

York Sample ID: 17I0191-01

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17I0191

Rowe Industries

Water

September 5, 2017 11:05 am

09/07/2017

Volatile Organics, 8260 List - Low Level

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
75-09-2	Methylene chloride	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY110854	09/12/2017 07:30	09/12/2017 18:50	SR
91-20-3	Naphthalene	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 18:50	SR
104-51-8	n-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY110854	09/12/2017 07:30	09/12/2017 18:50	SR
103-65-1	n-Propylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY110854	09/12/2017 07:30	09/12/2017 18:50	SR
95-47-6	o-Xylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 18:50	SR
179601-23-1	p- & m- Xylenes	ND		ug/L	0.50	1.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 18:50	SR
99-87-6	p-Isopropyltoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY110854	09/12/2017 07:30	09/12/2017 18:50	SR
135-98-8	sec-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY110854	09/12/2017 07:30	09/12/2017 18:50	SR
100-42-5	Styrene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY110854	09/12/2017 07:30	09/12/2017 18:50	SR
98-06-6	tert-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY110854	09/12/2017 07:30	09/12/2017 18:50	SR
127-18-4	Tetrachloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY110854	09/12/2017 07:30	09/12/2017 18:50	SR
108-88-3	Toluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY110854	09/12/2017 07:30	09/12/2017 18:50	SR
156-60-5	trans-1,2-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY110854	09/12/2017 07:30	09/12/2017 18:50	SR
10061-02-6	trans-1,3-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY110854	09/12/2017 07:30	09/12/2017 18:50	SR
79-01-6	Trichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY110854	09/12/2017 07:30	09/12/2017 18:50	SR
75-69-4	Trichlorofluoromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY110854	09/12/2017 07:30	09/12/2017 18:50	SR
75-01-4	Vinyl Chloride	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY110854	09/12/2017 07:30	09/12/2017 18:50	SR
1330-20-7	Xylenes, Total	ND		ug/L	0.60	1.5	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY110854	09/12/2017 07:30	09/12/2017 18:50	SR

Surrogate Recoveries

Result

Acceptance Range

17060-07-0	Surrogate: 1,2-Dichloroethane-d4	100 %	69-130
2037-26-5	Surrogate: Toluene-d8	105 %	81-117
460-00-4	Surrogate: p-Bromofluorobenzene	110 %	79-122

Iron by EPA 200.7

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.7

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
---------	-----------	--------	------	-------	-----------------	----------	------------------	--------------------	--------------------	---------



Sample Information

Client Sample ID: WQ090517:1105 NP2-10

York Sample ID: 17I0191-01

<u>York Project (SDG) No.</u> 17I0191	<u>Client Project ID</u> Rowe Industries	<u>Matrix</u> Water	<u>Collection Date/Time</u> September 5, 2017 11:05 am	<u>Date Received</u> 09/07/2017
--	---	------------------------	---	------------------------------------

Iron by EPA 200.7

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.7

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-89-6	Iron	2.12		mg/L	0.0222	1	EPA 200.7	09/08/2017 09:11	09/08/2017 23:21	KML
Certifications: CTDOH,NELAC-NY10854,NJDEP,PADEP										

Iron, Dissolved by EPA 6010

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 3015A

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-89-6	Iron	0.0506		mg/L	0.0222	1	EPA 6010C	09/08/2017 14:04	09/09/2017 00:40	KML
Certifications: CTDOH,NELAC-NY10854,NJDEP,PADEP										

Total Dissolved Solids

Log-in Notes:

Sample Notes:

Sample Prepared by Method: % Solids Prep

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
	Total Dissolved Solids	298		mg/L	10.0	1	SM 2540C	09/07/2017 23:25	09/08/2017 15:36	TJM
Certifications: NELAC-NY10854,CTDOH,NJDEP,PADEP										



Analytical Batch Summary

Batch ID: BI70279 **Preparation Method:** % Solids Prep **Prepared By:** AA

YORK Sample ID	Client Sample ID	Preparation Date
17I0191-01	WQ090517:1105 NP2-10	09/07/17
BI70279-BLK1	Blank	09/07/17

Batch ID: BI70303 **Preparation Method:** EPA 200.7 **Prepared By:** SY

YORK Sample ID	Client Sample ID	Preparation Date
17I0191-01	WQ090517:1105 NP2-10	09/08/17
BI70303-BLK1	Blank	09/08/17
BI70303-SRM1	Reference	09/08/17

Batch ID: BI70330 **Preparation Method:** EPA 3015A **Prepared By:** SY

YORK Sample ID	Client Sample ID	Preparation Date
17I0191-01	WQ090517:1105 NP2-10	09/08/17
BI70330-BLK1	Blank	09/08/17
BI70330-DUP1	Duplicate	09/08/17
BI70330-MS1	Matrix Spike	09/08/17
BI70330-SRM1	Reference	09/08/17

Batch ID: BI70424 **Preparation Method:** EPA 5030B **Prepared By:** RDS

YORK Sample ID	Client Sample ID	Preparation Date
17I0189-01	WQ090517:1100 NP2-6	09/12/17
17I0191-01	WQ090517:1105 NP2-10	09/12/17
BI70424-BLK1	Blank	09/12/17
BI70424-BS1	LCS	09/12/17
BI70424-BSD1	LCS Dup	09/12/17



Volatile Organic Compounds by GC/MS - Quality Control Data
York Analytical Laboratories, Inc.

Analyte	Result	Reporting Limit	Units	Spike Level	Source* Result	%REC	%REC Limits	Flag	RPD	RPD Limit	Flag
---------	--------	-----------------	-------	-------------	----------------	------	-------------	------	-----	-----------	------

Batch BI70424 - EPA 5030B

Blank (BI70424-BLK1)

Prepared & Analyzed: 09/12/2017

1,1,1,2-Tetrachloroethane	ND	0.50	ug/L								
1,1,1-Trichloroethane	ND	0.50	"								
1,1,2,2-Tetrachloroethane	ND	0.50	"								
1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	ND	0.50	"								
1,1,2-Trichloroethane	ND	0.50	"								
1,1-Dichloroethane	ND	0.50	"								
1,1-Dichloroethylene	ND	0.50	"								
1,1-Dichloropropylene	ND	0.50	"								
1,2,3-Trichlorobenzene	ND	0.50	"								
1,2,3-Trichloropropane	ND	0.50	"								
1,2,4-Trichlorobenzene	ND	0.50	"								
1,2,4-Trimethylbenzene	ND	0.50	"								
1,2-Dibromo-3-chloropropane	ND	0.50	"								
1,2-Dibromoethane	ND	0.50	"								
1,2-Dichlorobenzene	ND	0.50	"								
1,2-Dichloroethane	ND	0.50	"								
1,2-Dichloropropane	ND	0.50	"								
1,3,5-Trimethylbenzene	ND	0.50	"								
1,3-Dichlorobenzene	ND	0.50	"								
1,3-Dichloropropane	ND	0.50	"								
1,4-Dichlorobenzene	ND	0.50	"								
2,2-Dichloropropane	ND	0.50	"								
2-Chlorotoluene	ND	0.50	"								
2-Hexanone	ND	0.50	"								
4-Chlorotoluene	ND	0.50	"								
Acetone	ND	2.0	"								
Benzene	ND	0.50	"								
Bromobenzene	ND	0.50	"								
Bromochloromethane	ND	0.50	"								
Bromodichloromethane	ND	0.50	"								
Bromoform	ND	0.50	"								
Bromomethane	ND	0.50	"								
Carbon tetrachloride	ND	0.50	"								
Chlorobenzene	ND	0.50	"								
Chloroethane	ND	0.50	"								
Chloroform	ND	0.50	"								
Chloromethane	ND	0.50	"								
cis-1,2-Dichloroethylene	ND	0.50	"								
cis-1,3-Dichloropropylene	ND	0.50	"								
Dibromochloromethane	ND	0.50	"								
Dibromomethane	ND	0.50	"								
Dichlorodifluoromethane	ND	0.50	"								
Ethyl Benzene	ND	0.50	"								
Hexachlorobutadiene	ND	0.50	"								
Isopropylbenzene	ND	0.50	"								
Methyl tert-butyl ether (MTBE)	ND	0.50	"								
Methylene chloride	ND	2.0	"								
Naphthalene	ND	2.0	"								
n-Butylbenzene	ND	0.50	"								
n-Propylbenzene	ND	0.50	"								



Volatile Organic Compounds by GC/MS - Quality Control Data

York Analytical Laboratories, Inc.

Analyte	Result	Reporting Limit	Units	Spike Level	Source* Result	%REC	%REC Limits	Flag	RPD	RPD Limit	Flag
---------	--------	-----------------	-------	-------------	----------------	------	-------------	------	-----	-----------	------

Batch BI70424 - EPA 5030B

Blank (BI70424-BLK1)

Prepared & Analyzed: 09/12/2017

o-Xylene	ND	0.50	ug/L								
p- & m- Xylenes	ND	1.0	"								
p-Isopropyltoluene	ND	0.50	"								
sec-Butylbenzene	ND	0.50	"								
Styrene	ND	0.50	"								
tert-Butylbenzene	ND	0.50	"								
Tetrachloroethylene	ND	0.50	"								
Toluene	ND	0.50	"								
trans-1,2-Dichloroethylene	ND	0.50	"								
trans-1,3-Dichloropropylene	ND	0.50	"								
Trichloroethylene	ND	0.50	"								
Trichlorofluoromethane	ND	0.50	"								
Vinyl Chloride	ND	0.50	"								
Xylenes, Total	ND	1.5	"								
Surrogate: 1,2-Dichloroethane-d4	9.99		"	10.0		99.9	69-130				
Surrogate: Toluene-d8	10.3		"	10.0		103	81-117				
Surrogate: p-Bromofluorobenzene	11.8		"	10.0		118	79-122				

LCS (BI70424-BS1)

Prepared & Analyzed: 09/12/2017

1,1,1,2-Tetrachloroethane	9.12		ug/L	10.0		91.2	82-126				
1,1,1-Trichloroethane	9.85		"	10.0		98.5	78-136				
1,1,2,2-Tetrachloroethane	10.5		"	10.0		105	76-129				
1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	9.79		"	10.0		97.9	54-165				
1,1,2-Trichloroethane	9.16		"	10.0		91.6	82-123				
1,1-Dichloroethane	10.0		"	10.0		100	82-129				
1,1-Dichloroethylene	10.8		"	10.0		108	68-138				
1,1-Dichloropropylene	9.92		"	10.0		99.2	83-133				
1,2,3-Trichlorobenzene	5.79		"	10.0		57.9	76-136	Low Bias			
1,2,3-Trichloropropane	10.6		"	10.0		106	77-128				
1,2,4-Trichlorobenzene	5.78		"	10.0		57.8	76-137	Low Bias			
1,2,4-Trimethylbenzene	10.6		"	10.0		106	82-132				
1,2-Dibromo-3-chloropropane	10.1		"	10.0		101	45-147				
1,2-Dibromoethane	8.98		"	10.0		89.8	83-124				
1,2-Dichlorobenzene	9.26		"	10.0		92.6	79-123				
1,2-Dichloroethane	9.21		"	10.0		92.1	73-132				
1,2-Dichloropropane	9.98		"	10.0		99.8	78-126				
1,3,5-Trimethylbenzene	11.0		"	10.0		110	80-131				
1,3-Dichlorobenzene	9.86		"	10.0		98.6	86-122				
1,3-Dichloropropane	9.32		"	10.0		93.2	81-125				
1,4-Dichlorobenzene	9.68		"	10.0		96.8	85-124				
2,2-Dichloropropane	5.56		"	10.0		55.6	56-150	Low Bias			
2-Chlorotoluene	11.6		"	10.0		116	79-130				
2-Hexanone	9.16		"	10.0		91.6	51-146				
4-Chlorotoluene	11.2		"	10.0		112	79-128				
Acetone	9.04		"	10.0		90.4	14-150				
Benzene	9.75		"	10.0		97.5	85-126				
Bromobenzene	11.0		"	10.0		110	78-129				
Bromochloromethane	10.1		"	10.0		101	77-128				
Bromodichloromethane	9.53		"	10.0		95.3	79-128				
Bromoform	8.04		"	10.0		80.4	78-133				
Bromomethane	4.66		"	10.0		46.6	43-168				



Volatile Organic Compounds by GC/MS - Quality Control Data

York Analytical Laboratories, Inc.

Analyte	Result	Reporting	Units	Spike Level	Source*	%REC	%REC Limits	Flag	RPD	RPD	Flag
		Limit			Result					Limit	

Batch BI70424 - EPA 5030B

LCS (BI70424-BS1)

Prepared & Analyzed: 09/12/2017

Carbon tetrachloride	9.78		ug/L	10.0		97.8	77-141				
Chlorobenzene	9.57		"	10.0		95.7	88-120				
Chloroethane	10.2		"	10.0		102	65-136				
Chloroform	9.03		"	10.0		90.3	82-128				
Chloromethane	9.18		"	10.0		91.8	43-155				
cis-1,2-Dichloroethylene	9.63		"	10.0		96.3	83-129				
cis-1,3-Dichloropropylene	8.58		"	10.0		85.8	80-131				
Dibromochloromethane	8.84		"	10.0		88.4	80-130				
Dibromomethane	9.29		"	10.0		92.9	72-134				
Dichlorodifluoromethane	8.34		"	10.0		83.4	44-144				
Ethyl Benzene	10.2		"	10.0		102	80-131				
Hexachlorobutadiene	4.14		"	10.0		41.4	67-146	Low Bias			
Isopropylbenzene	11.2		"	10.0		112	76-140				
Methyl tert-butyl ether (MTBE)	8.65		"	10.0		86.5	76-135				
Methylene chloride	9.73		"	10.0		97.3	55-137				
Naphthalene	7.27		"	10.0		72.7	70-147				
n-Butylbenzene	8.01		"	10.0		80.1	79-132				
n-Propylbenzene	11.4		"	10.0		114	78-133				
o-Xylene	9.58		"	10.0		95.8	78-130				
p- & m- Xylenes	21.1		"	20.0		105	77-133				
p-Isopropyltoluene	9.18		"	10.0		91.8	81-136				
sec-Butylbenzene	9.26		"	10.0		92.6	79-137				
Styrene	9.10		"	10.0		91.0	67-132				
tert-Butylbenzene	10.0		"	10.0		100	77-138				
Tetrachloroethylene	11.6		"	10.0		116	82-131				
Toluene	10.3		"	10.0		103	80-127				
trans-1,2-Dichloroethylene	10.0		"	10.0		100	80-132				
trans-1,3-Dichloropropylene	8.43		"	10.0		84.3	78-131				
Trichloroethylene	10.2		"	10.0		102	82-128				
Trichlorofluoromethane	9.84		"	10.0		98.4	67-139				
Vinyl Chloride	9.70		"	10.0		97.0	58-145				
<i>Surrogate: 1,2-Dichloroethane-d4</i>	<i>9.50</i>		<i>"</i>	<i>10.0</i>		<i>95.0</i>	<i>69-130</i>				
<i>Surrogate: Toluene-d8</i>	<i>10.7</i>		<i>"</i>	<i>10.0</i>		<i>107</i>	<i>81-117</i>				
<i>Surrogate: p-Bromofluorobenzene</i>	<i>11.7</i>		<i>"</i>	<i>10.0</i>		<i>117</i>	<i>79-122</i>				



Volatile Organic Compounds by GC/MS - Quality Control Data

York Analytical Laboratories, Inc.

Analyte	Result	Reporting Limit	Units	Spike Level	Source* Result	%REC	%REC Limits	Flag	RPD	RPD Limit	Flag
Batch BI70424 - EPA 5030B											
LCS Dup (BI70424-BSD1)											
Prepared & Analyzed: 09/12/2017											
1,1,1,2-Tetrachloroethane	9.37		ug/L	10.0		93.7	82-126		2.70	30	
1,1,1-Trichloroethane	9.72		"	10.0		97.2	78-136		1.33	30	
1,1,2,2-Tetrachloroethane	10.8		"	10.0		108	76-129		3.20	30	
1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	10.6		"	10.0		106	54-165		7.66	30	
1,1,2-Trichloroethane	9.73		"	10.0		97.3	82-123		6.03	30	
1,1-Dichloroethane	10.0		"	10.0		100	82-129		0.299	30	
1,1-Dichloroethylene	11.1		"	10.0		111	68-138		2.66	30	
1,1-Dichloropropylene	9.82		"	10.0		98.2	83-133		1.01	30	
1,2,3-Trichlorobenzene	6.88		"	10.0		68.8	76-136	Low Bias	17.2	30	
1,2,3-Trichloropropane	11.2		"	10.0		112	77-128		5.50	30	
1,2,4-Trichlorobenzene	6.54		"	10.0		65.4	76-137	Low Bias	12.3	30	
1,2,4-Trimethylbenzene	10.3		"	10.0		103	82-132		3.25	30	
1,2-Dibromo-3-chloropropane	11.1		"	10.0		111	45-147		9.32	30	
1,2-Dibromoethane	9.69		"	10.0		96.9	83-124		7.61	30	
1,2-Dichlorobenzene	9.60		"	10.0		96.0	79-123		3.61	30	
1,2-Dichloroethane	9.97		"	10.0		99.7	73-132		7.92	30	
1,2-Dichloropropane	9.96		"	10.0		99.6	78-126		0.201	30	
1,3,5-Trimethylbenzene	10.4		"	10.0		104	80-131		5.81	30	
1,3-Dichlorobenzene	9.76		"	10.0		97.6	86-122		1.02	30	
1,3-Dichloropropane	9.91		"	10.0		99.1	81-125		6.14	30	
1,4-Dichlorobenzene	9.94		"	10.0		99.4	85-124		2.65	30	
2,2-Dichloropropane	5.40		"	10.0		54.0	56-150	Low Bias	2.92	30	
2-Chlorotoluene	11.0		"	10.0		110	79-130		4.51	30	
2-Hexanone	10.4		"	10.0		104	51-146		12.5	30	
4-Chlorotoluene	10.8		"	10.0		108	79-128		4.28	30	
Acetone	9.11		"	10.0		91.1	14-150		0.771	30	
Benzene	9.76		"	10.0		97.6	85-126		0.103	30	
Bromobenzene	11.0		"	10.0		110	78-129		0.818	30	
Bromochloromethane	10.6		"	10.0		106	77-128		5.01	30	
Bromodichloromethane	9.86		"	10.0		98.6	79-128		3.40	30	
Bromoform	9.03		"	10.0		90.3	78-133		11.6	30	
Bromomethane	4.06		"	10.0		40.6	43-168	Low Bias	13.8	30	
Carbon tetrachloride	9.64		"	10.0		96.4	77-141		1.44	30	
Chlorobenzene	9.51		"	10.0		95.1	88-120		0.629	30	
Chloroethane	9.81		"	10.0		98.1	65-136		4.00	30	
Chloroform	9.64		"	10.0		96.4	82-128		6.53	30	
Chloromethane	8.95		"	10.0		89.5	43-155		2.54	30	
cis-1,2-Dichloroethylene	9.60		"	10.0		96.0	83-129		0.312	30	
cis-1,3-Dichloropropylene	9.01		"	10.0		90.1	80-131		4.89	30	
Dibromochloromethane	9.40		"	10.0		94.0	80-130		6.14	30	
Dibromomethane	9.88		"	10.0		98.8	72-134		6.16	30	
Dichlorodifluoromethane	8.23		"	10.0		82.3	44-144		1.33	30	
Ethyl Benzene	9.98		"	10.0		99.8	80-131		2.28	30	
Hexachlorobutadiene	4.55		"	10.0		45.5	67-146	Low Bias	9.44	30	
Isopropylbenzene	10.6		"	10.0		106	76-140		5.12	30	
Methyl tert-butyl ether (MTBE)	9.84		"	10.0		98.4	76-135		12.9	30	
Methylene chloride	10.0		"	10.0		100	55-137		3.24	30	
Naphthalene	8.36		"	10.0		83.6	70-147		13.9	30	
n-Butylbenzene	7.97		"	10.0		79.7	79-132		0.501	30	
n-Propylbenzene	10.8		"	10.0		108	78-133		5.24	30	
o-Xylene	9.61		"	10.0		96.1	78-130		0.313	30	



Volatile Organic Compounds by GC/MS - Quality Control Data

York Analytical Laboratories, Inc.

Analyte	Result	Reporting Limit	Units	Spike Level	Source* Result	%REC	%REC Limits	Flag	RPD	RPD Limit	Flag
---------	--------	-----------------	-------	-------------	----------------	------	-------------	------	-----	-----------	------

Batch BI70424 - EPA 5030B

LCS Dup (BI70424-BSD1)

Prepared & Analyzed: 09/12/2017

p- & m- Xylenes	20.6		ug/L	20.0		103	77-133		2.50	30	
p-Isopropyltoluene	8.98		"	10.0		89.8	81-136		2.20	30	
sec-Butylbenzene	9.08		"	10.0		90.8	79-137		1.96	30	
Styrene	9.38		"	10.0		93.8	67-132		3.03	30	
tert-Butylbenzene	9.79		"	10.0		97.9	77-138		2.42	30	
Tetrachloroethylene	13.3		"	10.0		133	82-131	High Bias	13.8	30	
Toluene	10.0		"	10.0		100	80-127		2.75	30	
trans-1,2-Dichloroethylene	9.83		"	10.0		98.3	80-132		1.91	30	
trans-1,3-Dichloropropylene	8.92		"	10.0		89.2	78-131		5.65	30	
Trichloroethylene	9.88		"	10.0		98.8	82-128		3.58	30	
Trichlorofluoromethane	9.57		"	10.0		95.7	67-139		2.78	30	
Vinyl Chloride	9.43		"	10.0		94.3	58-145		2.82	30	
Surrogate: 1,2-Dichloroethane-d4	9.88		"	10.0		98.8	69-130				
Surrogate: Toluene-d8	10.3		"	10.0		103	81-117				
Surrogate: p-Bromofluorobenzene	11.3		"	10.0		113	79-122				



Metals by ICP - Quality Control Data
York Analytical Laboratories, Inc.

Analyte	Result	Reporting	Units	Spike	Source*	%REC	%REC	Limits	Flag	RPD	
		Limit								RPD	Limit
Batch BI70303 - EPA 200.7											
Blank (BI70303-BLK1)										Prepared & Analyzed: 09/08/2017	
Iron	ND	0.0222	mg/L								
Reference (BI70303-SRM1)										Prepared & Analyzed: 09/08/2017	
Iron	0.854		ug/mL	0.900		94.9	84.9-115				
Batch BI70330 - EPA 3015A											
Blank (BI70330-BLK1)										Prepared: 09/08/2017 Analyzed: 09/09/2017	
Iron - Dissolved	ND	0.0222	mg/L								
Duplicate (BI70330-DUP1)										*Source sample: 17I0191-01 (WQ090517:1105 NP2-10) Prepared: 09/08/2017 Analyzed: 09/09/2017	
Iron - Dissolved	0.0701	0.0222	mg/L		0.0506					32.3	20 Non-dir.
Matrix Spike (BI70330-MS1)										*Source sample: 17I0191-01 (WQ090517:1105 NP2-10) Prepared: 09/08/2017 Analyzed: 09/09/2017	
Iron - Dissolved	1.12	0.0222	mg/L	1.11	0.0506	96.1	75-125				
Reference (BI70330-SRM1)										Prepared: 09/08/2017 Analyzed: 09/09/2017	
Iron - Dissolved	0.827		ug/mL	0.900		91.9	84.9-115				



Miscellaneous Physical Parameters - Quality Control Data

York Analytical Laboratories, Inc.

Analyte	Result	Reporting Limit	Units	Spike Level	Source* Result	%REC	%REC Limits	Flag	RPD	RPD Limit	Flag
---------	--------	-----------------	-------	-------------	----------------	------	-------------	------	-----	-----------	------

Batch BI70279 - % Solids Prep

Blank (BI70279-BLK1)

Prepared: 09/07/2017 Analyzed: 09/08/2017

Total Dissolved Solids	ND	10.0	mg/L								
------------------------	----	------	------	--	--	--	--	--	--	--	--



Volatile Analysis Sample Containers

Lab ID	Client Sample ID	Volatile Sample Container
17I0189-01	WQ090517:1100 NP2-6	40mL Clear Vial (pre-pres.) HCl; Cool to 4° C
17I0191-01	WQ090517:1105 NP2-10	40mL Clear Vial (pre-pres.) HCl; Cool to 4° C



Sample and Data Qualifiers Relating to This Work Order

- QL-02 This LCS analyte is outside Laboratory Recovery limits due the analyte behavior using the referenced method. The reference method has certain limitations with respect to analytes of this nature.
- J Detected below the Reporting Limit but greater than or equal to the Method Detection Limit (MDL/LOD) or in the case of a TIC, the result is an estimated concentration.

Definitions and Other Explanations

- * Analyte is not certified or the state of the samples origination does not offer certification for the Analyte.
- ND NOT DETECTED - the analyte is not detected at the Reported to level (LOQ/RL or LOD/MDL)
- RL REPORTING LIMIT - the minimum reportable value based upon the lowest point in the analyte calibration curve.
- LOQ LIMIT OF QUANTITATION - the minimum concentration of a target analyte that can be reported within a specified degree of confidence. This is the lowest point in an analyte calibration curve that has been subjected to all steps of the processing/analysis and verified to meet defined criteria. This is based upon NELAC 2009 Standards and applies to all analyses.
- LOD LIMIT OF DETECTION - a verified estimate of the minimum concentration of a substance in a given matrix that an analytical process can reliably detect. This is based upon NELAC 2009 Standards and applies to all analyses conducted under the auspices of EPA SW-846.
- MDL METHOD DETECTION LIMIT - a statistically derived estimate of the minimum amount of a substance an analytical system can reliably detect with a 99% confidence that the concentration of the substance is greater than zero. This is based upon 40 CFR Part 136 Appendix B and applies only to EPA 600 and 200 series methods.
- Reported to This indicates that the data for a particular analysis is reported to either the LOD/MDL, or the LOQ/RL. In cases where the "Reported to" is located above the LOD/MDL, any value between this and the LOQ represents an estimated value which is "J" flagged accordingly. This applies to volatile and semi-volatile target compounds only.
- NR Not reported
- RPD Relative Percent Difference
- Wet The data has been reported on an as-received (wet weight) basis
- Low Bias Low Bias flag indicates that the recovery of the flagged analyte is below the laboratory or regulatory lower control limit. The data user should take note that this analyte may be biased low but should evaluate multiple lines of evidence including the LCS and site-specific MS/MSD data to draw bias conclusions. In cases where no site-specific MS/MSD was requested, only the LCS data can be used to evaluate such bias.
- High Bias High Bias flag indicates that the recovery of the flagged analyte is above the laboratory or regulatory upper control limit. The data user should take note that this analyte may be biased high but should evaluate multiple lines of evidence including the LCS and site-specific MS/MSD data to draw bias conclusions. In cases where no site-specific MS/MSD was requested, only the LCS data can be used to evaluate such bias.
- Non-Dir. Non-dir. flag (Non-Directional Bias) indicates that the Relative Percent Difference (RPD) (a measure of precision) among the MS and MSD data is outside the laboratory or regulatory control limit. This alerts the data user where the MS and MSD are from site-specific samples that the RPD is high due to either non-homogeneous distribution of target analyte between the MS/MSD or indicates poor reproducibility for other reasons.

If EPA SW-846 method 8270 is included herein it is noted that the target compound N-nitrosodiphenylamine (NDPA) decomposes in the gas chromatographic inlet and cannot be separated from diphenylamine (DPA). These results could actually represent 100% DPA, 100% NDPA or some combination of the two. For this reason, York reports the combined result for n-nitrosodiphenylamine and diphenylamine for either of these compounds as a combined concentration as Diphenylamine.

If Total PCBs are detected and the target aroclors reported are "Not detected", the Total PCB value is reported due to the presence of either or both Aroclors 1262 and 1268 which are non-target aroclors for some regulatory lists.

2-chloroethylvinyl ether readily breaks down under acidic conditions. Samples that are acid preserved, including standards will exhibit breakdown. The data user should take note.

Certification for pH is no longer offered by NYDOH ELAP.

Semi-Volatile and Volatile analyses are reported down to the LOD/MDL, with values between the LOD/MDL and the LOQ being "J" flagged as estimated results.



For analyses by EPA SW-846-8270D, the Limit of Quantitation (LOQ) reported for benzidine is based upon the lowest standard used for calibration and is not a verified LOQ due to this compound's propensity for oxidative losses during extraction/concentration procedures and non-reproducible chromatographic performance.



APPENDIX II
SEPTEMBER 2017 LABORATORY ANALYTICAL REPORTS
FOR FSP&T AND FP&T RECOVERY WELLS



Technical Report

prepared for:

Leggette Brashears & Graham Shelton Office

4 Research Drive, Suite 204

Shelton CT, 06484

Attention: Tunde Komuves-Sandor

Report Date: 09/13/2017

Client Project ID: Rowe Industries

York Project (SDG) No.: 17I0195

CT Cert. No. PH-0723

New Jersey Cert. No. CT005 and NY037



New York Cert. Nos. 10854 and 12058

PA Cert. No. 68-04440

120 RESEARCH DRIVE
www.YORKLAB.com

STRATFORD, CT 06615
(203) 325-1371

132-02 89th AVENUE
FAX (203) 357-0166

RICHMOND HILL, NY 11418
ClientServices@yorklab.com

Report Date: 09/13/2017
Client Project ID: Rowe Industries
York Project (SDG) No.: 17I0195

Leggette Brashears & Graham Shelton Office
4 Research Drive, Suite 204
Shelton CT, 06484
Attention: Tunde Komuves-Sandor

Purpose and Results

This report contains the analytical data for the sample(s) identified on the attached chain-of-custody received in our laboratory on September 07, 2017 and listed below. The project was identified as your project: **Rowe Industries**.

The analyses were conducted utilizing appropriate EPA, Standard Methods, and ASTM methods as detailed in the data summary tables.

All samples were received in proper condition meeting the customary acceptance requirements for environmental samples except those indicated under the Sample and Analysis Qualifiers section of this report.

All analyses met the method and laboratory standard operating procedure requirements except as indicated by any data flags, the meaning of which are explained in the Sample and Data Qualifiers Relating to This Work Order section of this report and case narrative if applicable.

The results of the analyses, which are all reported on dry weight basis (soils) unless otherwise noted, are detailed in the following pages.

Please contact Client Services at 203.325.1371 with any questions regarding this report.

<u>York Sample ID</u>	<u>Client Sample ID</u>	<u>Matrix</u>	<u>Date Collected</u>	<u>Date Received</u>
17I0195-01	WQ090517:1110 NP1-1-2	Water	09/05/2017	09/07/2017

General Notes for York Project (SDG) No.: 17I0195

1. The RLs and MDLs (Reporting Limit and Method Detection Limit respectively) reported are adjusted for any dilution necessary due to the levels of target and/or non-target analytes and matrix interference. The RL(REPORTING LIMIT) is based upon the lowest standard utilized for the calibration where applicable.
2. Samples are retained for a period of thirty days after submittal of report, unless other arrangements are made.
3. York's liability for the above data is limited to the dollar value paid to York for the referenced project.
4. This report shall not be reproduced without the written approval of York Analytical Laboratories, Inc.
5. All analyses conducted met method or Laboratory SOP requirements. See the Sample and Data Qualifiers Section for further information.
6. It is noted that no analyses reported herein were subcontracted to another laboratory, unless noted in the report.
7. This report reflects results that relate only to the samples submitted on the attached chain-of-custody form(s) received by York.
8. Analyses conducted at York Analytical Laboratories, Inc. Stratford, CT are indicated by NY Cert. No. 10854; those conducted at York Analytical Laboratories, Inc., Richmond Hill, NY are indicated by NY Cert. No. 12058.

Approved By:



Benjamin Gulizia
Laboratory Director

Date: 09/13/2017





Sample Information

Client Sample ID: WQ090517:1110 NP1-1-2

York Sample ID: 1710195-01

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
1710195	Rowe Industries	Water	September 5, 2017 11:10 am	09/07/2017

Volatile Organics, 8260 List - Low Level

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
630-20-6	1,1,1,2-Tetrachloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
71-55-6	1,1,1-Trichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
79-34-5	1,1,2,2-Tetrachloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
76-13-1	1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
79-00-5	1,1,2-Trichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
75-34-3	1,1-Dichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
75-35-4	1,1-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
563-58-6	1,1-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 19:18	SR
87-61-6	1,2,3-Trichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 19:18	SR
96-18-4	1,2,3-Trichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 19:18	SR
120-82-1	1,2,4-Trichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 19:18	SR
95-63-6	1,2,4-Trimethylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
96-12-8	1,2-Dibromo-3-chloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
106-93-4	1,2-Dibromoethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
95-50-1	1,2-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
107-06-2	1,2-Dichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
78-87-5	1,2-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
108-67-8	1,3,5-Trimethylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
541-73-1	1,3-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
142-28-9	1,3-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 19:18	SR
106-46-7	1,4-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
594-20-7	2,2-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 19:18	SR



Sample Information

Client Sample ID: WQ090517:1110 NP1-1-2

York Sample ID: 17I0195-01

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17I0195

Rowe Industries

Water

September 5, 2017 11:10 am

09/07/2017

Volatile Organics, 8260 List - Low Level

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
95-49-8	2-Chlorotoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
591-78-6	2-Hexanone	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
106-43-4	4-Chlorotoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
67-64-1	Acetone	1.5	J	ug/L	1.0	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
71-43-2	Benzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
108-86-1	Bromobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 19:18	SR
74-97-5	Bromochloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 19:18	SR
75-27-4	Bromodichloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
75-25-2	Bromoform	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
74-83-9	Bromomethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
56-23-5	Carbon tetrachloride	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
108-90-7	Chlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
75-00-3	Chloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
67-66-3	Chloroform	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
74-87-3	Chloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
156-59-2	cis-1,2-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
10061-01-5	cis-1,3-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
124-48-1	Dibromochloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
74-95-3	Dibromomethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 19:18	SR
75-71-8	Dichlorodifluoromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 19:18	SR
100-41-4	Ethyl Benzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
87-68-3	Hexachlorobutadiene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 19:18	SR
98-82-8	Isopropylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR



Sample Information

Client Sample ID: WQ090517:1110 NP1-1-2

York Sample ID: 17I0195-01

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17I0195

Rowe Industries

Water

September 5, 2017 11:10 am

09/07/2017

Volatile Organics, 8260 List - Low Level

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
1634-04-4	Methyl tert-butyl ether (MTBE)	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
75-09-2	Methylene chloride	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
91-20-3	Naphthalene	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 19:18	SR
104-51-8	n-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
103-65-1	n-Propylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
95-47-6	o-Xylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 19:18	SR
179601-23-1	p- & m- Xylenes	ND		ug/L	0.50	1.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NELAC-NY10854-Que	09/12/2017 07:30	09/12/2017 19:18	SR
99-87-6	p-Isopropyltoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
135-98-8	sec-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
100-42-5	Styrene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
98-06-6	tert-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
127-18-4	Tetrachloroethylene	0.23	J	ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
108-88-3	Toluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
156-60-5	trans-1,2-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
10061-02-6	trans-1,3-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
79-01-6	Trichloroethylene	0.32	J	ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
75-69-4	Trichlorofluoromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
75-01-4	Vinyl Chloride	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
1330-20-7	Xylenes, Total	ND		ug/L	0.60	1.5	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY11	09/12/2017 07:30	09/12/2017 19:18	SR
	Surrogate Recoveries	Result			Acceptance Range						
17060-07-0	Surrogate: 1,2-Dichloroethane-d4	99.5 %			69-130						
2037-26-5	Surrogate: Toluene-d8	105 %			81-117						
460-00-4	Surrogate: p-Bromofluorobenzene	110 %			79-122						



Analytical Batch Summary

Batch ID: BI70424

Preparation Method: EPA 5030B

Prepared By: RDS

YORK Sample ID	Client Sample ID	Preparation Date
17I0195-01	WQ090517:1110 NP1-1-2	09/12/17
BI70424-BLK1	Blank	09/12/17
BI70424-BS1	LCS	09/12/17
BI70424-BSD1	LCS Dup	09/12/17



Volatile Organic Compounds by GC/MS - Quality Control Data
York Analytical Laboratories, Inc.

Analyte	Result	Reporting Limit	Units	Spike Level	Source* Result	%REC	%REC Limits	Flag	RPD	RPD Limit	Flag
---------	--------	-----------------	-------	-------------	----------------	------	-------------	------	-----	-----------	------

Batch BI70424 - EPA 5030B

Blank (BI70424-BLK1)

Prepared & Analyzed: 09/12/2017

1,1,1,2-Tetrachloroethane	ND	0.50	ug/L								
1,1,1-Trichloroethane	ND	0.50	"								
1,1,2,2-Tetrachloroethane	ND	0.50	"								
1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	ND	0.50	"								
1,1,2-Trichloroethane	ND	0.50	"								
1,1-Dichloroethane	ND	0.50	"								
1,1-Dichloroethylene	ND	0.50	"								
1,1-Dichloropropylene	ND	0.50	"								
1,2,3-Trichlorobenzene	ND	0.50	"								
1,2,3-Trichloropropane	ND	0.50	"								
1,2,4-Trichlorobenzene	ND	0.50	"								
1,2,4-Trimethylbenzene	ND	0.50	"								
1,2-Dibromo-3-chloropropane	ND	0.50	"								
1,2-Dibromoethane	ND	0.50	"								
1,2-Dichlorobenzene	ND	0.50	"								
1,2-Dichloroethane	ND	0.50	"								
1,2-Dichloropropane	ND	0.50	"								
1,3,5-Trimethylbenzene	ND	0.50	"								
1,3-Dichlorobenzene	ND	0.50	"								
1,3-Dichloropropane	ND	0.50	"								
1,4-Dichlorobenzene	ND	0.50	"								
2,2-Dichloropropane	ND	0.50	"								
2-Chlorotoluene	ND	0.50	"								
2-Hexanone	ND	0.50	"								
4-Chlorotoluene	ND	0.50	"								
Acetone	ND	2.0	"								
Benzene	ND	0.50	"								
Bromobenzene	ND	0.50	"								
Bromochloromethane	ND	0.50	"								
Bromodichloromethane	ND	0.50	"								
Bromoform	ND	0.50	"								
Bromomethane	ND	0.50	"								
Carbon tetrachloride	ND	0.50	"								
Chlorobenzene	ND	0.50	"								
Chloroethane	ND	0.50	"								
Chloroform	ND	0.50	"								
Chloromethane	ND	0.50	"								
cis-1,2-Dichloroethylene	ND	0.50	"								
cis-1,3-Dichloropropylene	ND	0.50	"								
Dibromochloromethane	ND	0.50	"								
Dibromomethane	ND	0.50	"								
Dichlorodifluoromethane	ND	0.50	"								
Ethyl Benzene	ND	0.50	"								
Hexachlorobutadiene	ND	0.50	"								
Isopropylbenzene	ND	0.50	"								
Methyl tert-butyl ether (MTBE)	ND	0.50	"								
Methylene chloride	ND	2.0	"								
Naphthalene	ND	2.0	"								
n-Butylbenzene	ND	0.50	"								
n-Propylbenzene	ND	0.50	"								



Volatile Organic Compounds by GC/MS - Quality Control Data

York Analytical Laboratories, Inc.

Analyte	Result	Reporting Limit	Units	Spike Level	Source* Result	%REC	%REC Limits	Flag	RPD	RPD Limit	Flag
---------	--------	-----------------	-------	-------------	----------------	------	-------------	------	-----	-----------	------

Batch BI70424 - EPA 5030B

Blank (BI70424-BLK1)

Prepared & Analyzed: 09/12/2017

o-Xylene	ND	0.50	ug/L								
p- & m- Xylenes	ND	1.0	"								
p-Isopropyltoluene	ND	0.50	"								
sec-Butylbenzene	ND	0.50	"								
Styrene	ND	0.50	"								
tert-Butylbenzene	ND	0.50	"								
Tetrachloroethylene	ND	0.50	"								
Toluene	ND	0.50	"								
trans-1,2-Dichloroethylene	ND	0.50	"								
trans-1,3-Dichloropropylene	ND	0.50	"								
Trichloroethylene	ND	0.50	"								
Trichlorofluoromethane	ND	0.50	"								
Vinyl Chloride	ND	0.50	"								
Xylenes, Total	ND	1.5	"								
Surrogate: 1,2-Dichloroethane-d4	9.99		"	10.0		99.9	69-130				
Surrogate: Toluene-d8	10.3		"	10.0		103	81-117				
Surrogate: p-Bromofluorobenzene	11.8		"	10.0		118	79-122				

LCS (BI70424-BS1)

Prepared & Analyzed: 09/12/2017

1,1,1,2-Tetrachloroethane	9.12		ug/L	10.0		91.2	82-126				
1,1,1-Trichloroethane	9.85		"	10.0		98.5	78-136				
1,1,2,2-Tetrachloroethane	10.5		"	10.0		105	76-129				
1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	9.79		"	10.0		97.9	54-165				
1,1,2-Trichloroethane	9.16		"	10.0		91.6	82-123				
1,1-Dichloroethane	10.0		"	10.0		100	82-129				
1,1-Dichloroethylene	10.8		"	10.0		108	68-138				
1,1-Dichloropropylene	9.92		"	10.0		99.2	83-133				
1,2,3-Trichlorobenzene	5.79		"	10.0		57.9	76-136	Low Bias			
1,2,3-Trichloropropane	10.6		"	10.0		106	77-128				
1,2,4-Trichlorobenzene	5.78		"	10.0		57.8	76-137	Low Bias			
1,2,4-Trimethylbenzene	10.6		"	10.0		106	82-132				
1,2-Dibromo-3-chloropropane	10.1		"	10.0		101	45-147				
1,2-Dibromoethane	8.98		"	10.0		89.8	83-124				
1,2-Dichlorobenzene	9.26		"	10.0		92.6	79-123				
1,2-Dichloroethane	9.21		"	10.0		92.1	73-132				
1,2-Dichloropropane	9.98		"	10.0		99.8	78-126				
1,3,5-Trimethylbenzene	11.0		"	10.0		110	80-131				
1,3-Dichlorobenzene	9.86		"	10.0		98.6	86-122				
1,3-Dichloropropane	9.32		"	10.0		93.2	81-125				
1,4-Dichlorobenzene	9.68		"	10.0		96.8	85-124				
2,2-Dichloropropane	5.56		"	10.0		55.6	56-150	Low Bias			
2-Chlorotoluene	11.6		"	10.0		116	79-130				
2-Hexanone	9.16		"	10.0		91.6	51-146				
4-Chlorotoluene	11.2		"	10.0		112	79-128				
Acetone	9.04		"	10.0		90.4	14-150				
Benzene	9.75		"	10.0		97.5	85-126				
Bromobenzene	11.0		"	10.0		110	78-129				
Bromochloromethane	10.1		"	10.0		101	77-128				
Bromodichloromethane	9.53		"	10.0		95.3	79-128				
Bromoform	8.04		"	10.0		80.4	78-133				
Bromomethane	4.66		"	10.0		46.6	43-168				



Volatile Organic Compounds by GC/MS - Quality Control Data

York Analytical Laboratories, Inc.

Analyte	Result	Reporting	Units	Spike	Source*	%REC	%REC	Limits	Flag	RPD	RPD	Limit	Flag
		Limit			Result					Limit			

Batch BI70424 - EPA 5030B

LCS (BI70424-BS1)

Prepared & Analyzed: 09/12/2017

Carbon tetrachloride	9.78		ug/L	10.0		97.8	77-141						
Chlorobenzene	9.57		"	10.0		95.7	88-120						
Chloroethane	10.2		"	10.0		102	65-136						
Chloroform	9.03		"	10.0		90.3	82-128						
Chloromethane	9.18		"	10.0		91.8	43-155						
cis-1,2-Dichloroethylene	9.63		"	10.0		96.3	83-129						
cis-1,3-Dichloropropylene	8.58		"	10.0		85.8	80-131						
Dibromochloromethane	8.84		"	10.0		88.4	80-130						
Dibromomethane	9.29		"	10.0		92.9	72-134						
Dichlorodifluoromethane	8.34		"	10.0		83.4	44-144						
Ethyl Benzene	10.2		"	10.0		102	80-131						
Hexachlorobutadiene	4.14		"	10.0		41.4	67-146		Low Bias				
Isopropylbenzene	11.2		"	10.0		112	76-140						
Methyl tert-butyl ether (MTBE)	8.65		"	10.0		86.5	76-135						
Methylene chloride	9.73		"	10.0		97.3	55-137						
Naphthalene	7.27		"	10.0		72.7	70-147						
n-Butylbenzene	8.01		"	10.0		80.1	79-132						
n-Propylbenzene	11.4		"	10.0		114	78-133						
o-Xylene	9.58		"	10.0		95.8	78-130						
p- & m- Xylenes	21.1		"	20.0		105	77-133						
p-Isopropyltoluene	9.18		"	10.0		91.8	81-136						
sec-Butylbenzene	9.26		"	10.0		92.6	79-137						
Styrene	9.10		"	10.0		91.0	67-132						
tert-Butylbenzene	10.0		"	10.0		100	77-138						
Tetrachloroethylene	11.6		"	10.0		116	82-131						
Toluene	10.3		"	10.0		103	80-127						
trans-1,2-Dichloroethylene	10.0		"	10.0		100	80-132						
trans-1,3-Dichloropropylene	8.43		"	10.0		84.3	78-131						
Trichloroethylene	10.2		"	10.0		102	82-128						
Trichlorofluoromethane	9.84		"	10.0		98.4	67-139						
Vinyl Chloride	9.70		"	10.0		97.0	58-145						
<i>Surrogate: 1,2-Dichloroethane-d4</i>	<i>9.50</i>		<i>"</i>	<i>10.0</i>		<i>95.0</i>	<i>69-130</i>						
<i>Surrogate: Toluene-d8</i>	<i>10.7</i>		<i>"</i>	<i>10.0</i>		<i>107</i>	<i>81-117</i>						
<i>Surrogate: p-Bromofluorobenzene</i>	<i>11.7</i>		<i>"</i>	<i>10.0</i>		<i>117</i>	<i>79-122</i>						



Volatile Organic Compounds by GC/MS - Quality Control Data

York Analytical Laboratories, Inc.

Analyte	Result	Reporting Limit	Units	Spike Level	Source* Result	%REC	%REC Limits	Flag	RPD	RPD Limit	Flag
Batch BI70424 - EPA 5030B											
LCS Dup (BI70424-BSD1)											
Prepared & Analyzed: 09/12/2017											
1,1,1,2-Tetrachloroethane	9.37		ug/L	10.0		93.7	82-126		2.70	30	
1,1,1-Trichloroethane	9.72		"	10.0		97.2	78-136		1.33	30	
1,1,2,2-Tetrachloroethane	10.8		"	10.0		108	76-129		3.20	30	
1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	10.6		"	10.0		106	54-165		7.66	30	
1,1,2-Trichloroethane	9.73		"	10.0		97.3	82-123		6.03	30	
1,1-Dichloroethane	10.0		"	10.0		100	82-129		0.299	30	
1,1-Dichloroethylene	11.1		"	10.0		111	68-138		2.66	30	
1,1-Dichloropropylene	9.82		"	10.0		98.2	83-133		1.01	30	
1,2,3-Trichlorobenzene	6.88		"	10.0		68.8	76-136	Low Bias	17.2	30	
1,2,3-Trichloropropane	11.2		"	10.0		112	77-128		5.50	30	
1,2,4-Trichlorobenzene	6.54		"	10.0		65.4	76-137	Low Bias	12.3	30	
1,2,4-Trimethylbenzene	10.3		"	10.0		103	82-132		3.25	30	
1,2-Dibromo-3-chloropropane	11.1		"	10.0		111	45-147		9.32	30	
1,2-Dibromoethane	9.69		"	10.0		96.9	83-124		7.61	30	
1,2-Dichlorobenzene	9.60		"	10.0		96.0	79-123		3.61	30	
1,2-Dichloroethane	9.97		"	10.0		99.7	73-132		7.92	30	
1,2-Dichloropropane	9.96		"	10.0		99.6	78-126		0.201	30	
1,3,5-Trimethylbenzene	10.4		"	10.0		104	80-131		5.81	30	
1,3-Dichlorobenzene	9.76		"	10.0		97.6	86-122		1.02	30	
1,3-Dichloropropane	9.91		"	10.0		99.1	81-125		6.14	30	
1,4-Dichlorobenzene	9.94		"	10.0		99.4	85-124		2.65	30	
2,2-Dichloropropane	5.40		"	10.0		54.0	56-150	Low Bias	2.92	30	
2-Chlorotoluene	11.0		"	10.0		110	79-130		4.51	30	
2-Hexanone	10.4		"	10.0		104	51-146		12.5	30	
4-Chlorotoluene	10.8		"	10.0		108	79-128		4.28	30	
Acetone	9.11		"	10.0		91.1	14-150		0.771	30	
Benzene	9.76		"	10.0		97.6	85-126		0.103	30	
Bromobenzene	11.0		"	10.0		110	78-129		0.818	30	
Bromochloromethane	10.6		"	10.0		106	77-128		5.01	30	
Bromodichloromethane	9.86		"	10.0		98.6	79-128		3.40	30	
Bromoform	9.03		"	10.0		90.3	78-133		11.6	30	
Bromomethane	4.06		"	10.0		40.6	43-168	Low Bias	13.8	30	
Carbon tetrachloride	9.64		"	10.0		96.4	77-141		1.44	30	
Chlorobenzene	9.51		"	10.0		95.1	88-120		0.629	30	
Chloroethane	9.81		"	10.0		98.1	65-136		4.00	30	
Chloroform	9.64		"	10.0		96.4	82-128		6.53	30	
Chloromethane	8.95		"	10.0		89.5	43-155		2.54	30	
cis-1,2-Dichloroethylene	9.60		"	10.0		96.0	83-129		0.312	30	
cis-1,3-Dichloropropylene	9.01		"	10.0		90.1	80-131		4.89	30	
Dibromochloromethane	9.40		"	10.0		94.0	80-130		6.14	30	
Dibromomethane	9.88		"	10.0		98.8	72-134		6.16	30	
Dichlorodifluoromethane	8.23		"	10.0		82.3	44-144		1.33	30	
Ethyl Benzene	9.98		"	10.0		99.8	80-131		2.28	30	
Hexachlorobutadiene	4.55		"	10.0		45.5	67-146	Low Bias	9.44	30	
Isopropylbenzene	10.6		"	10.0		106	76-140		5.12	30	
Methyl tert-butyl ether (MTBE)	9.84		"	10.0		98.4	76-135		12.9	30	
Methylene chloride	10.0		"	10.0		100	55-137		3.24	30	
Naphthalene	8.36		"	10.0		83.6	70-147		13.9	30	
n-Butylbenzene	7.97		"	10.0		79.7	79-132		0.501	30	
n-Propylbenzene	10.8		"	10.0		108	78-133		5.24	30	
o-Xylene	9.61		"	10.0		96.1	78-130		0.313	30	



Volatile Organic Compounds by GC/MS - Quality Control Data

York Analytical Laboratories, Inc.

Analyte	Result	Reporting	Units	Spike	Source*	%REC	%REC	Limits	Flag	RPD	RPD	Limit	Flag
		Limit			Result					Limit			

Batch BI70424 - EPA 5030B

LCS Dup (BI70424-BSD1)

Prepared & Analyzed: 09/12/2017

p- & m- Xylenes	20.6		ug/L	20.0		103	77-133			2.50	30		
p-Isopropyltoluene	8.98		"	10.0		89.8	81-136			2.20	30		
sec-Butylbenzene	9.08		"	10.0		90.8	79-137			1.96	30		
Styrene	9.38		"	10.0		93.8	67-132			3.03	30		
tert-Butylbenzene	9.79		"	10.0		97.9	77-138			2.42	30		
Tetrachloroethylene	13.3		"	10.0		133	82-131	High Bias		13.8	30		
Toluene	10.0		"	10.0		100	80-127			2.75	30		
trans-1,2-Dichloroethylene	9.83		"	10.0		98.3	80-132			1.91	30		
trans-1,3-Dichloropropylene	8.92		"	10.0		89.2	78-131			5.65	30		
Trichloroethylene	9.88		"	10.0		98.8	82-128			3.58	30		
Trichlorofluoromethane	9.57		"	10.0		95.7	67-139			2.78	30		
Vinyl Chloride	9.43		"	10.0		94.3	58-145			2.82	30		
<i>Surrogate: 1,2-Dichloroethane-d4</i>	<i>9.88</i>		<i>"</i>	<i>10.0</i>		<i>98.8</i>	<i>69-130</i>						
<i>Surrogate: Toluene-d8</i>	<i>10.3</i>		<i>"</i>	<i>10.0</i>		<i>103</i>	<i>81-117</i>						
<i>Surrogate: p-Bromofluorobenzene</i>	<i>11.3</i>		<i>"</i>	<i>10.0</i>		<i>113</i>	<i>79-122</i>						



Volatile Analysis Sample Containers

Lab ID	Client Sample ID	Volatile Sample Container
17I0195-01	WQ090517:1110 NP1-1-2	40mL Clear Vial (pre-pres.) HCl; Cool to 4° C



Sample and Data Qualifiers Relating to This Work Order

- QL-02 This LCS analyte is outside Laboratory Recovery limits due the analyte behavior using the referenced method. The reference method has certain limitations with respect to analytes of this nature.
- J Detected below the Reporting Limit but greater than or equal to the Method Detection Limit (MDL/LOD) or in the case of a TIC, the result is an estimated concentration.

Definitions and Other Explanations

- * Analyte is not certified or the state of the samples origination does not offer certification for the Analyte.
- ND NOT DETECTED - the analyte is not detected at the Reported to level (LOQ/RL or LOD/MDL)
- RL REPORTING LIMIT - the minimum reportable value based upon the lowest point in the analyte calibration curve.
- LOQ LIMIT OF QUANTITATION - the minimum concentration of a target analyte that can be reported within a specified degree of confidence. This is the lowest point in an analyte calibration curve that has been subjected to all steps of the processing/analysis and verified to meet defined criteria. This is based upon NELAC 2009 Standards and applies to all analyses.
- LOD LIMIT OF DETECTION - a verified estimate of the minimum concentration of a substance in a given matrix that an analytical process can reliably detect. This is based upon NELAC 2009 Standards and applies to all analyses conducted under the auspices of EPA SW-846.
- MDL METHOD DETECTION LIMIT - a statistically derived estimate of the minimum amount of a substance an analytical system can reliably detect with a 99% confidence that the concentration of the substance is greater than zero. This is based upon 40 CFR Part 136 Appendix B and applies only to EPA 600 and 200 series methods.
- Reported to This indicates that the data for a particular analysis is reported to either the LOD/MDL, or the LOQ/RL. In cases where the "Reported to" is located above the LOD/MDL, any value between this and the LOQ represents an estimated value which is "J" flagged accordingly. This applies to volatile and semi-volatile target compounds only.
- NR Not reported
- RPD Relative Percent Difference
- Wet The data has been reported on an as-received (wet weight) basis
- Low Bias Low Bias flag indicates that the recovery of the flagged analyte is below the laboratory or regulatory lower control limit. The data user should take note that this analyte may be biased low but should evaluate multiple lines of evidence including the LCS and site-specific MS/MSD data to draw bias conclusions. In cases where no site-specific MS/MSD was requested, only the LCS data can be used to evaluate such bias.
- High Bias High Bias flag indicates that the recovery of the flagged analyte is above the laboratory or regulatory upper control limit. The data user should take note that this analyte may be biased high but should evaluate multiple lines of evidence including the LCS and site-specific MS/MSD data to draw bias conclusions. In cases where no site-specific MS/MSD was requested, only the LCS data can be used to evaluate such bias.
- Non-Dir. Non-dir. flag (Non-Directional Bias) indicates that the Relative Percent Difference (RPD) (a measure of precision) among the MS and MSD data is outside the laboratory or regulatory control limit. This alerts the data user where the MS and MSD are from site-specific samples that the RPD is high due to either non-homogeneous distribution of target analyte between the MS/MSD or indicates poor reproducibility for other reasons.

If EPA SW-846 method 8270 is included herein it is noted that the target compound N-nitrosodiphenylamine (NDPA) decomposes in the gas chromatographic inlet and cannot be separated from diphenylamine (DPA). These results could actually represent 100% DPA, 100% NDPA or some combination of the two. For this reason, York reports the combined result for n-nitrosodiphenylamine and diphenylamine for either of these compounds as a combined concentration as Diphenylamine.

If Total PCBs are detected and the target aroclors reported are "Not detected", the Total PCB value is reported due to the presence of either or both Aroclors 1262 and 1268 which are non-target aroclors for some regulatory lists.

2-chloroethylvinyl ether readily breaks down under acidic conditions. Samples that are acid preserved, including standards will exhibit breakdown. The data user should take note.

Certification for pH is no longer offered by NYDOH ELAP.

Semi-Volatile and Volatile analyses are reported down to the LOD/MDL, with values between the LOD/MDL and the LOQ being "J" flagged as estimated results.



For analyses by EPA SW-846-8270D, the Limit of Quantitation (LOQ) reported for benzidine is based upon the lowest standard used for calibration and is not a verified LOQ due to this compound's propensity for oxidative losses during extraction/concentration procedures and non-reproducible chromatographic performance.



YORK

ANALYTICAL LABORATORIES, INC.
120 RESEARCH DR. STRATFORD, CT 06615
(203) 325-1371 FAX (203) 357-0166

Field Chain-of-Custody Record

NOTE: York's Std. Terms & Conditions are listed on the back side of this document. This document serves as your written authorization to York to proceed with the analyses requested and your signature binds you to York's Std. Terms & Conditions.

York Project No. 171019C

YOUR INFORMATION		Report To:		Invoice To:		YOUR PROJECT ID		Turn-Around Time		Report Type	
Company: <u>LB6</u>	Company: <u>Same</u>	Company: <u>Same</u>	Company: <u>Rowe Industries</u>	8260 full	Volatiles	Semi-Volatiles	Metals	Full Lists	<input checked="" type="checkbox"/> RUSH - Same Day	Summary Report <u>X</u>	Summary w/ QA <u>pd</u>
Address: <u>4 Research Dr, Suite 301</u>	Address: <u>Same</u>	Address: <u>Same</u>	Address: <u>Rowe Industries</u>	624	Site Spec.	8082PCB	RCRA8	Misc. Org.	<input type="checkbox"/> RUSH - Next Day	CT RCP Package	CT RCP Package
Phone No. <u>Shelton, CT 06484</u>	Phone No. <u>Same</u>	Phone No. <u>Same</u>	Phone No. <u>Rowe Industries</u>	STARS list	Nissan Co.	8081Pest	PP13 list	TPH GRO	<input type="checkbox"/> RUSH - Two Day	CTRCP DOA/DUE Pkg	CTRCP DOA/DUE Pkg
Attention: <u>203-929-8555</u>	Attention: <u>Same</u>	Attention: <u>Same</u>	Attention: <u>Rowe Industries</u>	BTEX	Suffolk Co.	8151Herb	TAL	CT ETPH	<input type="checkbox"/> RUSH - Three Day	NY ASP A Package	NY ASP A Package
Contact Person: <u>Tunde Sandoz</u>	E-Mail Address: <u>TSandoz@LB6CT.com</u>	E-Mail Address: <u>Same</u>	E-Mail Address: <u>Rowe Industries</u>	MTBE	Ketones	PAH list	CT RCP	NY 310-13	<input type="checkbox"/> RUSH - Four Day	NY ASP B Package <u>X</u>	NY ASP B Package <u>X</u>
E-Mail Address: <u>TSandoz@LB6CT.com</u>		E-Mail Address: <u>Same</u>		TCL list	Oxyanions	App. IX	App. IX	TPH 1664	Standard (5-7 Days) <input checked="" type="checkbox"/>	NIDEP Red. Deliv.	NIDEP Red. Deliv.
Print Clearly and Legibly. All information must be complete. Samples will NOT be logged in and the turn-around time clock will not begin until any questions by York are resolved.		Print Clearly and Legibly. All information must be complete. Samples will NOT be logged in and the turn-around time clock will not begin until any questions by York are resolved.		TAGM list	TCLP list	CT RCP list	Site Spec.	Air TO14A		Electronic Data Deliverables (EDD)	Electronic Data Deliverables (EDD)
Matrix Codes		Matrix Codes		CT RCP list	524.2	NIDEP list	App. IX	Air TO15	Simple Excel <u>X</u>	NYSDEC EQuIS	NYSDEC EQuIS
S - soil		S - soil		Atom. only	502.2	NIDEP list	App. IX	Air STARS	EQQuIS (std)	EQQuIS (std)	EQQuIS (std)
Other - specify (oil, etc)		Other - specify (oil, etc)		Halog. only	NIDEP list	App. IX	Chloride	Air VPH	EZ-EDD (BQuIS)	EZ-EDD (BQuIS)	EZ-EDD (BQuIS)
WW - wastewater		WW - wastewater		App. IX list	SELP list	SELP list	SELP list	NIDEP list	NIDEP SRP HazSite EDD	NIDEP SRP HazSite EDD	NIDEP SRP HazSite EDD
GW - groundwater		GW - groundwater		8021B list				Other	GIS/KEY (std)	GIS/KEY (std)	GIS/KEY (std)
DW - drinking water		DW - drinking water						Other	Other	Other	Other
Air-A - ambient air		Air-A - ambient air						Other	Other	Other	Other
Air-SV - soil vapor		Air-SV - soil vapor						Other	Other	Other	Other
Samples Collected/Authorized By (Signature)		Samples Collected/Authorized By (Signature)						Other	Other	Other	Other
<u>Evan Feltz</u>		<u>Evan Feltz</u>						Other	Other	Other	Other
Name (printed)		Name (printed)						Other	Other	Other	Other
<u>Evan Feltz</u>		<u>Evan Feltz</u>						Other	Other	Other	Other
Sample Identification		Date Sampled		Sample Matrix		Choose Analyses Needed from the Menu Above and Enter Below		Container Description(s)		Temperature on Receipt	
<u>W000517-110 NPI-2</u>		<u>9-5-17</u>		<u>GW</u>		<u>VOC 8260 full list (EPA SW846-8260) plus from 113</u>		<u>3 VOC's</u>		<u>22 °C</u>	
Comments		Preservation		Check these Applicable		Special Instructions		Field Filtered <input type="checkbox"/>		Lab to Filter <input type="checkbox"/>	
<u>Rec'd at 9/7/17 13:27</u>		<u>4°C Frozen</u>		<u>4°C Frozen</u>		<u>4°C Frozen</u>		<u>4°C Frozen</u>		<u>4°C Frozen</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>		<u>NaOH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>		<u>HNO3</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>		<u>Other</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>		<u>Ascorbic Acid</u>	
<u>Lab Frig 9/6/17 800</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>		<u>Mr. OH</u>	
<u>Lab Frig 9/6/17 800</u>		<u>NaOH</u>									



Technical Report

prepared for:

Leggette Brashears & Graham Shelton Office

4 Research Drive, Suite 204

Shelton CT, 06484

Attention: Tunde Komuves-Sandor

Report Date: 09/14/2017

Client Project ID: Rowe Industries

York Project (SDG) No.: 17I0210

CT Cert. No. PH-0723

New Jersey Cert. No. CT005 and NY037



New York Cert. Nos. 10854 and 12058

PA Cert. No. 68-04440

120 RESEARCH DRIVE
www.YORKLAB.com

STRATFORD, CT 06615
(203) 325-1371

132-02 89th AVENUE
FAX (203) 357-0166

RICHMOND HILL, NY 11418
ClientServices@yorklab.com

Report Date: 09/14/2017
Client Project ID: Rowe Industries
York Project (SDG) No.: 17I0210

Leggette Brashears & Graham Shelton Office
4 Research Drive, Suite 204
Shelton CT, 06484
Attention: Tunde Komuves-Sandor

Purpose and Results

This report contains the analytical data for the sample(s) identified on the attached chain-of-custody received in our laboratory on September 07, 2017 and listed below. The project was identified as your project: **Rowe Industries**.

The analyses were conducted utilizing appropriate EPA, Standard Methods, and ASTM methods as detailed in the data summary tables.

All samples were received in proper condition meeting the customary acceptance requirements for environmental samples except those indicated under the Sample and Analysis Qualifiers section of this report.

All analyses met the method and laboratory standard operating procedure requirements except as indicated by any data flags, the meaning of which are explained in the Sample and Data Qualifiers Relating to This Work Order section of this report and case narrative if applicable.

The results of the analyses, which are all reported on dry weight basis (soils) unless otherwise noted, are detailed in the following pages.

Please contact Client Services at 203.325.1371 with any questions regarding this report.

<u>York Sample ID</u>	<u>Client Sample ID</u>	<u>Matrix</u>	<u>Date Collected</u>	<u>Date Received</u>
17I0210-01	WQ090517:1200 FRW-1	Water	09/05/2017	09/07/2017
17I0210-02	WQ090517:1205 FRW-2	Water	09/05/2017	09/07/2017
17I0210-03	WQ090517:1210 FRW-3	Water	09/05/2017	09/07/2017
17I0210-04	WQ090517:1215 FRW-4	Water	09/05/2017	09/07/2017

General Notes for York Project (SDG) No.: 17I0210

1. The RLs and MDLs (Reporting Limit and Method Detection Limit respectively) reported are adjusted for any dilution necessary due to the levels of target and/or non-target analytes and matrix interference. The RL(REPORTING LIMIT) is based upon the lowest standard utilized for the calibration where applicable.
2. Samples are retained for a period of thirty days after submittal of report, unless other arrangements are made.
3. York's liability for the above data is limited to the dollar value paid to York for the referenced project.
4. This report shall not be reproduced without the written approval of York Analytical Laboratories, Inc.
5. All analyses conducted met method or Laboratory SOP requirements. See the Sample and Data Qualifiers Section for further information.
6. It is noted that no analyses reported herein were subcontracted to another laboratory, unless noted in the report.
7. This report reflects results that relate only to the samples submitted on the attached chain-of-custody form(s) received by York.
8. Analyses conducted at York Analytical Laboratories, Inc. Stratford, CT are indicated by NY Cert. No. 10854; those conducted at York Analytical Laboratories, Inc., Richmond Hill, NY are indicated by NY Cert. No. 12058.

Approved By:



Benjamin Gulizia
Laboratory Director

Date: 09/14/2017





Sample Information

Client Sample ID: WQ090517:1200 FRW-1

York Sample ID: 1710210-01

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
1710210	Rowe Industries	Water	September 5, 2017 12:00 pm	09/07/2017

Volatile Organics, 8260 List - Low Level

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
630-20-6	1,1,1,2-Tetrachloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
71-55-6	1,1,1-Trichloroethane	0.22	J	ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
79-34-5	1,1,2,2-Tetrachloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
76-13-1	1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
79-00-5	1,1,2-Trichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
75-34-3	1,1-Dichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
75-35-4	1,1-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
563-58-6	1,1-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 03:39	AS
87-61-6	1,2,3-Trichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 03:39	AS
96-18-4	1,2,3-Trichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 03:39	AS
120-82-1	1,2,4-Trichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 03:39	AS
95-63-6	1,2,4-Trimethylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
96-12-8	1,2-Dibromo-3-chloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
106-93-4	1,2-Dibromoethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
95-50-1	1,2-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
107-06-2	1,2-Dichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
78-87-5	1,2-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
108-67-8	1,3,5-Trimethylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
541-73-1	1,3-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
142-28-9	1,3-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 03:39	AS
106-46-7	1,4-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
594-20-7	2,2-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 03:39	AS



Sample Information

Client Sample ID: WQ090517:1200 FRW-1

York Sample ID: 17I0210-01

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17I0210

Rowe Industries

Water

September 5, 2017 12:00 pm

09/07/2017

Volatile Organics, 8260 List - Low Level

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
95-49-8	2-Chlorotoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
591-78-6	2-Hexanone	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
106-43-4	4-Chlorotoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
67-64-1	Acetone	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
71-43-2	Benzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
108-86-1	Bromobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 03:39	AS
74-97-5	Bromochloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 03:39	AS
75-27-4	Bromodichloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
75-25-2	Bromoform	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
74-83-9	Bromomethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
56-23-5	Carbon tetrachloride	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
108-90-7	Chlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
75-00-3	Chloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
67-66-3	Chloroform	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
74-87-3	Chloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
156-59-2	cis-1,2-Dichloroethylene	2.9		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
10061-01-5	cis-1,3-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
124-48-1	Dibromochloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
74-95-3	Dibromomethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 03:39	AS
75-71-8	Dichlorodifluoromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 03:39	AS
100-41-4	Ethyl Benzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
87-68-3	Hexachlorobutadiene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 03:39	AS
98-82-8	Isopropylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS



Sample Information

Client Sample ID: WQ090517:1200 FRW-1

York Sample ID: 17I0210-01

<u>York Project (SDG) No.</u> 17I0210	<u>Client Project ID</u> Rowe Industries	<u>Matrix</u> Water	<u>Collection Date/Time</u> September 5, 2017 12:00 pm	<u>Date Received</u> 09/07/2017
--	---	------------------------	---	------------------------------------

Volatile Organics, 8260 List - Low Level

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
1634-04-4	Methyl tert-butyl ether (MTBE)	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
75-09-2	Methylene chloride	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
91-20-3	Naphthalene	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 03:39	AS
104-51-8	n-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
103-65-1	n-Propylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
95-47-6	o-Xylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NELAC-NY10854-Qt	09/12/2017 18:00	09/13/2017 03:39	AS
179601-23-1	p- & m- Xylenes	ND		ug/L	0.50	1.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NELAC-NY10854-Qt	09/12/2017 18:00	09/13/2017 03:39	AS
99-87-6	p-Isopropyltoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
135-98-8	sec-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
100-42-5	Styrene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
98-06-6	tert-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
127-18-4	Tetrachloroethylene	34		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
108-88-3	Toluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
156-60-5	trans-1,2-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
10061-02-6	trans-1,3-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
79-01-6	Trichloroethylene	0.93		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
75-69-4	Trichlorofluoromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
75-01-4	Vinyl Chloride	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
1330-20-7	Xylenes, Total	ND		ug/L	0.60	1.5	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 03:39	AS
	Surrogate Recoveries	Result			Acceptance Range						
17060-07-0	Surrogate: 1,2-Dichloroethane-d4	99.1 %			69-130						
2037-26-5	Surrogate: Toluene-d8	96.2 %			81-117						
460-00-4	Surrogate: p-Bromofluorobenzene	107 %			79-122						



Sample Information

Client Sample ID: WQ090517:1205 FRW-2

York Sample ID: 17I0210-02

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17I0210

Rowe Industries

Water

September 5, 2017 12:05 pm

09/07/2017

Volatile Organics, 8260 List - Low Level

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
630-20-6	1,1,1,2-Tetrachloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
71-55-6	1,1,1-Trichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
79-34-5	1,1,2,2-Tetrachloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
76-13-1	1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
79-00-5	1,1,2-Trichloroethane	0.65		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
75-34-3	1,1-Dichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
75-35-4	1,1-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
563-58-6	1,1-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:06	AS
87-61-6	1,2,3-Trichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:06	AS
96-18-4	1,2,3-Trichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:06	AS
120-82-1	1,2,4-Trichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:06	AS
95-63-6	1,2,4-Trimethylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
96-12-8	1,2-Dibromo-3-chloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
106-93-4	1,2-Dibromoethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
95-50-1	1,2-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
107-06-2	1,2-Dichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
78-87-5	1,2-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
108-67-8	1,3,5-Trimethylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
541-73-1	1,3-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
142-28-9	1,3-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:06	AS
106-46-7	1,4-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
594-20-7	2,2-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:06	AS
95-49-8	2-Chlorotoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS



Sample Information

Client Sample ID: WQ090517:1205 FRW-2

York Sample ID: 17I0210-02

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17I0210

Rowe Industries

Water

September 5, 2017 12:05 pm

09/07/2017

Volatile Organics, 8260 List - Low Level

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
591-78-6	2-Hexanone	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
106-43-4	4-Chlorotoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
67-64-1	Acetone	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
71-43-2	Benzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
108-86-1	Bromobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:06	AS
74-97-5	Bromochloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:06	AS
75-27-4	Bromodichloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
75-25-2	Bromoform	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
74-83-9	Bromomethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
56-23-5	Carbon tetrachloride	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
108-90-7	Chlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
75-00-3	Chloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
67-66-3	Chloroform	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
74-87-3	Chloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
156-59-2	cis-1,2-Dichloroethylene	0.59		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
10061-01-5	cis-1,3-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
124-48-1	Dibromochloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
74-95-3	Dibromomethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:06	AS
75-71-8	Dichlorodifluoromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:06	AS
100-41-4	Ethyl Benzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
87-68-3	Hexachlorobutadiene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:06	AS
98-82-8	Isopropylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
1634-04-4	Methyl tert-butyl ether (MTBE)	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS



Sample Information

Client Sample ID: WQ090517:1205 FRW-2

York Sample ID: 17I0210-02

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17I0210

Rowe Industries

Water

September 5, 2017 12:05 pm

09/07/2017

Volatile Organics, 8260 List - Low Level

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
75-09-2	Methylene chloride	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
91-20-3	Naphthalene	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:06	AS
104-51-8	n-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
103-65-1	n-Propylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
95-47-6	o-Xylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:06	AS
179601-23-1	p- & m- Xylenes	ND		ug/L	0.50	1.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:06	AS
99-87-6	p-Isopropyltoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
135-98-8	sec-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
100-42-5	Styrene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
98-06-6	tert-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
127-18-4	Tetrachloroethylene	33		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
108-88-3	Toluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
156-60-5	trans-1,2-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
10061-02-6	trans-1,3-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
79-01-6	Trichloroethylene	0.85		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
75-69-4	Trichlorofluoromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
75-01-4	Vinyl Chloride	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
1330-20-7	Xylenes, Total	ND		ug/L	0.60	1.5	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:06	AS
	Surrogate Recoveries	Result			Acceptance Range						
17060-07-0	Surrogate: 1,2-Dichloroethane-d4	102 %			69-130						
2037-26-5	Surrogate: Toluene-d8	95.7 %			81-117						
460-00-4	Surrogate: p-Bromofluorobenzene	104 %			79-122						



Sample Information

Client Sample ID: WQ090517:1210 FRW-3

York Sample ID: 17I0210-03

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17I0210

Rowe Industries

Water

September 5, 2017 12:10 pm

09/07/2017

Volatile Organics, 8260 List - Low Level

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
630-20-6	1,1,1,2-Tetrachloroethane	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
71-55-6	1,1,1-Trichloroethane	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
79-34-5	1,1,2,2-Tetrachloroethane	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
76-13-1	1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
79-00-5	1,1,2-Trichloroethane	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
75-34-3	1,1-Dichloroethane	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
75-35-4	1,1-Dichloroethylene	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
563-58-6	1,1-Dichloropropylene	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:59	AS
87-61-6	1,2,3-Trichlorobenzene	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:59	AS
96-18-4	1,2,3-Trichloropropane	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:59	AS
120-82-1	1,2,4-Trichlorobenzene	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:59	AS
95-63-6	1,2,4-Trimethylbenzene	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
96-12-8	1,2-Dibromo-3-chloropropane	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
106-93-4	1,2-Dibromoethane	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
95-50-1	1,2-Dichlorobenzene	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
107-06-2	1,2-Dichloroethane	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
78-87-5	1,2-Dichloropropane	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
108-67-8	1,3,5-Trimethylbenzene	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
541-73-1	1,3-Dichlorobenzene	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
142-28-9	1,3-Dichloropropane	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:59	AS
106-46-7	1,4-Dichlorobenzene	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
594-20-7	2,2-Dichloropropane	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:59	AS
95-49-8	2-Chlorotoluene	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS



Sample Information

Client Sample ID: WQ090517:1210 FRW-3

York Sample ID: 17I0210-03

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17I0210

Rowe Industries

Water

September 5, 2017 12:10 pm

09/07/2017

Volatile Organics, 8260 List - Low Level

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
591-78-6	2-Hexanone	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
106-43-4	4-Chlorotoluene	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
67-64-1	Acetone	ND		ug/L	2.0	4.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
71-43-2	Benzene	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
108-86-1	Bromobenzene	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:59	AS
74-97-5	Bromochloromethane	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:59	AS
75-27-4	Bromodichloromethane	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
75-25-2	Bromoform	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
74-83-9	Bromomethane	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
56-23-5	Carbon tetrachloride	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
108-90-7	Chlorobenzene	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
75-00-3	Chloroethane	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
67-66-3	Chloroform	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
74-87-3	Chloromethane	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
156-59-2	cis-1,2-Dichloroethylene	6.1		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
10061-01-5	cis-1,3-Dichloropropylene	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
124-48-1	Dibromochloromethane	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
74-95-3	Dibromomethane	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:59	AS
75-71-8	Dichlorodifluoromethane	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:59	AS
100-41-4	Ethyl Benzene	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
87-68-3	Hexachlorobutadiene	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:59	AS
98-82-8	Isopropylbenzene	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
1634-04-4	Methyl tert-butyl ether (MTBE)	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS



Sample Information

Client Sample ID: WQ090517:1210 FRW-3

York Sample ID: 17I0210-03

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17I0210

Rowe Industries

Water

September 5, 2017 12:10 pm

09/07/2017

Volatile Organics, 8260 List - Low Level

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
75-09-2	Methylene chloride	ND		ug/L	2.0	4.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
91-20-3	Naphthalene	ND		ug/L	2.0	4.0	2	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:59	AS
104-51-8	n-Butylbenzene	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
103-65-1	n-Propylbenzene	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
95-47-6	o-Xylene	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NELAC-NY10854-Qt	09/12/2017 18:00	09/13/2017 04:59	AS
179601-23-1	p- & m- Xylenes	ND		ug/L	1.0	2.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NELAC-NY10854-Qt	09/12/2017 18:00	09/13/2017 04:59	AS
99-87-6	p-Isopropyltoluene	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
135-98-8	sec-Butylbenzene	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
100-42-5	Styrene	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
98-06-6	tert-Butylbenzene	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
127-18-4	Tetrachloroethylene	15		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
108-88-3	Toluene	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
156-60-5	trans-1,2-Dichloroethylene	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
10061-02-6	trans-1,3-Dichloropropylene	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
79-01-6	Trichloroethylene	1.7		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
75-69-4	Trichlorofluoromethane	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
75-01-4	Vinyl Chloride	ND		ug/L	0.40	1.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
1330-20-7	Xylenes, Total	ND		ug/L	1.2	3.0	2	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:59	AS
	Surrogate Recoveries	Result			Acceptance Range						
17060-07-0	Surrogate: 1,2-Dichloroethane-d4	100 %			69-130						
2037-26-5	Surrogate: Toluene-d8	96.9 %			81-117						
460-00-4	Surrogate: p-Bromofluorobenzene	108 %			79-122						



Sample Information

Client Sample ID: WQ090517:1215 FRW-4

York Sample ID: 17I0210-04

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17I0210

Rowe Industries

Water

September 5, 2017 12:15 pm

09/07/2017

Volatile Organics, 8260 List - Low Level

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
630-20-6	1,1,1,2-Tetrachloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
71-55-6	1,1,1-Trichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
79-34-5	1,1,2,2-Tetrachloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
76-13-1	1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
79-00-5	1,1,2-Trichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
75-34-3	1,1-Dichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
75-35-4	1,1-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
563-58-6	1,1-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:32	AS
87-61-6	1,2,3-Trichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:32	AS
96-18-4	1,2,3-Trichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:32	AS
120-82-1	1,2,4-Trichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:32	AS
95-63-6	1,2,4-Trimethylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
96-12-8	1,2-Dibromo-3-chloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
106-93-4	1,2-Dibromoethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
95-50-1	1,2-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
107-06-2	1,2-Dichloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
78-87-5	1,2-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
108-67-8	1,3,5-Trimethylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
541-73-1	1,3-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
142-28-9	1,3-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:32	AS
106-46-7	1,4-Dichlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
594-20-7	2,2-Dichloropropane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:32	AS
95-49-8	2-Chlorotoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS



Sample Information

Client Sample ID: WQ090517:1215 FRW-4

York Sample ID: 17I0210-04

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17I0210

Rowe Industries

Water

September 5, 2017 12:15 pm

09/07/2017

Volatile Organics, 8260 List - Low Level

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
591-78-6	2-Hexanone	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
106-43-4	4-Chlorotoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
67-64-1	Acetone	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
71-43-2	Benzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
108-86-1	Bromobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:32	AS
74-97-5	Bromochloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:32	AS
75-27-4	Bromodichloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
75-25-2	Bromoform	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
74-83-9	Bromomethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
56-23-5	Carbon tetrachloride	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
108-90-7	Chlorobenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
75-00-3	Chloroethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
67-66-3	Chloroform	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
74-87-3	Chloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
156-59-2	cis-1,2-Dichloroethylene	0.51		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
10061-01-5	cis-1,3-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
124-48-1	Dibromochloromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
74-95-3	Dibromomethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:32	AS
75-71-8	Dichlorodifluoromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:32	AS
100-41-4	Ethyl Benzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
87-68-3	Hexachlorobutadiene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:32	AS
98-82-8	Isopropylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
1634-04-4	Methyl tert-butyl ether (MTBE)	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS



Sample Information

Client Sample ID: WQ090517:1215 FRW-4

York Sample ID: 17I0210-04

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

17I0210

Rowe Industries

Water

September 5, 2017 12:15 pm

09/07/2017

Volatile Organics, 8260 List - Low Level

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 5030B

CAS No.	Parameter	Result	Flag	Units	Reported to LOD/MDL	LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
75-09-2	Methylene chloride	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
91-20-3	Naphthalene	ND		ug/L	1.0	2.0	1	EPA 8260C Certifications: NELAC-NY10854,NJDEP,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:32	AS
104-51-8	n-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
103-65-1	n-Propylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
95-47-6	o-Xylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:32	AS
179601-23-1	p- & m- Xylenes	ND		ug/L	0.50	1.0	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NELAC-NY10854-Que	09/12/2017 18:00	09/13/2017 04:32	AS
99-87-6	p-Isopropyltoluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
135-98-8	sec-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
100-42-5	Styrene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
98-06-6	tert-Butylbenzene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
127-18-4	Tetrachloroethylene	2.7		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
108-88-3	Toluene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
156-60-5	trans-1,2-Dichloroethylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
10061-02-6	trans-1,3-Dichloropropylene	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
79-01-6	Trichloroethylene	0.42	J	ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
75-69-4	Trichlorofluoromethane	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
75-01-4	Vinyl Chloride	ND		ug/L	0.20	0.50	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
1330-20-7	Xylenes, Total	ND		ug/L	0.60	1.5	1	EPA 8260C Certifications: CTDOH,NELAC-NY10854,NJDEP,NELAC-NY10	09/12/2017 18:00	09/13/2017 04:32	AS
	Surrogate Recoveries	Result			Acceptance Range						
17060-07-0	Surrogate: 1,2-Dichloroethane-d4	101 %			69-130						
2037-26-5	Surrogate: Toluene-d8	96.8 %			81-117						
460-00-4	Surrogate: p-Bromofluorobenzene	107 %			79-122						



Analytical Batch Summary

Batch ID: BI70515

Preparation Method: EPA 5030B

Prepared By: AS

YORK Sample ID	Client Sample ID	Preparation Date
17I0210-01	WQ090517:1200 FRW-1	09/12/17
17I0210-02	WQ090517:1205 FRW-2	09/12/17
17I0210-03	WQ090517:1210 FRW-3	09/12/17
17I0210-04	WQ090517:1215 FRW-4	09/12/17
BI70515-BLK1	Blank	09/12/17
BI70515-BS1	LCS	09/12/17
BI70515-BSD1	LCS Dup	09/12/17



Volatile Organic Compounds by GC/MS - Quality Control Data
York Analytical Laboratories, Inc.

Analyte	Result	Reporting Limit	Units	Spike Level	Source* Result	%REC	%REC Limits	Flag	RPD	RPD Limit	Flag
---------	--------	-----------------	-------	-------------	----------------	------	-------------	------	-----	-----------	------

Batch BI70515 - EPA 5030B

Blank (BI70515-BLK1)

Prepared: 09/12/2017 Analyzed: 09/13/2017

1,1,1,2-Tetrachloroethane	ND	0.50	ug/L								
1,1,1-Trichloroethane	ND	0.50	"								
1,1,2,2-Tetrachloroethane	ND	0.50	"								
1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	ND	0.50	"								
1,1,2-Trichloroethane	ND	0.50	"								
1,1-Dichloroethane	ND	0.50	"								
1,1-Dichloroethylene	ND	0.50	"								
1,1-Dichloropropylene	ND	0.50	"								
1,2,3-Trichlorobenzene	ND	0.50	"								
1,2,3-Trichloropropane	ND	0.50	"								
1,2,4-Trichlorobenzene	ND	0.50	"								
1,2,4-Trimethylbenzene	ND	0.50	"								
1,2-Dibromo-3-chloropropane	ND	0.50	"								
1,2-Dibromoethane	ND	0.50	"								
1,2-Dichlorobenzene	ND	0.50	"								
1,2-Dichloroethane	ND	0.50	"								
1,2-Dichloropropane	ND	0.50	"								
1,3,5-Trimethylbenzene	ND	0.50	"								
1,3-Dichlorobenzene	ND	0.50	"								
1,3-Dichloropropane	ND	0.50	"								
1,4-Dichlorobenzene	ND	0.50	"								
2,2-Dichloropropane	ND	0.50	"								
2-Chlorotoluene	ND	0.50	"								
2-Hexanone	ND	0.50	"								
4-Chlorotoluene	ND	0.50	"								
Acetone	ND	2.0	"								
Benzene	ND	0.50	"								
Bromobenzene	ND	0.50	"								
Bromochloromethane	ND	0.50	"								
Bromodichloromethane	ND	0.50	"								
Bromoform	ND	0.50	"								
Bromomethane	ND	0.50	"								
Carbon tetrachloride	ND	0.50	"								
Chlorobenzene	ND	0.50	"								
Chloroethane	ND	0.50	"								
Chloroform	ND	0.50	"								
Chloromethane	ND	0.50	"								
cis-1,2-Dichloroethylene	ND	0.50	"								
cis-1,3-Dichloropropylene	ND	0.50	"								
Dibromochloromethane	ND	0.50	"								
Dibromomethane	ND	0.50	"								
Dichlorodifluoromethane	ND	0.50	"								
Ethyl Benzene	ND	0.50	"								
Hexachlorobutadiene	ND	0.50	"								
Isopropylbenzene	ND	0.50	"								
Methyl tert-butyl ether (MTBE)	ND	0.50	"								
Methylene chloride	ND	2.0	"								
Naphthalene	ND	2.0	"								
n-Butylbenzene	ND	0.50	"								
n-Propylbenzene	ND	0.50	"								



Volatile Organic Compounds by GC/MS - Quality Control Data

York Analytical Laboratories, Inc.

Analyte	Result	Reporting Limit	Units	Spike Level	Source* Result	%REC	%REC Limits	Flag	RPD	RPD Limit	Flag
---------	--------	-----------------	-------	-------------	----------------	------	-------------	------	-----	-----------	------

Batch BI70515 - EPA 5030B

Blank (BI70515-BLK1)

Prepared: 09/12/2017 Analyzed: 09/13/2017

o-Xylene	ND	0.50	ug/L								
p- & m- Xylenes	ND	1.0	"								
p-Isopropyltoluene	ND	0.50	"								
sec-Butylbenzene	ND	0.50	"								
Styrene	ND	0.50	"								
tert-Butylbenzene	ND	0.50	"								
Tetrachloroethylene	ND	0.50	"								
Toluene	ND	0.50	"								
trans-1,2-Dichloroethylene	ND	0.50	"								
trans-1,3-Dichloropropylene	ND	0.50	"								
Trichloroethylene	ND	0.50	"								
Trichlorofluoromethane	ND	0.50	"								
Vinyl Chloride	ND	0.50	"								
Xylenes, Total	ND	1.5	"								
Surrogate: 1,2-Dichloroethane-d4	10.0		"	10.0		100	69-130				
Surrogate: Toluene-d8	9.69		"	10.0		96.9	81-117				
Surrogate: p-Bromofluorobenzene	10.4		"	10.0		104	79-122				

LCS (BI70515-BS1)

Prepared: 09/12/2017 Analyzed: 09/13/2017

1,1,1,2-Tetrachloroethane	9.26		ug/L	10.0		92.6	82-126				
1,1,1-Trichloroethane	10.5		"	10.0		105	78-136				
1,1,2,2-Tetrachloroethane	10.4		"	10.0		104	76-129				
1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	10.4		"	10.0		104	54-165				
1,1,2-Trichloroethane	10.3		"	10.0		103	82-123				
1,1-Dichloroethane	10.8		"	10.0		108	82-129				
1,1-Dichloroethylene	10.6		"	10.0		106	68-138				
1,1-Dichloropropylene	10.5		"	10.0		105	83-133				
1,2,3-Trichlorobenzene	12.1		"	10.0		121	76-136				
1,2,3-Trichloropropane	10.7		"	10.0		107	77-128				
1,2,4-Trichlorobenzene	11.5		"	10.0		115	76-137				
1,2,4-Trimethylbenzene	10.8		"	10.0		108	82-132				
1,2-Dibromo-3-chloropropane	9.94		"	10.0		99.4	45-147				
1,2-Dibromoethane	10.5		"	10.0		105	83-124				
1,2-Dichlorobenzene	10.1		"	10.0		101	79-123				
1,2-Dichloroethane	10.2		"	10.0		102	73-132				
1,2-Dichloropropane	9.99		"	10.0		99.9	78-126				
1,3,5-Trimethylbenzene	11.2		"	10.0		112	80-131				
1,3-Dichlorobenzene	10.1		"	10.0		101	86-122				
1,3-Dichloropropane	10.3		"	10.0		103	81-125				
1,4-Dichlorobenzene	10.2		"	10.0		102	85-124				
2,2-Dichloropropane	9.50		"	10.0		95.0	56-150				
2-Chlorotoluene	10.3		"	10.0		103	79-130				
2-Hexanone	10.1		"	10.0		101	51-146				
4-Chlorotoluene	10.3		"	10.0		103	79-128				
Acetone	4.02		"	10.0		40.2	14-150				
Benzene	10.6		"	10.0		106	85-126				
Bromobenzene	10.9		"	10.0		109	78-129				
Bromochloromethane	10.7		"	10.0		107	77-128				
Bromodichloromethane	10.2		"	10.0		102	79-128				
Bromoform	9.96		"	10.0		99.6	78-133				
Bromomethane	5.96		"	10.0		59.6	43-168				



Volatile Organic Compounds by GC/MS - Quality Control Data

York Analytical Laboratories, Inc.

Analyte	Result	Reporting	Units	Spike Level	Source*	%REC	%REC Limits	Flag	RPD	RPD	
		Limit			Result					Limit	Flag

Batch BI70515 - EPA 5030B

LCS (BI70515-BS1)

Prepared: 09/12/2017 Analyzed: 09/13/2017

Carbon tetrachloride	10.2		ug/L	10.0		102	77-141				
Chlorobenzene	9.97		"	10.0		99.7	88-120				
Chloroethane	10.4		"	10.0		104	65-136				
Chloroform	10.6		"	10.0		106	82-128				
Chloromethane	9.72		"	10.0		97.2	43-155				
cis-1,2-Dichloroethylene	10.4		"	10.0		104	83-129				
cis-1,3-Dichloropropylene	9.78		"	10.0		97.8	80-131				
Dibromochloromethane	9.80		"	10.0		98.0	80-130				
Dibromomethane	10.4		"	10.0		104	72-134				
Dichlorodifluoromethane	10.4		"	10.0		104	44-144				
Ethyl Benzene	10.8		"	10.0		108	80-131				
Hexachlorobutadiene	11.0		"	10.0		110	67-146				
Isopropylbenzene	10.7		"	10.0		107	76-140				
Methyl tert-butyl ether (MTBE)	10.3		"	10.0		103	76-135				
Methylene chloride	10.2		"	10.0		102	55-137				
Naphthalene	9.00		"	10.0		90.0	70-147				
n-Butylbenzene	10.9		"	10.0		109	79-132				
n-Propylbenzene	10.8		"	10.0		108	78-133				
o-Xylene	9.96		"	10.0		99.6	78-130				
p- & m- Xylenes	22.1		"	20.0		110	77-133				
p-Isopropyltoluene	10.8		"	10.0		108	81-136				
sec-Butylbenzene	10.3		"	10.0		103	79-137				
Styrene	10.8		"	10.0		108	67-132				
tert-Butylbenzene	10.2		"	10.0		102	77-138				
Tetrachloroethylene	11.2		"	10.0		112	82-131				
Toluene	10.3		"	10.0		103	80-127				
trans-1,2-Dichloroethylene	10.6		"	10.0		106	80-132				
trans-1,3-Dichloropropylene	9.79		"	10.0		97.9	78-131				
Trichloroethylene	10.2		"	10.0		102	82-128				
Trichlorofluoromethane	10.6		"	10.0		106	67-139				
Vinyl Chloride	10.3		"	10.0		103	58-145				
<i>Surrogate: 1,2-Dichloroethane-d4</i>	9.85		"	10.0		98.5	69-130				
<i>Surrogate: Toluene-d8</i>	9.73		"	10.0		97.3	81-117				
<i>Surrogate: p-Bromofluorobenzene</i>	10.6		"	10.0		106	79-122				



Volatile Organic Compounds by GC/MS - Quality Control Data

York Analytical Laboratories, Inc.

Analyte	Result	Reporting	Spike	Source*	%REC	%REC	Limits	Flag	RPD	
		Limit							Units	Level
Batch BI70515 - EPA 5030B										
LCS Dup (BI70515-BSD1)										
Prepared: 09/12/2017 Analyzed: 09/13/2017										
1,1,1,2-Tetrachloroethane	9.25		ug/L	10.0	92.5	82-126			0.108	30
1,1,1-Trichloroethane	9.91		"	10.0	99.1	78-136			5.69	30
1,1,2,2-Tetrachloroethane	10.1		"	10.0	101	76-129			2.44	30
1,1,2-Trichloro-1,2,2-trifluoroethane (Freon 113)	9.75		"	10.0	97.5	54-165			6.64	30
1,1,2-Trichloroethane	10.1		"	10.0	101	82-123			1.37	30
1,1-Dichloroethane	10.4		"	10.0	104	82-129			4.24	30
1,1-Dichloroethylene	10.0		"	10.0	100	68-138			6.30	30
1,1-Dichloropropylene	9.74		"	10.0	97.4	83-133			7.70	30
1,2,3-Trichlorobenzene	11.7		"	10.0	117	76-136			3.28	30
1,2,3-Trichloropropane	10.2		"	10.0	102	77-128			4.78	30
1,2,4-Trichlorobenzene	11.2		"	10.0	112	76-137			2.38	30
1,2,4-Trimethylbenzene	10.2		"	10.0	102	82-132			6.00	30
1,2-Dibromo-3-chloropropane	9.59		"	10.0	95.9	45-147			3.58	30
1,2-Dibromoethane	10.3		"	10.0	103	83-124			1.44	30
1,2-Dichlorobenzene	9.89		"	10.0	98.9	79-123			2.50	30
1,2-Dichloroethane	9.97		"	10.0	99.7	73-132			2.57	30
1,2-Dichloropropane	9.68		"	10.0	96.8	78-126			3.15	30
1,3,5-Trimethylbenzene	10.4		"	10.0	104	80-131			7.13	30
1,3-Dichlorobenzene	9.50		"	10.0	95.0	86-122			5.83	30
1,3-Dichloropropane	10.2		"	10.0	102	81-125			1.46	30
1,4-Dichlorobenzene	9.70		"	10.0	97.0	85-124			5.12	30
2,2-Dichloropropane	8.87		"	10.0	88.7	56-150			6.86	30
2-Chlorotoluene	9.74		"	10.0	97.4	79-130			5.98	30
2-Hexanone	10.2		"	10.0	102	51-146			1.28	30
4-Chlorotoluene	9.74		"	10.0	97.4	79-128			5.88	30
Acetone	4.39		"	10.0	43.9	14-150			8.80	30
Benzene	10.1		"	10.0	101	85-126			5.51	30
Bromobenzene	10.4		"	10.0	104	78-129			5.54	30
Bromochloromethane	10.1		"	10.0	101	77-128			5.59	30
Bromodichloromethane	10.1		"	10.0	101	79-128			0.984	30
Bromoform	9.63		"	10.0	96.3	78-133			3.37	30
Bromomethane	6.24		"	10.0	62.4	43-168			4.59	30
Carbon tetrachloride	9.62		"	10.0	96.2	77-141			6.05	30
Chlorobenzene	9.61		"	10.0	96.1	88-120			3.68	30
Chloroethane	10.1		"	10.0	101	65-136			2.63	30
Chloroform	10.1		"	10.0	101	82-128			5.41	30
Chloromethane	8.60		"	10.0	86.0	43-155			12.2	30
cis-1,2-Dichloroethylene	9.66		"	10.0	96.6	83-129			6.99	30
cis-1,3-Dichloropropylene	9.66		"	10.0	96.6	80-131			1.23	30
Dibromochloromethane	9.68		"	10.0	96.8	80-130			1.23	30
Dibromomethane	10.1		"	10.0	101	72-134			2.63	30
Dichlorodifluoromethane	9.51		"	10.0	95.1	44-144			8.56	30
Ethyl Benzene	10.4		"	10.0	104	80-131			4.15	30
Hexachlorobutadiene	10.3		"	10.0	103	67-146			7.22	30
Isopropylbenzene	9.93		"	10.0	99.3	76-140			7.18	30
Methyl tert-butyl ether (MTBE)	10.1		"	10.0	101	76-135			2.15	30
Methylene chloride	9.84		"	10.0	98.4	55-137			3.69	30
Naphthalene	8.98		"	10.0	89.8	70-147			0.222	30
n-Butylbenzene	10.3		"	10.0	103	79-132			6.32	30
n-Propylbenzene	10.1		"	10.0	101	78-133			7.19	30
o-Xylene	9.61		"	10.0	96.1	78-130			3.58	30



Volatile Organic Compounds by GC/MS - Quality Control Data
York Analytical Laboratories, Inc.

Analyte	Result	Reporting	Units	Spike	Source*	%REC	%REC	Limits	Flag	RPD	
		Limit			Result					%REC	RPD

Batch BI70515 - EPA 5030B

LCS Dup (BI70515-BSD1)

Prepared: 09/12/2017 Analyzed: 09/13/2017

p- & m- Xylenes	21.2		ug/L	20.0		106	77-133			3.92	30
p-Isopropyltoluene	10.2		"	10.0		102	81-136			5.63	30
sec-Butylbenzene	9.55		"	10.0		95.5	79-137			7.85	30
Styrene	10.5		"	10.0		105	67-132			2.54	30
tert-Butylbenzene	9.70		"	10.0		97.0	77-138			5.51	30
Tetrachloroethylene	10.7		"	10.0		107	82-131			4.67	30
Toluene	10.0		"	10.0		100	80-127			3.15	30
trans-1,2-Dichloroethylene	9.92		"	10.0		99.2	80-132			6.16	30
trans-1,3-Dichloropropylene	9.70		"	10.0		97.0	78-131			0.924	30
Trichloroethylene	9.74		"	10.0		97.4	82-128			4.22	30
Trichlorofluoromethane	9.51		"	10.0		95.1	67-139			11.1	30
Vinyl Chloride	9.43		"	10.0		94.3	58-145			8.43	30
<i>Surrogate: 1,2-Dichloroethane-d4</i>	<i>10.1</i>		<i>"</i>	<i>10.0</i>		<i>101</i>	<i>69-130</i>				
<i>Surrogate: Toluene-d8</i>	<i>9.78</i>		<i>"</i>	<i>10.0</i>		<i>97.8</i>	<i>81-117</i>				
<i>Surrogate: p-Bromofluorobenzene</i>	<i>10.3</i>		<i>"</i>	<i>10.0</i>		<i>103</i>	<i>79-122</i>				



Volatile Analysis Sample Containers

Lab ID	Client Sample ID	Volatile Sample Container
17I0210-01	WQ090517:1200 FRW-1	40mL Clear Vial (pre-pres.) HCl; Cool to 4° C
17I0210-02	WQ090517:1205 FRW-2	40mL Clear Vial (pre-pres.) HCl; Cool to 4° C
17I0210-03	WQ090517:1210 FRW-3	40mL Clear Vial (pre-pres.) HCl; Cool to 4° C
17I0210-04	WQ090517:1215 FRW-4	40mL Clear Vial (pre-pres.) HCl; Cool to 4° C



Sample and Data Qualifiers Relating to This Work Order

J Detected below the Reporting Limit but greater than or equal to the Method Detection Limit (MDL/LOD) or in the case of a TIC, the result is an estimated concentration.

Definitions and Other Explanations

*	Analyte is not certified or the state of the samples origination does not offer certification for the Analyte.
ND	NOT DETECTED - the analyte is not detected at the Reported to level (LOQ/RL or LOD/MDL)
RL	REPORTING LIMIT - the minimum reportable value based upon the lowest point in the analyte calibration curve.
LOQ	LIMIT OF QUANTITATION - the minimum concentration of a target analyte that can be reported within a specified degree of confidence. This is the lowest point in an analyte calibration curve that has been subjected to all steps of the processing/analysis and verified to meet defined criteria. This is based upon NELAC 2009 Standards and applies to all analyses.
LOD	LIMIT OF DETECTION - a verified estimate of the minimum concentration of a substance in a given matrix that an analytical process can reliably detect. This is based upon NELAC 2009 Standards and applies to all analyses conducted under the auspices of EPA SW-846.
MDL	METHOD DETECTION LIMIT - a statistically derived estimate of the minimum amount of a substance an analytical system can reliably detect with a 99% confidence that the concentration of the substance is greater than zero. This is based upon 40 CFR Part 136 Appendix B and applies only to EPA 600 and 200 series methods.
Reported to	This indicates that the data for a particular analysis is reported to either the LOD/MDL, or the LOQ/RL. In cases where the "Reported to" is located above the LOD/MDL, any value between this and the LOQ represents an estimated value which is "J" flagged accordingly. This applies to volatile and semi-volatile target compounds only.
NR	Not reported
RPD	Relative Percent Difference
Wet	The data has been reported on an as-received (wet weight) basis
Low Bias	Low Bias flag indicates that the recovery of the flagged analyte is below the laboratory or regulatory lower control limit. The data user should take note that this analyte may be biased low but should evaluate multiple lines of evidence including the LCS and site-specific MS/MSD data to draw bias conclusions. In cases where no site-specific MS/MSD was requested, only the LCS data can be used to evaluate such bias.
High Bias	High Bias flag indicates that the recovery of the flagged analyte is above the laboratory or regulatory upper control limit. The data user should take note that this analyte may be biased high but should evaluate multiple lines of evidence including the LCS and site-specific MS/MSD data to draw bias conclusions. In cases where no site-specific MS/MSD was requested, only the LCS data can be used to evaluate such bias.
Non-Dir.	Non-dir. flag (Non-Directional Bias) indicates that the Relative Percent Difference (RPD) (a measure of precision) among the MS and MSD data is outside the laboratory or regulatory control limit. This alerts the data user where the MS and MSD are from site-specific samples that the RPD is high due to either non-homogeneous distribution of target analyte between the MS/MSD or indicates poor reproducibility for other reasons.

If EPA SW-846 method 8270 is included herein it is noted that the target compound N-nitrosodiphenylamine (NDPA) decomposes in the gas chromatographic inlet and cannot be separated from diphenylamine (DPA). These results could actually represent 100% DPA, 100% NDPA or some combination of the two. For this reason, York reports the combined result for n-nitrosodiphenylamine and diphenylamine for either of these compounds as a combined concentration as Diphenylamine.

If Total PCBs are detected and the target aroclors reported are "Not detected", the Total PCB value is reported due to the presence of either or both Aroclors 1262 and 1268 which are non-target aroclors for some regulatory lists.

2-chloroethylvinyl ether readily breaks down under acidic conditions. Samples that are acid preserved, including standards will exhibit breakdown. The data user should take note.

Certification for pH is no longer offered by NYDOH ELAP.

Semi-Volatile and Volatile analyses are reported down to the LOD/MDL, with values between the LOD/MDL and the LOQ being "J" flagged as estimated results.

For analyses by EPA SW-846-8270D, the Limit of Quantitation (LOQ) reported for benzidine is based upon the lowest standard used for calibration and is not a verified LOQ due to this compound's propensity for oxidative losses during extraction/concentration procedures and non-reproducible chromatographic performance.

