

LBG ENGINEERING SERVICES, P.C.

PROFESSIONAL ENVIRONMENTAL & CIVIL ENGINEERS



4 RESEARCH DRIVE, SUITE 301
SHELTON, CT 06484
203-929-8555
203-926-9140 (FAX)

May 24, 2010

Mr. Michael Sordi
Town Attorney
Town of Southampton
116 Hampton Road, Town Hall
Southampton, NY 11968

RE: March 2010 Status Report
Groundwater Remedial Action
Rowe Industries Superfund Site
Sag Harbor, New York

Dear Mr. Sordi:

The March 2010 Status Report for the above-referenced site is attached. The enclosed tables, graphs and laboratory reports are provided as required by a condition of the Agreement for 1087 Middle Lane Highway, Noyac, New York and the Effluent Limitations and Monitoring Requirements of the New York State Department of Environmental Conservation.

Should you have any questions regarding the information, please feel free to contact me or Paul Jobmann at (203) 929-8555.

Very truly yours,

LBG ENGINEERING SERVICES, P.C.

Mark M. Goldberg
Mark M. Goldberg, P.E.
Senior Environmental Engineer

MG:cm

Enclosures

H:\Nabsag\2010\FSP&T\Sordi_Mar2010.doc

GRAPH 1
GROUNDWATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

EFFLUENT FLOW DATA
 (March 1, 2010 through March 31, 2010)




TABLE 2

GROUNDWATER REMEDIAL ACTION
 ROWE INDUSTRIES SUPERFUND SITE
 SAG HARBOR, NEW YORK

EFFLUENT WATER QUALITY RESULTS

| Date Sampled ^{2/} SPDES Limits | pH ^{1/} 5.0 to 8.5 | TDS (mg/l) | PCE (ug/l) | 1,1,1-TCA (ug/l) | TCE (ug/l) | 1,1-DCA (ug/l) | 1,1-DCE 1,2-DCE (ug/l) | Xylene (ug/l) | Bromoform (ug/l) | Dibromo- chloromethane (ug/l) | Methylene Chloride (ug/l) | Freon 113 (ug/l) | Acetone (ug/l) | Chloroform (ug/l) | MTBE (ug/l) | Total Iron (mg/l) | Dissolved Iron (mg/l) |
|--|--------------------------------|---------------|---------------|---------------------|---------------|-------------------|---------------------------|------------------|---------------------|-------------------------------------|---------------------------------|---------------------|-------------------|----------------------|----------------|----------------------|-----------------------------|
| 2-Mar-10 | 5.3 | 107 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | 1.05 | 0.111 |
| 9-Mar-10 | 5.4 | 106 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | 33.80 | 0.278 |
| 17-Mar-10 | 5.4 | 104 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | 1.91 | 0.166 |
| 23-Mar-10 | 5.4 | 104 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | 0.92 | 0.112 |
| 30-Mar-10 | 5.4 | 118 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | ND<1.0 | 1.38 | 0.115 |

SPDES: State Pollutant Discharge Elimination System

NM: Not Measured

TDS: Total dissolved solids

PCE: Tetrachloroethylene

TCE: Trichloroethylene

1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene

1,2-DCE: 1,2-Dichloroethene

MTBE: Methyl tert-butyl ether

1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene

1,2-DCE: 1,2-Dichloroethene

MTBE: Methyl tert-butyl ether

ug/l: Micrograms per liter

---: Not established

J: Analyte detected below quantitation limits, value shown is a laboratory estimate.

B: Method blank contamination. The associated method blank contains the target analyte at a reportable level.

Notes:

- Based on the new SPDES criteria from an NYSDEC letter dated on May 11, 2006, the new allowable pH range for the Rowe Site is between 5.0 and 8.5. The pH was measured with a new calibrated electronic pH meter. Influent pH values from recovery wells typically range between 5 and 6.
- "Effluent" samples were collected from sample port labeled NP2-10 unless otherwise noted.

APPENDIX I

Tuesday, March 09, 2010

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555

FAX (203) 926-9140

RE: Rowe

Order No.: 1003022

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 3/3/2010 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The results reported herein relate only to the items tested or to the samples as received by the laboratory. This report may not be reproduced, except in full, without the approval of American Analytical Laboratories, LLC and is not considered complete without a cover page and chain of custody documentation. The limits (LOQ) provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report or the data is qualified. This package has been reviewed by American Analytical Laboratories' QA Department/Laboratory Director to comply with NELAC standards prior to report submittal. This report consists of 28 pages.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe
Lab Order: 1003022

Work Order Sample Summary

| Lab Sample ID | Client Sample ID | Date Collected | Date Received |
|----------------------|-------------------------|-----------------------|----------------------|
| 1003022-01A | WQ3210:1245NP2-6 | 3/2/2010 12:45:00 PM | 3/3/2010 |
| 1003022-01B | WQ3210:1245NP2-6 | 3/2/2010 12:45:00 PM | 3/3/2010 |
| 1003022-01C | WQ3210:1245NP2-6 | 3/2/2010 12:45:00 PM | 3/3/2010 |
| 1003022-02A | WQ3210:1250NP2-7 | 3/2/2010 12:50:00 PM | 3/3/2010 |
| 1003022-02B | WQ3210:1250NP2-7 | 3/2/2010 12:50:00 PM | 3/3/2010 |
| 1003022-02C | WQ3210:1250NP2-7 | 3/2/2010 12:50:00 PM | 3/3/2010 |
| 1003022-03A | WQ3210:1255NP2-10 | 3/2/2010 12:55:00 PM | 3/3/2010 |
| 1003022-03B | WQ3210:1255NP2-10 | 3/2/2010 12:55:00 PM | 3/3/2010 |
| 1003022-03C | WQ3210:1255NP2-10 | 3/2/2010 12:55:00 PM | 3/3/2010 |
| 1003022-03D | WQ3210:1255NP2-10 | 3/2/2010 12:55:00 PM | 3/3/2010 |

Friday, March 19, 2010

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555

FAX (203) 926-9140

RE: Rowe

Order No.: 1003113

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 3/11/2010 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The results reported herein relate only to the items tested or to the samples as received by the laboratory. This report may not be reproduced, except in full, without the approval of American Analytical Laboratories, LLC and is not considered complete without a cover page and chain of custody documentation. The limits (LOQ) provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report or the data is qualified. This package has been reviewed by American Analytical Laboratories' QA Department/Laboratory Director to comply with NELAC standards prior to report submittal. This report consists of 27 pages.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe
Lab Order: 1003113

Work Order Sample Summary

| Lab Sample ID | Client Sample ID | Date Collected | Date Received |
|----------------------|-------------------------|-----------------------|----------------------|
| 1003113-01A | WQ3910:1600NP2-6 | 3/9/2010 4:00:00 PM | 3/11/2010 |
| 1003113-01B | WQ3910:1600NP2-6 | 3/9/2010 4:00:00 PM | 3/11/2010 |
| 1003113-01C | WQ3910:1600NP2-6 | 3/9/2010 4:00:00 PM | 3/11/2010 |
| 1003113-02A | WQ3910:1605NP2-7 | 3/9/2010 4:05:00 PM | 3/11/2010 |
| 1003113-02B | WQ3910:1605NP2-7 | 3/9/2010 4:05:00 PM | 3/11/2010 |
| 1003113-02C | WQ3910:1605NP2-7 | 3/9/2010 4:05:00 PM | 3/11/2010 |
| 1003113-03A | WQ3910:1610NP2-10 | 3/9/2010 4:10:00 PM | 3/11/2010 |
| 1003113-03B | WQ3910:1610NP2-10 | 3/9/2010 4:10:00 PM | 3/11/2010 |
| 1003113-03C | WQ3910:1610NP2-10 | 3/9/2010 4:10:00 PM | 3/11/2010 |
| 1003113-03D | WQ3910:1610NP2-10 | 3/9/2010 4:10:00 PM | 3/11/2010 |

American Analytical Laboratories, LLC.

Sample Receipt Checklist

Client Name **LBG CT**

Date and Time Receive **3/11/2010 12:19:32 PM**

Work Order Number **1003113**

RcptNo: **1**

Received by **CB**

COC_ID:

CoolerID:

Checklist completed by

C. Ban
Signature

3/11/10
Date

Reviewed by

LB
Initials

3/11/10
Date

Matrix:

Carrier name FedEx

- | | | | |
|---|---|---|---|
| Shipping container/cooler in good condition? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | Not Present <input type="checkbox"/> |
| Custody seals intact on shipping container/cooler? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | Not Present <input checked="" type="checkbox"/> |
| Custody seals intact on sample bottles? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | Not Present <input checked="" type="checkbox"/> |
| Chain of custody present? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Chain of custody signed when relinquished and received? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Chain of custody agrees with sample labels? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Samples in proper container/bottle? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Sample containers intact? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Sufficient sample volume for indicated test? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| All samples received within holding time? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Container/Temp Blank temperature in compliance? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | |
| Water - VOA vials have zero headspace? | No VOA vials submitted <input type="checkbox"/> | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> |
| Water - pH acceptable upon receipt? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | N/A <input type="checkbox"/> |

Adjusted? _____ Checked b _____

Any No and/or NA (not applicable) response must be detailed in the comments section be

Client contacted _____ Date contacted: _____ Person contacted _____

Contacted by: _____ Regarding: _____

Comments: Cooler with ice @ 1.7C

Corrective Action _____

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003113
 Project: Rowe
 Lab ID: 1003113-01A

Client Sample ID: WQ3910:1600NP2-6
 Collection Date: 3/9/2010 4:00:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|-----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| 1,1,1,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| 1,1,1-Trichloroethane | 0.94 | 0.3 | 1.0 | J | µg/L | 1 | 3/18/2010 10:47:00 AM |
| 1,1,2,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| 1,1,2-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| 1,1-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| 1,1-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| 1,1-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| 1,2,3-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| 1,2,3-Trichloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| 1,2,4-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| 1,2,4-Trimethylbenzene | U | 0.3 | 1.0 | C | µg/L | 1 | 3/18/2010 10:47:00 AM |
| 1,2-Dibromo-3-chloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| 1,2-Dibromoethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| 1,2-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| 1,2-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| 1,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| 1,3,5-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| 1,3-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| 1,3-dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| 1,4-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| 2,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| 2-Butanone | U | 0.3 | 3.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| 2-Chloroethyl vinyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| 2-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| 2-Hexanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| 4-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| 4-Isopropyltoluene | U | 0.3 | 1.0 | C | µg/L | 1 | 3/18/2010 10:47:00 AM |
| 4-Methyl-2-pentanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| Acetone | U | 0.3 | 2.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| Benzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| Bromobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| Bromochloromethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 19-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003113
 Project: Rowe
 Lab ID: 1003113-01A

Client Sample ID: WQ3910:1600NP2-6
 Collection Date: 3/9/2010 4:00:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|-----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Bromodichloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| Bromoform | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| Bromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| Carbon disulfide | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| Carbon tetrachloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| Chlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| Chloroethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| Chloroform | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| Chloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| cis-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| cis-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| Dibromochloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| Dibromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| Dichlorodifluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| Ethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| Hexachlorobutadiene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| Isopropylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| m,p-Xylene | U | 0.3 | 2.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| Methyl tert-butyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| Methylene chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| Naphthalene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| n-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| n-Propylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| o-Xylene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| sec-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| Styrene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| tert-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| Tetrachloroethene | 2.2 | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| Toluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| trans-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| trans-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| Trichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| Trichlorofluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 19-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 1003113
Project: Rowe
Lab ID: 1003113-01A

Client Sample ID: WQ3910:1600NP2-6
Collection Date: 3/9/2010 4:00:00 PM
Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|-----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Vinyl acetate | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| Vinyl chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 10:47:00 AM |
| Surr: 4-Bromofluorobenzene | 94.6 | 0 | 60-130 | | %REC | 1 | 3/18/2010 10:47:00 AM |
| Surr: Dibromofluoromethane | 110 | 0 | 63-127 | | %REC | 1 | 3/18/2010 10:47:00 AM |
| Surr: Toluene-d8 | 105 | 0 | 61-128 | | %REC | 1 | 3/18/2010 10:47:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 19-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 1003113
Project: Rowe
Lab ID: 1003113-01B

Client Sample ID: WQ3910:1600NP2-6
Collection Date: 3/9/2010 4:00:00 PM
Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|------------|---------------|-------|--------|------|---------|----|-----------------------|
| TOTAL IRON | | | E200.7 | | SW3010A | | Analyst: JP |
| Iron | 17.1 | 0.005 | 0.0200 | | mg/L | 1 | 3/12/2010 10:04:06 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- Qualifiers:
- * Value exceeds Maximum Contaminant Level
 - C Calibration %RSD/%D exceeded for non-CCC analytes
 - H Holding times for preparation or analysis exceeded
 - LOD Limit of Detection
 - ND Not Detected at the Reporting Limit
 - U Indicates the compound was analyzed but not detected.
 - B Analyte detected in the associated Method Blank
 - E Value above quantitation range
 - J Analyte detected below quantitation limits
 - LOQ Limit of Quantitation
 - S Spike Recovery outside accepted recovery limits

American Analytical Laboratories, LLC.

Date: 19-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003113
 Project: Rowe
 Lab ID: 1003113-01C

Client Sample ID: WQ3910:1600NP2-6
 Collection Date: 3/9/2010 4:00:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|----------------|---------------|-------|--------|------|---------|----|-----------------------|
| DISSOLVED IRON | | | E200.7 | | SW3005A | | Analyst: JP |
| Iron | 0.0642 | 0.005 | 0.0200 | | mg/L | 1 | 3/12/2010 10:02:02 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003113
 Project: Rowe
 Lab ID: 1003113-02A

Client Sample ID: WQ3910:1605NP2-7
 Collection Date: 3/9/2010 4:05:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|-----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| 1,1,1,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| 1,1,1-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| 1,1,2,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| 1,1,2-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| 1,1-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| 1,1-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| 1,1-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| 1,2,3-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| 1,2,3-Trichloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| 1,2,4-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| 1,2,4-Trimethylbenzene | U | 0.3 | 1.0 | C | µg/L | 1 | 3/18/2010 11:17:00 AM |
| 1,2-Dibromo-3-chloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| 1,2-Dibromoethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| 1,2-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| 1,2-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| 1,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| 1,3,5-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| 1,3-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| 1,3-dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| 1,4-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| 2,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| 2-Butanone | U | 0.3 | 3.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| 2-Chloroethyl vinyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| 2-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| 2-Hexanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| 4-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| 4-Isopropyltoluene | U | 0.3 | 1.0 | C | µg/L | 1 | 3/18/2010 11:17:00 AM |
| 4-Methyl-2-pentanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| Acetone | U | 0.3 | 2.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| Benzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| Bromobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| Bromochloromethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003113
 Project: Rowe
 Lab ID: 1003113-02A

Client Sample ID: WQ3910:1605NP2-7
 Collection Date: 3/9/2010 4:05:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|-----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Bromodichloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| Bromoform | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| Bromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| Carbon disulfide | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| Carbon tetrachloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| Chlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| Chloroethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| Chloroform | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| Chloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| cis-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| cis-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| Dibromochloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| Dibromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| Dichlorodifluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| Ethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| Hexachlorobutadiene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| Isopropylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| m,p-Xylene | U | 0.3 | 2.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| Methyl tert-butyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| Methylene chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| Naphthalene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| n-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| n-Propylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| o-Xylene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| sec-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| Styrene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| tert-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| Tetrachloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| Toluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| trans-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| trans-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| Trichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| Trichlorofluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 19-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 1003113
Project: Rowe
Lab ID: 1003113-02A

Client Sample ID: WQ3910:1605NP2-7
Collection Date: 3/9/2010 4:05:00 PM
Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|-----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Vinyl acetate | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| Vinyl chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:17:00 AM |
| Surr: 4-Bromofluorobenzene | 94.9 | 0 | 60-130 | | %REC | 1 | 3/18/2010 11:17:00 AM |
| Surr: Dibromofluoromethane | 109 | 0 | 63-127 | | %REC | 1 | 3/18/2010 11:17:00 AM |
| Surr: Toluene-d8 | 109 | 0 | 61-128 | | %REC | 1 | 3/18/2010 11:17:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 19-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003113
 Project: Rowe
 Lab ID: 1003113-02B

Client Sample ID: WQ3910:1605NP2-7
 Collection Date: 3/9/2010 4:05:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|------------|---------------|-------|--------|--------|---------|----|-----------------------|
| TOTAL IRON | | | | E200.7 | SW3010A | | Analyst: JP |
| Iron | 30.0 | 0.005 | 0.0200 | | mg/L | 1 | 3/12/2010 10:22:48 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- Qualifiers:**
- * Value exceeds Maximum Contaminant Level
 - B Analyte detected in the associated Method Blank
 - C Calibration %RSD/%D exceeded for non-CCC analytes
 - E Value above quantitation range
 - H Holding times for preparation or analysis exceeded
 - J Analyte detected below quantitation limits
 - LOD Limit of Detection
 - LOQ Limit of Quantitation
 - ND Not Detected at the Reporting Limit
 - S Spike Recovery outside accepted recovery limits
 - U Indicates the compound was analyzed but not detected.

American Analytical Laboratories, LLC.

Date: 19-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003113
 Project: Rowe
 Lab ID: 1003113-02C

Client Sample ID: WQ3910:1605NP2-7
 Collection Date: 3/9/2010 4:05:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|----------------|---------------|-------|--------|------|---------|----|-----------------------|
| DISSOLVED IRON | | | E200.7 | | SW3005A | | Analyst: JP |
| Iron | 0.253 | 0.005 | 0.0200 | | mg/L | 1 | 3/12/2010 10:06:09 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- Qualifiers:**
- * Value exceeds Maximum Contaminant Level
 - C Calibration %RSD/%D exceeded for non-CCC analytes
 - H Holding times for preparation or analysis exceeded
 - LOD Limit of Detection
 - ND Not Detected at the Reporting Limit
 - U Indicates the compound was analyzed but not detected.
 - B Analyte detected in the associated Method Blank
 - E Value above quantitation range
 - J Analyte detected below quantitation limits
 - LOQ Limit of Quantitation
 - S Spike Recovery outside accepted recovery limits

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003113
 Project: Rowe
 Lab ID: 1003113-03A

Client Sample ID: WQ3910:1610NP2-10
 Collection Date: 3/9/2010 4:10:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|-----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| 1,1,1,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| 1,1,1-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| 1,1,2,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| 1,1,2-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| 1,1-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| 1,1-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| 1,1-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| 1,2,3-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| 1,2,3-Trichloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| 1,2,4-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| 1,2,4-Trimethylbenzene | U | 0.3 | 1.0 | C | µg/L | 1 | 3/18/2010 11:47:00 AM |
| 1,2-Dibromo-3-chloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| 1,2-Dibromoethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| 1,2-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| 1,2-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| 1,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| 1,3,5-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| 1,3-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| 1,3-dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| 1,4-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| 2,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| 2-Butanone | U | 0.3 | 3.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| 2-Chloroethyl vinyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| 2-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| 2-Hexanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| 4-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| 4-Isopropyltoluene | U | 0.3 | 1.0 | C | µg/L | 1 | 3/18/2010 11:47:00 AM |
| 4-Methyl-2-pentanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| Acetone | U | 0.3 | 2.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| Benzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| Bromobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| Bromochloromethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 19-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003113
 Project: Rowe
 Lab ID: 1003113-03A

Client Sample ID: WQ3910:1610NP2-10
 Collection Date: 3/9/2010 4:10:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|-----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Bromodichloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| Bromoform | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| Bromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| Carbon disulfide | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| Carbon tetrachloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| Chlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| Chloroethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| Chloroform | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| Chloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| cis-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| cis-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| Dibromochloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| Dibromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| Dichlorodifluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| Ethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| Hexachlorobutadiene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| Isopropylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| m,p-Xylene | U | 0.3 | 2.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| Methyl tert-butyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| Methylene chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| Naphthalene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| n-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| n-Propylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| o-Xylene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| sec-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| Styrene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| tert-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| Tetrachloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| Toluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| trans-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| trans-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| Trichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| Trichlorofluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 19-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 1003113
Project: Rowe
Lab ID: 1003113-03A

Client Sample ID: WQ3910:1610NP2-10
Collection Date: 3/9/2010 4:10:00 PM
Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|--------------------|----|-----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Vinyl acetate | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| Vinyl chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/18/2010 11:47:00 AM |
| Surr: 4-Bromofluorobenzene | 95.1 | 0 | 60-130 | | %REC | 1 | 3/18/2010 11:47:00 AM |
| Surr: Dibromofluoromethane | 111 | 0 | 63-127 | | %REC | 1 | 3/18/2010 11:47:00 AM |
| Surr: Toluene-d8 | 106 | 0 | 61-128 | | %REC | 1 | 3/18/2010 11:47:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

| | | | |
|-------------------|----------------------------------|--------------------------|---------------------|
| CLIENT: | Leggette Brashears & Graham Inc. | Client Sample ID: | WQ3910:1610NP2-10 |
| Lab Order: | 1003113 | Collection Date: | 3/9/2010 4:10:00 PM |
| Project: | Rowe | Matrix: | LIQUID |
| Lab ID: | 1003113-03B | | |

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|-------------------|---------------|-------|---------------|------|----------------|----|-----------------------|
| TOTAL IRON | | | E200.7 | | SW3010A | | Analyst: JP |
| Iron | 33.8 | 0.005 | 0.0200 | | mg/L | 1 | 3/12/2010 10:26:55 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- | | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 19-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003113
 Project: Rowe
 Lab ID: 1003113-03C

Client Sample ID: WQ3910:1610NP2-10
 Collection Date: 3/9/2010 4:10:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|----------------|---------------|-------|--------|------|---------|----|-----------------------|
| DISSOLVED IRON | | | E200.7 | | SW3005A | | Analyst: JP |
| Iron | 0.278 | 0.005 | 0.0200 | | mg/L | 1 | 3/12/2010 10:24:52 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 19-Mar-10

ELAP ID : 11418

| | | | |
|-------------------|----------------------------------|--------------------------|---------------------|
| CLIENT: | Leggette Brashears & Graham Inc. | Client Sample ID: | WQ3910:1610NP2-10 |
| Lab Order: | 1003113 | Collection Date: | 3/9/2010 4:10:00 PM |
| Project: | Rowe | Matrix: | LIQUID |
| Lab ID: | 1003113-03D | | |

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|--|---------------|-----|------|---------------|-------|----|--------------------|
| TOTAL DISSOLVED SOLIDS | | | | M2540C | | | Analyst: AS |
| Total Dissolved Solids (Residue, Filterable) | 106 | 0 | 1.00 | | mg/L | 1 | 3/12/2010 |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- | | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 19-Mar-10

CLIENT: Leggette Brashears & Graham Inc.
 Work Order: 1003113
 Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

| | | | | | |
|-----------------------------|------------------|----------------------|-------------|--------------------------|---------------|
| Sample ID: V624LCS-031810LW | SampType: LCS | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49504 |
| Client ID: LCSW | Batch ID: R49504 | TestNo: SW8260B | | Analysis Date: 3/18/2010 | SeqNo: 685350 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | Units: µg/L | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---------------------------|--------|-----|-----------|-------------|-------------|------|----------|-----------|-------------|------|----------|------|
| 1,1,1-Trichloroethane | 39 | 1.0 | 50.00 | 0 | | 77.1 | 43 | 148 | | | | |
| 1,1,2,2-Tetrachloroethane | 39 | 1.0 | 50.00 | 0 | | 78.9 | 32 | 148 | | | | |
| 1,1,2-Trichloroethane | 40 | 1.0 | 50.00 | 0 | | 80.0 | 42 | 136 | | | | |
| 1,1-Dichloroethane | 40 | 1.0 | 50.00 | 0 | | 80.1 | 40 | 150 | | | | |
| 1,1-Dichloroethene | 42 | 1.0 | 50.00 | 0 | | 83.5 | 30 | 154 | | | | |
| 1,2-Dichlorobenzene | 37 | 1.0 | 50.00 | 0 | | 73.9 | 40 | 129 | | | | |
| 1,2-Dichloroethane | 40 | 1.0 | 50.00 | 0 | | 79.4 | 36 | 141 | | | | |
| 1,2-Dichloropropane | 40 | 1.0 | 50.00 | 0 | | 79.7 | 44 | 138 | | | | |
| 1,3-Dichlorobenzene | 38 | 1.0 | 50.00 | 0 | | 75.2 | 40 | 133 | | | | |
| 1,4-Dichlorobenzene | 38 | 1.0 | 50.00 | 0 | | 75.1 | 40 | 135 | | | | |
| 2-Chloroethyl vinyl ether | 37 | 1.0 | 50.00 | 0 | | 73.7 | 21 | 139 | | | | |
| Benzene | 36 | 1.0 | 50.00 | 0 | | 72.1 | 45 | 144 | | | | |
| Bromodichloromethane | 41 | 1.0 | 50.00 | 0 | | 82.1 | 35 | 136 | | | | |
| Bromoform | 36 | 1.0 | 50.00 | 0 | | 72.1 | 28 | 138 | | | | |
| Bromomethane | 51 | 1.0 | 50.00 | 0 | | 101 | 26 | 148 | | | | |
| Carbon tetrachloride | 38 | 1.0 | 50.00 | 0 | | 76.5 | 45 | 141 | | | | |
| Chlorobenzene | 38 | 1.0 | 50.00 | 0 | | 75.4 | 41 | 142 | | | | |
| Chloroethane | 55 | 1.0 | 50.00 | 0 | | 110 | 36 | 143 | | | | |
| Chloroform | 40 | 1.0 | 50.00 | 0 | | 80.0 | 42 | 137 | | | | |
| Chloromethane | 55 | 1.0 | 50.00 | 0 | | 110 | 35 | 151 | | | | |
| cis-1,3-Dichloropropene | 36 | 1.0 | 50.00 | 0 | | 72.6 | 42 | 130 | | | | |
| Dibromochloromethane | 34 | 1.0 | 50.00 | 0 | | 67.2 | 21 | 134 | | | | |
| Ethylbenzene | 40 | 1.0 | 50.00 | 0 | | 79.6 | 45 | 146 | | | | |
| Tetrachloroethene | 35 | 1.0 | 50.00 | 0 | | 71.0 | 45 | 136 | | | | |
| Toluene | 38 | 1.0 | 50.00 | 0 | | 77.0 | 43 | 134 | | | | |
| trans-1,2-Dichloroethene | 36 | 1.0 | 50.00 | 0 | | 71.7 | 42 | 135 | | | | |
| trans-1,3-Dichloropropene | 35 | 1.0 | 50.00 | 0 | | 69.8 | 37 | 133 | | | | |
| Trichloroethene | 36 | 1.0 | 50.00 | 0 | | 72.9 | 43 | 140 | | | | |
| Trichlorofluoromethane | 54 | 1.0 | 50.00 | 0 | | 107 | 50 | 148 | | | | |
| Vinyl chloride | 57 | 1.0 | 50.00 | 0 | | 113 | 35 | 142 | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analysis
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

CLIENT: Leggette Brashears & Graham Inc.
 Work Order: 1003113
 Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

| | | | | | | | | | | | |
|-----------------------------|------------------|----------------------|-------------|--------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Sample ID: V624LCS-031810LW | SampType: LCS | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49504 | | | | | | |
| Client ID: LCSW | Batch ID: R49504 | TestNo: SW8260B | | Analysis Date: 3/18/2010 | SeqNo: 685350 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|----------------------------|----|--|-------|--|------|----|-----|--|--|--|--|
| Surr: 4-Bromofluorobenzene | 48 | | 50.00 | | 95.8 | 60 | 130 | | | | |
| Surr: Dibromofluoromethane | 50 | | 50.00 | | 101 | 63 | 127 | | | | |
| Surr: Toluene-d8 | 50 | | 50.00 | | 101 | 61 | 128 | | | | |

| | | | | | | | | | | | |
|--------------------------|------------------|----------------------|-------------|--------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Sample ID: VBLK-031810LW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49504 | | | | | | |
| Client ID: PBW | Batch ID: R49504 | TestNo: SW8260B | | Analysis Date: 3/18/2010 | SeqNo: 685351 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|---------------------------------------|---|-----|--|--|--|--|--|--|--|--|--|
| 1,1,1,2-Tetrachloroethane | U | 1.0 | | | | | | | | | |
| 1,1,1-Trichloroethane | U | 1.0 | | | | | | | | | |
| 1,1,2,2-Tetrachloroethane | U | 1.0 | | | | | | | | | |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 1.0 | | | | | | | | | |
| 1,1,2-Trichloroethane | U | 1.0 | | | | | | | | | |
| 1,1-Dichloroethane | U | 1.0 | | | | | | | | | |
| 1,1-Dichloroethene | U | 1.0 | | | | | | | | | |
| 1,1-Dichloropropene | U | 1.0 | | | | | | | | | |
| 1,2,3-Trichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2,3-Trichloropropane | U | 1.0 | | | | | | | | | |
| 1,2,4-Trichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2,4-Trimethylbenzene | U | 1.0 | | | | | | | | | |
| 1,2-Dibromo-3-chloropropane | U | 1.0 | | | | | | | | | |
| 1,2-Dibromoethane | U | 1.0 | | | | | | | | | |
| 1,2-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2-Dichloroethane | U | 1.0 | | | | | | | | | |
| 1,2-Dichloropropane | U | 1.0 | | | | | | | | | |
| 1,3,5-Trimethylbenzene | U | 1.0 | | | | | | | | | |
| 1,3-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,3-dichloropropane | U | 1.0 | | | | | | | | | |
| 1,4-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 2,2-Dichloropropane | U | 1.0 | | | | | | | | | |
| 2-Butanone | U | 3.0 | | | | | | | | | |

C

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analysis
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

CLIENT: Leggette Brashears & Graham Inc.
 Work Order: 1003113
 Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

| Sample ID: VBLK-031810LW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49504 | | | | | | |
|--------------------------|------------------|----------------------|-------------|--------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Client ID: PBW | Batch ID: R49504 | TestNo: SW8260B | | Analysis Date: 3/18/2010 | SeqNo: 685351 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|---------------------------|---|-----|--|--|--|--|--|--|--|--|---|
| 2-Chloroethyl vinyl ether | U | 1.0 | | | | | | | | | |
| 2-Chlorotoluene | U | 1.0 | | | | | | | | | |
| 2-Hexanone | U | 2.0 | | | | | | | | | |
| 4-Chlorotoluene | U | 1.0 | | | | | | | | | |
| 4-Isopropyltoluene | U | 1.0 | | | | | | | | | |
| 4-Methyl-2-pentanone | U | 2.0 | | | | | | | | | C |
| Acetone | U | 2.0 | | | | | | | | | |
| Benzene | U | 1.0 | | | | | | | | | |
| Bromobenzene | U | 1.0 | | | | | | | | | |
| Bromochloromethane | U | 1.0 | | | | | | | | | |
| Bromodichloromethane | U | 1.0 | | | | | | | | | |
| Bromoform | U | 1.0 | | | | | | | | | |
| Bromomethane | U | 1.0 | | | | | | | | | |
| Carbon disulfide | U | 1.0 | | | | | | | | | |
| Carbon tetrachloride | U | 1.0 | | | | | | | | | |
| Chlorobenzene | U | 1.0 | | | | | | | | | |
| Chloroethane | U | 1.0 | | | | | | | | | |
| Chloroform | U | 1.0 | | | | | | | | | |
| Chloromethane | U | 1.0 | | | | | | | | | |
| cis-1,2-Dichloroethene | U | 1.0 | | | | | | | | | |
| cis-1,3-Dichloropropene | U | 1.0 | | | | | | | | | |
| Dibromochloromethane | U | 1.0 | | | | | | | | | |
| Dibromomethane | U | 1.0 | | | | | | | | | |
| Dichlorodifluoromethane | U | 1.0 | | | | | | | | | |
| Ethylbenzene | U | 1.0 | | | | | | | | | |
| Hexachlorobutadiene | U | 1.0 | | | | | | | | | |
| Isopropylbenzene | U | 1.0 | | | | | | | | | |
| m,p-Xylene | U | 2.0 | | | | | | | | | |
| Methyl tert-butyl ether | U | 1.0 | | | | | | | | | |
| Methylene chloride | U | 1.0 | | | | | | | | | |
| Naphthalene | U | 1.0 | | | | | | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analyte
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 1003113
Project: Rowe

TestCode: 8260MTBE113_W

| | | | |
|--------------------------|------------------|--------------------------|---------------|
| Sample ID: VBLK-031810LW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L |
| Client ID: PBW | Batch ID: R49504 | Prep Date: | RunNo: 49504 |
| | | Analysis Date: 3/18/2010 | SeqNo: 685351 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | Units: µg/L | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|----------------------------|--------|-----|-----------|-------------|-------------|------|----------|-----------|-------------|------|----------|------|
| n-Butylbenzene | U | 1.0 | | | | | | | | | | |
| n-Propylbenzene | U | 1.0 | | | | | | | | | | |
| o-Xylene | U | 1.0 | | | | | | | | | | |
| sec-Butylbenzene | U | 1.0 | | | | | | | | | | |
| Styrene | U | 1.0 | | | | | | | | | | |
| tert-Butylbenzene | U | 1.0 | | | | | | | | | | |
| Tetrachloroethene | U | 1.0 | | | | | | | | | | |
| Toluene | U | 1.0 | | | | | | | | | | |
| trans-1,2-Dichloroethene | U | 1.0 | | | | | | | | | | |
| trans-1,3-Dichloropropene | U | 1.0 | | | | | | | | | | |
| Trichloroethene | U | 1.0 | | | | | | | | | | |
| Trichlorofluoromethane | U | 1.0 | | | | | | | | | | |
| Vinyl acetate | U | 1.0 | | | | | | | | | | |
| Vinyl chloride | U | 1.0 | | | | | | | | | | |
| Surr: 4-Bromofluorobenzene | 48 | | 50.00 | | | 95.6 | 60 | | 130 | | | |
| Surr: Dibromofluoromethane | 54 | | 50.00 | | | 108 | 63 | | 127 | | | |
| Surr: Toluene-d8 | 52 | | 50.00 | | | 105 | 61 | | 128 | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 1003113
Project: Rowe

TestCode: FE_D

| | | | | | | | | | | |
|------------------------|-----------------|----------------|-------------|--------------------------|---------------|-----------|-------------|------|----------|------|
| Sample ID: PBW-031110A | SampType: MBLK | TestCode: FE_D | Units: mg/L | Prep Date: 3/11/2010 | RunNo: 49438 | | | | | |
| Client ID: PBW | Batch ID: 28388 | TestNo: E200.7 | SW3010A | Analysis Date: 3/12/2010 | SeqNo: 684451 | | | | | |
| Analyte | Result | PQL | SPK value | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| Iron | U | 0.0200 | | | | | | | | |

| | | | | | | | | | | |
|-------------------------|-----------------|----------------|-------------|--------------------------|---------------|-----------|-------------|------|----------|------|
| Sample ID: LCSW-031110A | SampType: LCS | TestCode: FE_D | Units: mg/L | Prep Date: 3/11/2010 | RunNo: 49438 | | | | | |
| Client ID: LCSW | Batch ID: 28388 | TestNo: E200.7 | SW3010A | Analysis Date: 3/12/2010 | SeqNo: 684452 | | | | | |
| Analyte | Result | PQL | SPK value | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| Iron | 1.91 | 0.0200 | 2.000 | 95.5 | 68 | 122 | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 1003113
Project: Rowe

TestCode: FE_T

| | | | | | | | | | | |
|------------------------|-----------------|----------------|-------------|--------------------------|---------------|-----------|-------------|------|----------|------|
| Sample ID: PBW-031110A | SampType: MBLK | TestCode: FE_T | Units: mg/L | Prep Date: 3/11/2010 | RunNo: 49438 | | | | | |
| Client ID: PBW | Batch ID: 28388 | TestNo: E200.7 | SW3010A | Analysis Date: 3/12/2010 | SeqNo: 684471 | | | | | |
| Analyte | Result | PQL | SPK value | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| Iron | U | 0.0200 | | | | | | | | |

| | | | | | | | | | | |
|-------------------------|-----------------|----------------|-------------|--------------------------|---------------|-----------|-------------|------|----------|------|
| Sample ID: LCSW-031110A | SampType: LCS | TestCode: FE_T | Units: mg/L | Prep Date: 3/11/2010 | RunNo: 49438 | | | | | |
| Client ID: LCSW | Batch ID: 28388 | TestNo: E200.7 | SW3010A | Analysis Date: 3/12/2010 | SeqNo: 684472 | | | | | |
| Analyte | Result | PQL | SPK value | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| Iron | 1.91 | 0.0200 | 2.000 | 95.5 | 68 | 122 | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 1003113
Project: Rowe

TestCode: TDS_W

| | | | | | |
|----------------------|------------------|-----------------|-------------|--------------------------|---------------|
| Sample ID: MB-R49480 | SampType: MBLK | TestCode: TDS_W | Units: mg/L | Prep Date: | RunNo: 49480 |
| Client ID: PBW | Batch ID: R49480 | TestNo: M2540C | | Analysis Date: 3/12/2010 | SeqNo: 684931 |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC |
| | | | | RPD Ref Val | %RPD |
| | | | | HighLimit | RPDLimit |
| | | | | LowLimit | Qual |

Total Dissolved Solids (Residue, Filtera) U 1.00

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

American Analytical Laboratories, LLC.

Sample Receipt Checklist

Client Name **LBG CT**

Date and Time Receive **3/3/2010 10:01:25 AM**

Work Order Numbe **1003022**

RcptNo: **1**

Received by **CB**

COC_ID:

CoolerID:

Checklist completed by CPan 3/3/10
Signature Date

Reviewed by JA B 3/3/10
Initials Date

Matrix: Carrier name FedEx

- Shipping container/cooler in good condition? Yes No Not Presen
- Custody seals intact on shipping container/cooler? Yes No Not Presen
- Custody seals intact on sample bottles? Yes No Not Presen
- Chain of custody present? Yes No
- Chain of custody signed when relinquished and received? Yes No
- Chain of custody agrees with sample labels? Yes No
- Samples in proper container/bottle? Yes No
- Sample containers intact? Yes No
- Sufficient sample volume for indicated test? Yes No
- All samples received within holding time? Yes No
- Container/Temp Blank temperature in compliance? Yes No
- Water - VOA vials have zero headspace? No VOA vials submitted Yes No
- Water - pH acceptable upon receipt? Yes No N/A

Adjusted? _____ Checked b _____

Any No and/or NA (not applicable) response must be detailed in the comments section be

Client contacted _____ Date contacted: _____ Person contacted _____

Contacted by: _____ Regarding: _____

Comments: Cooler with ice @ 1.1C

Corrective Action _____

American Analytical Laboratories, LLC.

Date: 09-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003022
 Project: Rowe
 Lab ID: 1003022-01A

Client Sample ID: WQ3210:1245NP2-6
 Collection Date: 3/2/2010 12:45:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|---------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| 1,1,1,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| 1,1,1-Trichloroethane | 1.5 | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| 1,1,2,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| 1,1,2-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| 1,1-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| 1,1-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| 1,1-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| 1,2,3-Trichlorobenzene | U | 0.3 | 1.0 | C | µg/L | 1 | 3/3/2010 5:28:00 PM |
| 1,2,3-Trichloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| 1,2,4-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| 1,2,4-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| 1,2-Dibromo-3-chloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| 1,2-Dibromoethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| 1,2-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| 1,2-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| 1,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| 1,3,5-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| 1,3-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| 1,3-dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| 1,4-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| 2,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| 2-Butanone | U | 0.3 | 3.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| 2-Chloroethyl vinyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| 2-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| 2-Hexanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| 4-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| 4-Isopropyltoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| 4-Methyl-2-pentanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| Acetone | U | 0.3 | 2.0 | C | µg/L | 1 | 3/3/2010 5:28:00 PM |
| Benzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| Bromobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| Bromochloromethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 09-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003022
 Project: Rowe
 Lab ID: 1003022-01A

Client Sample ID: WQ3210:1245NP2-6
 Collection Date: 3/2/2010 12:45:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------|----|---------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | | | Analyst: LA |
| Bromodichloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| Bromoform | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| Bromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| Carbon disulfide | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| Carbon tetrachloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| Chlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| Chloroethane | U | 0.4 | 1.0 | C | µg/L | 1 | 3/3/2010 5:28:00 PM |
| Chloroform | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| Chloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| cis-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| cis-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| Dibromochloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| Dibromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| Dichlorodifluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| Ethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| Hexachlorobutadiene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| Isopropylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| m,p-Xylene | U | 0.3 | 2.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| Methyl tert-butyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| Methylene chloride | U | 0.3 | 1.0 | C | µg/L | 1 | 3/3/2010 5:28:00 PM |
| Naphthalene | U | 0.3 | 1.0 | C | µg/L | 1 | 3/3/2010 5:28:00 PM |
| n-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| n-Propylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| o-Xylene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| sec-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| Styrene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| tert-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| Tetrachloroethene | 5.1 | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| Toluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| trans-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| trans-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| Trichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| Trichlorofluoromethane | U | 0.3 | 1.0 | C | µg/L | 1 | 3/3/2010 5:28:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 09-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003022
 Project: Rowe
 Lab ID: 1003022-01A

Client Sample ID: WQ3210:1245NP2-6
 Collection Date: 3/2/2010 12:45:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|---------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Vinyl acetate | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| Vinyl chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 5:28:00 PM |
| Surr: 4-Bromofluorobenzene | 96.5 | 0 | 60-130 | | %REC | 1 | 3/3/2010 5:28:00 PM |
| Surr: Dibromofluoromethane | 113 | 0 | 63-127 | | %REC | 1 | 3/3/2010 5:28:00 PM |
| Surr: Toluene-d8 | 99.9 | 0 | 61-128 | | %REC | 1 | 3/3/2010 5:28:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

| | | | |
|-------------------|----------------------------------|--------------------------|----------------------|
| CLIENT: | Leggette Brashears & Graham Inc. | Client Sample ID: | WQ3210:1245NP2-6 |
| Lab Order: | 1003022 | Collection Date: | 3/2/2010 12:45:00 PM |
| Project: | Rowe | Matrix: | LIQUID |
| Lab ID: | 1003022-01B | | |

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|-------------------|---------------|-------|--------|---------------|----------------|----|----------------------|
| TOTAL IRON | | | | E200.7 | SW3010A | | Analyst: JP |
| Iron | 1.54 | 0.005 | 0.0200 | | mg/L | 1 | 3/3/2010 11:41:28 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- Qualifiers:**
- * Value exceeds Maximum Contaminant Level
 - B Analyte detected in the associated Method Blank
 - C Calibration %RSD/%D exceeded for non-CCC analytes
 - E Value above quantitation range
 - H Holding times for preparation or analysis exceeded
 - J Analyte detected below quantitation limits
 - LOD Limit of Detection
 - LOQ Limit of Quantitation
 - ND Not Detected at the Reporting Limit
 - S Spike Recovery outside accepted recovery limits
 - U Indicates the compound was analyzed but not detected.

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003022
 Project: Rowe
 Lab ID: 1003022-01C

Client Sample ID: WQ3210:1245NP2-6
 Collection Date: 3/2/2010 12:45:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|----------------|---------------|-------|--------|------|---------|----|----------------------|
| DISSOLVED IRON | | | E200.7 | | SW3005A | | Analyst: JP |
| Iron | 0.166 | 0.005 | 0.0200 | | mg/L | 1 | 3/3/2010 11:39:25 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- Qualifiers:**
- * Value exceeds Maximum Contaminant Level
 - C Calibration %RSD/%D exceeded for non-CCC analytes
 - H Holding times for preparation or analysis exceeded
 - LOD Limit of Detection
 - ND Not Detected at the Reporting Limit
 - U Indicates the compound was analyzed but not detected.
 - B Analyte detected in the associated Method Blank
 - E Value above quantitation range
 - J Analyte detected below quantitation limits
 - LOQ Limit of Quantitation
 - S Spike Recovery outside accepted recovery limits

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003022
 Project: Rowe
 Lab ID: 1003022-02A

Client Sample ID: WQ3210:1250NP2-7
 Collection Date: 3/2/2010 12:50:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|---------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| 1,1,1,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| 1,1,1-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| 1,1,2,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| 1,1,2-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| 1,1-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| 1,1-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| 1,1-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| 1,2,3-Trichlorobenzene | U | 0.3 | 1.0 | C | µg/L | 1 | 3/3/2010 6:00:00 PM |
| 1,2,3-Trichloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| 1,2,4-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| 1,2,4-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| 1,2-Dibromo-3-chloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| 1,2-Dibromoethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| 1,2-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| 1,2-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| 1,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| 1,3,5-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| 1,3-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| 1,3-dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| 1,4-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| 2,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| 2-Butanone | U | 0.3 | 3.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| 2-Chloroethyl vinyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| 2-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| 2-Hexanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| 4-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| 4-Isopropyltoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| 4-Methyl-2-pentanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| Acetone | U | 0.3 | 2.0 | C | µg/L | 1 | 3/3/2010 6:00:00 PM |
| Benzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| Bromobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| Bromochloromethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003022
 Project: Rowe
 Lab ID: 1003022-02A

Client Sample ID: WQ3210:1250NP2-7
 Collection Date: 3/2/2010 12:50:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------|----|---------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | | | | | |
| | | | SW8260B | | | | Analyst: LA |
| Bromodichloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| Bromoform | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| Bromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| Carbon disulfide | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| Carbon tetrachloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| Chlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| Chloroethane | U | 0.4 | 1.0 | C | µg/L | 1 | 3/3/2010 6:00:00 PM |
| Chloroform | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| Chloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| cis-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| cis-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| Dibromochloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| Dibromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| Dichlorodifluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| Ethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| Hexachlorobutadiene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| Isopropylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| m,p-Xylene | U | 0.3 | 2.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| Methyl tert-butyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| Methylene chloride | U | 0.3 | 1.0 | C | µg/L | 1 | 3/3/2010 6:00:00 PM |
| Naphthalene | U | 0.3 | 1.0 | C | µg/L | 1 | 3/3/2010 6:00:00 PM |
| n-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| n-Propylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| o-Xylene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| sec-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| Styrene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| tert-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| Tetrachloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| Toluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| trans-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| trans-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| Trichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| Trichlorofluoromethane | U | 0.3 | 1.0 | C | µg/L | 1 | 3/3/2010 6:00:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 09-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003022
 Project: Rowe
 Lab ID: 1003022-02A

Client Sample ID: WQ3210:1250NP2-7
 Collection Date: 3/2/2010 12:50:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|---------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Vinyl acetate | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| Vinyl chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:00:00 PM |
| Surr: 4-Bromofluorobenzene | 98.0 | 0 | 60-130 | | %REC | 1 | 3/3/2010 6:00:00 PM |
| Surr: Dibromofluoromethane | 108 | 0 | 63-127 | | %REC | 1 | 3/3/2010 6:00:00 PM |
| Surr: Toluene-d8 | 99.1 | 0 | 61-128 | | %REC | 1 | 3/3/2010 6:00:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 09-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003022
 Project: Rowe
 Lab ID: 1003022-02B

Client Sample ID: WQ3210:1250NP2-7
 Collection Date: 3/2/2010 12:50:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|------------|---------------|-------|--------|------|---------|----|----------------------|
| TOTAL IRON | | | E200.7 | | SW3010A | | Analyst: JP |
| Iron | 1.34 | 0.005 | 0.0200 | | mg/L | 1 | 3/3/2010 11:45:53 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

| | | | |
|-------------------|----------------------------------|--------------------------|----------------------|
| CLIENT: | Leggette Brashears & Graham Inc. | Client Sample ID: | WQ3210:1250NP2-7 |
| Lab Order: | 1003022 | Collection Date: | 3/2/2010 12:50:00 PM |
| Project: | Rowe | Matrix: | LIQUID |
| Lab ID: | 1003022-02C | | |

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|-----------------------|---------------|-------|---------------|------|----------------|----|----------------------|
| DISSOLVED IRON | | | E200.7 | | SW3005A | | Analyst: JP |
| Iron | 0.116 | 0.005 | 0.0200 | | mg/L | 1 | 3/3/2010 11:43:50 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003022
 Project: Rowe
 Lab ID: 1003022-03A

Client Sample ID: WQ3210:1255NP2-10
 Collection Date: 3/2/2010 12:55:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|---------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| 1,1,1,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| 1,1,1-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| 1,1,2,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| 1,1,2-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| 1,1-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| 1,1-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| 1,1-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| 1,2,3-Trichlorobenzene | U | 0.3 | 1.0 | C | µg/L | 1 | 3/3/2010 6:31:00 PM |
| 1,2,3-Trichloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| 1,2,4-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| 1,2,4-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| 1,2-Dibromo-3-chloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| 1,2-Dibromoethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| 1,2-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| 1,2-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| 1,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| 1,3,5-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| 1,3-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| 1,3-dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| 1,4-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| 2,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| 2-Butanone | U | 0.3 | 3.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| 2-Chloroethyl vinyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| 2-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| 2-Hexanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| 4-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| 4-Isopropyltoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| 4-Methyl-2-pentanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| Acetone | U | 0.3 | 2.0 | C | µg/L | 1 | 3/3/2010 6:31:00 PM |
| Benzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| Bromobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| Bromochloromethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735

Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003022
 Project: Rowe
 Lab ID: 1003022-03A

Client Sample ID: WQ3210:1255NP2-10
 Collection Date: 3/2/2010 12:55:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|--------------------|----|---------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Bromodichloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| Bromoform | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| Bromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| Carbon disulfide | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| Carbon tetrachloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| Chlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| Chloroethane | U | 0.4 | 1.0 | C | µg/L | 1 | 3/3/2010 6:31:00 PM |
| Chloroform | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| Chloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| cis-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| cis-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| Dibromochloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| Dibromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| Dichlorodifluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| Ethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| Hexachlorobutadiene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| Isopropylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| m,p-Xylene | U | 0.3 | 2.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| Methyl tert-butyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| Methylene chloride | U | 0.3 | 1.0 | C | µg/L | 1 | 3/3/2010 6:31:00 PM |
| Naphthalene | U | 0.3 | 1.0 | C | µg/L | 1 | 3/3/2010 6:31:00 PM |
| n-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| n-Propylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| o-Xylene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| sec-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| Styrene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| tert-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| Tetrachloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| Toluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| trans-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| trans-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| Trichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| Trichlorofluoromethane | U | 0.3 | 1.0 | C | µg/L | 1 | 3/3/2010 6:31:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003022
 Project: Rowe
 Lab ID: 1003022-03A

Client Sample ID: WQ3210:1255NP2-10
 Collection Date: 3/2/2010 12:55:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------|----|---------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | | | Analyst: LA |
| Vinyl acetate | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| Vinyl chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/3/2010 6:31:00 PM |
| Surr: 4-Bromofluorobenzene | 97.0 | 0 | 60-130 | | %REC | 1 | 3/3/2010 6:31:00 PM |
| Surr: Dibromofluoromethane | 109 | 0 | 63-127 | | %REC | 1 | 3/3/2010 6:31:00 PM |
| Surr: Toluene-d8 | 98.4 | 0 | 61-128 | | %REC | 1 | 3/3/2010 6:31:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | | | |
|--------------------|-----|---|-----|---|
| Qualifiers: | * | Value exceeds Maximum Contaminant Level | B | Analyte detected in the associated Method Blank |
| | C | Calibration %RSD/%D exceeded for non-CCC analytes | E | Value above quantitation range |
| | H | Holding times for preparation or analysis exceeded | J | Analyte detected below quantitation limits |
| | LOD | Limit of Detection | LOQ | Limit of Quantitation |
| | ND | Not Detected at the Reporting Limit | S | Spike Recovery outside accepted recovery limits |
| | U | Indicates the compound was analyzed but not detected. | | |

American Analytical Laboratories, LLC.

Date: 09-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003022
 Project: Rowe
 Lab ID: 1003022-03B

Client Sample ID: WQ3210:1255NP2-10
 Collection Date: 3/2/2010 12:55:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|------------|---------------|-------|--------|------|---------|----|----------------------|
| TOTAL IRON | | | E200.7 | | SW3010A | | Analyst: JP |
| Iron | 1.05 | 0.005 | 0.0200 | | mg/L | 1 | 3/3/2010 11:50:17 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 09-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 1003022
Project: Rowe
Lab ID: 1003022-03C

Client Sample ID: WQ3210:1255NP2-10
Collection Date: 3/2/2010 12:55:00 PM
Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|----------------|---------------|-------|--------|--------|---------|----|----------------------|
| DISSOLVED IRON | | | | E200.7 | SW3005A | | Analyst: JP |
| Iron | 0.111 | 0.005 | 0.0200 | | mg/L | 1 | 3/3/2010 11:48:14 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- Qualifiers:**
- * Value exceeds Maximum Contaminant Level
 - C Calibration %RSD/%D exceeded for non-CCC analytes
 - H Holding times for preparation or analysis exceeded
 - LOD Limit of Detection
 - ND Not Detected at the Reporting Limit
 - U Indicates the compound was analyzed but not detected.
 - B Analyte detected in the associated Method Blank
 - E Value above quantitation range
 - J Analyte detected below quantitation limits
 - LOQ Limit of Quantitation
 - S Spike Recovery outside accepted recovery limits

American Analytical Laboratories, LLC.

Date: 09-Mar-10

ELAP ID : 11418

| | | | |
|-------------------|----------------------------------|--------------------------|----------------------|
| CLIENT: | Leggette Brashears & Graham Inc. | Client Sample ID: | WQ3210:1255NP2-10 |
| Lab Order: | 1003022 | Collection Date: | 3/2/2010 12:55:00 PM |
| Project: | Rowe | Matrix: | LIQUID |
| Lab ID: | 1003022-03D | | |

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|--|---------------|-----|------|--------|-------|----|--------------------|
| TOTAL DISSOLVED SOLIDS | | | | | | | |
| Total Dissolved Solids (Residue, Filterable) | 107 | 0 | 1.00 | M2540C | mg/L | 1 | 3/5/2010 |
| | | | | | | | Analyst: AS |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- | | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 09-Mar-10

CLIENT: Leggette Brashears & Graham Inc.
 Work Order: 1003022
 Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

Sample ID: V624LCS-030310HW SampType: LCS TestCode: 8260MTBE11 Units: µg/L Prep Date: RunNo: 49296
 Client ID: LCSW Batch ID: R49296 TestNo: SW8260B Analysis Date: 3/3/2010 SeqNo: 681772

| Analyte | Result | PQL | SPK value | SPK Ref Val | Units: µg/L | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---------------------------|--------|-----|-----------|-------------|-------------|------|----------|-----------|-------------|------|----------|------|
| 1,1,1-Trichloroethane | 55 | 1.0 | 50.00 | 0 | 0 | 110 | 43 | 148 | | | | |
| 1,1,2,2-Tetrachloroethane | 54 | 1.0 | 50.00 | 0 | 0 | 108 | 32 | 148 | | | | |
| 1,1,2-Trichloroethane | 49 | 1.0 | 50.00 | 0 | 0 | 98.8 | 42 | 136 | | | | |
| 1,1-Dichloroethane | 56 | 1.0 | 50.00 | 0 | 0 | 111 | 40 | 150 | | | | |
| 1,1-Dichlorobenzene | 60 | 1.0 | 50.00 | 0 | 0 | 120 | 30 | 154 | | | | |
| 1,2-Dichloroethane | 52 | 1.0 | 50.00 | 0 | 0 | 104 | 40 | 129 | | | | |
| 1,2-Dichloropropane | 49 | 1.0 | 50.00 | 0 | 0 | 97.9 | 36 | 141 | | | | |
| 1,3-Dichlorobenzene | 50 | 1.0 | 50.00 | 0 | 0 | 101 | 44 | 138 | | | | |
| 1,4-Dichlorobenzene | 55 | 1.0 | 50.00 | 0 | 0 | 109 | 40 | 133 | | | | |
| 2-Chloroethyl vinyl ether | 53 | 1.0 | 50.00 | 0 | 0 | 106 | 40 | 135 | | | | |
| Benzene | 37 | 1.0 | 50.00 | 0 | 0 | 73.3 | 21 | 139 | | | | |
| Bromodichloromethane | 51 | 1.0 | 50.00 | 0 | 0 | 102 | 45 | 144 | | | | |
| Bromoform | 49 | 1.0 | 50.00 | 0 | 0 | 97.8 | 35 | 136 | | | | |
| Bromomethane | 48 | 1.0 | 50.00 | 0 | 0 | 95.0 | 28 | 138 | | | | |
| Carbon tetrachloride | 51 | 1.0 | 50.00 | 0 | 0 | 102 | 26 | 148 | | | | |
| Chlorobenzene | 56 | 1.0 | 50.00 | 0 | 0 | 113 | 45 | 141 | | | | |
| Chloroethane | 47 | 1.0 | 50.00 | 0 | 0 | 94.8 | 41 | 142 | | | | |
| Chloroform | 60 | 1.0 | 50.00 | 0 | 0 | 119 | 36 | 143 | | | | |
| Chloromethane | 52 | 1.0 | 50.00 | 0 | 0 | 103 | 42 | 137 | | | | |
| cis-1,3-Dichloropropene | 59 | 1.0 | 50.00 | 0 | 0 | 118 | 35 | 151 | | | | |
| Dibromochloromethane | 50 | 1.0 | 50.00 | 0 | 0 | 99.5 | 42 | 130 | | | | |
| Ethylbenzene | 49 | 1.0 | 50.00 | 0 | 0 | 98.2 | 21 | 134 | | | | |
| Tetrachloroethene | 50 | 1.0 | 50.00 | 0 | 0 | 99.7 | 45 | 146 | | | | |
| Toluene | 53 | 1.0 | 50.00 | 0 | 0 | 105 | 45 | 136 | | | | |
| trans-1,2-Dichloroethene | 52 | 1.0 | 50.00 | 0 | 0 | 105 | 43 | 134 | | | | |
| trans-1,3-Dichloropropene | 55 | 1.0 | 50.00 | 0 | 0 | 111 | 42 | 135 | | | | |
| Trichloroethene | 46 | 1.0 | 50.00 | 0 | 0 | 92.9 | 37 | 133 | | | | |
| Trichlorofluoromethane | 57 | 1.0 | 50.00 | 0 | 0 | 115 | 43 | 140 | | | | |
| Vinyl chloride | 51 | 1.0 | 50.00 | 0 | 0 | 102 | 50 | 148 | | | | C |
| | 60 | 1.0 | 50.00 | 0 | 0 | 120 | 35 | 142 | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analyte
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

CLIENT: Leggett Brashears & Graham Inc.
Work Order: 1003022
Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

| | | | | | |
|-----------------------------|------------------|----------------------|-------------|-------------------------|---------------|
| Sample ID: V624LCS-030310HW | SampType: LCS | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49296 |
| Client ID: LCSW | Batch ID: R49296 | TestNo: SW8260B | | Analysis Date: 3/3/2010 | SeqNo: 681772 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|----------------------------|--------|-----|-----------|-------------|------|----------|-----------|-------------|------|----------|------|
| Surr: 4-Bromofluorobenzene | 50 | | 50.00 | | 99.4 | 60 | 130 | | | | |
| Surr: Dibromofluoromethane | 53 | | 50.00 | | 106 | 63 | 127 | | | | |
| Surr: Toluene-d8 | 50 | | 50.00 | | 100 | 61 | 128 | | | | |

| | | | | | |
|--------------------------|------------------|----------------------|-------------|-------------------------|---------------|
| Sample ID: VBLK-030310HW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49296 |
| Client ID: PBW | Batch ID: R49296 | TestNo: SW8260B | | Analysis Date: 3/3/2010 | SeqNo: 681773 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---------------------------------------|--------|-----|-----------|-------------|------|----------|-----------|-------------|------|----------|------|
| 1,1,1,2-Tetrachloroethane | U | 1.0 | | | | | | | | | |
| 1,1,1-Trichloroethane | U | 1.0 | | | | | | | | | |
| 1,1,2,2-Tetrachloroethane | U | 1.0 | | | | | | | | | |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 1.0 | | | | | | | | | |
| 1,1,2-Trichloroethane | U | 1.0 | | | | | | | | | |
| 1,1-Dichloroethane | U | 1.0 | | | | | | | | | |
| 1,1-Dichloroethene | U | 1.0 | | | | | | | | | |
| 1,1-Dichloropropene | U | 1.0 | | | | | | | | | |
| 1,2,3-Trichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2,3-Trichloropropane | U | 1.0 | | | | | | | | | |
| 1,2,4-Trichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2,4-Trimethylbenzene | U | 1.0 | | | | | | | | | |
| 1,2-Dibromo-3-chloropropane | U | 1.0 | | | | | | | | | |
| 1,2-Dibromoethane | U | 1.0 | | | | | | | | | |
| 1,2-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2-Dichloroethane | U | 1.0 | | | | | | | | | |
| 1,2-Dichloropropane | U | 1.0 | | | | | | | | | |
| 1,3,5-Trimethylbenzene | U | 1.0 | | | | | | | | | |
| 1,3-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,3-dichloropropane | U | 1.0 | | | | | | | | | |
| 1,4-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 2,2-Dichloropropane | U | 1.0 | | | | | | | | | |
| 2-Butanone | U | 3.0 | | | | | | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

CLIENT: Leggett Brashears & Graham Inc.
Work Order: 1003022
Project: Rowe

TestCode: 8260MTBE113_W

| | | | | | |
|--------------------------|------------------|----------------------|-------------|-------------------------|---------------|
| Sample ID: VBLK-030310HW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49296 |
| Client ID: PBW | Batch ID: R49296 | TestNo: SW8260B | | Analysis Date: 3/3/2010 | SeqNo: 681773 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---------------------------|--------|-----|-----------|-------------|------|----------|-----------|-------------|------|----------|------|
| 2-Chloroethyl vinyl ether | U | 1.0 | | | | | | | | | |
| 2-Chlorotoluene | U | 1.0 | | | | | | | | | |
| 2-Hexanone | U | 2.0 | | | | | | | | | |
| 4-Chlorotoluene | U | 1.0 | | | | | | | | | |
| 4-Isopropyltoluene | U | 1.0 | | | | | | | | | |
| 4-Methyl-2-pentanone | U | 2.0 | | | | | | | | | |
| Acetone | U | 2.0 | | | | | | | | | C |
| Benzene | U | 1.0 | | | | | | | | | |
| Bromobenzene | U | 1.0 | | | | | | | | | |
| Bromochloromethane | U | 1.0 | | | | | | | | | |
| Bromodichloromethane | U | 1.0 | | | | | | | | | |
| Bromoform | U | 1.0 | | | | | | | | | |
| Bromomethane | U | 1.0 | | | | | | | | | |
| Carbon disulfide | U | 1.0 | | | | | | | | | |
| Carbon tetrachloride | U | 1.0 | | | | | | | | | |
| Chlorobenzene | U | 1.0 | | | | | | | | | |
| Chloroethane | U | 1.0 | | | | | | | | | |
| Chloroform | U | 1.0 | | | | | | | | | |
| Chloromethane | U | 1.0 | | | | | | | | | |
| cis-1,2-Dichloroethene | U | 1.0 | | | | | | | | | |
| cis-1,3-Dichloropropene | U | 1.0 | | | | | | | | | |
| Dibromochloromethane | U | 1.0 | | | | | | | | | |
| Dibromomethane | U | 1.0 | | | | | | | | | |
| Dichlorodifluoromethane | U | 1.0 | | | | | | | | | |
| Ethylbenzene | U | 1.0 | | | | | | | | | |
| Hexachlorobutadiene | U | 1.0 | | | | | | | | | |
| Isopropylbenzene | U | 1.0 | | | | | | | | | |
| m,p-Xylene | U | 2.0 | | | | | | | | | |
| Methyl tert-butyl ether | U | 1.0 | | | | | | | | | |
| Methylene chloride | U | 1.0 | | | | | | | | | C |
| Naphthalene | U | 1.0 | | | | | | | | | C |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

CLIENT: Leggett Brashears & Graham Inc.
Work Order: 1003022
Project: Rowe

TestCode: 8260MTBE113_W

| Sample ID: VBLK-030310HW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49296 | | | | | | |
|--------------------------|------------------|----------------------|-------------|-------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Client ID: PBW | Batch ID: R49296 | TestNo: SW8260B | | Analysis Date: 3/3/2010 | SeqNo: 681773 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|----------------------------|----|-----|-------|--|------|----|-----|--|--|--|---|
| n-Butylbenzene | U | 1.0 | | | | | | | | | |
| n-Propylbenzene | U | 1.0 | | | | | | | | | |
| o-Xylene | U | 1.0 | | | | | | | | | |
| sec-Butylbenzene | U | 1.0 | | | | | | | | | |
| Styrene | U | 1.0 | | | | | | | | | |
| tert-Butylbenzene | U | 1.0 | | | | | | | | | |
| Tetrachloroethene | U | 1.0 | | | | | | | | | |
| Toluene | U | 1.0 | | | | | | | | | |
| trans-1,2-Dichloroethene | U | 1.0 | | | | | | | | | |
| trans-1,3-Dichloropropene | U | 1.0 | | | | | | | | | |
| Trichloroethene | U | 1.0 | | | | | | | | | |
| Trichlorofluoromethane | U | 1.0 | | | | | | | | | C |
| Vinyl acetate | U | 1.0 | | | | | | | | | |
| Vinyl chloride | U | 1.0 | | | | | | | | | |
| Surr: 4-Bromofluorobenzene | 48 | | 50.00 | | 96.9 | 60 | 130 | | | | |
| Surr: Dibromofluoromethane | 53 | | 50.00 | | 106 | 63 | 127 | | | | |
| Surr: Toluene-d8 | 50 | | 50.00 | | 99.9 | 61 | 128 | | | | |

| Sample ID: 1003022-03AMS | SampType: MS | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49296 | | | | | | |
|-----------------------------|------------------|----------------------|-------------|-------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Client ID: WQ3210:1255NP2-1 | Batch ID: R49296 | TestNo: SW8260B | | Analysis Date: 3/3/2010 | SeqNo: 681777 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|---------------------------|----|-----|-------|---|------|----|-----|--|--|--|--|
| 1,1,1-Trichloroethane | 53 | 1.0 | 50.00 | 0 | 105 | 43 | 148 | | | | |
| 1,1,2,2-Tetrachloroethane | 48 | 1.0 | 50.00 | 0 | 96.0 | 32 | 148 | | | | |
| 1,1,2-Trichloroethane | 47 | 1.0 | 50.00 | 0 | 94.5 | 42 | 136 | | | | |
| 1,1-Dichloroethane | 53 | 1.0 | 50.00 | 0 | 105 | 40 | 150 | | | | |
| 1,1-Dichloroethene | 54 | 1.0 | 50.00 | 0 | 108 | 30 | 154 | | | | |
| 1,2-Dichlorobenzene | 46 | 1.0 | 50.00 | 0 | 91.2 | 40 | 129 | | | | |
| 1,2-Dichloroethane | 48 | 1.0 | 50.00 | 0 | 95.2 | 36 | 141 | | | | |
| 1,2-Dichloropropane | 48 | 1.0 | 50.00 | 0 | 95.1 | 44 | 138 | | | | |
| 1,3-Dichlorobenzene | 48 | 1.0 | 50.00 | 0 | 95.3 | 40 | 133 | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

CLIENT: Leggette Brashears & Graham Inc.
 Work Order: 1003022
 Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

| | | | | | |
|-----------------------------|------------------|----------------------|-------------|-------------------------|---------------|
| Sample ID: 1003022-03AMS | SampType: MS | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49296 |
| Client ID: WQ3210:1255NP2-1 | Batch ID: R49296 | TestNo: SW8260B | | Analysis Date: 3/3/2010 | SeqNo: 681777 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|----------------------------|--------|-----|-----------|-------------|------|----------|-----------|-------------|------|----------|------|
| 1,4-Dichlorobenzene | 47 | 1.0 | 50.00 | 0 | 94.1 | 40 | 135 | | | | |
| Benzene | 49 | 1.0 | 50.00 | 0 | 98.5 | 45 | 144 | | | | |
| Bromodichloromethane | 47 | 1.0 | 50.00 | 0 | 94.3 | 35 | 136 | | | | |
| Bromoform | 43 | 1.0 | 50.00 | 0 | 86.2 | 28 | 138 | | | | |
| Bromomethane | 52 | 1.0 | 50.00 | 0 | 104 | 26 | 148 | | | | |
| Carbon tetrachloride | 54 | 1.0 | 50.00 | 0 | 108 | 45 | 141 | | | | |
| Chlorobenzene | 46 | 1.0 | 50.00 | 0 | 91.6 | 41 | 142 | | | | C |
| Chloroethane | 67 | 1.0 | 50.00 | 0 | 133 | 36 | 143 | | | | |
| Chloroform | 50 | 1.0 | 50.00 | 0 | 99.9 | 42 | 137 | | | | |
| Chloromethane | 62 | 1.0 | 50.00 | 0 | 125 | 35 | 151 | | | | |
| cis-1,3-Dichloropropene | 47 | 1.0 | 50.00 | 0 | 93.7 | 42 | 130 | | | | |
| Dibromochloromethane | 48 | 1.0 | 50.00 | 0 | 95.7 | 21 | 134 | | | | |
| Ethylbenzene | 48 | 1.0 | 50.00 | 0 | 95.4 | 45 | 146 | | | | |
| Tetrachloroethene | 51 | 1.0 | 50.00 | 0 | 102 | 45 | 136 | | | | |
| Toluene | 50 | 1.0 | 50.00 | 0 | 99.3 | 43 | 134 | | | | |
| trans-1,2-Dichloroethene | 50 | 1.0 | 50.00 | 0 | 101 | 42 | 135 | | | | |
| trans-1,3-Dichloropropene | 44 | 1.0 | 50.00 | 0 | 87.8 | 37 | 133 | | | | |
| Trichloroethene | 55 | 1.0 | 50.00 | 0 | 110 | 43 | 140 | | | | |
| Trichlorofluoromethane | 72 | 1.0 | 50.00 | 0 | 144 | 50 | 148 | | | | |
| Vinyl chloride | 69 | 1.0 | 50.00 | 0 | 138 | 35 | 142 | | | | C |
| Surr: 4-Bromofluorobenzene | 50 | | 50.00 | | 101 | 60 | 130 | | | | |
| Surr: Dibromofluoromethane | 55 | | 50.00 | | 110 | 63 | 127 | | | | |
| Surr: Toluene-d8 | 51 | | 50.00 | | 103 | 61 | 128 | | | | |

| | | | | | |
|-----------------------------|------------------|----------------------|-------------|-------------------------|---------------|
| Sample ID: 1003022-03AMS | SampType: MSD | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49296 |
| Client ID: WQ3210:1255NP2-1 | Batch ID: R49296 | TestNo: SW8260B | | Analysis Date: 3/3/2010 | SeqNo: 681778 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---------------------------|--------|-----|-----------|-------------|------|----------|-----------|-------------|------|----------|------|
| 1,1,1-Trichloroethane | 54 | 1.0 | 50.00 | 0 | 108 | 43 | 148 | 52.68 | 2.25 | 20 | |
| 1,1,2,2-Tetrachloroethane | 50 | 1.0 | 50.00 | 0 | 99.7 | 32 | 148 | 47.98 | 3.86 | 20 | |
| 1,1,2-Trichloroethane | 46 | 1.0 | 50.00 | 0 | 92.9 | 42 | 136 | 47.24 | 1.64 | 20 | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analyte
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

CLIENT: Leggett Brashears & Graham Inc.
 Work Order: 1003022
 Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

| Sample ID: 1003022-03AMSD | SampType: MSD | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49296 | | | | | | |
|-----------------------------|------------------|----------------------|-------------|-------------------------|---------------|----------|-----------|------------|-------|----------|------|
| Client ID: WQ3210:1255NP2-1 | Batch ID: R49296 | TestNo: SW8260B | | Analysis Date: 3/3/2010 | SeqNo: 681778 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD RefVal | %RPD | RPDLimit | Qual |
| 1,1-Dichloroethane | 53 | 1.0 | 50.00 | 0 | 106 | 40 | 150 | 52.51 | 0.608 | 20 | |
| 1,1-Dichloroethene | 55 | 1.0 | 50.00 | 0 | 110 | 30 | 154 | 54.21 | 1.45 | 20 | |
| 1,2-Dichlorobenzene | 48 | 1.0 | 50.00 | 0 | 95.4 | 40 | 129 | 45.58 | 4.57 | 20 | |
| 1,2-Dichloroethane | 48 | 1.0 | 50.00 | 0 | 95.3 | 36 | 141 | 47.59 | 0.126 | 20 | |
| 1,2-Dichloropropane | 46 | 1.0 | 50.00 | 0 | 92.9 | 44 | 138 | 47.53 | 2.34 | 20 | |
| 1,3-Dichlorobenzene | 50 | 1.0 | 50.00 | 0 | 101 | 40 | 133 | 47.64 | 5.49 | 20 | |
| 1,4-Dichlorobenzene | 50 | 1.0 | 50.00 | 0 | 99.8 | 40 | 135 | 47.06 | 5.88 | 20 | |
| Benzene | 49 | 1.0 | 50.00 | 0 | 98.9 | 45 | 144 | 49.23 | 0.446 | 20 | |
| Bromodichloromethane | 46 | 1.0 | 50.00 | 0 | 91.8 | 35 | 136 | 47.16 | 2.75 | 20 | |
| Bromoform | 45 | 1.0 | 50.00 | 0 | 89.3 | 28 | 138 | 43.08 | 3.53 | 20 | |
| Bromomethane | 53 | 1.0 | 50.00 | 0 | 106 | 26 | 148 | 51.91 | 2.04 | 20 | |
| Carbon tetrachloride | 54 | 1.0 | 50.00 | 0 | 108 | 45 | 141 | 53.78 | 0.612 | 20 | |
| Chlorobenzene | 47 | 1.0 | 50.00 | 0 | 93.4 | 41 | 142 | 45.82 | 1.92 | 20 | |
| Chloroethane | 70 | 1.0 | 50.00 | 0 | 140 | 36 | 143 | 66.68 | 5.00 | 20 | C |
| Chloroform | 50 | 1.0 | 50.00 | 0 | 100 | 42 | 137 | 49.93 | 0.300 | 20 | |
| Chloromethane | 68 | 1.0 | 50.00 | 0 | 135 | 35 | 151 | 62.36 | 7.95 | 20 | |
| cis-1,3-Dichloropropene | 46 | 1.0 | 50.00 | 0 | 92.7 | 42 | 130 | 46.85 | 1.03 | 20 | |
| Dibromochloromethane | 46 | 1.0 | 50.00 | 0 | 91.7 | 21 | 134 | 47.84 | 4.20 | 20 | |
| Ethylbenzene | 48 | 1.0 | 50.00 | 0 | 96.4 | 45 | 146 | 47.69 | 1.11 | 20 | |
| Tetrachloroethene | 51 | 1.0 | 50.00 | 0 | 101 | 45 | 136 | 51.20 | 0.902 | 20 | |
| Toluene | 49 | 1.0 | 50.00 | 0 | 98.8 | 43 | 134 | 49.63 | 0.424 | 20 | |
| trans-1,2-Dichloroethene | 52 | 1.0 | 50.00 | 0 | 105 | 42 | 135 | 50.45 | 3.73 | 20 | |
| trans-1,3-Dichloropropene | 43 | 1.0 | 50.00 | 0 | 85.9 | 37 | 133 | 43.89 | 2.21 | 20 | |
| Trichloroethene | 54 | 1.0 | 50.00 | 0 | 108 | 43 | 140 | 54.81 | 1.71 | 20 | |
| Trichlorofluoromethane | 74 | 1.0 | 50.00 | 0 | 148 | 50 | 148 | 72.11 | 2.42 | 20 | C |
| Vinyl chloride | 69 | 1.0 | 50.00 | 0 | 139 | 35 | 142 | 69.15 | 0.447 | 20 | |
| Surr: 4-Bromofluorobenzene | 51 | | 50.00 | | 102 | 60 | 130 | | 0 | 0 | |
| Surr: Dibromofluoromethane | 54 | | 50.00 | | 109 | 63 | 127 | | 0 | 0 | |
| Surr: Toluene-d8 | 51 | | 50.00 | | 102 | 61 | 128 | | 0 | 0 | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 1003022
Project: Rowe

TestCode: FE_T

| | | | | | |
|-------------------------|-----------------|----------------|-------------|-------------------------|---------------|
| Sample ID: LCSW-030210A | SampType: LCS | TestCode: FE_T | Units: mg/L | Prep Date: 3/2/2010 | RunNo: 49282 |
| Client ID: LCSW | Batch ID: 28297 | TestNo: E200.7 | SW3010A | Analysis Date: 3/3/2010 | SeqNo: 681469 |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC |
| Iron | 2.05 | 0.0200 | 2.000 | 0 | 103 |
| | | | | LowLimit | HighLimit |
| | | | | 68 | 122 |
| | | | | RPDRefVal | RPDLimit |
| | | | | | Qual |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 1003022
Project: Rowe

TestCode: TDS_W

| | | | | | | | | | | | |
|----------------------|------------------|-----------------|-------------|-------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Sample ID: MB-R49357 | SampType: MBLK | TestCode: TDS_W | Units: mg/L | Prep Date: | RunNo: 49357 | | | | | | |
| Client ID: PBW | Batch ID: R49357 | TestNo: M2540C | | Analysis Date: 3/5/2010 | SeqNo: 682639 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

Total Dissolved Solids (Residue, Filtera) U 1.00

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

Tuesday, March 23, 2010

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555

FAX (203) 926-9140

RE: Rowe

Order No.: 1003153

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 3/17/2010 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The results reported herein relate only to the items tested or to the samples as received by the laboratory. This report may not be reproduced, except in full, without the approval of American Analytical Laboratories, LLC and is not considered complete without a cover page and chain of custody documentation. The limits (LOQ) provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report or the data is qualified. This package has been reviewed by American Analytical Laboratories' QA Department/Laboratory Director to comply with NELAC standards prior to report submittal. This report consists of 31 pages.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe
Lab Order: 1003153

Work Order Sample Summary

| Lab Sample ID | Client Sample ID | Date Collected | Date Received |
|----------------------|-------------------------|-----------------------|----------------------|
| 1003153-01A | WQ31710:1110NP2-6 | 3/17/2010 11:10:00 AM | 3/17/2010 |
| 1003153-01B | WQ31710:1110NP2-6 | 3/17/2010 11:10:00 AM | 3/17/2010 |
| 1003153-01C | WQ31710:1110NP2-6 | 3/17/2010 11:10:00 AM | 3/17/2010 |
| 1003153-02A | WQ31710:1115NP2-7 | 3/17/2010 11:15:00 AM | 3/17/2010 |
| 1003153-02B | WQ31710:1115NP2-7 | 3/17/2010 11:15:00 AM | 3/17/2010 |
| 1003153-02C | WQ31710:1115NP2-7 | 3/17/2010 11:15:00 AM | 3/17/2010 |
| 1003153-03A | WQ31710:1120NP2-10 | 3/17/2010 11:20:00 AM | 3/17/2010 |
| 1003153-03B | WQ31710:1120NP2-10 | 3/17/2010 11:20:00 AM | 3/17/2010 |
| 1003153-03C | WQ31710:1120NP2-10 | 3/17/2010 11:20:00 AM | 3/17/2010 |
| 1003153-03D | WQ31710:1120NP2-10 | 3/17/2010 11:20:00 AM | 3/17/2010 |

American Analytical Laboratories, LLC.

Sample Receipt Checklist

Client Name LBG CT

Date and Time Receive 3/17/2010

Work Order Numbe 1003153

RcptNo: 1

Received by LB

COC_ID:

CoolerID:

Checklist completed b

Signature: Jon Berg Date: 3/17/10

Reviewed by

Initials: CB Date: 3/18/10

Matrix

Carrier name Lab Courier

- Shipping container/cooler in good condition? Yes [checked] No [] Not Present []
Custody seals intact on shipping container/cooler? Yes [] No [] Not Present [checked]
Custody seals intact on sample bottles? Yes [] No [] Not Present [checked]
Chain of custody present? Yes [checked] No []
Chain of custody signed when relinquished and received? Yes [checked] No []
Chain of custody agrees with sample labels? Yes [checked] No []
Samples in proper container/bottle? Yes [checked] No []
Sample containers intact? Yes [checked] No []
Sufficient sample volume for indicated test? Yes [checked] No []
All samples received within holding time? Yes [checked] No []
Container/Temp Blank temperature in compliance? Yes [checked] No []
Water - VOA vials have zero headspace? No VOA vials submitted [] Yes [checked] No []
Water - pH acceptable upon receipt? Yes [checked] No [] N/A []

Adjusted _____ Checked b _____

Any No and/or NA (not applicable) response must be detailed in the comments section b

Client contacted _____ Date contacted: _____ Person contacted _____

Contacted by: _____ Regarding _____

Comments: cooler with ice. 3.4 degrees C

Corrective Action _____

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003153
 Project: Rowe
 Lab ID: 1003153-01A

Client Sample ID: WQ31710:1110NP2-6
 Collection Date: 3/17/2010 11:10:00 AM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| 1,1,1,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| 1,1,1-Trichloroethane | 1.2 | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| 1,1,2,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| 1,1,2-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| 1,1-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| 1,1-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| 1,1-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| 1,2,3-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| 1,2,3-Trichloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| 1,2,4-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| 1,2,4-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| 1,2-Dibromo-3-chloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| 1,2-Dibromoethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| 1,2-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| 1,2-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| 1,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| 1,3,5-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| 1,3-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| 1,3-dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| 1,4-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| 2,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| 2-Butanone | U | 0.3 | 3.0 | C | µg/L | 1 | 3/23/2010 4:22:00 AM |
| 2-Chloroethyl vinyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| 2-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| 2-Hexanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| 4-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| 4-Isopropyltoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| 4-Methyl-2-pentanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| Acetone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| Benzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| Bromobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| Bromochloromethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 23-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003153
 Project: Rowe
 Lab ID: 1003153-01A

Client Sample ID: WQ31710:1110NP2-6
 Collection Date: 3/17/2010 11:10:00 AM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Bromodichloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| Bromoform | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| Bromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| Carbon disulfide | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| Carbon tetrachloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| Chlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| Chloroethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| Chloroform | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| Chloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| cis-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| cis-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| Dibromochloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| Dibromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| Dichlorodifluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| Ethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| Hexachlorobutadiene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| Isopropylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| m,p-Xylene | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| Methyl tert-butyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| Methylene chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| Naphthalene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| n-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| n-Propylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| o-Xylene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| sec-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| Styrene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| tert-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| Tetrachloroethene | 2.3 | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| Toluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| trans-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| trans-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| Trichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| Trichlorofluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 23-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 1003153
Project: Rowe
Lab ID: 1003153-01A

Client Sample ID: WQ31710:1110NP2-6
Collection Date: 3/17/2010 11:10:00 AM
Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Vinyl acetate | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| Vinyl chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:22:00 AM |
| Surr: 4-Bromofluorobenzene | 107 | 0 | 60-130 | | %REC | 1 | 3/23/2010 4:22:00 AM |
| Surr: Dibromofluoromethane | 89.6 | 0 | 63-127 | | %REC | 1 | 3/23/2010 4:22:00 AM |
| Surr: Toluene-d8 | 102 | 0 | 61-128 | | %REC | 1 | 3/23/2010 4:22:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 23-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 1003153
Project: Rowe
Lab ID: 1003153-01B

Client Sample ID: WQ31710:1110NP2-6
Collection Date: 3/17/2010 11:10:00 AM
Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|------------|---------------|-------|--------|--------|---------|----|-----------------------|
| TOTAL IRON | | | | E200.7 | SW3010A | | Analyst: JP |
| Iron | 1.43 | 0.005 | 0.0200 | | mg/L | 1 | 3/19/2010 10:09:06 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- Qualifiers:**
- * Value exceeds Maximum Contaminant Level
 - C Calibration %RSD/%D exceeded for non-CCC analytes
 - H Holding times for preparation or analysis exceeded
 - LOD Limit of Detection
 - ND Not Detected at the Reporting Limit
 - U Indicates the compound was analyzed but not detected.
 - B Analyte detected in the associated Method Blank
 - E Value above quantitation range
 - J Analyte detected below quantitation limits
 - LOQ Limit of Quantitation
 - S Spike Recovery outside accepted recovery limits

American Analytical Laboratories, LLC.

Date: 23-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 1003153
Project: Rowe
Lab ID: 1003153-01C

Client Sample ID: WQ31710:1110NP2-6
Collection Date: 3/17/2010 11:10:00 AM
Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|----------------|---------------|-------|--------|--------|-------|---------|-----------------------|
| DISSOLVED IRON | | | | E200.7 | | SW3005A | Analyst: JP |
| Iron | 0.323 | 0.005 | 0.0200 | | mg/L | 1 | 3/19/2010 10:07:03 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- Qualifiers:**
- * Value exceeds Maximum Contaminant Level
 - C Calibration %RSD/%D exceeded for non-CCC analytes
 - H Holding times for preparation or analysis exceeded
 - LOD Limit of Detection
 - ND Not Detected at the Reporting Limit
 - U Indicates the compound was analyzed but not detected.
 - B Analyte detected in the associated Method Blank
 - E Value above quantitation range
 - J Analyte detected below quantitation limits
 - LOQ Limit of Quantitation
 - S Spike Recovery outside accepted recovery limits

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003153
 Project: Rowe
 Lab ID: 1003153-02A

Client Sample ID: WQ31710:1115NP2-7
 Collection Date: 3/17/2010 11:15:00 AM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| 1,1,1,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| 1,1,1-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| 1,1,2,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| 1,1,2-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| 1,1-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| 1,1-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| 1,1-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| 1,2,3-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| 1,2,3-Trichloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| 1,2,4-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| 1,2,4-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| 1,2-Dibromo-3-chloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| 1,2-Dibromoethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| 1,2-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| 1,2-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| 1,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| 1,3,5-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| 1,3-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| 1,3-dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| 1,4-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| 2,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| 2-Butanone | U | 0.3 | 3.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| 2-Chloroethyl vinyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| 2-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| 2-Hexanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| 4-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| 4-Isopropyltoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| 4-Methyl-2-pentanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| Acetone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| Benzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| Bromobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| Bromochloromethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 23-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003153
 Project: Rowe
 Lab ID: 1003153-02A

Client Sample ID: WQ31710:1115NP2-7
 Collection Date: 3/17/2010 11:15:00 AM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Bromodichloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| Bromoform | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| Bromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| Carbon disulfide | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| Carbon tetrachloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| Chlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| Chloroethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| Chloroform | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| Chloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| cis-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| cis-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| Dibromochloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| Dibromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| Dichlorodifluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| Ethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| Hexachlorobutadiene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| Isopropylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| m,p-Xylene | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| Methyl tert-butyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| Methylene chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| Naphthalene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| n-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| n-Propylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| o-Xylene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| sec-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| Styrene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| tert-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| Tetrachloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| Toluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| trans-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| trans-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| Trichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| Trichlorofluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003153
 Project: Rowe
 Lab ID: 1003153-02A

Client Sample ID: WQ31710:1115NP2-7
 Collection Date: 3/17/2010 11:15:00 AM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Vinyl acetate | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| Vinyl chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:49:00 AM |
| Surr: 4-Bromofluorobenzene | 104 | 0 | 60-130 | | %REC | 1 | 3/23/2010 4:49:00 AM |
| Surr: Dibromofluoromethane | 91.1 | 0 | 63-127 | | %REC | 1 | 3/23/2010 4:49:00 AM |
| Surr: Toluene-d8 | 102 | 0 | 61-128 | | %REC | 1 | 3/23/2010 4:49:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- Qualifiers:**
- * Value exceeds Maximum Contaminant Level
 - C Calibration %RSD/%D exceeded for non-CCC analytes
 - H Holding times for preparation or analysis exceeded
 - LOD Limit of Detection
 - ND Not Detected at the Reporting Limit
 - U Indicates the compound was analyzed but not detected.
 - B Analyte detected in the associated Method Blank
 - E Value above quantitation range
 - J Analyte detected below quantitation limits
 - LOQ Limit of Quantitation
 - S Spike Recovery outside accepted recovery limits

American Analytical Laboratories, LLC.

Date: 23-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 1003153
Project: Rowe
Lab ID: 1003153-02B

Client Sample ID: WQ31710:1115NP2-7
Collection Date: 3/17/2010 11:15:00 AM
Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|-------------------|---------------|-------|--------|---------------|----------------|----|-----------------------|
| TOTAL IRON | | | | E200.7 | SW3010A | | Analyst: JP |
| Iron | 1.34 | 0.005 | 0.0200 | | mg/L | 1 | 3/19/2010 10:13:13 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003153
 Project: Rowe
 Lab ID: 1003153-02C

Client Sample ID: WQ31710:1115NP2-7
 Collection Date: 3/17/2010 11:15:00 AM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|----------------|---------------|-------|--------|------|---------|----|-----------------------|
| DISSOLVED IRON | | | E200.7 | | SW3005A | | Analyst: JP |
| Iron | 0.0971 | 0.005 | 0.0200 | | mg/L | 1 | 3/19/2010 10:11:10 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- Qualifiers:**
- * Value exceeds Maximum Contaminant Level
 - C Calibration %RSD/%D exceeded for non-CCC analytes
 - H Holding times for preparation or analysis exceeded
 - LOD Limit of Detection
 - ND Not Detected at the Reporting Limit
 - U Indicates the compound was analyzed but not detected.
 - B Analyte detected in the associated Method Blank
 - E Value above quantitation range
 - J Analyte detected below quantitation limits
 - LOQ Limit of Quantitation
 - S Spike Recovery outside accepted recovery limits

American Analytical Laboratories, LLC.

Date: 23-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003153
 Project: Rowe
 Lab ID: 1003153-03A

Client Sample ID: WQ31710:1120NP2-10
 Collection Date: 3/17/2010 11:20:00 AM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| 1,1,1,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| 1,1,1-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| 1,1,2,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| 1,1,2-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| 1,1-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| 1,1-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| 1,1-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| 1,2,3-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| 1,2,3-Trichloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| 1,2,4-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| 1,2,4-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| 1,2-Dibromo-3-chloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| 1,2-Dibromoethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| 1,2-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| 1,2-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| 1,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| 1,3,5-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| 1,3-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| 1,3-dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| 1,4-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| 2,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| 2-Butanone | U | 0.3 | 3.0 | C | µg/L | 1 | 3/23/2010 5:15:00 AM |
| 2-Chloroethyl vinyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| 2-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| 2-Hexanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| 4-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| 4-Isopropyltoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| 4-Methyl-2-pentanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| Acetone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| Benzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| Bromobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| Bromochloromethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003153
 Project: Rowe
 Lab ID: 1003153-03A

Client Sample ID: WQ31710:1120NP2-10
 Collection Date: 3/17/2010 11:20:00 AM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|--------------------|----|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Bromodichloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| Bromoform | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| Bromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| Carbon disulfide | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| Carbon tetrachloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| Chlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| Chloroethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| Chloroform | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| Chloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| cis-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| cis-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| Dibromochloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| Dibromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| Dichlorodifluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| Ethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| Hexachlorobutadiene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| Isopropylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| m,p-Xylene | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| Methyl tert-butyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| Methylene chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| Naphthalene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| n-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| n-Propylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| o-Xylene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| sec-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| Styrene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| tert-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| Tetrachloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| Toluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| trans-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| trans-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| Trichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| Trichlorofluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 23-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003153
 Project: Rowe
 Lab ID: 1003153-03A

Client Sample ID: WQ31710:1120NP2-10
 Collection Date: 3/17/2010 11:20:00 AM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Vinyl acetate | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| Vinyl chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:15:00 AM |
| Surr: 4-Bromofluorobenzene | 103 | 0 | 60-130 | | %REC | 1 | 3/23/2010 5:15:00 AM |
| Surr: Dibromofluoromethane | 90.2 | 0 | 63-127 | | %REC | 1 | 3/23/2010 5:15:00 AM |
| Surr: Toluene-d8 | 101 | 0 | 61-128 | | %REC | 1 | 3/23/2010 5:15:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 23-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 1003153
Project: Rowe
Lab ID: 1003153-03B

Client Sample ID: WQ31710:1120NP2-10
Collection Date: 3/17/2010 11:20:00 AM
Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|------------|---------------|-------|--------|--------|---------|----|-----------------------|
| TOTAL IRON | | | | E200.7 | SW3010A | | Analyst: JP |
| Iron | 1.91 | 0.005 | 0.0200 | | mg/L | 1 | 3/19/2010 10:17:19 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 23-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003153
 Project: Rowe
 Lab ID: 1003153-03C

Client Sample ID: WQ31710:1120NP2-10
 Collection Date: 3/17/2010 11:20:00 AM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|----------------|---------------|-------|--------|------|---------|----|-----------------------|
| DISSOLVED IRON | | | E200.7 | | SW3005A | | Analyst: JP |
| Iron | 0.166 | 0.005 | 0.0200 | | mg/L | 1 | 3/19/2010 10:15:15 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- Qualifiers:**
- * Value exceeds Maximum Contaminant Level
 - C Calibration %RSD/%D exceeded for non-CCC analytes
 - H Holding times for preparation or analysis exceeded
 - LOD Limit of Detection
 - ND Not Detected at the Reporting Limit
 - U Indicates the compound was analyzed but not detected.
 - B Analyte detected in the associated Method Blank
 - E Value above quantitation range
 - J Analyte detected below quantitation limits
 - LOQ Limit of Quantitation
 - S Spike Recovery outside accepted recovery limits

American Analytical Laboratories, LLC.

Date: 23-Mar-10

ELAP ID : 11418

| | | | |
|-------------------|----------------------------------|--------------------------|-----------------------|
| CLIENT: | Leggette Brashears & Graham Inc. | Client Sample ID: | WQ31710:1120NP2-10 |
| Lab Order: | 1003153 | Collection Date: | 3/17/2010 11:20:00 AM |
| Project: | Rowe | Matrix: | LIQUID |
| Lab ID: | 1003153-03D | | |

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|--|---------------|-----|---------------|------|-------|----|--------------------|
| TOTAL DISSOLVED SOLIDS | | | M2540C | | | | Analyst: AS |
| Total Dissolved Solids (Residue, Filterable) | 104 | 0 | 1.00 | | mg/L | 1 | 3/19/2010 |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- | | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| LOD | Limit of Detection | LOQ Limit of Quantitation |
| ND | Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| U | Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 23-Mar-10

CLIENT: Leggett Brashears & Graham Inc.
 Work Order: 1003153
 Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

Sample ID: V624LCS-032210aY SampType: LCS TestCode: 8260MTBE11 Units: µg/L Prep Date: RunNo: 49606
 Client ID: LCSW Batch ID: R49606 TestNo: SW8260B Analysis Date: 3/22/2010 SeqNo: 686840

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---------------------------|--------|-----|-----------|-------------|------|----------|-----------|-------------|------|----------|------|
| 1,1,1-Trichloroethane | 38 | 1.0 | 50.00 | 0 | 76.7 | 43 | 148 | | | | |
| 1,1,2,2-Tetrachloroethane | 37 | 1.0 | 50.00 | 0 | 73.1 | 32 | 148 | | | | |
| 1,1,2-Trichloroethane | 35 | 1.0 | 50.00 | 0 | 70.1 | 42 | 136 | | | | |
| 1,1-Dichloroethane | 35 | 1.0 | 50.00 | 0 | 69.3 | 40 | 150 | | | | |
| 1,1-Dichloroethene | 39 | 1.0 | 50.00 | 0 | 77.7 | 30 | 154 | | | | |
| 1,2-Dichlorobenzene | 39 | 1.0 | 50.00 | 0 | 77.6 | 40 | 129 | | | | |
| 1,2-Dichloroethane | 37 | 1.0 | 50.00 | 0 | 74.8 | 36 | 141 | | | | |
| 1,2-Dichloropropane | 35 | 1.0 | 50.00 | 0 | 70.5 | 44 | 138 | | | | |
| 1,3-Dichlorobenzene | 38 | 1.0 | 50.00 | 0 | 75.8 | 40 | 133 | | | | |
| 1,4-Dichlorobenzene | 38 | 1.0 | 50.00 | 0 | 76.1 | 40 | 135 | | | | |
| 2-Chloroethyl vinyl ether | 36 | 1.0 | 50.00 | 0 | 71.1 | 21 | 139 | | | | |
| Benzene | 34 | 1.0 | 50.00 | 0 | 67.2 | 45 | 144 | | | | |
| Bromodichloromethane | 40 | 1.0 | 50.00 | 0 | 79.3 | 35 | 136 | | | | |
| Bromoform | 36 | 1.0 | 50.00 | 0 | 72.3 | 28 | 138 | | | | |
| Bromomethane | 47 | 1.0 | 50.00 | 0 | 94.5 | 26 | 148 | | | | |
| Carbon tetrachloride | 40 | 1.0 | 50.00 | 0 | 79.5 | 45 | 141 | | | | |
| Chlorobenzene | 39 | 1.0 | 50.00 | 0 | 77.8 | 41 | 142 | | | | |
| Chloroethane | 47 | 1.0 | 50.00 | 0 | 94.8 | 36 | 143 | | | | |
| Chloroform | 33 | 1.0 | 50.00 | 0 | 66.0 | 42 | 137 | | | | |
| Chloromethane | 45 | 1.0 | 50.00 | 0 | 89.4 | 35 | 151 | | | | |
| cis-1,3-Dichloropropene | 35 | 1.0 | 50.00 | 0 | 71.0 | 42 | 130 | | | | |
| Dibromochloromethane | 35 | 1.0 | 50.00 | 0 | 69.7 | 21 | 134 | | | | |
| Ethylbenzene | 40 | 1.0 | 50.00 | 0 | 80.9 | 45 | 146 | | | | |
| Tetrachloroethene | 36 | 1.0 | 50.00 | 0 | 72.8 | 45 | 136 | | | | |
| Toluene | 38 | 1.0 | 50.00 | 0 | 75.4 | 43 | 134 | | | | |
| trans-1,2-Dichloroethene | 34 | 1.0 | 50.00 | 0 | 68.1 | 42 | 135 | | | | |
| trans-1,3-Dichloropropene | 40 | 1.0 | 50.00 | 0 | 79.7 | 37 | 133 | | | | |
| Trichloroethene | 39 | 1.0 | 50.00 | 0 | 78.3 | 43 | 140 | | | | |
| Trichlorofluoromethane | 56 | 1.0 | 50.00 | 0 | 111 | 50 | 148 | | | | |
| Vinyl chloride | 53 | 1.0 | 50.00 | 0 | 105 | 35 | 142 | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

CLIENT: Leggett Brashears & Graham Inc.
 Work Order: 1003153
 Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

| | | | | | |
|-----------------------------|------------------|----------------------|-------------|--------------------------|---------------|
| Sample ID: V624LCS-032210aY | SampType: LCS | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49606 |
| Client ID: LCSW | Batch ID: R49606 | TestNo: SW8260B | | Analysis Date: 3/22/2010 | SeqNo: 686840 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|----------------------------|--------|-----|-----------|-------------|------|----------|-----------|-------------|------|----------|------|
| Surr: 4-Bromofluorobenzene | 52 | | 50.00 | | 104 | 60 | 130 | | | | |
| Surr: Dibromofluoromethane | 48 | | 50.00 | | 95.9 | 63 | 127 | | | | |
| Surr: Toluene-d8 | 51 | | 50.00 | | 102 | 61 | 128 | | | | |

| | | | | | |
|---------------------------|------------------|----------------------|-------------|--------------------------|---------------|
| Sample ID: VBLK-032210aYW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49606 |
| Client ID: PBW | Batch ID: R49606 | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 686841 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---------------------------------------|--------|-----|-----------|-------------|------|----------|-----------|-------------|------|----------|------|
| 1,1,1,2-Tetrachloroethane | U | 1.0 | | | | | | | | | |
| 1,1,1-Trichloroethane | U | 1.0 | | | | | | | | | |
| 1,1,2,2-Tetrachloroethane | U | 1.0 | | | | | | | | | |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 1.0 | | | | | | | | | |
| 1,1,2-Trichloroethane | U | 1.0 | | | | | | | | | |
| 1,1-Dichloroethane | U | 1.0 | | | | | | | | | |
| 1,1-Dichloroethene | U | 1.0 | | | | | | | | | |
| 1,1-Dichloropropene | U | 1.0 | | | | | | | | | |
| 1,2,3-Trichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2,3-Trichloropropane | U | 1.0 | | | | | | | | | |
| 1,2,4-Trichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2,4-Trimethylbenzene | U | 1.0 | | | | | | | | | |
| 1,2-Dibromo-3-chloropropane | U | 1.0 | | | | | | | | | |
| 1,2-Dibromoethane | U | 1.0 | | | | | | | | | |
| 1,2-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2-Dichloroethane | U | 1.0 | | | | | | | | | |
| 1,2-Dichloropropane | U | 1.0 | | | | | | | | | |
| 1,3,5-Trimethylbenzene | U | 1.0 | | | | | | | | | |
| 1,3-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,3-dichloropropane | U | 1.0 | | | | | | | | | |
| 1,4-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 2,2-Dichloropropane | U | 1.0 | | | | | | | | | |
| 2-Butanone | U | 3.0 | | | | | | | | | C |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analysis
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 1003153
Project: Rowe

TestCode: 8260MTBE113_W

| Sample ID: VBLK-032210aYW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49606 | | | | | | |
|---------------------------|------------------|----------------------|-------------|--------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Client ID: PBW | Batch ID: R49606 | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 686841 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|---------------------------|---|-----|--|--|--|--|--|--|--|--|--|
| 2-Chloroethyl vinyl ether | U | 1.0 | | | | | | | | | |
| 2-Chlorotoluene | U | 1.0 | | | | | | | | | |
| 2-Hexanone | U | 2.0 | | | | | | | | | |
| 4-Chlorotoluene | U | 1.0 | | | | | | | | | |
| 4-Isopropyltoluene | U | 1.0 | | | | | | | | | |
| 4-Methyl-2-pentanone | U | 2.0 | | | | | | | | | |
| Acetone | U | 2.0 | | | | | | | | | |
| Benzene | U | 1.0 | | | | | | | | | |
| Bromobenzene | U | 1.0 | | | | | | | | | |
| Bromochloromethane | U | 1.0 | | | | | | | | | |
| Bromodichloromethane | U | 1.0 | | | | | | | | | |
| Bromoform | U | 1.0 | | | | | | | | | |
| Bromomethane | U | 1.0 | | | | | | | | | |
| Carbon disulfide | U | 1.0 | | | | | | | | | |
| Carbon tetrachloride | U | 1.0 | | | | | | | | | |
| Chlorobenzene | U | 1.0 | | | | | | | | | |
| Chloroethane | U | 1.0 | | | | | | | | | |
| Chloroform | U | 1.0 | | | | | | | | | |
| Chloromethane | U | 1.0 | | | | | | | | | |
| cis-1,2-Dichloroethene | U | 1.0 | | | | | | | | | |
| cis-1,3-Dichloropropene | U | 1.0 | | | | | | | | | |
| Dibromochloromethane | U | 1.0 | | | | | | | | | |
| Dibromomethane | U | 1.0 | | | | | | | | | |
| Dichlorodifluoromethane | U | 1.0 | | | | | | | | | |
| Ethylbenzene | U | 1.0 | | | | | | | | | |
| Hexachlorobutadiene | U | 1.0 | | | | | | | | | |
| Isopropylbenzene | U | 1.0 | | | | | | | | | |
| m,p-Xylene | U | 2.0 | | | | | | | | | |
| Methyl tert-butyl ether | U | 1.0 | | | | | | | | | |
| Methylene chloride | U | 1.0 | | | | | | | | | |
| Naphthalene | U | 1.0 | | | | | | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 1003153
Project: Rowe

TestCode: 8260MTBE113_W

| | | | | | | | | | | | |
|----------------------------------|-------------------------|-----------------------------|--------------------|---------------------------------|----------------------|----------|-----------|-------------|------|----------|------|
| Sample ID: VBLK-032210aYW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49606 | | | | | | |
| Client ID: PBW | Batch ID: R49606 | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 686841 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|----------------------------|----|-----|-------|--|------|----|--|-----|--|--|--|
| n-Butylbenzene | U | 1.0 | | | | | | | | | |
| n-Propylbenzene | U | 1.0 | | | | | | | | | |
| o-Xylene | U | 1.0 | | | | | | | | | |
| sec-Butylbenzene | U | 1.0 | | | | | | | | | |
| Styrene | U | 1.0 | | | | | | | | | |
| tert-Butylbenzene | U | 1.0 | | | | | | | | | |
| Tetrachloroethene | U | 1.0 | | | | | | | | | |
| Toluene | U | 1.0 | | | | | | | | | |
| trans-1,2-Dichloroethene | U | 1.0 | | | | | | | | | |
| trans-1,3-Dichloropropene | U | 1.0 | | | | | | | | | |
| Trichloroethene | U | 1.0 | | | | | | | | | |
| Trichlorofluoromethane | U | 1.0 | | | | | | | | | |
| Vinyl acetate | U | 1.0 | | | | | | | | | |
| Vinyl chloride | U | 1.0 | | | | | | | | | |
| Surr: 4-Bromofluorobenzene | 51 | | 50.00 | | 103 | 60 | | 130 | | | |
| Surr: Dibromofluoromethane | 49 | | 50.00 | | 98.7 | 63 | | 127 | | | |
| Surr: Toluene-d8 | 52 | | 50.00 | | 104 | 61 | | 128 | | | |

| | | | | | | | | | | | |
|------------------------------------|--------------------------|-----------------------------|--------------------|---------------------------------|----------------------|----------|-----------|-------------|------|----------|------|
| Sample ID: V624LCS-032210aY | SampType: LCS | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49606 | | | | | | |
| Client ID: LCSW | Batch ID: R49606A | TestNo: SW8260B | | Analysis Date: 3/22/2010 | SeqNo: 686844 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|---------------------------|----|-----|-------|---|------|----|--|-----|--|--|--|
| 1,1,1-Trichloroethane | 38 | 1.0 | 50.00 | 0 | 76.3 | 43 | | 148 | | | |
| 1,1,2,2-Tetrachloroethane | 35 | 1.0 | 50.00 | 0 | 71.0 | 32 | | 148 | | | |
| 1,1,2-Trichloroethane | 35 | 1.0 | 50.00 | 0 | 70.0 | 42 | | 136 | | | |
| 1,1-Dichloroethane | 33 | 1.0 | 50.00 | 0 | 65.6 | 40 | | 150 | | | |
| 1,1-Dichloroethene | 37 | 1.0 | 50.00 | 0 | 73.4 | 30 | | 154 | | | |
| 1,2-Dichlorobenzene | 37 | 1.0 | 50.00 | 0 | 73.9 | 40 | | 129 | | | |
| 1,2-Dichloroethane | 36 | 1.0 | 50.00 | 0 | 71.8 | 36 | | 141 | | | |
| 1,2-Dichloropropane | 39 | 1.0 | 50.00 | 0 | 78.9 | 44 | | 138 | | | |
| 1,3-Dichlorobenzene | 37 | 1.0 | 50.00 | 0 | 74.5 | 40 | | 133 | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analyte
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

CLIENT: Leggett Brashears & Graham Inc.
 Work Order: 1003153
 Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

| | | | | | |
|-----------------------------|-------------------|----------------------|-------------|--------------------------|---------------|
| Sample ID: V624LCS-032210aY | SampType: LCS | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49606 |
| Client ID: LCSW | Batch ID: R49606A | TestNo: SW8260B | | Analysis Date: 3/22/2010 | SeqNo: 686844 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|----------------------------|--------|-----|-----------|-------------|------|----------|-----------|-------------|------|----------|------|
| 1,4-Dichlorobenzene | 38 | 1.0 | 50.00 | 0 | 75.0 | 40 | 135 | | | | |
| 2-Chloroethyl vinyl ether | 31 | 1.0 | 50.00 | 0 | 61.3 | 21 | 139 | | | | |
| Benzene | 37 | 1.0 | 50.00 | 0 | 73.4 | 45 | 144 | | | | |
| Bromodichloromethane | 35 | 1.0 | 50.00 | 0 | 70.4 | 35 | 136 | | | | |
| Bromoform | 35 | 1.0 | 50.00 | 0 | 69.8 | 28 | 138 | | | | |
| Bromomethane | 34 | 1.0 | 50.00 | 0 | 67.2 | 26 | 148 | | | | |
| Carbon tetrachloride | 38 | 1.0 | 50.00 | 0 | 76.3 | 45 | 141 | | | | |
| Chlorobenzene | 38 | 1.0 | 50.00 | 0 | 76.8 | 41 | 142 | | | | |
| Chloroethane | 45 | 1.0 | 50.00 | 0 | 89.1 | 36 | 143 | | | | |
| Chloroform | 37 | 1.0 | 50.00 | 0 | 73.9 | 42 | 137 | | | | |
| Chloromethane | 38 | 1.0 | 50.00 | 0 | 76.4 | 35 | 151 | | | | |
| cis-1,3-Dichloropropene | 39 | 1.0 | 50.00 | 0 | 78.3 | 42 | 130 | | | | |
| Dibromochloromethane | 34 | 1.0 | 50.00 | 0 | 67.2 | 21 | 134 | | | | |
| Ethylbenzene | 40 | 1.0 | 50.00 | 0 | 80.2 | 45 | 146 | | | | |
| Tetrachloroethene | 38 | 1.0 | 50.00 | 0 | 75.8 | 45 | 136 | | | | |
| Toluene | 37 | 1.0 | 50.00 | 0 | 74.6 | 43 | 134 | | | | |
| trans-1,2-Dichloroethene | 35 | 1.0 | 50.00 | 0 | 69.6 | 42 | 135 | | | | |
| trans-1,3-Dichloropropene | 36 | 1.0 | 50.00 | 0 | 71.5 | 37 | 133 | | | | |
| Trichloroethene | 38 | 1.0 | 50.00 | 0 | 76.4 | 43 | 140 | | | | |
| Trichlorofluoromethane | 51 | 1.0 | 50.00 | 0 | 103 | 50 | 148 | | | | |
| Vinyl chloride | 49 | 1.0 | 50.00 | 0 | 97.7 | 35 | 142 | | | | |
| Surr: 4-Bromofluorobenzene | 51 | | 50.00 | | 102 | 60 | 130 | | | | |
| Surr: Dibromofluoromethane | 47 | | 50.00 | | 94.3 | 63 | 127 | | | | |
| Surr: Toluene-d8 | 50 | | 50.00 | | 101 | 61 | 128 | | | | |

| | | | | | |
|---------------------------|-------------------|----------------------|-------------|--------------------------|---------------|
| Sample ID: VBLK-032210aYW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49606 |
| Client ID: PBW | Batch ID: R49606A | TestNo: SW8260B | | Analysis Date: 3/22/2010 | SeqNo: 686845 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---------------------------|--------|-----|-----------|-------------|------|----------|-----------|-------------|------|----------|------|
| 1,1,1,2-Tetrachloroethane | U | 1.0 | | | | | | | | | |
| 1,1,1-Trichloroethane | U | 1.0 | | | | | | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 1003153
Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

| | | | |
|----------------------------------|--------------------------|-----------------------------|--------------------|
| Sample ID: VBLK-032210aYW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L |
| Client ID: PBW | Batch ID: R49606A | TestNo: SW8260B | |
| Prep Date: | | RunNo: 49606 | |
| Analysis Date: 3/22/2010 | | SeqNo: 686845 | |

| Analyte | Result | PQL | SPK value | SPK Ref Val | Units: µg/L | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---------------------------------------|--------|-----|-----------|-------------|-------------|------|----------|-----------|-------------|------|----------|------|
| 1,1,2,2-Tetrachloroethane | U | 1.0 | | | | | | | | | | |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 1.0 | | | | | | | | | | |
| 1,1,2-Trichloroethane | U | 1.0 | | | | | | | | | | |
| 1,1-Dichloroethane | U | 1.0 | | | | | | | | | | |
| 1,1-Dichloroethene | U | 1.0 | | | | | | | | | | |
| 1,1-Dichloropropene | U | 1.0 | | | | | | | | | | |
| 1,2,3-Trichlorobenzene | U | 1.0 | | | | | | | | | | |
| 1,2,3-Trichloropropane | U | 1.0 | | | | | | | | | | |
| 1,2,4-Trichlorobenzene | U | 1.0 | | | | | | | | | | |
| 1,2,4-Trimethylbenzene | U | 1.0 | | | | | | | | | | |
| 1,2-Dibromo-3-chloropropane | U | 1.0 | | | | | | | | | | |
| 1,2-Dibromoethane | U | 1.0 | | | | | | | | | | |
| 1,2-Dichlorobenzene | U | 1.0 | | | | | | | | | | |
| 1,2-Dichloroethane | U | 1.0 | | | | | | | | | | |
| 1,2-Dichloropropane | U | 1.0 | | | | | | | | | | |
| 1,3,5-Trimethylbenzene | U | 1.0 | | | | | | | | | | |
| 1,3-Dichlorobenzene | U | 1.0 | | | | | | | | | | |
| 1,3-dichloropropane | U | 1.0 | | | | | | | | | | |
| 1,4-Dichlorobenzene | U | 1.0 | | | | | | | | | | |
| 2,2-Dichloropropane | U | 1.0 | | | | | | | | | | |
| 2-Butanone | U | 3.0 | | | | | | | | | | |
| 2-Chloroethyl vinyl ether | U | 1.0 | | | | | | | | | | |
| 2-Chlorotoluene | U | 1.0 | | | | | | | | | | |
| 2-Hexanone | U | 2.0 | | | | | | | | | | |
| 4-Chlorotoluene | U | 1.0 | | | | | | | | | | |
| 4-Isopropyltoluene | U | 1.0 | | | | | | | | | | |
| 4-Methyl-2-pentanone | U | 2.0 | | | | | | | | | | |
| Acetone | U | 2.0 | | | | | | | | | | |
| Benzene | U | 1.0 | | | | | | | | | | |
| Bromobenzene | U | 1.0 | | | | | | | | | | |
| Bromochloromethane | U | 1.0 | | | | | | | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 1003153
Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

| | | | | | | | | | | | |
|----------------------------------|--------------------------|-----------------------------|--------------------|---------------------------------|----------------------|----------|-----------|-------------|------|----------|------|
| Sample ID: VBLK-032210aYW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49606 | | | | | | |
| Client ID: PBW | Batch ID: R49606A | TestNo: SW8260B | | Analysis Date: 3/22/2010 | SeqNo: 686845 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK RefVal | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|---------------------------|---|-----|--|--|--|--|--|--|--|--|--|
| Bromodichloromethane | U | 1.0 | | | | | | | | | |
| Bromoform | U | 1.0 | | | | | | | | | |
| Bromomethane | U | 1.0 | | | | | | | | | |
| Carbon disulfide | U | 1.0 | | | | | | | | | |
| Carbon tetrachloride | U | 1.0 | | | | | | | | | |
| Chlorobenzene | U | 1.0 | | | | | | | | | |
| Chloroethane | U | 1.0 | | | | | | | | | |
| Chloroform | U | 1.0 | | | | | | | | | |
| Chloromethane | U | 1.0 | | | | | | | | | |
| cis-1,2-Dichloroethene | U | 1.0 | | | | | | | | | |
| cis-1,3-Dichloropropene | U | 1.0 | | | | | | | | | |
| Dibromochloromethane | U | 1.0 | | | | | | | | | |
| Dibromomethane | U | 1.0 | | | | | | | | | |
| Dichlorodifluoromethane | U | 1.0 | | | | | | | | | |
| Ethylbenzene | U | 1.0 | | | | | | | | | |
| Hexachlorobutadiene | U | 1.0 | | | | | | | | | |
| Isopropylbenzene | U | 1.0 | | | | | | | | | |
| m,p-Xylene | U | 2.0 | | | | | | | | | |
| Methyl tert-butyl ether | U | 1.0 | | | | | | | | | |
| Methylene chloride | U | 1.0 | | | | | | | | | |
| Naphthalene | U | 1.0 | | | | | | | | | |
| n-Butylbenzene | U | 1.0 | | | | | | | | | |
| n-Propylbenzene | U | 1.0 | | | | | | | | | |
| o-Xylene | U | 1.0 | | | | | | | | | |
| sec-Butylbenzene | U | 1.0 | | | | | | | | | |
| Styrene | U | 1.0 | | | | | | | | | |
| tert-Butylbenzene | U | 1.0 | | | | | | | | | |
| Tetrachloroethene | U | 1.0 | | | | | | | | | |
| Toluene | U | 1.0 | | | | | | | | | |
| trans-1,2-Dichloroethene | U | 1.0 | | | | | | | | | |
| trans-1,3-Dichloropropene | U | 1.0 | | | | | | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes
 J Analyte detected below quantitation limits
 ND Not Detected at the Reporting Limit
 E Value above quantitation range
 LOD Limit of Detection
 R RPD outside accepted recovery limits
 H Holding times for preparation or analy
 LOQ Limit of Quantitation
 S Spike Recovery outside accepted reco

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 1003153
Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

| | | | | | | | | | | | |
|----------------------------------|--------------------------|-----------------------------|--------------------|---------------------------------|----------------------|----------|-----------|-------------|------|----------|------|
| Sample ID: VBLK-032210aYW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49606 | | | | | | |
| Client ID: PBW | Batch ID: R49606A | TestNo: SW8260B | | Analysis Date: 3/22/2010 | SeqNo: 686845 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|----------------------------|----|-----|-------|--|------|----|-----|--|--|--|--|
| Trichloroethene | U | 1.0 | | | | | | | | | |
| Trichlorofluoromethane | U | 1.0 | | | | | | | | | |
| Vinyl acetate | U | 1.0 | | | | | | | | | |
| Vinyl chloride | U | 1.0 | | | | | | | | | |
| Surr: 4-Bromofluorobenzene | 50 | | 50.00 | | 101 | 60 | 130 | | | | |
| Surr: Dibromofluoromethane | 48 | | 50.00 | | 96.2 | 63 | 127 | | | | |
| Surr: Toluene-d8 | 52 | | 50.00 | | 103 | 61 | 128 | | | | |

Qualifiers:

- C Calibration %RSD/%D exceeded for non-CCC analytes
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- E Value above quantitation range
- LOD Limit of Detection
- R RPD outside accepted recovery limits
- H Holding times for preparation or analysis
- LOQ Limit of Quantitation
- S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 1003153
Project: Rowe

TestCode: FE_D

| | | | | | |
|-------------------------------|------------------------|-----------------------|--------------------|---------------------------------|----------------------|
| Sample ID: PBW-031810A | SampType: MBLK | TestCode: FE_D | Units: mg/L | Prep Date: 3/18/2010 | RunNo: 49534 |
| Client ID: PBW | Batch ID: 28439 | TestNo: E200.7 | SW3005A | Analysis Date: 3/19/2010 | SeqNo: 685808 |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC |
| Iron | U | 0.0200 | | | |
| | | | | LowLimit | HighLimit |
| | | | | RPD Ref Val | RPD |
| | | | | | RPDLimit |
| | | | | | Qual |

| | | | | | |
|--------------------------------|------------------------|-----------------------|--------------------|---------------------------------|----------------------|
| Sample ID: LCSW-031810A | SampType: LCS | TestCode: FE_D | Units: mg/L | Prep Date: 3/18/2010 | RunNo: 49534 |
| Client ID: LCSW | Batch ID: 28439 | TestNo: E200.7 | SW3005A | Analysis Date: 3/19/2010 | SeqNo: 685809 |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC |
| Iron | 2.00 | 0.0200 | 2.000 | 0 | 100 |
| | | | | LowLimit | HighLimit |
| | | | | RPD Ref Val | RPD |
| | | | | | RPDLimit |
| | | | | | Qual |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

CLIENT: Leggett Brashears & Graham Inc.
Work Order: 1003153
Project: Rowe

TestCode: FE_T

| | | | | | | | | | | | |
|-------------------------------|------------------------|-----------------------|--------------------|---------------------------------|----------------------|----------|-----------|-------------|------|----------|------|
| Sample ID: PBW-031810B | SampType: MBLK | TestCode: FE_T | Units: mg/L | Prep Date: 3/18/2010 | RunNo: 49534 | | | | | | |
| Client ID: PBW | Batch ID: 28440 | TestNo: E200.7 | SW3010A | Analysis Date: 3/19/2010 | SeqNo: 685734 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| Iron | U | 0.0200 | | | | | | | | | |

| | | | | | | | | | | | |
|--------------------------------|------------------------|-----------------------|--------------------|---------------------------------|----------------------|----------|-----------|-------------|------|----------|------|
| Sample ID: LCSW-031810B | SampType: LCS | TestCode: FE_T | Units: mg/L | Prep Date: 3/18/2010 | RunNo: 49534 | | | | | | |
| Client ID: LCSW | Batch ID: 28440 | TestNo: E200.7 | SW3010A | Analysis Date: 3/19/2010 | SeqNo: 685735 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| Iron | 2.08 | 0.0200 | 2.000 | 0 | 104 | 68 | 122 | | | | |

| | | | | | | | | | | | |
|----------------------------------|------------------------|-----------------------|--------------------|---------------------------------|----------------------|----------|-----------|-------------|------|----------|------|
| Sample ID: 1003155-08B-MS | SampType: MS | TestCode: FE_T | Units: mg/L | Prep Date: 3/18/2010 | RunNo: 49534 | | | | | | |
| Client ID: ZZZZZZ | Batch ID: 28440 | TestNo: E200.7 | SW3010A | Analysis Date: 3/19/2010 | SeqNo: 685764 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| Iron | 3.64 | 0.0200 | 1.000 | 2.644 | 99.7 | 68 | 122 | | | | |

| | | | | | | | | | | | |
|-----------------------------------|------------------------|-----------------------|--------------------|---------------------------------|----------------------|----------|-----------|-------------|-------|----------|------|
| Sample ID: 1003155-08B-MSD | SampType: MSD | TestCode: FE_T | Units: mg/L | Prep Date: 3/18/2010 | RunNo: 49534 | | | | | | |
| Client ID: ZZZZZZ | Batch ID: 28440 | TestNo: E200.7 | SW3010A | Analysis Date: 3/19/2010 | SeqNo: 685765 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| Iron | 3.63 | 0.0200 | 1.000 | 2.644 | 99.0 | 68 | 122 | 3.641 | 0.191 | 20 | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

TestCode: TDS_W

CLIENT: Leggette Brashears & Graham Inc.
 Work Order: 1003153
 Project: Rowe

| | | | | | |
|----------------------|------------------|-----------------|-------------|--------------------------|---------------|
| Sample ID: MB-R49597 | SampType: MBLK | TestCode: TDS_W | Units: mg/L | Prep Date: | RunNo: 49597 |
| Client ID: PBW | Batch ID: R49597 | TestNo: M2540C | | Analysis Date: 3/19/2010 | SeqNo: 686682 |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC |
| | | | | LowLimit | HighLimit |
| | | | | RPD Ref Val | %RPD |
| | | | | | RPDLimit |
| | | | | | Qual |

Total Dissolved Solids (Residue, Filtera) U 1.00

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

Monday, April 05, 2010

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555

FAX (203) 926-9140

RE: Rowe

Order No.: 1003214

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 3/25/2010 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The results reported herein relate only to the items tested or to the samples as received by the laboratory. This report may not be reproduced, except in full, without the approval of American Analytical Laboratories, LLC and is not considered complete without a cover page and chain of custody documentation. The limits (LOQ) provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report or the data is qualified. This package has been reviewed by American Analytical Laboratories' QA Department/Laboratory Director to comply with NELAC standards prior to report submittal. This report consists of 31 pages.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe
Lab Order: 1003214

Work Order Sample Summary

| Lab Sample ID | Client Sample ID | Date Collected | Date Received |
|----------------------|-------------------------|-----------------------|----------------------|
| 1003214-01A | WQ32310:1310NP2-6 | 3/23/2010 1:10:00 PM | 3/25/2010 |
| 1003214-01B | WQ32310:1310NP2-6 | 3/23/2010 1:10:00 PM | 3/25/2010 |
| 1003214-01C | WQ32310:1310NP2-6 | 3/23/2010 1:10:00 PM | 3/25/2010 |
| 1003214-02A | WQ32310:1315NP2-7 | 3/23/2010 1:15:00 PM | 3/25/2010 |
| 1003214-02B | WQ32310:1315NP2-7 | 3/23/2010 1:15:00 PM | 3/25/2010 |
| 1003214-02C | WQ32310:1315NP2-7 | 3/23/2010 1:15:00 PM | 3/25/2010 |
| 1003214-03A | WQ32310:1320NP2-10 | 3/23/2010 1:20:00 PM | 3/25/2010 |
| 1003214-03B | WQ32310:1320NP2-10 | 3/23/2010 1:20:00 PM | 3/25/2010 |
| 1003214-03C | WQ32310:1320NP2-10 | 3/23/2010 1:20:00 PM | 3/25/2010 |
| 1003214-03D | WQ32310:1320NP2-10 | 3/23/2010 1:20:00 PM | 3/25/2010 |

American Analytical Laboratories, LLC.

Sample Receipt Checklist

Client Name LBG CT

Date and Time Receive 3/25/2010 9:55:51 AM

Work Order Number 1003214

RcptNo: 1

Received by CB

COC_ID:

CoolerID:

Checklist completed by

Signature: CBam Date: 3/25/10

Reviewed by

Initials: JB Date: 3/25/10

Matrix:

Carrier name FedEx

- Shipping container/cooler in good condition? Yes No Not Present
- Custody seals intact on shipping container/cooler? Yes No Not Present
- Custody seals intact on sample bottles? Yes No Not Present
- Chain of custody present? Yes No
- Chain of custody signed when relinquished and received? Yes No
- Chain of custody agrees with sample labels? Yes No
- Samples in proper container/bottle? Yes No
- Sample containers intact? Yes No
- Sufficient sample volume for indicated test? Yes No
- All samples received within holding time? Yes No
- Container/Temp Blank temperature in compliance? Yes No
- Water - VOA vials have zero headspace? Yes No VOA vials submitted Yes No
- Water - pH acceptable upon receipt? Yes No N/A

Adjusted? _____ Checked b _____

Any No and/or NA (not applicable) response must be detailed in the comments section be

Client contacted _____ Date contacted: _____ Person contacted _____

Contacted by: _____ Regarding: _____

Comments: Cooler with ice @ 4.8C

Corrective Action _____

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003214
 Project: Rowe
 Lab ID: 1003214-01A

Client Sample ID: WQ32310:1310NP2-6
 Collection Date: 3/23/2010 1:10:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|-----|----------------|-------|-------------|---------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | | SW8260B | | Analyst: LA | |
| 1,1,1,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| 1,1,1-Trichloroethane | 2.0 | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| 1,1,2,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| 1,1,2-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| 1,1-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| 1,1-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| 1,1-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| 1,2,3-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| 1,2,3-Trichloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| 1,2,4-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| 1,2,4-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| 1,2-Dibromo-3-chloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| 1,2-Dibromoethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| 1,2-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| 1,2-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| 1,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| 1,3,5-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| 1,3-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| 1,3-dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| 1,4-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| 2,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| 2-Butanone | U | 0.3 | 3.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| 2-Chloroethyl vinyl ether | U | 0.3 | 1.0 | C | µg/L | 1 | 4/2/2010 4:11:00 PM |
| 2-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| 2-Hexanone | U | 0.3 | 2.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| 4-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| 4-Isopropyltoluene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| 4-Methyl-2-pentanone | U | 0.3 | 2.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| Acetone | U | 0.3 | 2.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| Benzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| Bromobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| Bromochloromethane | U | 0.4 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003214
 Project: Rowe
 Lab ID: 1003214-01A

Client Sample ID: WQ32310:1310NP2-6
 Collection Date: 3/23/2010 1:10:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|-----|------|-------|----|---------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | | | | | Analyst: LA |
| SW8260B | | | | | | | |
| Bromodichloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| Bromoform | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| Bromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| Carbon disulfide | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| Carbon tetrachloride | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| Chlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| Chloroethane | U | 0.4 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| Chloroform | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| Chloromethane | U | 0.3 | 1.0 | C | µg/L | 1 | 4/2/2010 4:11:00 PM |
| cis-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| cis-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| Dibromochloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| Dibromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| Dichlorodifluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| Ethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| Hexachlorobutadiene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| Isopropylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| m,p-Xylene | U | 0.3 | 2.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| Methyl tert-butyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| Methylene chloride | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| Naphthalene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| n-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| n-Propylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| o-Xylene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| sec-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| Styrene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| tert-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| Tetrachloroethene | 6.0 | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| Toluene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| trans-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| trans-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| Trichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| Trichlorofluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 05-Apr-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003214
 Project: Rowe
 Lab ID: 1003214-01A

Client Sample ID: WQ32310:1310NP2-6
 Collection Date: 3/23/2010 1:10:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|--------|------|-------|----|---------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | | | | | Analyst: LA |
| Vinyl acetate | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| Vinyl chloride | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:11:00 PM |
| Surr: 4-Bromofluorobenzene | 90.3 | 0 | 60-130 | | %REC | 1 | 4/2/2010 4:11:00 PM |
| Surr: Dibromofluoromethane | 97.3 | 0 | 63-127 | | %REC | 1 | 4/2/2010 4:11:00 PM |
| Surr: Toluene-d8 | 98.4 | 0 | 61-128 | | %REC | 1 | 4/2/2010 4:11:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003214
 Project: Rowe
 Lab ID: 1003214-01B

Client Sample ID: WQ32310:1310NP2-6
 Collection Date: 3/23/2010 1:10:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|------------|---------------|-------|--------|--------|---------|----|----------------------|
| TOTAL IRON | | | | E200.7 | SW3010A | | Analyst: JP |
| Iron | 1.36 | 0.005 | 0.0200 | | mg/L | 1 | 3/29/2010 3:16:21 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003214
 Project: Rowe
 Lab ID: 1003214-01C

Client Sample ID: WQ32310:1310NP2-6
 Collection Date: 3/23/2010 1:10:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|----------------|---------------|-------|--------|--------|---------|----|----------------------|
| DISSOLVED IRON | | | | E200.7 | SW3010A | | Analyst: JP |
| Iron | 0.105 | 0.005 | 0.0200 | | mg/L | 1 | 3/29/2010 3:14:18 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- Qualifiers:**
- * Value exceeds Maximum Contaminant Level
 - C Calibration %RSD/%D exceeded for non-CCC analytes
 - H Holding times for preparation or analysis exceeded
 - LOD Limit of Detection
 - ND Not Detected at the Reporting Limit
 - U Indicates the compound was analyzed but not detected.
 - B Analyte detected in the associated Method Blank
 - E Value above quantitation range
 - J Analyte detected below quantitation limits
 - LOQ Limit of Quantitation
 - S Spike Recovery outside accepted recovery limits

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003214
 Project: Rowe
 Lab ID: 1003214-02A

Client Sample ID: WQ32310:1315NP2-7
 Collection Date: 3/23/2010 1:15:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|-----|------|-------|----|---------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | | | | | |
| SW8260B | | | | | | | Analyst: LA |
| 1,1,1,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| 1,1,1-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| 1,1,2,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 0.3 | 1.0 | C | µg/L | 1 | 4/2/2010 4:36:00 PM |
| 1,1,2-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| 1,1-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| 1,1-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| 1,1-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| 1,2,3-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| 1,2,3-Trichloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| 1,2,4-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| 1,2,4-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| 1,2-Dibromo-3-chloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| 1,2-Dibromoethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| 1,2-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| 1,2-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| 1,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| 1,3,5-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| 1,3-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| 1,3-dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| 1,4-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| 2,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| 2-Butanone | U | 0.3 | 3.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| 2-Chloroethyl vinyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| 2-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| 2-Hexanone | U | 0.3 | 2.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| 4-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| 4-Isopropyltoluene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| 4-Methyl-2-pentanone | U | 0.3 | 2.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| Acetone | U | 0.3 | 2.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| Benzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| Bromobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| Bromochloromethane | U | 0.4 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003214
 Project: Rowe
 Lab ID: 1003214-02A

Client Sample ID: WQ32310:1315NP2-7
 Collection Date: 3/23/2010 1:15:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------|----|---------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | | | | | |
| | | | SW8260B | | | | Analyst: LA |
| Bromodichloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| Bromoform | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| Bromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| Carbon disulfide | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| Carbon tetrachloride | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| Chlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| Chloroethane | U | 0.4 | 1.0 | C | µg/L | 1 | 4/2/2010 4:36:00 PM |
| Chloroform | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| Chloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| cis-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| cis-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| Dibromochloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| Dibromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| Dichlorodifluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| Ethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| Hexachlorobutadiene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| Isopropylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| m,p-Xylene | U | 0.3 | 2.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| Methyl tert-butyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| Methylene chloride | U | 0.3 | 1.0 | C | µg/L | 1 | 4/2/2010 4:36:00 PM |
| Naphthalene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| n-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| n-Propylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| o-Xylene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| sec-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| Styrene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| tert-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| Tetrachloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| Toluene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| trans-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| trans-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| Trichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| Trichlorofluoromethane | U | 0.3 | 1.0 | C | µg/L | 1 | 4/2/2010 4:36:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 05-Apr-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003214
 Project: Rowe
 Lab ID: 1003214-02A

Client Sample ID: WQ32310:1315NP2-7
 Collection Date: 3/23/2010 1:15:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|--------|------|-------|----|---------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | | | | | Analyst: LA |
| Vinyl acetate | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| Vinyl chloride | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 4:36:00 PM |
| Surr: 4-Bromofluorobenzene | 95.1 | 0 | 60-130 | | %REC | 1 | 4/2/2010 4:36:00 PM |
| Surr: Dibromofluoromethane | 106 | 0 | 63-127 | | %REC | 1 | 4/2/2010 4:36:00 PM |
| Surr: Toluene-d8 | 102 | 0 | 61-128 | | %REC | 1 | 4/2/2010 4:36:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- Qualifiers:**
- * Value exceeds Maximum Contaminant Level
 - B Analyte detected in the associated Method Blank
 - C Calibration %RSD/%D exceeded for non-CCC analytes
 - E Value above quantitation range
 - H Holding times for preparation or analysis exceeded
 - J Analyte detected below quantitation limits
 - LOD Limit of Detection
 - LOQ Limit of Quantitation
 - ND Not Detected at the Reporting Limit
 - S Spike Recovery outside accepted recovery limits
 - U Indicates the compound was analyzed but not detected.

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003214
 Project: Rowe
 Lab ID: 1003214-02B

Client Sample ID: WQ32310:1315NP2-7
 Collection Date: 3/23/2010 1:15:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|------------|---------------|-------|--------|------|---------|----|----------------------|
| TOTAL IRON | | | E200.7 | | SW3010A | | Analyst: JP |
| Iron | 0.818 | 0.005 | 0.0200 | | mg/L | 1 | 3/29/2010 3:20:28 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003214
 Project: Rowe
 Lab ID: 1003214-02C

Client Sample ID: WQ32310:1315NP2-7
 Collection Date: 3/23/2010 1:15:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|----------------|---------------|-------|--------|--------|---------|----|----------------------|
| DISSOLVED IRON | | | | E200.7 | SW3010A | | Analyst: JP |
| Iron | 0.101 | 0.005 | 0.0200 | | mg/L | 1 | 3/29/2010 3:18:24 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- Qualifiers:**
- * Value exceeds Maximum Contaminant Level
 - C Calibration %RSD/%D exceeded for non-CCC analytes
 - H Holding times for preparation or analysis exceeded
 - LOD Limit of Detection
 - ND Not Detected at the Reporting Limit
 - U Indicates the compound was analyzed but not detected.
 - B Analyte detected in the associated Method Blank
 - E Value above quantitation range
 - J Analyte detected below quantitation limits
 - LOQ Limit of Quantitation
 - S Spike Recovery outside accepted recovery limits

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003214
 Project: Rowe
 Lab ID: 1003214-03A

Client Sample ID: WQ32310:1320NP2-10
 Collection Date: 3/23/2010 1:20:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|-----|------|-------|----|---------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | | | | | Analyst: LA |
| SW8260B | | | | | | | |
| 1,1,1,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| 1,1,1-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| 1,1,2,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| 1,1,2-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| 1,1-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| 1,1-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| 1,1-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| 1,2,3-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| 1,2,3-Trichloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| 1,2,4-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| 1,2,4-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| 1,2-Dibromo-3-chloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| 1,2-Dibromoethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| 1,2-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| 1,2-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| 1,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| 1,3,5-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| 1,3-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| 1,3-dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| 1,4-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| 2,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| 2-Butanone | U | 0.3 | 3.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| 2-Chloroethyl vinyl ether | U | 0.3 | 1.0 | C | µg/L | 1 | 4/2/2010 5:02:00 PM |
| 2-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| 2-Hexanone | U | 0.3 | 2.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| 4-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| 4-Isopropyltoluene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| 4-Methyl-2-pentanone | U | 0.3 | 2.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| Acetone | U | 0.3 | 2.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| Benzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| Bromobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| Bromochloromethane | U | 0.4 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003214
 Project: Rowe
 Lab ID: 1003214-03A

Client Sample ID: WQ32310:1320NP2-10
 Collection Date: 3/23/2010 1:20:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|-----|------|-------|----|---------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | | | | | |
| | | | | | | | Analyst: LA |
| Bromodichloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| Bromoform | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| Bromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| Carbon disulfide | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| Carbon tetrachloride | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| Chlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| Chloroethane | U | 0.4 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| Chloroform | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| Chloromethane | U | 0.3 | 1.0 | C | µg/L | 1 | 4/2/2010 5:02:00 PM |
| cis-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| cis-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| Dibromochloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| Dibromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| Dichlorodifluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| Ethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| Hexachlorobutadiene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| Isopropylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| m,p-Xylene | U | 0.3 | 2.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| Methyl tert-butyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| Methylene chloride | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| Naphthalene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| n-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| n-Propylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| o-Xylene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| sec-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| Styrene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| tert-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| Tetrachloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| Toluene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| trans-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| trans-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| Trichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| Trichlorofluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003214
 Project: Rowe
 Lab ID: 1003214-03A

Client Sample ID: WQ32310:1320NP2-10
 Collection Date: 3/23/2010 1:20:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|--------|------|-------|----|---------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | | | | | Analyst: LA |
| Vinyl acetate | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| Vinyl chloride | U | 0.3 | 1.0 | | µg/L | 1 | 4/2/2010 5:02:00 PM |
| Surr: 4-Bromofluorobenzene | 92.5 | 0 | 60-130 | | %REC | 1 | 4/2/2010 5:02:00 PM |
| Surr: Dibromofluoromethane | 94.3 | 0 | 63-127 | | %REC | 1 | 4/2/2010 5:02:00 PM |
| Surr: Toluene-d8 | 97.8 | 0 | 61-128 | | %REC | 1 | 4/2/2010 5:02:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- Qualifiers:**
- * Value exceeds Maximum Contaminant Level
 - C Calibration %RSD/%D exceeded for non-CCC analytes
 - H Holding times for preparation or analysis exceeded
 - LOD Limit of Detection
 - ND Not Detected at the Reporting Limit
 - U Indicates the compound was analyzed but not detected.
 - B Analyte detected in the associated Method Blank
 - E Value above quantitation range
 - J Analyte detected below quantitation limits
 - LOQ Limit of Quantitation
 - S Spike Recovery outside accepted recovery limits

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003214
 Project: Rowe
 Lab ID: 1003214-03B

Client Sample ID: WQ32310:1320NP2-10
 Collection Date: 3/23/2010 1:20:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|------------|---------------|-------|--------|------|---------|----|----------------------|
| TOTAL IRON | | | E200.7 | | SW3010A | | Analyst: JP |
| Iron | 0.919 | 0.005 | 0.0200 | | mg/L | 1 | 3/29/2010 3:35:26 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- Qualifiers:**
- * Value exceeds Maximum Contaminant Level
 - B Analyte detected in the associated Method Blank
 - C Calibration %RSD/%D exceeded for non-CCC analytes
 - E Value above quantitation range
 - H Holding times for preparation or analysis exceeded
 - J Analyte detected below quantitation limits
 - LOD Limit of Detection
 - LOQ Limit of Quantitation
 - ND Not Detected at the Reporting Limit
 - S Spike Recovery outside accepted recovery limits
 - U Indicates the compound was analyzed but not detected.

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003214
 Project: Rowe
 Lab ID: 1003214-03C

Client Sample ID: WQ32310:1320NP2-10
 Collection Date: 3/23/2010 1:20:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|----------------|---------------|-------|--------|------|---------|----|----------------------|
| DISSOLVED IRON | | | E200.7 | | SW3010A | | Analyst: JP |
| Iron | 0.112 | 0.005 | 0.0200 | | mg/L | 1 | 3/29/2010 3:33:21 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- Qualifiers:**
- * Value exceeds Maximum Contaminant Level
 - B Analyte detected in the associated Method Blank
 - C Calibration %RSD/%D exceeded for non-CCC analytes
 - E Value above quantitation range
 - H Holding times for preparation or analysis exceeded
 - J Analyte detected below quantitation limits
 - LOD Limit of Detection
 - LOQ Limit of Quantitation
 - ND Not Detected at the Reporting Limit
 - S Spike Recovery outside accepted recovery limits
 - U Indicates the compound was analyzed but not detected.

American Analytical Laboratories, LLC.

Date: 05-Apr-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003214
 Project: Rowe
 Lab ID: 1003214-03D

Client Sample ID: WQ32310:1320NP2-10
 Collection Date: 3/23/2010 1:20:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|--|---------------|-----|------|---------------|-------|----|--------------------|
| TOTAL DISSOLVED SOLIDS | | | | M2540C | | | Analyst: AS |
| Total Dissolved Solids (Residue, Filterable) | 104 | 0 | 1.00 | | mg/L | 1 | 3/25/2010 |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- Qualifiers:**
- * Value exceeds Maximum Contaminant Level
 - C Calibration %RSD/%D exceeded for non-CCC analytes
 - H Holding times for preparation or analysis exceeded
 - LOD Limit of Detection
 - ND Not Detected at the Reporting Limit
 - U Indicates the compound was analyzed but not detected.
 - B Analyte detected in the associated Method Blank
 - E Value above quantitation range
 - J Analyte detected below quantitation limits
 - LOQ Limit of Quantitation
 - S Spike Recovery outside accepted recovery limits

American Analytical Laboratories, LLC.

Date: 05-Apr-10

CLIENT: Leggett Brashears & Graham Inc.
Work Order: 1003214
Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

Sample ID: V624LCS-040210YW SampType: LCS TestCode: 8260MTBE11 Units: µg/L Prep Date: RunNo: 49804
 Client ID: LCSW Batch ID: R49804 TestNo: SW8260B Analysis Date: 4/2/2010 SeqNo: 691404

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---------------------------|--------|-----|-----------|-------------|------|----------|-----------|-------------|------|----------|------|
| 1,1,1-Trichloroethane | 49 | 1.0 | 50.00 | 0 | 98.4 | 43 | 148 | | | | |
| 1,1,2,2-Tetrachloroethane | 42 | 1.0 | 50.00 | 0 | 84.0 | 32 | 148 | | | | |
| 1,1,2-Trichloroethane | 47 | 1.0 | 50.00 | 0 | 93.7 | 42 | 136 | | | | |
| 1,1-Dichloroethane | 48 | 1.0 | 50.00 | 0 | 95.4 | 40 | 150 | | | | |
| 1,1-Dichloroethene | 51 | 1.0 | 50.00 | 0 | 102 | 30 | 154 | | | | |
| 1,2-Dichlorobenzene | 45 | 1.0 | 50.00 | 0 | 89.5 | 40 | 129 | | | | |
| 1,2-Dichloroethane | 47 | 1.0 | 50.00 | 0 | 94.0 | 36 | 141 | | | | |
| 1,2-Dichloropropane | 45 | 1.0 | 50.00 | 0 | 90.3 | 44 | 138 | | | | |
| 1,3-Dichlorobenzene | 45 | 1.0 | 50.00 | 0 | 89.2 | 40 | 133 | | | | |
| 1,4-Dichlorobenzene | 46 | 1.0 | 50.00 | 0 | 91.8 | 40 | 135 | | | | |
| 2-Chloroethyl vinyl ether | 32 | 1.0 | 50.00 | 0 | 64.8 | 21 | 139 | | | | C |
| Benzene | 49 | 1.0 | 50.00 | 0 | 98.1 | 45 | 144 | | | | |
| Bromodichloromethane | 47 | 1.0 | 50.00 | 0 | 94.1 | 35 | 136 | | | | |
| Bromoform | 42 | 1.0 | 50.00 | 0 | 84.7 | 28 | 138 | | | | |
| Bromomethane | 40 | 1.0 | 50.00 | 0 | 79.2 | 26 | 148 | | | | |
| Carbon tetrachloride | 49 | 1.0 | 50.00 | 0 | 97.8 | 45 | 141 | | | | |
| Chlorobenzene | 48 | 1.0 | 50.00 | 0 | 96.4 | 41 | 142 | | | | |
| Chloroethane | 57 | 1.0 | 50.00 | 0 | 114 | 36 | 143 | | | | |
| Chloroform | 49 | 1.0 | 50.00 | 0 | 98.1 | 42 | 137 | | | | |
| Chloromethane | 50 | 1.0 | 50.00 | 0 | 101 | 35 | 151 | | | | C |
| cis-1,3-Dichloropropene | 47 | 1.0 | 50.00 | 0 | 93.4 | 42 | 130 | | | | |
| Dibromochloromethane | 44 | 1.0 | 50.00 | 0 | 87.1 | 21 | 134 | | | | |
| Ethylbenzene | 47 | 1.0 | 50.00 | 0 | 94.8 | 45 | 146 | | | | |
| Tetrachloroethene | 48 | 1.0 | 50.00 | 0 | 96.7 | 45 | 136 | | | | |
| Toluene | 48 | 1.0 | 50.00 | 0 | 96.8 | 43 | 134 | | | | |
| trans-1,2-Dichloroethene | 50 | 1.0 | 50.00 | 0 | 100 | 42 | 135 | | | | |
| trans-1,3-Dichloropropene | 46 | 1.0 | 50.00 | 0 | 92.2 | 37 | 133 | | | | |
| Trichloroethene | 48 | 1.0 | 50.00 | 0 | 96.4 | 43 | 140 | | | | |
| Trichlorofluoromethane | 59 | 1.0 | 50.00 | 0 | 118 | 50 | 148 | | | | |
| Vinyl chloride | 49 | 1.0 | 50.00 | 0 | 97.4 | 35 | 142 | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analyte
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 1003214
Project: Rowe

TestCode: 8260MTBE113_W

| | | | |
|------------------------------------|-------------------------|--------------------------------|----------------------|
| Sample ID: V624LCS-040210YW | SampType: LCS | TestCode: 8260MTBE11 | Units: µg/L |
| Client ID: LCSW | Batch ID: R49804 | TestNo: SW8260B | |
| Analyte | | Result | PQL |
| Surr: 4-Bromofluorobenzene | 48 | 50.00 | 96.4 |
| Surr: Dibromofluoromethane | 49 | 50.00 | 98.8 |
| Surr: Toluene-d8 | 51 | 50.00 | 102 |
| | | | LowLimit |
| | | | HighLimit |
| | | | RPD Ref Val |
| | | | %RPD |
| | | | RPDLimit |
| | | | Qual |
| | | Prep Date: | RunNo: 49804 |
| | | Analysis Date: 4/2/2010 | SeqNo: 691404 |

| | | | |
|---------------------------------------|-------------------------|--------------------------------|----------------------|
| Sample ID: VBLK-040210YW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L |
| Client ID: PBW | Batch ID: R49804 | TestNo: SW8260B | |
| Analyte | | Result | PQL |
| 1,1,1,2-Tetrachloroethane | U | 1.0 | |
| 1,1,1-Trichloroethane | U | 1.0 | |
| 1,1,2,2-Tetrachloroethane | U | 1.0 | |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 1.0 | |
| 1,1,2-Trichloroethane | U | 1.0 | |
| 1,1-Dichloroethane | U | 1.0 | |
| 1,1-Dichloroethene | U | 1.0 | |
| 1,1-Dichloropropene | U | 1.0 | |
| 1,2,3-Trichlorobenzene | U | 1.0 | |
| 1,2,3-Trichloropropane | U | 1.0 | |
| 1,2,4-Trichlorobenzene | U | 1.0 | |
| 1,2,4-Trimethylbenzene | U | 1.0 | |
| 1,2-Dibromo-3-chloropropane | U | 1.0 | |
| 1,2-Dibromoethane | U | 1.0 | |
| 1,2-Dichlorobenzene | U | 1.0 | |
| 1,2-Dichloroethane | U | 1.0 | |
| 1,2-Dichloropropane | U | 1.0 | |
| 1,3,5-Trimethylbenzene | U | 1.0 | |
| 1,3-Dichlorobenzene | U | 1.0 | |
| 1,3-dichloropropane | U | 1.0 | |
| 1,4-Dichlorobenzene | U | 1.0 | |
| 2,2-Dichloropropane | U | 1.0 | |
| 2-Butanone | U | 3.0 | |
| | | Prep Date: | RunNo: 49804 |
| | | Analysis Date: 4/2/2010 | SeqNo: 691405 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | Units: µg/L | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---------------------------------------|--------|-----|-----------|-------------|-------------|------|----------|-----------|-------------|------|----------|------|
| 1,1,1,2-Tetrachloroethane | U | 1.0 | | | | | | | | | | |
| 1,1,1-Trichloroethane | U | 1.0 | | | | | | | | | | |
| 1,1,2,2-Tetrachloroethane | U | 1.0 | | | | | | | | | | |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 1.0 | | | | | | | | | | |
| 1,1,2-Trichloroethane | U | 1.0 | | | | | | | | | | |
| 1,1-Dichloroethane | U | 1.0 | | | | | | | | | | |
| 1,1-Dichloroethene | U | 1.0 | | | | | | | | | | |
| 1,1-Dichloropropene | U | 1.0 | | | | | | | | | | |
| 1,2,3-Trichlorobenzene | U | 1.0 | | | | | | | | | | |
| 1,2,3-Trichloropropane | U | 1.0 | | | | | | | | | | |
| 1,2,4-Trichlorobenzene | U | 1.0 | | | | | | | | | | |
| 1,2,4-Trimethylbenzene | U | 1.0 | | | | | | | | | | |
| 1,2-Dibromo-3-chloropropane | U | 1.0 | | | | | | | | | | |
| 1,2-Dibromoethane | U | 1.0 | | | | | | | | | | |
| 1,2-Dichlorobenzene | U | 1.0 | | | | | | | | | | |
| 1,2-Dichloroethane | U | 1.0 | | | | | | | | | | |
| 1,2-Dichloropropane | U | 1.0 | | | | | | | | | | |
| 1,3,5-Trimethylbenzene | U | 1.0 | | | | | | | | | | |
| 1,3-Dichlorobenzene | U | 1.0 | | | | | | | | | | |
| 1,3-dichloropropane | U | 1.0 | | | | | | | | | | |
| 1,4-Dichlorobenzene | U | 1.0 | | | | | | | | | | |
| 2,2-Dichloropropane | U | 1.0 | | | | | | | | | | |
| 2-Butanone | U | 3.0 | | | | | | | | | | |

| Qualifiers: | C | Calibration %RSD/%D exceeded for non-CCC analytes | E | Value above quantitation range | H | Holding times for preparation or analy |
|-------------|----|---|-----|--------------------------------------|-----|--|
| | J | Analyte detected below quantitation limits | LOD | Limit of Detection | LOQ | Limit of Quantitation |
| | ND | Not Detected at the Reporting Limit | R | RPD outside accepted recovery limits | S | Spike Recovery outside accepted reco |

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 1003214
Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

| | | | | | | | | | | | |
|--------------------------|------------------|----------------------|-------------|-------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Sample ID: VBLK-040210YW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49804 | | | | | | |
| Client ID: PBW | Batch ID: R49804 | TestNo: SW8260B | | Analysis Date: 4/2/2010 | SeqNo: 691405 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|---------------------------|---|-----|--|--|--|--|--|--|--|--|---|
| 2-Chloroethyl vinyl ether | U | 1.0 | | | | | | | | | C |
| 2-Chlorotoluene | U | 1.0 | | | | | | | | | |
| 2-Hexanone | U | 2.0 | | | | | | | | | |
| 4-Chlorotoluene | U | 1.0 | | | | | | | | | |
| 4-Isopropyltoluene | U | 1.0 | | | | | | | | | |
| 4-Methyl-2-pentanone | U | 2.0 | | | | | | | | | |
| Acetone | U | 2.0 | | | | | | | | | |
| Benzene | U | 1.0 | | | | | | | | | |
| Bromobenzene | U | 1.0 | | | | | | | | | |
| Bromochloromethane | U | 1.0 | | | | | | | | | |
| Bromodichloromethane | U | 1.0 | | | | | | | | | |
| Bromoform | U | 1.0 | | | | | | | | | |
| Bromomethane | U | 1.0 | | | | | | | | | |
| Carbon disulfide | U | 1.0 | | | | | | | | | |
| Carbon tetrachloride | U | 1.0 | | | | | | | | | |
| Chlorobenzene | U | 1.0 | | | | | | | | | |
| Chloroethane | U | 1.0 | | | | | | | | | |
| Chloroform | U | 1.0 | | | | | | | | | |
| Chloromethane | U | 1.0 | | | | | | | | | |
| cis-1,2-Dichloroethene | U | 1.0 | | | | | | | | | |
| cis-1,3-Dichloropropene | U | 1.0 | | | | | | | | | |
| Dibromochloromethane | U | 1.0 | | | | | | | | | |
| Dibromomethane | U | 1.0 | | | | | | | | | |
| Dichlorodifluoromethane | U | 1.0 | | | | | | | | | |
| Ethylbenzene | U | 1.0 | | | | | | | | | |
| Hexachlorobutadiene | U | 1.0 | | | | | | | | | |
| Isopropylbenzene | U | 1.0 | | | | | | | | | |
| m,p-Xylene | U | 2.0 | | | | | | | | | |
| Methyl tert-butyl ether | U | 1.0 | | | | | | | | | |
| Methylene chloride | U | 1.0 | | | | | | | | | |
| Naphthalene | U | 1.0 | | | | | | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

CLIENT: Leggett Brashears & Graham Inc.
Work Order: 1003214
Project: Rowe

TestCode: 8260MTBE113_W

| | | | | | | | | | | | |
|---------------------------------|-------------------------|-----------------------------|--------------------|--------------------------------|----------------------|----------|-----------|-------------|------|----------|------|
| Sample ID: VBLK-040210YW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49804 | | | | | | |
| Client ID: PBW | Batch ID: R49804 | TestNo: SW8260B | | Analysis Date: 4/2/2010 | SeqNo: 691405 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|----------------------------|----|-----|-------|--|------|----|-----|--|--|--|--|
| n-Butylbenzene | U | 1.0 | | | | | | | | | |
| n-Propylbenzene | U | 1.0 | | | | | | | | | |
| o-Xylene | U | 1.0 | | | | | | | | | |
| sec-Butylbenzene | U | 1.0 | | | | | | | | | |
| Styrene | U | 1.0 | | | | | | | | | |
| tert-Butylbenzene | U | 1.0 | | | | | | | | | |
| Tetrachloroethene | U | 1.0 | | | | | | | | | |
| Toluene | U | 1.0 | | | | | | | | | |
| trans-1,2-Dichloroethene | U | 1.0 | | | | | | | | | |
| trans-1,3-Dichloropropene | U | 1.0 | | | | | | | | | |
| Trichloroethene | U | 1.0 | | | | | | | | | |
| Trichlorofluoromethane | U | 1.0 | | | | | | | | | |
| Vinyl acetate | U | 1.0 | | | | | | | | | |
| Vinyl chloride | U | 1.0 | | | | | | | | | |
| Surr: 4-Bromofluorobenzene | 49 | | 50.00 | | 99.0 | 60 | 130 | | | | |
| Surr: Dibromofluoromethane | 50 | | 50.00 | | 100 | 63 | 127 | | | | |
| Surr: Toluene-d8 | 49 | | 50.00 | | 97.2 | 61 | 128 | | | | |

| | | | | | | | | | | | |
|------------------------------------|--------------------------|-----------------------------|--------------------|--------------------------------|----------------------|----------|-----------|-------------|------|----------|------|
| Sample ID: V624LCS-040210YW | SampType: LCS | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49804 | | | | | | |
| Client ID: LCSW | Batch ID: R49804A | TestNo: SW8260B | | Analysis Date: 4/2/2010 | SeqNo: 691408 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|---------------------------|----|-----|-------|---|------|----|-----|--|--|--|--|
| 1,1,1-Trichloroethane | 47 | 1.0 | 50.00 | 0 | 93.2 | 43 | 148 | | | | |
| 1,1,2,2-Tetrachloroethane | 47 | 1.0 | 50.00 | 0 | 94.0 | 32 | 148 | | | | |
| 1,1,2-Trichloroethane | 45 | 1.0 | 50.00 | 0 | 90.9 | 42 | 136 | | | | |
| 1,1-Dichloroethane | 47 | 1.0 | 50.00 | 0 | 94.4 | 40 | 150 | | | | |
| 1,1-Dichloroethene | 48 | 1.0 | 50.00 | 0 | 95.4 | 30 | 154 | | | | |
| 1,2-Dichlorobenzene | 46 | 1.0 | 50.00 | 0 | 92.1 | 40 | 129 | | | | |
| 1,2-Dichloroethane | 43 | 1.0 | 50.00 | 0 | 86.9 | 36 | 141 | | | | |
| 1,2-Dichloropropane | 46 | 1.0 | 50.00 | 0 | 92.3 | 44 | 138 | | | | |
| 1,3-Dichlorobenzene | 45 | 1.0 | 50.00 | 0 | 90.4 | 40 | 133 | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analysis
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

CLIENT: Leggett Brashears & Graham Inc.
Work Order: 1003214
Project: Rowe

TestCode: 8260MTBE113_W

| Sample ID: V624LCS-040210YW | SampType: LCS | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49804 | | | | | | |
|-----------------------------|-------------------|----------------------|-------------|-------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Client ID: LCSW | Batch ID: R49804A | TestNo: SW8260B | | Analysis Date: 4/2/2010 | SeqNo: 691408 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| 1,4-Dichlorobenzene | 46 | 1.0 | 50.00 | 0 | 91.4 | 40 | 135 | | | | |
| 2-Chloroethyl vinyl ether | 46 | 1.0 | 50.00 | 0 | 91.3 | 21 | 139 | | | | |
| Benzene | 48 | 1.0 | 50.00 | 0 | 96.4 | 45 | 144 | | | | |
| Bromodichloromethane | 46 | 1.0 | 50.00 | 0 | 92.6 | 35 | 136 | | | | |
| Bromoform | 43 | 1.0 | 50.00 | 0 | 85.9 | 28 | 138 | | | | |
| Bromomethane | 59 | 1.0 | 50.00 | 0 | 119 | 26 | 148 | | | | |
| Carbon tetrachloride | 47 | 1.0 | 50.00 | 0 | 93.9 | 45 | 141 | | | | |
| Chlorobenzene | 47 | 1.0 | 50.00 | 0 | 93.4 | 41 | 142 | | | | |
| Chloroethane | 48 | 1.0 | 50.00 | 0 | 95.2 | 36 | 143 | | | | C |
| Chloroform | 48 | 1.0 | 50.00 | 0 | 96.8 | 42 | 137 | | | | |
| Chloromethane | 53 | 1.0 | 50.00 | 0 | 107 | 35 | 151 | | | | |
| cis-1,3-Dichloropropene | 47 | 1.0 | 50.00 | 0 | 94.7 | 42 | 130 | | | | |
| Dibromochloromethane | 43 | 1.0 | 50.00 | 0 | 85.5 | 21 | 134 | | | | |
| Ethylbenzene | 47 | 1.0 | 50.00 | 0 | 93.5 | 45 | 146 | | | | |
| Tetrachloroethene | 48 | 1.0 | 50.00 | 0 | 95.3 | 45 | 136 | | | | |
| Toluene | 48 | 1.0 | 50.00 | 0 | 96.1 | 43 | 134 | | | | |
| trans-1,2-Dichloroethene | 51 | 1.0 | 50.00 | 0 | 102 | 42 | 135 | | | | |
| trans-1,3-Dichloropropene | 46 | 1.0 | 50.00 | 0 | 91.9 | 37 | 133 | | | | |
| Trichloroethene | 48 | 1.0 | 50.00 | 0 | 95.3 | 43 | 140 | | | | |
| Trichlorofluoromethane | 42 | 1.0 | 50.00 | 0 | 83.3 | 50 | 148 | | | | C |
| Vinyl chloride | 61 | 1.0 | 50.00 | 0 | 121 | 35 | 142 | | | | |
| Surr: 4-Bromofluorobenzene | 50 | | 50.00 | | 99.8 | 60 | 130 | | | | |
| Surr: Dibromofluoromethane | 39 | | 50.00 | | 78.6 | 63 | 127 | | | | |
| Surr: Toluene-d8 | 51 | | 50.00 | | 101 | 61 | 128 | | | | |

| Sample ID: VBLK-040210YW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49804 | | | | | | |
|---------------------------|-------------------|----------------------|-------------|-------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Client ID: PBW | Batch ID: R49804A | TestNo: SW8260B | | Analysis Date: 4/2/2010 | SeqNo: 691409 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| 1,1,1,2-Tetrachloroethane | U | 1.0 | | | | | | | | | |
| 1,1,1-Trichloroethane | U | 1.0 | | | | | | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

CLIENT: Leggett Brashears & Graham Inc.
Work Order: 1003214
Project: Rowe

TestCode: 8260MTBE113_W

| | | | | | | | | | | | |
|--------------------------|-------------------|----------------------|-------------|-------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Sample ID: VBLK-040210YW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49804 | | | | | | |
| Client ID: PBW | Batch ID: R49804A | TestNo: SW8260B | | Analysis Date: 4/2/2010 | SeqNo: 691409 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|---------------------------------------|---|-----|--|--|--|--|--|--|--|--|---|
| 1,1,2,2-Tetrachloroethane | U | 1.0 | | | | | | | | | |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 1.0 | | | | | | | | | C |
| 1,1,2-Trichloroethane | U | 1.0 | | | | | | | | | |
| 1,1-Dichloroethane | U | 1.0 | | | | | | | | | |
| 1,1-Dichloroethene | U | 1.0 | | | | | | | | | |
| 1,1-Dichloropropene | U | 1.0 | | | | | | | | | |
| 1,2,3-Trichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2,3-Trichloropropane | U | 1.0 | | | | | | | | | |
| 1,2,4-Trichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2,4-Trimethylbenzene | U | 1.0 | | | | | | | | | |
| 1,2-Dibromo-3-chloropropane | U | 1.0 | | | | | | | | | |
| 1,2-Dibromoethane | U | 1.0 | | | | | | | | | |
| 1,2-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2-Dichloroethane | U | 1.0 | | | | | | | | | |
| 1,2-Dichloropropane | U | 1.0 | | | | | | | | | |
| 1,3,5-Trimethylbenzene | U | 1.0 | | | | | | | | | |
| 1,3-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,3-dichloropropane | U | 1.0 | | | | | | | | | |
| 1,4-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 2,2-Dichloropropane | U | 1.0 | | | | | | | | | |
| 2-Butanone | U | 3.0 | | | | | | | | | |
| 2-Chloroethyl vinyl ether | U | 1.0 | | | | | | | | | |
| 2-Chlorotoluene | U | 1.0 | | | | | | | | | |
| 2-Hexanone | U | 2.0 | | | | | | | | | |
| 4-Chlorotoluene | U | 1.0 | | | | | | | | | |
| 4-Isopropyltoluene | U | 1.0 | | | | | | | | | |
| 4-Methyl-2-pentanone | U | 2.0 | | | | | | | | | |
| Acetone | U | 2.0 | | | | | | | | | |
| Benzene | U | 1.0 | | | | | | | | | |
| Bromobenzene | U | 1.0 | | | | | | | | | |
| Bromochloromethane | U | 1.0 | | | | | | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 1003214
Project: Rowe

TestCode: 8260MTBE113_W

| | | | |
|--------------------------|-------------------|----------------------|-------------|
| Sample ID: VBLK-040210YW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L |
| Client ID: PBW | Batch ID: R49804A | TestNo: SW8260B | |
| Analyte | Result | PQL | SPK value |
| | | %REC | SPK RefVal |
| | | LowLimit | RPD RefVal |
| | | HighLimit | RPD Limit |
| | | | %RPD |
| | | | RPDLimit |
| | | | Qual |

RunNo: 49804
 SeqNo: 691409

Prep Date:
 Analysis Date: 4/2/2010

| Analyte | Result | PQL | SPK value | SPK RefVal | %REC | LowLimit | HighLimit | RPD RefVal | %RPD | RPDLimit | Qual |
|---------------------------|--------|-----|-----------|------------|------|----------|-----------|------------|------|----------|------|
| Bromodichloromethane | U | 1.0 | | | | | | | | | |
| Bromoform | U | 1.0 | | | | | | | | | |
| Bromomethane | U | 1.0 | | | | | | | | | |
| Carbon disulfide | U | 1.0 | | | | | | | | | |
| Carbon tetrachloride | U | 1.0 | | | | | | | | | |
| Chlorobenzene | U | 1.0 | | | | | | | | | |
| Chloroethane | U | 1.0 | | | | | | | | | |
| Chloroform | U | 1.0 | | | | | | | | | |
| Chloromethane | U | 1.0 | | | | | | | | | |
| cis-1,2-Dichloroethene | U | 1.0 | | | | | | | | | |
| cis-1,3-Dichloropropene | U | 1.0 | | | | | | | | | |
| Dibromochloromethane | U | 1.0 | | | | | | | | | |
| Dibromomethane | U | 1.0 | | | | | | | | | |
| Dichlorodifluoromethane | U | 1.0 | | | | | | | | | |
| Ethylbenzene | U | 1.0 | | | | | | | | | |
| Hexachlorobutadiene | U | 1.0 | | | | | | | | | |
| Isopropylbenzene | U | 1.0 | | | | | | | | | |
| m,p-Xylene | U | 2.0 | | | | | | | | | |
| Methyl tert-butyl ether | U | 1.0 | | | | | | | | | |
| Methylene chloride | U | 1.0 | | | | | | | | | |
| Naphthalene | U | 1.0 | | | | | | | | | |
| n-Butylbenzene | U | 1.0 | | | | | | | | | |
| n-Propylbenzene | U | 1.0 | | | | | | | | | |
| o-Xylene | U | 1.0 | | | | | | | | | |
| sec-Butylbenzene | U | 1.0 | | | | | | | | | |
| Styrene | U | 1.0 | | | | | | | | | |
| tert-Butylbenzene | U | 1.0 | | | | | | | | | |
| Tetrachloroethene | U | 1.0 | | | | | | | | | |
| Toluene | U | 1.0 | | | | | | | | | |
| trans-1,2-Dichloroethene | U | 1.0 | | | | | | | | | |
| trans-1,3-Dichloropropene | U | 1.0 | | | | | | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analysis
 J Analyte detected below quantitation limits LOD Limit of Detection R RPD outside accepted recovery limits S Spike Recovery outside accepted reco
 ND Not Detected at the Reporting Limit

ANALYTICAL QC SUMMARY REPORT

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 1003214
Project: Rowe

TestCode: 8260MTBE113_W

| | | | | | | | | | | | |
|--------------------------|-------------------|----------------------|-------------|-------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Sample ID: VBLK-040210YW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49804 | | | | | | |
| Client ID: PBW | Batch ID: R49804A | TestNo: SW8260B | | Analysis Date: 4/2/2010 | SeqNo: 691409 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|----------------------------|----|-----|-------|--|------|----|-----|--|--|--|---|
| Trichloroethene | U | 1.0 | | | | | | | | | C |
| Trichlorofluoromethane | U | 1.0 | | | | | | | | | |
| Vinyl acetate | U | 1.0 | | | | | | | | | |
| Vinyl chloride | U | 1.0 | | | | | | | | | |
| Surr: 4-Bromofluorobenzene | 48 | | 50.00 | | 96.5 | 60 | 130 | | | | |
| Surr: Dibromofluoromethane | 49 | | 50.00 | | 97.6 | 63 | 127 | | | | |
| Surr: Toluene-d8 | 50 | | 50.00 | | 100 | 61 | 128 | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

CLIENT: Leggett Brashears & Graham Inc.
Work Order: 1003214
Project: Rowe

TestCode: FE_D

| | | | | | | | | | | |
|------------------------|-----------------|----------------|-------------|--------------------------|---------------|-----------|-------------|------|----------|------|
| Sample ID: PBW-032910A | SampType: MBLK | TestCode: FE_D | Units: mg/L | Prep Date: 3/29/2010 | RunNo: 49678 | | | | | |
| Client ID: PBW | Batch ID: 28517 | TestNo: E200.7 | SW3010A | Analysis Date: 3/29/2010 | SeqNo: 687966 | | | | | |
| Analyte | Result | PQL | SPK value | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

Iron U 0.0200

| | | | | | | | | | | |
|-------------------------|-----------------|----------------|-------------|--------------------------|---------------|-----------|-------------|------|----------|------|
| Sample ID: LCSW-032910A | SampType: LCS | TestCode: FE_D | Units: mg/L | Prep Date: 3/29/2010 | RunNo: 49678 | | | | | |
| Client ID: LCSW | Batch ID: 28517 | TestNo: E200.7 | SW3010A | Analysis Date: 3/29/2010 | SeqNo: 687967 | | | | | |
| Analyte | Result | PQL | SPK value | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

Iron 1.97 0.0200 2.000 0 98.3 68 122

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 1003214
Project: Rowe

TestCode: FE_T

| | | | | | |
|------------------------|-----------------|----------------|-------------|--------------------------|---------------|
| Sample ID: PBW-032910A | SampType: MBLK | TestCode: FE_T | Units: mg/L | Prep Date: 3/29/2010 | RunNo: 49678 |
| Client ID: PBW | Batch ID: 28517 | TestNo: E200.7 | SW3010A | Analysis Date: 3/29/2010 | SeqNo: 687990 |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC |
| | U | 0.0200 | | | |
| | | | | LowLimit | HighLimit |
| | | | | RPD Ref Val | RPDLimit |
| | | | | %RPD | Qual |

Iron

| | | | | | |
|-------------------------|-----------------|----------------|-------------|--------------------------|---------------|
| Sample ID: LCSW-032910A | SampType: LCS | TestCode: FE_T | Units: mg/L | Prep Date: 3/29/2010 | RunNo: 49678 |
| Client ID: LCSW | Batch ID: 28517 | TestNo: E200.7 | SW3010A | Analysis Date: 3/29/2010 | SeqNo: 687991 |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC |
| | 1.97 | 0.0200 | 2.000 | 0 | 98.3 |
| | | | | 68 | 122 |
| | | | | LowLimit | HighLimit |
| | | | | RPD Ref Val | RPDLimit |
| | | | | %RPD | Qual |

Iron

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 1003214
Project: Rowe

TestCode: TDS_W

| | | | | | |
|----------------------|------------------|-----------------|-------------|--------------------------|---------------|
| Sample ID: MB-R49656 | SampType: MBLK | TestCode: TDS_W | Units: mg/L | Prep Date: | RunNo: 49656 |
| Client ID: PBW | Batch ID: R49656 | TestNo: M2540C | | Analysis Date: 3/25/2010 | SeqNo: 687657 |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %RCD |
| | | | | HighLimit | RPD Ref Val |
| | | | | LowLimit | RPDlimit |
| | | | | | Qual |

Total Dissolved Solids (Residue, Filtera) U 1.00

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

Tuesday, April 13, 2010

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555

FAX (203) 926-9140

RE: Rowe

Order No.: 1004057

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 4/7/2010 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The results reported herein relate only to the items tested or to the samples as received by the laboratory. This report may not be reproduced, except in full, without the approval of American Analytical Laboratories, LLC and is not considered complete without a cover page and chain of custody documentation. The limits (LOQ) provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report or the data is qualified. This package has been reviewed by American Analytical Laboratories' QA Department/Laboratory Director to comply with NELAC standards prior to report submittal. This report consists of 27 pages.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe
Lab Order: 1004057

Work Order Sample Summary

| Lab Sample ID | Client Sample ID | Date Collected | Date Received |
|----------------------|-------------------------|-----------------------|----------------------|
| 1004057-01A | WQ33010:1110NP2-6 | 3/30/2010 11:10:00 AM | 4/7/2010 |
| 1004057-01B | WQ33010:1110NP2-6 | 3/30/2010 11:10:00 AM | 4/7/2010 |
| 1004057-01C | WQ33010:1110NP2-6 | 3/30/2010 11:10:00 AM | 4/7/2010 |
| 1004057-02A | WQ33010:1115NP2-7 | 3/30/2010 11:15:00 AM | 4/7/2010 |
| 1004057-02B | WQ33010:1115NP2-7 | 3/30/2010 11:15:00 AM | 4/7/2010 |
| 1004057-02C | WQ33010:1115NP2-7 | 3/30/2010 11:15:00 AM | 4/7/2010 |
| 1004057-03A | WQ33010:1120NP2-10 | 3/30/2010 11:20:00 AM | 4/7/2010 |
| 1004057-03B | WQ33010:1120NP2-10 | 3/30/2010 11:20:00 AM | 4/7/2010 |
| 1004057-03C | WQ33010:1120NP2-10 | 3/30/2010 11:20:00 AM | 4/7/2010 |
| 1004057-03D | WQ33010:1120NP2-10 | 3/30/2010 11:20:00 AM | 4/7/2010 |

American Analytical Laboratories, LLC.

Sample Receipt Checklist

Client Name **LBG CT**

Date and Time Receive **4/7/2010 10:36:12 AM**

Work Order Number **1004057**

RcptNo: **1**

Received by **CB**

COC_ID:

CoolerID:

Checklist completed by

CBear 4/7/10
Signature Date

Reviewed by

La B 4/7/10
Initials Date

Matrix:

Carrier name FedEx

- Shipping container/cooler in good condition? Yes No Not Present
- Custody seals intact on shipping container/cooler? Yes No Not Present
- Custody seals intact on sample bottles? Yes No Not Present
- Chain of custody present? Yes No
- Chain of custody signed when relinquished and received? Yes No
- Chain of custody agrees with sample labels? Yes No
- Samples in proper container/bottle? Yes No
- Sample containers intact? Yes No
- Sufficient sample volume for indicated test? Yes No
- All samples received within holding time? Yes No
- Container/Temp Blank temperature in compliance? Yes No
- Water - VOA vials have zero headspace? Yes No VOA vials submitted Yes No
- Water - pH acceptable upon receipt? Yes No N/A

Adjusted? _____ Checked b _____

Any No and/or NA (not applicable) response must be detailed in the comments section be

Client contacted _____ Date contacted: _____ Person contacted _____

Contacted by: _____ Regarding: _____

Comments: Cooler. Temp =18.7C

Corrective Action _____

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1004057
 Project: Rowe
 Lab ID: 1004057-01A

Client Sample ID: WQ33010:1110NP2-6
 Collection Date: 3/30/2010 11:10:00 AM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------|-------------|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | | Analyst: LA | |
| 1,1,1,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| 1,1,1-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| 1,1,2,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| 1,1,2-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| 1,1-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| 1,1-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| 1,1-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| 1,2,3-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| 1,2,3-Trichloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| 1,2,4-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| 1,2,4-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| 1,2-Dibromo-3-chloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| 1,2-Dibromoethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| 1,2-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| 1,2-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| 1,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| 1,3,5-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| 1,3-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| 1,3-dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| 1,4-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| 2,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| 2-Butanone | U | 0.3 | 3.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| 2-Chloroethyl vinyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| 2-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| 2-Hexanone | U | 0.3 | 2.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| 4-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| 4-Isopropyltoluene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| 4-Methyl-2-pentanone | U | 0.3 | 2.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| Acetone | U | 0.3 | 2.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| Benzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| Bromobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| Bromochloromethane | U | 0.4 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 13-Apr-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1004057
 Project: Rowe
 Lab ID: 1004057-01A

Client Sample ID: WQ33010:1110NP2-6
 Collection Date: 3/30/2010 11:10:00 AM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Bromodichloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| Bromoform | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| Bromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| Carbon disulfide | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| Carbon tetrachloride | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| Chlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| Chloroethane | U | 0.4 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| Chloroform | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| Chloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| cis-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| cis-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| Dibromochloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| Dibromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| Dichlorodifluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| Ethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| Hexachlorobutadiene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| Isopropylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| m,p-Xylene | U | 0.3 | 2.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| Methyl tert-butyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| Methylene chloride | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| Naphthalene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| n-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| n-Propylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| o-Xylene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| sec-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| Styrene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| tert-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| Tetrachloroethene | 2.1 | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| Toluene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| trans-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| trans-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| Trichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| Trichlorofluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 13-Apr-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1004057
 Project: Rowe
 Lab ID: 1004057-01A

Client Sample ID: WQ33010:1110NP2-6
 Collection Date: 3/30/2010 11:10:00 AM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Vinyl acetate | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| Vinyl chloride | U | 0.3 | 1.0 | | µg/L | 1 | 4/8/2010 11:46:00 PM |
| Surr: 4-Bromofluorobenzene | 97.1 | 0 | 60-130 | | %REC | 1 | 4/8/2010 11:46:00 PM |
| Surr: Dibromofluoromethane | 109 | 0 | 63-127 | | %REC | 1 | 4/8/2010 11:46:00 PM |
| Surr: Toluene-d8 | 102 | 0 | 61-128 | | %REC | 1 | 4/8/2010 11:46:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 13-Apr-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 1004057
Project: Rowe
Lab ID: 1004057-01B

Client Sample ID: WQ33010:1110NP2-6
Collection Date: 3/30/2010 11:10:00 AM
Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|------------|---------------|-------|--------|--------|---------|----|---------------------|
| TOTAL IRON | | | | E200.7 | SW3010A | | Analyst: JP |
| Iron | 2.02 | 0.005 | 0.0200 | | mg/L | 1 | 4/8/2010 2:42:43 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- Qualifiers:**
- * Value exceeds Maximum Contaminant Level
 - C Calibration %RSD/%D exceeded for non-CCC analytes
 - H Holding times for preparation or analysis exceeded
 - LOD Limit of Detection
 - ND Not Detected at the Reporting Limit
 - U Indicates the compound was analyzed but not detected.
 - B Analyte detected in the associated Method Blank
 - E Value above quantitation range
 - J Analyte detected below quantitation limits
 - LOQ Limit of Quantitation
 - S Spike Recovery outside accepted recovery limits

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1004057
 Project: Rowe
 Lab ID: 1004057-01C

Client Sample ID: WQ33010:1110NP2-6
 Collection Date: 3/30/2010 11:10:00 AM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|----------------|---------------|-------|--------|--------|---------|----|---------------------|
| DISSOLVED IRON | | | | E200.7 | SW3005A | | Analyst: JP |
| Iron | 0.0345 | 0.005 | 0.0200 | | mg/L | 1 | 4/8/2010 2:40:39 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- Qualifiers:**
- * Value exceeds Maximum Contaminant Level
 - C Calibration %RSD/%D exceeded for non-CCC analytes
 - H Holding times for preparation or analysis exceeded
 - LOD Limit of Detection
 - ND Not Detected at the Reporting Limit
 - U Indicates the compound was analyzed but not detected.
 - B Analyte detected in the associated Method Blank
 - E Value above quantitation range
 - J Analyte detected below quantitation limits
 - LOQ Limit of Quantitation
 - S Spike Recovery outside accepted recovery limits

American Analytical Laboratories, LLC.

Date: 13-Apr-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1004057
 Project: Rowe
 Lab ID: 1004057-02A

Client Sample ID: WQ33010:1115NP2-7
 Collection Date: 3/30/2010 11:15:00 AM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------|-------------|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | | Analyst: LA | |
| 1,1,1,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| 1,1,1-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| 1,1,2,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| 1,1,2-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| 1,1-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| 1,1-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| 1,1-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| 1,2,3-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| 1,2,3-Trichloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| 1,2,4-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| 1,2,4-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| 1,2-Dibromo-3-chloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| 1,2-Dibromoethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| 1,2-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| 1,2-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| 1,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| 1,3,5-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| 1,3-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| 1,3-dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| 1,4-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| 2,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| 2-Butanone | U | 0.3 | 3.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| 2-Chloroethyl vinyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| 2-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| 2-Hexanone | U | 0.3 | 2.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| 4-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| 4-Isopropyltoluene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| 4-Methyl-2-pentanone | U | 0.3 | 2.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| Acetone | U | 0.3 | 2.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| Benzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| Bromobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| Bromochloromethane | U | 0.4 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1004057
 Project: Rowe
 Lab ID: 1004057-02A

Client Sample ID: WQ33010:1115NP2-7
 Collection Date: 3/30/2010 11:15:00 AM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Bromodichloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| Bromoform | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| Bromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| Carbon disulfide | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| Carbon tetrachloride | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| Chlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| Chloroethane | U | 0.4 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| Chloroform | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| Chloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| cis-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| cis-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| Dibromochloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| Dibromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| Dichlorodifluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| Ethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| Hexachlorobutadiene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| Isopropylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| m,p-Xylene | U | 0.3 | 2.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| Methyl tert-butyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| Methylene chloride | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| Naphthalene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| n-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| n-Propylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| o-Xylene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| sec-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| Styrene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| tert-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| Tetrachloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| Toluene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| trans-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| trans-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| Trichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| Trichlorofluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 13-Apr-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1004057
 Project: Rowe
 Lab ID: 1004057-02A

Client Sample ID: WQ33010:1115NP2-7
 Collection Date: 3/30/2010 11:15:00 AM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------|-------------|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | | Analyst: LA | |
| Vinyl acetate | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| Vinyl chloride | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:18:00 AM |
| Surr: 4-Bromofluorobenzene | 103 | 0 | 60-130 | | %REC | 1 | 4/9/2010 12:18:00 AM |
| Surr: Dibromofluoromethane | 111 | 0 | 63-127 | | %REC | 1 | 4/9/2010 12:18:00 AM |
| Surr: Toluene-d8 | 101 | 0 | 61-128 | | %REC | 1 | 4/9/2010 12:18:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1004057
 Project: Rowe
 Lab ID: 1004057-02B

Client Sample ID: WQ33010:1115NP2-7
 Collection Date: 3/30/2010 11:15:00 AM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|------------|---------------|-------|--------|------|---------|----|---------------------|
| TOTAL IRON | | | E200.7 | | SW3010A | | Analyst: JP |
| Iron | 1.22 | 0.005 | 0.0200 | | mg/L | 1 | 4/8/2010 2:46:50 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- Qualifiers:**
- * Value exceeds Maximum Contaminant Level
 - C Calibration %RSD/%D exceeded for non-CCC analytes
 - H Holding times for preparation or analysis exceeded
 - LOD Limit of Detection
 - ND Not Detected at the Reporting Limit
 - U Indicates the compound was analyzed but not detected.
 - B Analyte detected in the associated Method Blank
 - E Value above quantitation range
 - J Analyte detected below quantitation limits
 - LOQ Limit of Quantitation
 - S Spike Recovery outside accepted recovery limits

American Analytical Laboratories, LLC.

Date: 13-Apr-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 1004057
Project: Rowe
Lab ID: 1004057-02C

Client Sample ID: WQ33010:1115NP2-7
Collection Date: 3/30/2010 11:15:00 AM
Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|----------------|---------------|-------|--------|--------|---------|----|---------------------|
| DISSOLVED IRON | | | | E200.7 | SW3005A | | Analyst: JP |
| Iron | 0.106 | 0.005 | 0.0200 | | mg/L | 1 | 4/8/2010 2:44:46 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| LOD | Limit of Detection | LOQ Limit of Quantitation |
| ND | Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| U | Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1004057
 Project: Rowe
 Lab ID: 1004057-03A

Client Sample ID: WQ33010:1120NP2-10
 Collection Date: 3/30/2010 11:20:00 AM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------|-------------|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | | Analyst: LA | |
| 1,1,1,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| 1,1,1-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| 1,1,2,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| 1,1,2-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| 1,1-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| 1,1-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| 1,1-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| 1,2,3-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| 1,2,3-Trichloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| 1,2,4-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| 1,2,4-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| 1,2-Dibromo-3-chloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| 1,2-Dibromoethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| 1,2-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| 1,2-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| 1,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| 1,3,5-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| 1,3-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| 1,3-dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| 1,4-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| 2,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| 2-Butanone | U | 0.3 | 3.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| 2-Chloroethyl vinyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| 2-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| 2-Hexanone | U | 0.3 | 2.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| 4-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| 4-Isopropyltoluene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| 4-Methyl-2-pentanone | U | 0.3 | 2.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| Acetone | U | 0.3 | 2.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| Benzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| Bromobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| Bromochloromethane | U | 0.4 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1004057
 Project: Rowe
 Lab ID: 1004057-03A

Client Sample ID: WQ33010:1120NP2-10
 Collection Date: 3/30/2010 11:20:00 AM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|--|---------------|-----|---------|------|-------|-------------|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | | Analyst: LA | |
| Bromodichloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| Bromoform | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| Bromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| Carbon disulfide | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| Carbon tetrachloride | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| Chlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| Chloroethane | U | 0.4 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| Chloroform | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| Chloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| cis-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| cis-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| Dibromochloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| Dibromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| Dichlorodifluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| Ethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| Hexachlorobutadiene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| Isopropylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| m,p-Xylene | U | 0.3 | 2.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| Methyl tert-butyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| Methylene chloride | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| Naphthalene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| n-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| n-Propylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| o-Xylene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| sec-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| Styrene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| tert-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| Tetrachloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| Toluene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| trans-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| trans-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| Trichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| Trichlorofluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 13-Apr-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1004057
 Project: Rowe
 Lab ID: 1004057-03A

Client Sample ID: WQ33010:1120NP2-10
 Collection Date: 3/30/2010 11:20:00 AM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------|-------------|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | | Analyst: LA | |
| Vinyl acetate | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| Vinyl chloride | U | 0.3 | 1.0 | | µg/L | 1 | 4/9/2010 12:49:00 AM |
| Surr: 4-Bromofluorobenzene | 97.9 | 0 | 60-130 | | %REC | 1 | 4/9/2010 12:49:00 AM |
| Surr: Dibromofluoromethane | 114 | 0 | 63-127 | | %REC | 1 | 4/9/2010 12:49:00 AM |
| Surr: Toluene-d8 | 104 | 0 | 61-128 | | %REC | 1 | 4/9/2010 12:49:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1004057
 Project: Rowe
 Lab ID: 1004057-03B

Client Sample ID: WQ33010:1120NP2-10
 Collection Date: 3/30/2010 11:20:00 AM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|------------|---------------|-------|--------|--------|---------|----|---------------------|
| TOTAL IRON | | | | E200.7 | SW3010A | | Analyst: JP |
| Iron | 1.38 | 0.005 | 0.0200 | | mg/L | 1 | 4/8/2010 2:50:57 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1004057
 Project: Rowe
 Lab ID: 1004057-03C

Client Sample ID: WQ33010:1120NP2-10
 Collection Date: 3/30/2010 11:20:00 AM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|----------------|---------------|-------|--------|--------|---------|----|---------------------|
| DISSOLVED IRON | | | | E200.7 | SW3005A | | Analyst: JP |
| Iron | 0.115 | 0.005 | 0.0200 | | mg/L | 1 | 4/8/2010 2:48:53 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 13-Apr-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1004057
 Project: Rowe
 Lab ID: 1004057-03D

Client Sample ID: WQ33010:1120NP2-10
 Collection Date: 3/30/2010 11:20:00 AM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|--|---------------|-----|------|------|-------|----|--------------------|
| TOTAL DISSOLVED SOLIDS | | | | | | | Analyst: AS |
| Total Dissolved Solids (Residue, Filterable) | 118 | 0 | 1.00 | H | mg/L | 1 | 4/7/2010 |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- Qualifiers:**
- * Value exceeds Maximum Contaminant Level
 - C Calibration %RSD/%D exceeded for non-CCC analytes
 - H Holding times for preparation or analysis exceeded
 - LOD Limit of Detection
 - ND Not Detected at the Reporting Limit
 - U Indicates the compound was analyzed but not detected.
 - B Analyte detected in the associated Method Blank
 - E Value above quantitation range
 - J Analyte detected below quantitation limits
 - LOQ Limit of Quantitation
 - S Spike Recovery outside accepted recovery limits

American Analytical Laboratories, LLC.

Date: 13-Apr-10

CLIENT: Leggette Brashears & Graham Inc.
 Work Order: 1004057
 Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

| | | | | | |
|-----------------------------|------------------|----------------------|-------------|-------------------------|---------------|
| Sample ID: V624LCS-040810aH | SampType: LCS | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49966 |
| Client ID: LCSW | Batch ID: R49966 | TestNo: SW8260B | | Analysis Date: 4/8/2010 | SeqNo: 693977 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---------------------------|--------|-----|-----------|-------------|------|----------|-----------|-------------|------|----------|------|
| 1,1,1-Trichloroethane | 47 | 1.0 | 50.00 | 0 | 94.1 | 43 | 148 | | | | |
| 1,1,2,2-Tetrachloroethane | 45 | 1.0 | 50.00 | 0 | 89.6 | 32 | 148 | | | | |
| 1,1,2-Trichloroethane | 46 | 1.0 | 50.00 | 0 | 91.9 | 42 | 136 | | | | |
| 1,1-Dichloroethane | 46 | 1.0 | 50.00 | 0 | 92.9 | 40 | 150 | | | | |
| 1,1-Dichloroethene | 47 | 1.0 | 50.00 | 0 | 94.4 | 30 | 154 | | | | |
| 1,2-Dichlorobenzene | 46 | 1.0 | 50.00 | 0 | 91.8 | 40 | 129 | | | | |
| 1,2-Dichloroethane | 51 | 1.0 | 50.00 | 0 | 101 | 36 | 141 | | | | |
| 1,2-Dichloropropane | 43 | 1.0 | 50.00 | 0 | 86.0 | 44 | 138 | | | | |
| 1,3-Dichlorobenzene | 50 | 1.0 | 50.00 | 0 | 99.3 | 40 | 133 | | | | |
| 1,4-Dichlorobenzene | 45 | 1.0 | 50.00 | 0 | 89.4 | 40 | 135 | | | | |
| 2-Chloroethyl vinyl ether | 41 | 1.0 | 50.00 | 0 | 81.7 | 21 | 139 | | | | |
| Benzene | 47 | 1.0 | 50.00 | 0 | 93.9 | 45 | 144 | | | | |
| Bromodichloromethane | 47 | 1.0 | 50.00 | 0 | 93.5 | 35 | 136 | | | | |
| Bromoform | 46 | 1.0 | 50.00 | 0 | 91.4 | 28 | 138 | | | | |
| Bromomethane | 36 | 1.0 | 50.00 | 0 | 72.9 | 26 | 148 | | | | |
| Carbon tetrachloride | 48 | 1.0 | 50.00 | 0 | 95.5 | 45 | 141 | | | | |
| Chlorobenzene | 49 | 1.0 | 50.00 | 0 | 97.6 | 41 | 142 | | | | |
| Chloroethane | 33 | 1.0 | 50.00 | 0 | 66.4 | 36 | 143 | | | | |
| Chloroform | 49 | 1.0 | 50.00 | 0 | 97.3 | 42 | 137 | | | | |
| Chloromethane | 48 | 1.0 | 50.00 | 0 | 97.0 | 35 | 151 | | | | |
| cis-1,3-Dichloropropene | 46 | 1.0 | 50.00 | 0 | 91.5 | 42 | 130 | | | | |
| Dibromochloromethane | 45 | 1.0 | 50.00 | 0 | 90.9 | 21 | 134 | | | | |
| Ethylbenzene | 50 | 1.0 | 50.00 | 0 | 99.4 | 45 | 146 | | | | |
| Tetrachloroethene | 45 | 1.0 | 50.00 | 0 | 89.2 | 45 | 136 | | | | |
| Toluene | 48 | 1.0 | 50.00 | 0 | 95.2 | 43 | 134 | | | | |
| trans-1,2-Dichloroethene | 46 | 1.0 | 50.00 | 0 | 92.3 | 42 | 135 | | | | |
| trans-1,3-Dichloropropene | 47 | 1.0 | 50.00 | 0 | 93.2 | 37 | 133 | | | | |
| Trichloroethene | 47 | 1.0 | 50.00 | 0 | 93.7 | 43 | 140 | | | | |
| Trichlorofluoromethane | 55 | 1.0 | 50.00 | 0 | 111 | 50 | 148 | | | | |
| Vinyl chloride | 55 | 1.0 | 50.00 | 0 | 109 | 35 | 142 | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection I RPD outside accepted recovery limits LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 1004057
Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

| | | | | | |
|-----------------------------|------------------|----------------------|-------------|-------------------------|---------------|
| Sample ID: V624LCS-040810aH | SampType: LCS | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49966 |
| Client ID: LCSW | Batch ID: R49966 | TestNo: SW8260B | | Analysis Date: 4/8/2010 | SeqNo: 693977 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | Units: µg/L | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|----------------------------|--------|-----|-----------|-------------|-------------|------|----------|-----------|-------------|------|----------|------|
| Surr: 4-Bromofluorobenzene | 53 | | 50.00 | | | 106 | 60 | 130 | | | | |
| Surr: Dibromofluoromethane | 53 | | 50.00 | | | 106 | 63 | 127 | | | | |
| Surr: Toluene-d8 | 50 | | 50.00 | | | 100 | 61 | 128 | | | | |

| | | | | | |
|---------------------------|------------------|----------------------|-------------|-------------------------|---------------|
| Sample ID: VBLK-040810aHW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49966 |
| Client ID: PBW | Batch ID: R49966 | TestNo: SW8260B | | Analysis Date: 4/8/2010 | SeqNo: 693978 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | Units: µg/L | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---------------------------------------|--------|-----|-----------|-------------|-------------|------|----------|-----------|-------------|------|----------|------|
| 1,1,1,2-Tetrachloroethane | U | 1.0 | | | | | | | | | | |
| 1,1,1-Trichloroethane | U | 1.0 | | | | | | | | | | |
| 1,1,2,2-Tetrachloroethane | U | 1.0 | | | | | | | | | | |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 1.0 | | | | | | | | | | |
| 1,1,2-Trichloroethane | U | 1.0 | | | | | | | | | | |
| 1,1-Dichloroethane | U | 1.0 | | | | | | | | | | |
| 1,1-Dichloroethene | U | 1.0 | | | | | | | | | | |
| 1,1-Dichloropropene | U | 1.0 | | | | | | | | | | |
| 1,2,3-Trichlorobenzene | U | 1.0 | | | | | | | | | | |
| 1,2,3-Trichloropropane | U | 1.0 | | | | | | | | | | |
| 1,2,4-Trichlorobenzene | U | 1.0 | | | | | | | | | | |
| 1,2,4-Trimethylbenzene | U | 1.0 | | | | | | | | | | |
| 1,2-Dibromo-3-chloropropane | U | 1.0 | | | | | | | | | | |
| 1,2-Dibromoethane | U | 1.0 | | | | | | | | | | |
| 1,2-Dichlorobenzene | U | 1.0 | | | | | | | | | | |
| 1,2-Dichloroethane | U | 1.0 | | | | | | | | | | |
| 1,2-Dichloropropane | U | 1.0 | | | | | | | | | | |
| 1,3,5-Trimethylbenzene | U | 1.0 | | | | | | | | | | |
| 1,3-Dichlorobenzene | U | 1.0 | | | | | | | | | | |
| 1,3-dichloropropane | U | 1.0 | | | | | | | | | | |
| 1,4-Dichlorobenzene | U | 1.0 | | | | | | | | | | |
| 2,2-Dichloropropane | U | 1.0 | | | | | | | | | | |
| 2-Butanone | U | 3.0 | | | | | | | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

CLIENT: Leggette Brashears & Graham Inc.
 Work Order: 1004057
 Project: Rowe

ANALYTICAL QC SUMMARY REPORT
 TestCode: 8260MTBE113_W

Sample ID: VBLK-040810aHW SampType: MBLK TestCode: 8260MTBE11 Units: µg/L Prep Date: RunNo: 49966
 Client ID: PBW Batch ID: R49966 TestNo: SW8260B Analysis Date: 4/8/2010 SeqNo: 693978

| Analyte | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---------------------------|-----|-----------|-------------|------|----------|-----------|-------------|------|----------|------|
| 2-Chloroethyl vinyl ether | 1.0 | | | | | | | | | |
| 2-Chlorotoluene | 1.0 | | | | | | | | | |
| 2-Hexanone | 2.0 | | | | | | | | | |
| 4-Chlorotoluene | 1.0 | | | | | | | | | |
| 4-Isopropyltoluene | 1.0 | | | | | | | | | |
| 4-Methyl-2-pentanone | 2.0 | | | | | | | | | |
| Acetone | 2.0 | | | | | | | | | |
| Benzene | 1.0 | | | | | | | | | |
| Bromobenzene | 1.0 | | | | | | | | | |
| Bromochloromethane | 1.0 | | | | | | | | | |
| Bromodichloromethane | 1.0 | | | | | | | | | |
| Bromoform | 1.0 | | | | | | | | | |
| Bromomethane | 1.0 | | | | | | | | | |
| Carbon disulfide | 1.0 | | | | | | | | | |
| Carbon tetrachloride | 1.0 | | | | | | | | | |
| Chlorobenzene | 1.0 | | | | | | | | | |
| Chloroethane | 1.0 | | | | | | | | | |
| Chloroform | 1.0 | | | | | | | | | |
| Chloromethane | 1.0 | | | | | | | | | |
| cis-1,2-Dichloroethene | 1.0 | | | | | | | | | |
| cis-1,3-Dichloropropene | 1.0 | | | | | | | | | |
| Dibromochloromethane | 1.0 | | | | | | | | | |
| Dibromomethane | 1.0 | | | | | | | | | |
| Dichlorodifluoromethane | 1.0 | | | | | | | | | |
| Ethylbenzene | 1.0 | | | | | | | | | |
| Hexachlorobutadiene | 1.0 | | | | | | | | | |
| Isopropylbenzene | 1.0 | | | | | | | | | |
| m,p-Xylene | 2.0 | | | | | | | | | |
| Methyl tert-butyl ether | 1.0 | | | | | | | | | |
| Methylene chloride | 1.0 | | | | | | | | | |
| Naphthalene | 1.0 | | | | | | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

CLIENT: Leggette Brashears & Graham Inc.
 Work Order: 1004057
 Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

| | | | | | |
|---------------------------|------------------|----------------------|-------------|-------------------------|---------------|
| Sample ID: VBLK-040810aHW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49966 |
| Client ID: PBW | Batch ID: R49966 | TestNo: SW8260B | | Analysis Date: 4/8/2010 | SeqNo: 693978 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|----------------------------|--------|-----|-----------|-------------|------|----------|-----------|-------------|------|----------|------|
| n-Butylbenzene | U | 1.0 | | | | | | | | | |
| n-Propylbenzene | U | 1.0 | | | | | | | | | |
| o-Xylene | U | 1.0 | | | | | | | | | |
| sec-Butylbenzene | U | 1.0 | | | | | | | | | |
| Styrene | U | 1.0 | | | | | | | | | |
| tert-Butylbenzene | U | 1.0 | | | | | | | | | |
| Tetrachloroethene | U | 1.0 | | | | | | | | | |
| Toluene | U | 1.0 | | | | | | | | | |
| trans-1,2-Dichloroethene | U | 1.0 | | | | | | | | | |
| trans-1,3-Dichloropropene | U | 1.0 | | | | | | | | | |
| Trichloroethene | U | 1.0 | | | | | | | | | |
| Trichlorofluoromethane | U | 1.0 | | | | | | | | | |
| Vinyl acetate | U | 1.0 | | | | | | | | | |
| Vinyl chloride | U | 1.0 | | | | | | | | | |
| Surr: 4-Bromofluorobenzene | 53 | | 50.00 | | 107 | 60 | | 130 | | | |
| Surr: Dibromofluoromethane | 61 | | 50.00 | | 123 | 63 | | 127 | | | |
| Surr: Toluene-d8 | 47 | | 50.00 | | 94.4 | 61 | | 128 | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

CLIENT: Leggett Brashears & Graham Inc.
Work Order: 1004057
Project: Rowe

TestCode: FE_D

| | | | | | |
|------------------------|-----------------|----------------|-------------|-------------------------|---------------|
| Sample ID: PBW-040810A | SampType: MBLK | TestCode: FE_D | Units: mg/L | Prep Date: | RunNo: 49940 |
| Client ID: PBW | Batch ID: 28631 | TestNo: E200.7 | SW3005A | Analysis Date: 4/8/2010 | SeqNo: 693573 |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC |
| Iron | U | 0.0200 | | | |
| | | | LowLimit | HighLimit | RPD Ref Val |
| | | | | | %RPD |
| | | | | | RPDLimit |
| | | | | | Qual |

| | | | | | |
|-------------------------|-----------------|----------------|-------------|-------------------------|---------------|
| Sample ID: LCSW-040810A | SampType: LCS | TestCode: FE_D | Units: mg/L | Prep Date: | RunNo: 49940 |
| Client ID: LCSW | Batch ID: 28631 | TestNo: E200.7 | SW3005A | Analysis Date: 4/8/2010 | SeqNo: 693574 |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC |
| Iron | 1.99 | 0.0200 | 2.000 | 0 | 99.5 |
| | | | LowLimit | HighLimit | RPD Ref Val |
| | | | | | %RPD |
| | | | | | RPDLimit |
| | | | | | Qual |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 1004057
Project: Rowe

TestCode: TDS_W

| | | | | | |
|-----------------------------|-------------------------|------------------------|--------------------|--------------------------------|----------------------|
| Sample ID: MB-R49999 | SampType: MBLK | TestCode: TDS_W | Units: mg/L | Prep Date: | RunNo: 49999 |
| Client ID: PBW | Batch ID: R49999 | TestNo: M2540C | | Analysis Date: 4/7/2010 | SeqNo: 694354 |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC |
| | | | | LowLimit | HighLimit |
| | | | | RPD Ref Val | %RPD |
| | | | | | RPDLimit |
| | | | | | Qual |

Total Dissolved Solids (Residue, Filtera) U 1.00

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

| | |
|---|-----------|
| H0C030436 Analytical Report | 1 |
| Sample Receipt Documentation | 16 |
| Total Number of Pages | 18 |

TestAmerica Laboratories, Inc.

ANALYTICAL REPORT


Rowe-NABSAG 0401

Lot #: H0C030436

Mark Goldberg

Leggette, Brashears & Graham,
4 Research Drive
Suite #301
Shelton, CT 06484

TESTAMERICA LABORATORIES, INC.



Handwritten signature of Jamie A. McKinney in black ink.

Jamie A. McKinney
Project Manager

March 8, 2010

ANALYTICAL METHODS SUMMARY

H0C030436

| <u>PARAMETER</u> | <u>ANALYTICAL METHOD</u> |
|---------------------------|------------------------------|
| Volatile Organics by TO15 | EPA-2 TO-15 |

References:

EPA-2 "Compendium of Methods for the Determination of Toxic Organic Compounds in Ambient Air", EPA-625/R-96/010b, January 1999.

SAMPLE SUMMARY

H0C030436

| <u>WO #</u> | <u>SAMPLE#</u> | <u>CLIENT SAMPLE ID</u> | <u>SAMPLED DATE</u> | <u>SAMP TIME</u> |
|-------------|----------------|-------------------------|---------------------|------------------|
| LV8J6 | 001 | AQ3210-1210NP4-1 | 03/02/10 | 12:10 |
| LV8J7 | 002 | AQ3210-1215NP4-2 | 03/02/10 | 12:15 |
| LV8J8 | 003 | AQ3210-1220NP4-3 | 03/02/10 | 12:20 |

NOTE (S) :

- The analytical results of the samples listed above are presented on the following pages.
- All calculations are performed before rounding to avoid round-off errors in calculated results.
- Results noted as "ND" were not detected at or above the stated limit.
- This report must not be reproduced, except in full, without the written approval of the laboratory.
- Results for the following parameters are never reported on a dry weight basis: color, corrosivity, density, flashpoint, ignitability, layers, odor, paint filter test, pH, porosity pressure, reactivity, redox potential, specific gravity, spot tests, solids, solubility, temperature, viscosity, and weight.

PROJECT NARRATIVE

HOC030436

The results reported herein are applicable to the samples submitted for analysis only.

This report shall not be reproduced except in full, without the written approval of the laboratory.

The original chain of custody documentation is included with this report.

Sample Receipt

There were no problems with the condition of the samples received.

Quality Control and Data Interpretation

Unless otherwise noted, all holding times and QC criteria were met and the test results shown in this report meet all applicable NELAC requirements.

EPA methods TO-14A and TO-15 specify the use of humidified "zero air" as the blank reagent for canister cleaning, instrument calibration and sample analysis. Ultra-high purity humidified nitrogen from a cryogenic reservoir is used in place of "zero air" by TestAmerica Knoxville.

The samples were received on 3/3/10 in Tedlar bags and analyzed within 72 hours of sampling.

TestAmerica Knoxville maintains the following certifications, approvals and accreditations: Arkansas DEQ Lab #88-0688, California DHS ELAP Cert. #2423, Colorado DPHE, Connecticut DPH Lab #PH-0223, Florida DOH Lab #E87177, Georgia DNR Lab #906, Hawaii DOH, Illinois EPA Lab #200012, Indiana DOH Lab #C-TN-02, Iowa DNR Lab #375, Kansas DHE Cert. #E-10349, Kentucky DEP Lab #90101, Louisiana DEQ Cert. #03079, Louisiana DOHH, Maryland DOE Cert. #277, Michigan DEQ Lab #9933, Nevada DEP, New Jersey DEP Lab #TN001, New York DOH Lab #10781, North Carolina DPH Lab #21705, North Carolina DEHNR Cert. #64, Ohio EPA VAP Lab #CL0059, Oklahoma DEQ Lab #9415, Pennsylvania DEP Lab #68-00576, South Carolina DHEC Cert #84001001, Tennessee DOH Lab #02014, Texas CEQ, Utah DOH Lab # QUAN3, Virginia DGS Lab #00165, Washington DOE Lab #C1314, West Virginia DEP Cert. #345, West Virginia DHHR Cert #9955C, Wisconsin DNR Lab #998044300, Naval Facilities Engineering Service Center and USDA Soil Permit #S-46424. This list of approvals is subject to change and does not imply that laboratory certification is available for all parameters reported in this environmental sample data report.

Sample Data Summary

Leggette, Brashears & Graham, Inc.

Client Sample ID: AQ3210-1210NP4-1

GC/MS Volatiles

Lot-Sample # H0C030436 - 001 Work Order # LV8J61AA Matrix.....: AIR

Date Sampled...: 03/02/2010 Date Received...: 03/03/2010
 Prep Date.....: 03/04/2010 Analysis Date...: 03/04/2010
 Prep Batch #.....: 0064128
 Dilution Factor.: 5 Method.....: TO-15

| PARAMETER | RESULTS (ppb(v/v)) | REPORTING LIMIT (ppb(v/v)) | RESULTS (ug/m3) | REPORTING LIMIT (ug/m3) |
|---------------------------|-----------------------|-------------------------------|--------------------|----------------------------|
| Benzene | ND | 1.0 | ND | 3.2 |
| Bromodichloromethane | ND | 1.0 | ND | 6.7 |
| Bromoform | ND | 1.0 | ND | 10 |
| Bromomethane | ND | 1.0 | ND | 3.9 |
| Carbon disulfide | 0.47 | 2.5 | 1.5 J | 7.8 |
| Carbon tetrachloride | ND | 1.0 | ND | 6.3 |
| Chlorobenzene | ND | 1.0 | ND | 4.6 |
| Dibromochloromethane | ND | 1.0 | ND | 8.5 |
| Chloroethane | ND | 1.0 | ND | 2.6 |
| Chloroform | 0.87 | 1.0 | 4.2 J | 4.9 |
| Chloromethane | ND | 2.5 | ND | 5.2 |
| 1,1-Dichloroethane | 2.2 | 1.0 | 8.9 | 4.0 |
| 1,2-Dichloroethane | ND | 1.0 | ND | 4.0 |
| cis-1,2-Dichloroethene | 0.34 | 1.0 | 1.3 J | 4.0 |
| trans-1,2-Dichloroethene | ND | 1.0 | ND | 4.0 |
| 1,1-Dichloroethene | 0.40 | 1.0 | 1.6 J | 4.0 |
| 1,2-Dichloropropane | ND | 1.0 | ND | 4.6 |
| cis-1,3-Dichloropropene | ND | 1.0 | ND | 4.5 |
| trans-1,3-Dichloropropene | ND | 1.0 | ND | 4.5 |
| Ethylbenzene | ND | 1.0 | ND | 4.3 |
| Methylene chloride | 0.48 | 2.5 | 1.7 J | 8.7 |
| Styrene | ND | 1.0 | ND | 4.3 |
| 1,1,2,2-Tetrachloroethane | ND | 1.0 | ND | 6.9 |
| Tetrachloroethene | 7.9 | 1.0 | 53 | 6.8 |
| Toluene | 0.27 | 1.0 | 1.0 J | 3.8 |
| 1,1,1-Trichloroethane | 6.3 | 1.0 | 34 | 5.5 |
| 1,1,2-Trichloroethane | ND | 1.0 | ND | 5.5 |
| Trichloroethene | 0.80 | 1.0 | 4.3 J | 5.4 |
| Vinyl chloride | ND | 1.0 | ND | 2.6 |
| m-Xylene & p-Xylene | ND | 1.0 | ND | 4.3 |
| o-Xylene | ND | 1.0 | ND | 4.3 |

| SURROGATE | PERCENT RECOVERY | LABORATORY CONTROL LIMITS (%) |
|----------------------|---------------------|-------------------------------------|
| 4-Bromofluorobenzene | 105 | 60 - 140 |

Leggette, Brashears & Graham, Inc.
Client Sample ID: AQ3210-1210NP4-1
GC/MS Volatiles

Lot-Sample # H0C030436 - 001 Work Order # LV8J61AA Matrix.....: AIR

Qualifiers

J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.

Client Sample ID: AQ3210-1215NP4-2

GC/MS Volatiles

Lot-Sample # H0C030436 - 002 Work Order # LV8J71AA Matrix.....: AIR

Date Sampled...: 03/02/2010 Date Received...: 03/03/2010
 Prep Date.....: 03/04/2010 Analysis Date...: 03/04/2010
 Prep Batch #.....: 0064128
 Dilution Factor.: 5 Method.....: TO-15

| PARAMETER | RESULTS (ppb(v/v)) | REPORTING LIMIT (ppb(v/v)) | RESULTS (ug/m3) | | REPORTING LIMIT (ug/m3) |
|--------------------------------|-----------------------|-------------------------------|--------------------|----------|----------------------------|
| Benzene | ND | 1.0 | ND | | 3.2 |
| Bromodichloromethane | ND | 1.0 | ND | | 6.7 |
| Bromoform | ND | 1.0 | ND | | 10 |
| Bromomethane | ND | 1.0 | ND | | 3.9 |
| Carbon disulfide | 0.26 | 2.5 | 0.80 | J | 7.8 |
| Carbon tetrachloride | ND | 1.0 | ND | | 6.3 |
| Chlorobenzene | ND | 1.0 | ND | | 4.6 |
| Dibromochloromethane | ND | 1.0 | ND | | 8.5 |
| Chloroethane | ND | 1.0 | ND | | 2.6 |
| Chloroform | ND | 1.0 | ND | | 4.9 |
| Chloromethane | 0.87 | 2.5 | 1.8 | J | 5.2 |
| 1,1-Dichloroethane | 0.20 | 1.0 | 0.82 | J | 4.0 |
| 1,2-Dichloroethane | ND | 1.0 | ND | | 4.0 |
| cis-1,2-Dichloroethene | ND | 1.0 | ND | | 4.0 |
| trans-1,2-Dichloroethene | ND | 1.0 | ND | | 4.0 |
| 1,1-Dichloroethene | ND | 1.0 | ND | | 4.0 |
| 1,2-Dichloropropane | ND | 1.0 | ND | | 4.6 |
| cis-1,3-Dichloropropene | ND | 1.0 | ND | | 4.5 |
| trans-1,3-Dichloropropene | ND | 1.0 | ND | | 4.5 |
| Ethylbenzene | ND | 1.0 | ND | | 4.3 |
| Methylene chloride | 5.4 | 2.5 | 19 | | 8.7 |
| Styrene | ND | 1.0 | ND | | 4.3 |
| 1,1,2,2-Tetrachloroethane | ND | 1.0 | ND | | 6.9 |
| Tetrachloroethene | 0.73 | 1.0 | 4.9 | J | 6.8 |
| Toluene | 1.5 | 1.0 | 5.5 | | 3.8 |
| 1,1,1-Trichloroethane | 0.83 | 1.0 | 4.5 | J | 5.5 |
| 1,1,2-Trichloroethane | ND | 1.0 | ND | | 5.5 |
| Trichloroethene | ND | 1.0 | ND | | 5.4 |
| Vinyl chloride | ND | 1.0 | ND | | 2.6 |
| m-Xylene & p-Xylene | 0.81 | 1.0 | 3.5 | J | 4.3 |
| o-Xylene | 0.34 | 1.0 | 1.5 | J | 4.3 |

| SURROGATE | PERCENT RECOVERY | LABORATORY CONTROL LIMITS (%) |
|----------------------|---------------------|-------------------------------------|
| 4-Bromofluorobenzene | 100 | 60 - 140 |

Leggette, Brashears & Graham, Inc.
Client Sample ID: AQ3210-1215NP4-2
GC/MS Volatiles

Lot-Sample # H0C030436 - 002 Work Order # LV8J71AA Matrix.....: AIR

Qualifiers

J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.
 Client Sample ID: AQ3210-1220NP4-3
 GC/MS Volatiles

Lot-Sample # H0C030436 - 003 Work Order # LV8J81AA Matrix.....: AIR

Date Sampled...: 03/02/2010 Date Received...: 03/03/2010
 Prep Date.....: 03/04/2010 Analysis Date...: 03/04/2010
 Prep Batch #.....: 0064128
 Dilution Factor.: 5 Method.....: TO-15

| PARAMETER | RESULTS (ppb(v/v)) | REPORTING LIMIT (ppb(v/v)) | RESULTS (ug/m3) | REPORTING LIMIT (ug/m3) |
|-------------------------------|-----------------------|-------------------------------|--------------------|----------------------------|
| Benzene | ND | 1.0 | ND | 3.2 |
| Bromodichloromethane | ND | 1.0 | ND | 6.7 |
| Bromoform | ND | 1.0 | ND | 10 |
| Bromomethane | ND | 1.0 | ND | 3.9 |
| Carbon disulfide | 0.61 | 2.5 | 1.9 J | 7.8 |
| Carbon tetrachloride | ND | 1.0 | ND | 6.3 |
| Chlorobenzene | ND | 1.0 | ND | 4.6 |
| Dibromochloromethane | ND | 1.0 | ND | 8.5 |
| Chloroethane | ND | 1.0 | ND | 2.6 |
| Chloroform | 2.0 | 1.0 | 9.7 | 4.9 |
| Chloromethane | ND | 2.5 | ND | 5.2 |
| 1,1-Dichloroethane | 4.4 | 1.0 | 18 | 4.0 |
| 1,2-Dichloroethane | ND | 1.0 | ND | 4.0 |
| cis-1,2-Dichloroethene | 0.74 | 1.0 | 2.9 J | 4.0 |
| trans-1,2-Dichloroethene | ND | 1.0 | ND | 4.0 |
| 1,1-Dichloroethene | 0.57 | 1.0 | 2.3 J | 4.0 |
| 1,2-Dichloropropane | ND | 1.0 | ND | 4.6 |
| cis-1,3-Dichloropropene | ND | 1.0 | ND | 4.5 |
| trans-1,3-Dichloropropene | ND | 1.0 | ND | 4.5 |
| Ethylbenzene | ND | 1.0 | ND | 4.3 |
| Methylene chloride | 0.38 | 2.5 | 1.3 J | 8.7 |
| Styrene | ND | 1.0 | ND | 4.3 |
| 1,1,2,2-Tetrachloroethane | ND | 1.0 | ND | 6.9 |
| Tetrachloroethene | ND | 1.0 | ND | 6.8 |
| Toluene | ND | 1.0 | ND | 3.8 |
| 1,1,1-Trichloroethane | 11 | 1.0 | 61 | 5.5 |
| 1,1,2-Trichloroethane | ND | 1.0 | ND | 5.5 |
| Trichloroethene | ND | 1.0 | ND | 5.4 |
| Vinyl chloride | ND | 1.0 | ND | 2.6 |
| m-Xylene & p-Xylene | ND | 1.0 | ND | 4.3 |
| o-Xylene | ND | 1.0 | ND | 4.3 |

| SURROGATE | PERCENT RECOVERY | LABORATORY CONTROL LIMITS (%) |
|----------------------|---------------------|-------------------------------------|
| 4-Bromofluorobenzene | 100 | 60 - 140 |

Leggette, Brashears & Graham, Inc.

Client Sample ID: AQ3210-1220NP4-3

GC/MS Volatiles

Lot-Sample # H0C030436 - 003 Work Order # LV8J81AA Matrix.....: AIR

Qualifiers

J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.
 Client Sample ID: INTRA-LAB BLANK
 GC/MS Volatiles

Lot-Sample # H0C050000 - 128B Work Order # LWA6G1AA Matrix.....: AIR

Prep Date.....: 02/25/2010 Date Received...: 03/02/2010
 Prep Date.....: 03/04/2010 Analysis Date...: 03/04/2010
 Prep Batch #.....: 0064128
 Dilution Factor.: 1 Method.....: TO-15

| PARAMETER | RESULTS (ppb(v/v)) | REPORTING LIMIT (ppb(v/v)) | RESULTS (ug/m3) | REPORTING LIMIT (ug/m3) |
|---------------------------|-----------------------|-------------------------------|--------------------|----------------------------|
| Benzene | ND | 0.20 | ND | 0.64 |
| Bromodichloromethane | ND | 0.20 | ND | 1.3 |
| Bromoform | ND | 0.20 | ND | 2.1 |
| Bromomethane | ND | 0.20 | ND | 0.78 |
| Carbon disulfide | ND | 0.50 | ND | 1.6 |
| Carbon tetrachloride | ND | 0.20 | ND | 1.3 |
| Chlorobenzene | ND | 0.20 | ND | 0.92 |
| Dibromochloromethane | ND | 0.20 | ND | 1.7 |
| Chloroethane | ND | 0.20 | ND | 0.53 |
| Chloroform | ND | 0.20 | ND | 0.98 |
| Chloromethane | ND | 0.50 | ND | 1.0 |
| 1,1-Dichloroethane | ND | 0.20 | ND | 0.81 |
| 1,2-Dichloroethane | ND | 0.20 | ND | 0.81 |
| cis-1,2-Dichloroethene | ND | 0.20 | ND | 0.79 |
| trans-1,2-Dichloroethene | ND | 0.20 | ND | 0.79 |
| 1,1-Dichloroethene | ND | 0.20 | ND | 0.79 |
| 1,2-Dichloropropane | ND | 0.20 | ND | 0.92 |
| cis-1,3-Dichloropropene | ND | 0.20 | ND | 0.91 |
| trans-1,3-Dichloropropene | ND | 0.20 | ND | 0.91 |
| Ethylbenzene | ND | 0.20 | ND | 0.87 |
| Methylene chloride | ND | 0.50 | ND | 1.7 |
| Styrene | ND | 0.20 | ND | 0.85 |
| 1,1,2,2-Tetrachloroethane | ND | 0.20 | ND | 1.4 |
| Tetrachloroethene | ND | 0.20 | ND | 1.4 |
| Toluene | ND | 0.20 | ND | 0.75 |
| 1,1,1-Trichloroethane | ND | 0.20 | ND | 1.1 |
| 1,1,2-Trichloroethane | ND | 0.20 | ND | 1.1 |
| Trichloroethene | ND | 0.20 | ND | 1.1 |
| Vinyl chloride | ND | 0.20 | ND | 0.51 |
| m-Xylene & p-Xylene | ND | 0.20 | ND | 0.87 |
| o-Xylene | ND | 0.20 | ND | 0.87 |

| SURROGATE | PERCENT RECOVERY | LABORATORY CONTROL LIMITS (%) |
|----------------------|---------------------|-------------------------------------|
| 4-Bromofluorobenzene | 103 | 60 - 140 |

Leggette, Brashears & Graham, Inc.
Client Sample ID: INTRA-LAB BLANK
GC/MS Volatiles

Lot-Sample # H0C050000 - 128B Work Order # LWA6G1AA Matrix.....: AIR

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding) \times (Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) \times Dilution Factor) \times (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.
 Client Sample ID: CHECK SAMPLE
 GC/MS Volatiles

Lot-Sample # H0C050000 - 128C Work Order # LWA6G1AC Matrix.....: AIR
 Prep Date.....: 02/25/2010 Date Received..: 03/02/2010
 Prep Batch #.....: 03/04/2010 Analysis Date... 03/04/2010
 Dilution Factor.: 0064128
 Method.....: 1 TO-15

| PARAMETER | SPIKE AMOUNT (ppb(v/v)) | MEASURED AMOUNT (ppb(v/v)) | SPIKE AMOUNT (ug/m3) | MEASURED AMOUNT (ug/m3) | PERCENT RECOVERY | RECOVERY LIMITS |
|---------------------------|-------------------------------|----------------------------------|----------------------------|-------------------------------|---------------------|--------------------|
| Benzene | 2.50 | 2.54 | 8.0 | 8.1 | 102 | 70 - 130 |
| Bromodichloromethane | 2.50 | 2.58 | 17 | 17 | 103 | 70 - 130 |
| Bromoform | 2.50 | 2.12 | 26 | 22 | 85 | 70 - 130 |
| Bromomethane | 2.50 | 2.63 | 9.7 | 10 | 105 | 70 - 130 |
| Carbon disulfide | 2.50 | 2.81 | 7.8 | 8.8 | 112 | 70 - 130 |
| Carbon tetrachloride | 2.50 | 2.65 | 16 | 17 | 106 | 70 - 130 |
| Chlorobenzene | 2.50 | 2.20 | 12 | 10 | 88 | 70 - 130 |
| Dibromochloromethane | 2.50 | 2.38 | 21 | 20 | 95 | 70 - 130 |
| Chloroethane | 2.50 | 2.66 | 6.6 | 7.0 | 106 | 70 - 130 |
| Chloroform | 2.50 | 2.51 | 12 | 12 | 100 | 70 - 130 |
| Chloromethane | 2.50 | 2.82 | 5.2 | 5.8 | 113 | 60 - 140 |
| 1,1-Dichloroethane | 2.50 | 2.64 | 10 | 11 | 105 | 70 - 130 |
| 1,2-Dichloroethane | 2.50 | 2.56 | 10 | 10 | 102 | 70 - 130 |
| cis-1,2-Dichloroethene | 2.50 | 2.59 | 9.9 | 10 | 104 | 70 - 130 |
| trans-1,2-Dichloroethene | 2.50 | 2.66 | 9.9 | 11 | 107 | 70 - 130 |
| 1,1-Dichloroethene | 2.50 | 2.76 | 9.9 | 11 | 110 | 70 - 130 |
| 1,2-Dichloropropane | 2.50 | 2.39 | 12 | 11 | 96 | 70 - 130 |
| cis-1,3-Dichloropropene | 2.50 | 2.36 | 11 | 11 | 94 | 70 - 130 |
| trans-1,3-Dichloropropene | 2.50 | 2.30 | 11 | 10 | 92 | 70 - 130 |
| Ethylbenzene | 2.50 | 2.08 | 11 | 9.0 | 83 | 70 - 130 |
| Methylene chloride | 2.50 | 2.74 | 8.7 | 9.5 | 110 | 70 - 130 |
| Styrene | 2.50 | 2.22 | 11 | 9.4 | 89 | 70 - 130 |
| 1,1,2,2-Tetrachloroethane | 2.50 | 1.94 | 17 | 13 | 78 | 70 - 130 |
| Tetrachloroethene | 2.50 | 2.36 | 17 | 16 | 94 | 70 - 130 |
| Toluene | 2.50 | 2.22 | 9.4 | 8.4 | 89 | 70 - 130 |
| 1,1,1-Trichloroethane | 2.50 | 2.54 | 14 | 14 | 102 | 70 - 130 |
| 1,1,2-Trichloroethane | 2.50 | 2.28 | 14 | 12 | 91 | 70 - 130 |
| Trichloroethene | 2.50 | 2.94 | 13 | 16 | 118 | 70 - 130 |
| Vinyl chloride | 2.50 | 2.76 | 6.4 | 7.1 | 110 | 70 - 130 |
| m-Xylene & p-Xylene | 5.00 | 4.21 | 22 | 18 | 84 | 70 - 130 |
| o-Xylene | 2.50 | 1.99 | 11 | 8.7 | 80 | 70 - 130 |

| SURROGATE | PERCENT RECOVERY | LABORATORY CONTROL LIMITS (%) |
|----------------------|---------------------|-------------------------------------|
| 4-Bromofluorobenzene | 105 | 60 - 140 |

Leggette, Brashears & Graham, Inc.
Client Sample ID: CHECK SAMPLE
GC/MS Volatiles

Lot-Sample # H0C050000 - 128C Work Order # LWA6G1AC Matrix.....: AIR

The 'Result' in ug/m³ is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m³ is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Sample Receipt Documentation

TestAmerica Knoxville
 5815 Middlebrook Pike
 Knoxville, TN 37921
 Phone 865 291-3000 (Main)
 Phone 865-291-3031 (Receiving)

HDCO 30436
 Chain of Custody Record

TestAmerica
 THE LEADER IN ENVIRONMENTAL TESTING

| | | | | | | | |
|--|--|---|--|--|--|---|--|
| Client Contact | | Project Manager: <i>M. G. Leberg</i> | | Site Contact: | | COC Record _____ of _____ | |
| Company Name <i>LBi</i> | | Tel/Mobile: | | Lab Contact: | | COC No: <i>01362</i> | |
| Address <i>4 Research Dr. Suite 361</i> | | Analysis Turnaround Time | | Carrier: | | Lab Use Only: | |
| City/State/Zip <i>Stamford, CT 06424</i> | | Calendar (C) or Work Days (W) _____ | | Analysis (Attach list if more space is needed) | | Custody Seals Intact <input checked="" type="checkbox"/> N NA | |
| Phone <i>203 944 5000 x 282</i> | | TAT if different from Below _____ | | Field Filtered Sample | | Number of Packages: <i>1</i> COVER | |
| Project Name/Number: <i>None</i> | | <input checked="" type="checkbox"/> 2 weeks | | Sample Time | | Temperature: <i>AMBIENT</i> deg C | |
| Site: <i>None</i> | | <input type="checkbox"/> 1 week | | Sample Date | | Shipper: <i>UPS</i> Other: _____ | |
| P O # | | <input type="checkbox"/> 2 days | | Matrix | | Tracking Number: <i>5706 0378 680</i> | |
| Sampled by: <i>S. Hunt</i> | | <input type="checkbox"/> 1 day | | # of Cont. | | Recorded by: <i>JS</i> Date: <i>3/3/10</i> | |
| Sample Identification | | Sample Type | | Sample Matrix | | Sample Specific Notes: | |
| <i>AQ3210:1210NP4-1</i> | | <i>6</i> | | <i>A</i> | | | |
| <i>AQ3210:1215NP4-2</i> | | <i>1215</i> | | <i>I</i> | | | |
| <i>AQ3210:1220NP4-3</i> | | <i>1220</i> | | <i>I</i> | | | |
| Preservation Used: 1 = Ice, 2 = HCl; 3 = H ₂ SO ₄ ; 4 = HNO ₃ ; 5 = NaOH; 6 = Na ₂ S ₂ O ₃ Other _____ | | Sample Disposal (A fee may be assessed if samples are retained longer than 1 month) | | Return To Client <input type="checkbox"/> | | Disposal By Lab <input type="checkbox"/> | |
| Possible Hazard Identification | | Skin Irritant <input type="checkbox"/> | | Poison B <input type="checkbox"/> | | Archive For _____ Months | |
| <input checked="" type="checkbox"/> Non-Hazard <input type="checkbox"/> Flammable | | Sample Disposal (A fee may be assessed if samples are retained longer than 1 month) | | Return To Client <input checked="" type="checkbox"/> | | Disposal By Lab <input type="checkbox"/> | |
| Special Instructions/QC Requirements & Comments: | | Relinquished by: _____ | | Date/Time: <i>3/2/10 1500</i> | | Received by: <i>[Signature]</i> | |
| | | Relinquished by: _____ | | Date/Time: _____ | | Date/Time: <i>3/3/10 10:15</i> | |
| | | Relinquished by: _____ | | Date/Time: _____ | | Date/Time: _____ | |

TESTAMERICA KNOXVILLE SAMPLE RECEIPT/CONDITION UPON RECEIPT ANOMALY CHECKLIST

Lot Number: A0C13113b

| Review Items | Yes | No | NA | If No, what was the problem? | Comments/Actions Taken |
|---|-------------------------------------|----|-------------------------------------|---|------------------------|
| 1. Do sample container labels match COC? (IDs, Dates, Times) | <input checked="" type="checkbox"/> | | | <input type="checkbox"/> 1a Do not match COC <input type="checkbox"/> 1b Incomplete information <input type="checkbox"/> 1c Marking smeared <input type="checkbox"/> 1d Label torn <input type="checkbox"/> 1e No label <input type="checkbox"/> 1f COC not received <input type="checkbox"/> 1g Other: _____ | |
| 2. Is the cooler temperature within limits? (> freezing temp. of water to 6 °C; NC, 1668, 1613B: 0-4°C; VOST: 10°C; MA: 2-6 °C) | | | <input checked="" type="checkbox"/> | <input type="checkbox"/> 2a Temp Blank = _____ <input type="checkbox"/> 2b Cooler Temp = _____ <input type="checkbox"/> 3a Sample preservative = _____ | |
| 3. Were samples received with correct chemical preservative (excluding Encore)? | <input checked="" type="checkbox"/> | | | <input type="checkbox"/> 4a Not present <input type="checkbox"/> 4b Not intact <input type="checkbox"/> 4c Other: _____ | |
| 4. Were custody seals present/intact on cooler and/or containers? | <input checked="" type="checkbox"/> | | | <input type="checkbox"/> 5a Samples received-not on COC <input type="checkbox"/> 5b Samples not received-on COC <input type="checkbox"/> 6a Leaking <input type="checkbox"/> 6b Broken <input type="checkbox"/> 7a Headspace (VOA only) <input type="checkbox"/> 8a Improper container | |
| 5. Were all of the samples listed on the COC received? | <input checked="" type="checkbox"/> | | | <input type="checkbox"/> 9a Could not be determined due to matrix interference <input type="checkbox"/> 10a Holding time expired <input type="checkbox"/> Incomplete information | |
| 6. Were all of the sample containers received intact? | <input checked="" type="checkbox"/> | | | If no, was pH adjusted to pH 7 - 9 with sulfuric acid? _____ | |
| 7. Were VOA samples received without headspace? | <input checked="" type="checkbox"/> | | | <input type="checkbox"/> 13a Leaking <input type="checkbox"/> 13b Other: _____ | |
| 8. Were samples received in appropriate containers? | <input checked="" type="checkbox"/> | | | <input type="checkbox"/> 14a Not relinquished <input type="checkbox"/> 15a Incomplete information | |
| 9. Did you check for residual chlorine, if necessary? | <input checked="" type="checkbox"/> | | | <input type="checkbox"/> 15a Incomplete information <input type="checkbox"/> 15a Incomplete information <input type="checkbox"/> 15a Incomplete information | |
| 10. Were samples received within holding time? | <input checked="" type="checkbox"/> | | | <input type="checkbox"/> 15a Incomplete information | |
| 11. For rad samples, was sample activity info. provided? | <input checked="" type="checkbox"/> | | | | |
| 12. For 1613B water samples is pH<9? | <input checked="" type="checkbox"/> | | | | |
| 13. Are the shipping containers intact? | <input checked="" type="checkbox"/> | | | | |
| 14. Was COC relinquished? (Signed/Dated/Timed) | <input checked="" type="checkbox"/> | | | | |
| 15. Are tests/parameters listed for each sample? | <input checked="" type="checkbox"/> | | | | |
| 16. Is the matrix of the samples noted? | <input checked="" type="checkbox"/> | | | | |
| 17. Is the date/time of sample collection noted? | <input checked="" type="checkbox"/> | | | | |
| 18. Is the client and project name/# identified? | <input checked="" type="checkbox"/> | | | | |
| 19. Was the sampler identified on the COC? | <input checked="" type="checkbox"/> | | | | |

Quote #: NA110 PM Instructions: _____

Sample Receiving Associate: Alex Mith

Date: 3/3/10

Thursday, March 25, 2010

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe

Order No.: 1003155

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 8 sample(s) on 3/17/2010 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The results reported herein relate only to the items tested or to the samples as received by the laboratory. This report may not be reproduced, except in full, without the approval of American Analytical Laboratories, LLC and is not considered complete without a cover page and chain of custody documentation. The limits (LOQ) provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report or the data is qualified. This package has been reviewed by American Analytical Laboratories' QA Department/Laboratory Director to comply with NELAC standards prior to report submittal. This report consists of 61 pages.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe
Lab Order: 1003155

Work Order Sample Summary

| Lab Sample ID | Client Sample ID | Date Collected | Date Received |
|----------------------|-------------------------|-----------------------|----------------------|
| 1003155-01A | GWQ31610:1410NP1-1-2 | 3/16/2010 2:40:00 PM | 3/17/2010 |
| 1003155-01B | GWQ31610:1410NP1-1-2 | 3/16/2010 2:40:00 PM | 3/17/2010 |
| 1003155-01C | GWQ31610:1410NP1-1-2 | 3/16/2010 2:40:00 PM | 3/17/2010 |
| 1003155-02A | GWQ31610:1420NP1-1-3 | 3/16/2010 2:20:00 PM | 3/17/2010 |
| 1003155-02B | GWQ31610:1420NP1-1-3 | 3/16/2010 2:20:00 PM | 3/17/2010 |
| 1003155-02C | GWQ31610:1420NP1-1-3 | 3/16/2010 2:20:00 PM | 3/17/2010 |
| 1003155-03A | GWQ31610:1430NP1-1-4 | 3/16/2010 2:30:00 PM | 3/17/2010 |
| 1003155-03B | GWQ31610:1430NP1-1-4 | 3/16/2010 2:30:00 PM | 3/17/2010 |
| 1003155-03C | GWQ31610:1430NP1-1-4 | 3/16/2010 2:30:00 PM | 3/17/2010 |
| 1003155-04A | GWQ31610:1440NP1-1-5 | 3/16/2010 2:40:00 PM | 3/17/2010 |
| 1003155-04B | GWQ31610:1440NP1-1-5 | 3/16/2010 2:40:00 PM | 3/17/2010 |
| 1003155-04C | GWQ31610:1440NP1-1-5 | 3/16/2010 2:40:00 PM | 3/17/2010 |
| 1003155-05A | GWQ31610:1450NP1-1-6 | 3/16/2010 2:50:00 PM | 3/17/2010 |
| 1003155-05B | GWQ31610:1450NP1-1-6 | 3/16/2010 2:50:00 PM | 3/17/2010 |
| 1003155-05C | GWQ31610:1450NP1-1-6 | 3/16/2010 2:50:00 PM | 3/17/2010 |
| 1003155-06A | GWQ31610:1500NP1-1-7 | 3/16/2010 3:00:00 PM | 3/17/2010 |
| 1003155-06B | GWQ31610:1500NP1-1-7 | 3/16/2010 3:00:00 PM | 3/17/2010 |
| 1003155-06C | GWQ31610:1500NP1-1-7 | 3/16/2010 3:00:00 PM | 3/17/2010 |
| 1003155-07A | GWQ31610:1510NP1-1-8 | 3/16/2010 3:10:00 PM | 3/17/2010 |
| 1003155-07B | GWQ31610:1510NP1-1-8 | 3/16/2010 3:10:00 PM | 3/17/2010 |
| 1003155-07C | GWQ31610:1510NP1-1-8 | 3/16/2010 3:10:00 PM | 3/17/2010 |
| 1003155-08A | GWQ31610:1520NP1-1-9 | 3/16/2010 2:10:00 PM | 3/17/2010 |
| 1003155-08B | GWQ31610:1520NP1-1-9 | 3/16/2010 2:10:00 PM | 3/17/2010 |
| 1003155-08C | GWQ31610:1520NP1-1-9 | 3/16/2010 2:10:00 PM | 3/17/2010 |



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735
 (631) 454-6100 • FAX (631) 454-8027
 www.american-analytical.com

11418
 PH-0205
 NY050
 NJDEP
 PADEP
 68-573

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS: **LAB**
 4 Research Dr. Suite 301
 Shelton, CT 06484

CONTACT: **M. Goldberg**

SAMPLER (SIGNATURE): *[Signature]*

SAMPLER NAME (PRINT): **STEPHEN ROJAT**

SAMPLE(S) SEALED: **YES** / NO

CORRECT CONTAINER(S): **YES** / NO

TEMPERATURE (°C):

PROJECT LOCATION: **Rowc**

| LABORATORY ID# LAB USE ONLY | MATRIX/ TYPE | NO. OF CONTAINERS | DATE | SAMPLING TIME | SAMPLE # - LOCATION | ANALYSIS REQUIRED | RECEIVED BY LAB (SIGNATURE) | DATE TIME | PRINTED NAME |
|-----------------------------|--------------|-------------------|---------|---------------|----------------------|-------------------|-----------------------------|-----------|--------------|
| 1003155-01ABC | M/B | 4 | 3/16/10 | 1440 | 6WR31610:1410NF1-1-2 | X | [Signature] | 3-17-10 | C. Dunn |
| 02ABC | | | | 1420 | 6WR31610:1420NF1-1-3 | X | [Signature] | 3-17-10 | C. Dunn |
| 03ABC | | | | 1430 | 6WR31610:1430NF1-1-4 | X | [Signature] | 3-17-10 | C. Dunn |
| 04ABC | | | | 1440 | 6WR31610:1440NF1-1-5 | X | [Signature] | 3-17-10 | C. Dunn |
| 05ABC | | | | 1450 | 6WR31610:1450NF1-1-6 | X | [Signature] | 3-17-10 | C. Dunn |
| 06ABC | | | | 1500 | 6WR31610:1500NF1-1-7 | X | [Signature] | 3-17-10 | C. Dunn |
| 07ABC | | | | 1510 | 6WR31610:1510NF1-1-8 | X | [Signature] | 3-17-10 | C. Dunn |
| 08ABC | | | | 1520 | 6WR31610:1520NF1-1-9 | X | [Signature] | 3-17-10 | C. Dunn |
| 09ABC | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |

COMMENTS / INSTRUCTIONS: **Samples must be on ICE (<6° C)**

MATRIX S=SOIL; W=WATER; SL=SLUDGE; A=AIR; M=MISCELLANEOUS

TURNAROUND REQUIRED: STANDARD STAT (7-10 business days)

E-MAIL ADDRESS FOR RESULTS: **MGoldberg@byct.com**

RELINQUISHED BY (SIGNATURE): *[Signature]* DATE TIME: 3/17/10 1500

RECEIVED BY LAB (SIGNATURE): *[Signature]* DATE TIME: 3-17-10

PRINTED NAME: **Patrick Walsh**

RELINQUISHED BY (SIGNATURE): *[Signature]* DATE TIME: 3-17-10

RECEIVED BY LAB (SIGNATURE): *[Signature]* DATE TIME: 3/17/10

PRINTED NAME: **C. Dunn**

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

PRINTED NAME: **and Beyer**

American Analytical Laboratories, LLC.

Sample Receipt Checklist

Client Name LBG CT

Date and Time Receive 3/17/2010

Work Order Numbe 1003155

RcptNo: 1

Received by LB

COC_ID:

CoolerID:

Checklist completed b

Signature: [Handwritten Signature] Date: 03/17/10

Reviewed by

Initials: [Handwritten Initials] Date: 3/18/10

Matrix

Carrier name Lab Courier

- Shipping container/cooler in good condition? Yes [checked] No [] Not Presen []
Custody seals intact on shipping container/cooler? Yes [] No [] Not Presen [checked]
Custody seals intact on sample bottles? Yes [] No [] Not Presen [checked]
Chain of custody present? Yes [checked] No []
Chain of custody signed when relinquished and received? Yes [checked] No []
Chain of custody agrees with sample labels? Yes [checked] No []
Samples in proper container/bottle? Yes [checked] No []
Sample containers intact? Yes [checked] No []
Sufficient sample volume for indicated test? Yes [checked] No []
All samples received within holding time? Yes [checked] No []
Container/Temp Blank temperature in compliance? Yes [checked] No []
Water - VOA vials have zero headspace? No VOA vials submitted [] Yes [checked] No []
Water - pH acceptable upon receipt? Yes [checked] No [] N/A []

Adjusted _____ Checked b _____

Any No and/or NA (not applicable) response must be detailed in the comments section b

Client contacted _____ Date contacted: _____ Person contacted _____

Contacted by: _____ Regarding _____

Comments: cooler with ice. temp 3.4 Degrees C

Corrective Action _____

American Analytical Laboratories, LLC.

Date: 25-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-01A

Client Sample ID: GWQ31610:1410NP1-1-2
 Collection Date: 3/16/2010 2:40:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| 1,1,1,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| 1,1,1-Trichloroethane | 1.7 | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| 1,1,2,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| 1,1,2-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| 1,1-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| 1,1-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| 1,1-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| 1,2,3-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| 1,2,3-Trichloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| 1,2,4-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| 1,2,4-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| 1,2-Dibromo-3-chloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| 1,2-Dibromoethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| 1,2-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| 1,2-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| 1,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| 1,3,5-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| 1,3-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| 1,3-dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| 1,4-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| 2,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| 2-Butanone | U | 0.3 | 3.0 | C | µg/L | 1 | 3/23/2010 4:58:00 PM |
| 2-Chloroethyl vinyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| 2-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| 2-Hexanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| 4-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| 4-Isopropyltoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| 4-Methyl-2-pentanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| Acetone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| Benzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| Bromobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| Bromochloromethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 25-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-01A

Client Sample ID: GWQ31610:1410NP1-1-2
 Collection Date: 3/16/2010 2:40:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Bromodichloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| Bromoform | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| Bromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| Carbon disulfide | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| Carbon tetrachloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| Chlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| Chloroethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| Chloroform | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| Chloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| cis-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| cis-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| Dibromochloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| Dibromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| Dichlorodifluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| Ethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| Hexachlorobutadiene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| Isopropylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| m,p-Xylene | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| Methyl tert-butyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| Methylene chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| Naphthalene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| n-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| n-Propylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| o-Xylene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| sec-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| Styrene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| tert-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| Tetrachloroethene | 1.0 | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| Toluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| trans-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| trans-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| Trichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| Trichlorofluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 25-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-01A

Client Sample ID: GWQ31610:1410NP1-1-2
 Collection Date: 3/16/2010 2:40:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------|-------------|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | | Analyst: LA | |
| Vinyl acetate | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| Vinyl chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:58:00 PM |
| Surr: 4-Bromofluorobenzene | 101 | 0 | 60-130 | | %REC | 1 | 3/23/2010 4:58:00 PM |
| Surr: Dibromofluoromethane | 94.6 | 0 | 63-127 | | %REC | 1 | 3/23/2010 4:58:00 PM |
| Surr: Toluene-d8 | 103 | 0 | 61-128 | | %REC | 1 | 3/23/2010 4:58:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 25-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 1003155
Project: Rowe
Lab ID: 1003155-01B

Client Sample ID: GWQ31610:1410NP1-1-2
Collection Date: 3/16/2010 2:40:00 PM
Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|------------|---------------|-------|--------|--------|---------|----|-----------------------|
| TOTAL IRON | | | | E200.7 | SW3010A | | Analyst: JP |
| Iron | 2.56 | 0.005 | 0.0200 | | mg/L | 1 | 3/19/2010 10:21:26 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- Qualifiers:**
- * Value exceeds Maximum Contaminant Level
 - C Calibration %RSD/%D exceeded for non-CCC analytes
 - H Holding times for preparation or analysis exceeded
 - LOD Limit of Detection
 - ND Not Detected at the Reporting Limit
 - U Indicates the compound was analyzed but not detected.
 - B Analyte detected in the associated Method Blank
 - E Value above quantitation range
 - J Analyte detected below quantitation limits
 - LOQ Limit of Quantitation
 - S Spike Recovery outside accepted recovery limits

American Analytical Laboratories, LLC.

Date: 25-Mar-10

ELAP ID : 11418

| | | | |
|-------------------|----------------------------------|--------------------------|----------------------|
| CLIENT: | Leggette Brashears & Graham Inc. | Client Sample ID: | GWQ31610:1410NP1-1-2 |
| Lab Order: | 1003155 | Collection Date: | 3/16/2010 2:40:00 PM |
| Project: | Rowe | Matrix: | LIQUID |
| Lab ID: | 1003155-01C | | |

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|----------------|---------------|-------|--------|------|---------|----|-----------------------|
| DISSOLVED IRON | | | E200.7 | | SW3005A | | Analyst: JP |
| Iron | 0.515 | 0.005 | 0.0200 | | mg/L | 1 | 3/19/2010 10:19:23 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735

Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| LOD | Limit of Detection | LOQ Limit of Quantitation |
| ND | Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| U | Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 25-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-02A

Client Sample ID: GWQ31610:1420NP1-1-3
 Collection Date: 3/16/2010 2:20:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| 1,1,1,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| 1,1,1-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| 1,1,2,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| 1,1,2-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| 1,1-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| 1,1-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| 1,1-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| 1,2,3-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| 1,2,3-Trichloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| 1,2,4-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| 1,2,4-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| 1,2-Dibromo-3-chloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| 1,2-Dibromoethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| 1,2-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| 1,2-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| 1,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| 1,3,5-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| 1,3-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| 1,3-dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| 1,4-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| 2,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| 2-Butanone | U | 0.3 | 3.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| 2-Chloroethyl vinyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| 2-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| 2-Hexanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| 4-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| 4-Isopropyltoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| 4-Methyl-2-pentanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| Acetone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| Benzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| Bromobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| Bromochloromethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735

Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 25-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-02A

Client Sample ID: GWQ31610:1420NP1-1-3
 Collection Date: 3/16/2010 2:20:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------|----|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | | | | | |
| | | | SW8260B | | | | Analyst: LA |
| Bromodichloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| Bromoform | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| Bromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| Carbon disulfide | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| Carbon tetrachloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| Chlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| Chloroethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| Chloroform | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| Chloromethane | U | 0.3 | 1.0 | C | µg/L | 1 | 3/23/2010 5:27:00 PM |
| cis-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| cis-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| Dibromochloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| Dibromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| Dichlorodifluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| Ethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| Hexachlorobutadiene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| Isopropylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| m,p-Xylene | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| Methyl tert-butyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| Methylene chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| Naphthalene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| n-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| n-Propylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| o-Xylene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| sec-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| Styrene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| tert-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| Tetrachloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| Toluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| trans-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| trans-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| Trichloroethene | 1.4 | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| Trichlorofluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735

Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 25-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-02A

Client Sample ID: GWQ31610:1420NP1-1-3
 Collection Date: 3/16/2010 2:20:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------|-------------|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | | Analyst: LA | |
| Vinyl acetate | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| Vinyl chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:27:00 PM |
| Surr: 4-Bromofluorobenzene | 100 | 0 | 60-130 | | %REC | 1 | 3/23/2010 5:27:00 PM |
| Surr: Dibromofluoromethane | 97.1 | 0 | 63-127 | | %REC | 1 | 3/23/2010 5:27:00 PM |
| Surr: Toluene-d8 | 102 | 0 | 61-128 | | %REC | 1 | 3/23/2010 5:27:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-02B

Client Sample ID: GWQ31610:1420NP1-1-3
 Collection Date: 3/16/2010 2:20:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|------------|---------------|-------|--------|------|---------|----|-----------------------|
| TOTAL IRON | | | E200.7 | | SW3010A | | Analyst: JP |
| Iron | 2.18 | 0.005 | 0.0200 | | mg/L | 1 | 3/19/2010 10:44:52 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 25-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 1003155
Project: Rowe
Lab ID: 1003155-02C

Client Sample ID: GWQ31610:1420NP1-1-3
Collection Date: 3/16/2010 2:20:00 PM
Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|----------------|---------------|-------|--------|--------|---------|----|-----------------------|
| DISSOLVED IRON | | | | E200.7 | SW3005A | | Analyst: JP |
| Iron | 0.0874 | 0.005 | 0.0200 | | mg/L | 1 | 3/19/2010 10:42:48 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | | | |
|--------------------|-----|---|-----|---|
| Qualifiers: | * | Value exceeds Maximum Contaminant Level | B | Analyte detected in the associated Method Blank |
| | C | Calibration %RSD/%D exceeded for non-CCC analytes | E | Value above quantitation range |
| | H | Holding times for preparation or analysis exceeded | J | Analyte detected below quantitation limits |
| | LOD | Limit of Detection | LOQ | Limit of Quantitation |
| | ND | Not Detected at the Reporting Limit | S | Spike Recovery outside accepted recovery limits |
| | U | Indicates the compound was analyzed but not detected. | | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-03A

Client Sample ID: GWQ31610:1430NP1-1-4
 Collection Date: 3/16/2010 2:30:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| 1,1,1,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| 1,1,1-Trichloroethane | 4.2 | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| 1,1,2,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| 1,1,2-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| 1,1-Dichloroethane | 0.63 | 0.3 | 1.0 | J | µg/L | 1 | 3/23/2010 5:54:00 PM |
| 1,1-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| 1,1-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| 1,2,3-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| 1,2,3-Trichloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| 1,2,4-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| 1,2,4-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| 1,2-Dibromo-3-chloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| 1,2-Dibromoethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| 1,2-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| 1,2-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| 1,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| 1,3,5-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| 1,3-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| 1,3-dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| 1,4-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| 2,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| 2-Butanone | U | 0.3 | 3.0 | C | µg/L | 1 | 3/23/2010 5:54:00 PM |
| 2-Chloroethyl vinyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| 2-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| 2-Hexanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| 4-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| 4-Isopropyltoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| 4-Methyl-2-pentanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| Acetone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| Benzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| Bromobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| Bromochloromethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 25-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-03A

Client Sample ID: GWQ31610:1430NP1-1-4
 Collection Date: 3/16/2010 2:30:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------|----|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | | | | | |
| | | | SW8260B | | | | Analyst: LA |
| Bromodichloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| Bromoform | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| Bromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| Carbon disulfide | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| Carbon tetrachloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| Chlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| Chloroethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| Chloroform | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| Chloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| cis-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| cis-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| Dibromochloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| Dibromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| Dichlorodifluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| Ethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| Hexachlorobutadiene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| Isopropylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| m,p-Xylene | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| Methyl tert-butyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| Methylene chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| Naphthalene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| n-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| n-Propylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| o-Xylene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| sec-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| Styrene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| tert-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| Tetrachloroethene | 2.1 | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| Toluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| trans-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| trans-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| Trichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| Trichlorofluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 25-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-03A

Client Sample ID: GWQ31610:1430NP1-1-4
 Collection Date: 3/16/2010 2:30:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Vinyl acetate | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| Vinyl chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 5:54:00 PM |
| Surr: 4-Bromofluorobenzene | 103 | 0 | 60-130 | | %REC | 1 | 3/23/2010 5:54:00 PM |
| Surr: Dibromofluoromethane | 94.7 | 0 | 63-127 | | %REC | 1 | 3/23/2010 5:54:00 PM |
| Surr: Toluene-d8 | 103 | 0 | 61-128 | | %REC | 1 | 3/23/2010 5:54:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-03B

Client Sample ID: GWQ31610:1430NP1-1-4
 Collection Date: 3/16/2010 2:30:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|------------|---------------|-------|--------|------|---------|----|-----------------------|
| TOTAL IRON | | | E200.7 | | SW3010A | | Analyst: JP |
| Iron | 4.69 | 0.005 | 0.0200 | | mg/L | 1 | 3/19/2010 10:48:59 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

| | | | |
|-------------------|----------------------------------|--------------------------|----------------------|
| CLIENT: | Leggette Brashears & Graham Inc. | Client Sample ID: | GWQ31610:1430NP1-1-4 |
| Lab Order: | 1003155 | Collection Date: | 3/16/2010 2:30:00 PM |
| Project: | Rowe | Matrix: | LIQUID |
| Lab ID: | 1003155-03C | | |

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|-----------------------|---------------|-------|---------------|------|----------------|----|-----------------------|
| DISSOLVED IRON | | | E200.7 | | SW3005A | | Analyst: JP |
| Iron | 2.77 | 0.005 | 0.0200 | | mg/L | 1 | 3/19/2010 10:46:55 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 25-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 1003155
Project: Rowe
Lab ID: 1003155-04A

Client Sample ID: GWQ31610:1440NP1-1-5
Collection Date: 3/16/2010 2:40:00 PM
Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|--------------------|----|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| 1,1,1,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| 1,1,1-Trichloroethane | 2.6 | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| 1,1,2,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| 1,1,2-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| 1,1-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| 1,1-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| 1,1-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| 1,2,3-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| 1,2,3-Trichloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| 1,2,4-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| 1,2,4-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| 1,2-Dibromo-3-chloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| 1,2-Dibromoethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| 1,2-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| 1,2-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| 1,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| 1,3,5-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| 1,3-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| 1,3-dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| 1,4-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| 2,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| 2-Butanone | U | 0.3 | 3.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| 2-Chloroethyl vinyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| 2-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| 2-Hexanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| 4-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| 4-Isopropyltoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| 4-Methyl-2-pentanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| Acetone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| Benzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| Bromobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| Bromochloromethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 25-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-04A

Client Sample ID: GWQ31610:1440NP1-1-5
 Collection Date: 3/16/2010 2:40:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|--------------------|----|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Bromodichloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| Bromoform | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| Bromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| Carbon disulfide | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| Carbon tetrachloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| Chlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| Chloroethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| Chloroform | 0.66 | 0.3 | 1.0 | J | µg/L | 1 | 3/23/2010 6:22:00 PM |
| Chloromethane | U | 0.3 | 1.0 | C | µg/L | 1 | 3/23/2010 6:22:00 PM |
| cis-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| cis-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| Dibromochloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| Dibromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| Dichlorodifluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| Ethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| Hexachlorobutadiene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| Isopropylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| m,p-Xylene | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| Methyl tert-butyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| Methylene chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| Naphthalene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| n-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| n-Propylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| o-Xylene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| sec-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| Styrene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| tert-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| Tetrachloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| Toluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| trans-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| trans-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| Trichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| Trichlorofluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-04A

Client Sample ID: GWQ31610:1440NP1-1-5
 Collection Date: 3/16/2010 2:40:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Vinyl acetate | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| Vinyl chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 6:22:00 PM |
| Surr: 4-Bromofluorobenzene | 98.7 | 0 | 60-130 | | %REC | 1 | 3/23/2010 6:22:00 PM |
| Surr: Dibromofluoromethane | 97.6 | 0 | 63-127 | | %REC | 1 | 3/23/2010 6:22:00 PM |
| Surr: Toluene-d8 | 98.9 | 0 | 61-128 | | %REC | 1 | 3/23/2010 6:22:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 25-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 1003155
Project: Rowe
Lab ID: 1003155-04B

Client Sample ID: GWQ31610:1440NP1-1-5
Collection Date: 3/16/2010 2:40:00 PM
Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|------------|---------------|-------|--------|--------|---------|----|-----------------------|
| TOTAL IRON | | | | E200.7 | SW3010A | | Analyst: JP |
| Iron | 0.0527 | 0.005 | 0.0200 | | mg/L | 1 | 3/19/2010 10:53:05 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- Qualifiers:**
- * Value exceeds Maximum Contaminant Level
 - C Calibration %RSD/%D exceeded for non-CCC analytes
 - H Holding times for preparation or analysis exceeded
 - LOD Limit of Detection
 - ND Not Detected at the Reporting Limit
 - U Indicates the compound was analyzed but not detected.
 - B Analyte detected in the associated Method Blank
 - E Value above quantitation range
 - J Analyte detected below quantitation limits
 - LOQ Limit of Quantitation
 - S Spike Recovery outside accepted recovery limits

American Analytical Laboratories, LLC.

Date: 25-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-04C

Client Sample ID: GWQ31610:1440NP1-1-5
 Collection Date: 3/16/2010 2:40:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|----------------|---------------|-------|--------|------|---------|----|-----------------------|
| DISSOLVED IRON | | | E200.7 | | SW3005A | | Analyst: JP |
| Iron | 0.0230 | 0.005 | 0.0200 | | mg/L | 1 | 3/19/2010 10:51:02 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735

Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| LOD | Limit of Detection | LOQ Limit of Quantitation |
| ND | Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| U | Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 25-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-05A

Client Sample ID: GWQ31610:1450NP1-1-6
 Collection Date: 3/16/2010 2:50:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|--------------------|----|-----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| 1,1,1,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| 1,1,1-Trichloroethane | 4.2 | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| 1,1,2,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| 1,1,2-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| 1,1-Dichloroethane | 0.91 | 0.3 | 1.0 | J | µg/L | 1 | 3/23/2010 11:57:00 PM |
| 1,1-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| 1,1-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| 1,2,3-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| 1,2,3-Trichloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| 1,2,4-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| 1,2,4-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| 1,2-Dibromo-3-chloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| 1,2-Dibromoethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| 1,2-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| 1,2-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| 1,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| 1,3,5-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| 1,3-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| 1,3-dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| 1,4-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| 2,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| 2-Butanone | U | 0.3 | 3.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| 2-Chloroethyl vinyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| 2-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| 2-Hexanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| 4-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| 4-Isopropyltoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| 4-Methyl-2-pentanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| Acetone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| Benzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| Bromobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| Bromochloromethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-05A

Client Sample ID: GWQ31610:1450NP1-1-6
 Collection Date: 3/16/2010 2:50:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|-----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Bromodichloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| Bromoform | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| Bromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| Carbon disulfide | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| Carbon tetrachloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| Chlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| Chloroethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| Chloroform | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| Chloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| cis-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| cis-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| Dibromochloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| Dibromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| Dichlorodifluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| Ethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| Hexachlorobutadiene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| Isopropylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| m,p-Xylene | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| Methyl tert-butyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| Methylene chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| Naphthalene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| n-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| n-Propylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| o-Xylene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| sec-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| Styrene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| tert-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| Tetrachloroethene | 7.0 | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| Toluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| trans-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| trans-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| Trichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| Trichlorofluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 25-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-05A

Client Sample ID: GWQ31610:1450NP1-1-6
 Collection Date: 3/16/2010 2:50:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|-----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Vinyl acetate | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| Vinyl chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 11:57:00 PM |
| Surr: 4-Bromofluorobenzene | 102 | 0 | 60-130 | | %REC | 1 | 3/23/2010 11:57:00 PM |
| Surr: Dibromofluoromethane | 97.1 | 0 | 63-127 | | %REC | 1 | 3/23/2010 11:57:00 PM |
| Surr: Toluene-d8 | 103 | 0 | 61-128 | | %REC | 1 | 3/23/2010 11:57:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-05B

Client Sample ID: GWQ31610:1450NP1-1-6
 Collection Date: 3/16/2010 2:50:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|------------|---------------|-------|--------|--------|---------|----|-----------------------|
| TOTAL IRON | | | | E200.7 | SW3010A | | Analyst: JP |
| Iron | 0.0550 | 0.005 | 0.0200 | | mg/L | 1 | 3/19/2010 10:57:11 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 25-Mar-10

ELAP ID : 11418

| | | | |
|-------------------|----------------------------------|--------------------------|----------------------|
| CLIENT: | Leggette Brashears & Graham Inc. | Client Sample ID: | GWQ31610:1450NP1-1-6 |
| Lab Order: | 1003155 | Collection Date: | 3/16/2010 2:50:00 PM |
| Project: | Rowe | Matrix: | LIQUID |
| Lab ID: | 1003155-05C | | |

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|----------------|---------------|-------|--------|------|---------|----|-----------------------|
| DISSOLVED IRON | | | E200.7 | | SW3005A | | Analyst: JP |
| Iron | 0.0241 | 0.005 | 0.0200 | | mg/L | 1 | 3/19/2010 10:55:08 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- | | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 25-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-06A

Client Sample ID: GWQ31610:1500NP1-1-7
 Collection Date: 3/16/2010 3:00:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|-----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| 1,1,1,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| 1,1,1-Trichloroethane | 0.77 | 0.3 | 1.0 | J | µg/L | 1 | 3/24/2010 12:23:00 AM |
| 1,1,2,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| 1,1,2-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| 1,1-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| 1,1-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| 1,1-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| 1,2,3-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| 1,2,3-Trichloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| 1,2,4-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| 1,2,4-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| 1,2-Dibromo-3-chloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| 1,2-Dibromoethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| 1,2-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| 1,2-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| 1,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| 1,3,5-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| 1,3-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| 1,3-dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| 1,4-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| 2,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| 2-Butanone | U | 0.3 | 3.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| 2-Chloroethyl vinyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| 2-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| 2-Hexanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| 4-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| 4-Isopropyltoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| 4-Methyl-2-pentanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| Acetone | U | 0.3 | 2.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| Benzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| Bromobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| Bromochloromethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 25-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-06A

Client Sample ID: GWQ31610:1500NP1-1-7
 Collection Date: 3/16/2010 3:00:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------|-------------|-----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | | Analyst: LA | |
| Bromodichloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| Bromoform | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| Bromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| Carbon disulfide | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| Carbon tetrachloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| Chlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| Chloroethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| Chloroform | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| Chloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| cis-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| cis-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| Dibromochloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| Dibromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| Dichlorodifluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| Ethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| Hexachlorobutadiene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| Isopropylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| m,p-Xylene | U | 0.3 | 2.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| Methyl tert-butyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| Methylene chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| Naphthalene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| n-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| n-Propylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| o-Xylene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| sec-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| Styrene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| tert-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| Tetrachloroethene | 3.6 | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| Toluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| trans-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| trans-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| Trichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| Trichlorofluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735

Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 25-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-06A

Client Sample ID: GWQ31610:1500NP1-1-7
 Collection Date: 3/16/2010 3:00:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|-----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Vinyl acetate | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| Vinyl chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:23:00 AM |
| Surr: 4-Bromofluorobenzene | 99.2 | 0 | 60-130 | | %REC | 1 | 3/24/2010 12:23:00 AM |
| Surr: Dibromofluoromethane | 100 | 0 | 63-127 | | %REC | 1 | 3/24/2010 12:23:00 AM |
| Surr: Toluene-d8 | 101 | 0 | 61-128 | | %REC | 1 | 3/24/2010 12:23:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 25-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-06B

Client Sample ID: GWQ31610:1500NP1-1-7
 Collection Date: 3/16/2010 3:00:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|------------|---------------|-------|--------|--------|---------|----|-----------------------|
| TOTAL IRON | | | | E200.7 | SW3010A | | Analyst: JP |
| Iron | 0.206 | 0.005 | 0.0200 | | mg/L | 1 | 3/19/2010 11:01:18 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- Qualifiers:**
- * Value exceeds Maximum Contaminant Level
 - C Calibration %RSD/%D exceeded for non-CCC analytes
 - H Holding times for preparation or analysis exceeded
 - LOD Limit of Detection
 - ND Not Detected at the Reporting Limit
 - U Indicates the compound was analyzed but not detected.
 - B Analyte detected in the associated Method Blank
 - E Value above quantitation range
 - J Analyte detected below quantitation limits
 - LOQ Limit of Quantitation
 - S Spike Recovery outside accepted recovery limits

ELAP ID : 11418

| | | | |
|-------------------|----------------------------------|--------------------------|----------------------|
| CLIENT: | Leggette Brashears & Graham Inc. | Client Sample ID: | GWQ31610:1500NP1-1-7 |
| Lab Order: | 1003155 | Collection Date: | 3/16/2010 3:00:00 PM |
| Project: | Rowe | Matrix: | LIQUID |
| Lab ID: | 1003155-06C | | |

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|-----------------------|---------------|-------|---------------|------|----------------|----|-----------------------|
| DISSOLVED IRON | | | E200.7 | | SW3005A | | Analyst: JP |
| Iron | 0.141 | 0.005 | 0.0200 | | mg/L | 1 | 3/19/2010 10:59:14 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-07A

Client Sample ID: GWQ31610:1510NP1-1-8
 Collection Date: 3/16/2010 3:10:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|-----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| 1,1,1,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| 1,1,1-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| 1,1,2,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| 1,1,2-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| 1,1-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| 1,1-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| 1,1-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| 1,2,3-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| 1,2,3-Trichloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| 1,2,4-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| 1,2,4-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| 1,2-Dibromo-3-chloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| 1,2-Dibromoethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| 1,2-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| 1,2-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| 1,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| 1,3,5-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| 1,3-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| 1,3-dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| 1,4-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| 2,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| 2-Butanone | U | 0.3 | 3.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| 2-Chloroethyl vinyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| 2-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| 2-Hexanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| 4-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| 4-Isopropyltoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| 4-Methyl-2-pentanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| Acetone | U | 0.3 | 2.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| Benzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| Bromobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| Bromochloromethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 25-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-07A

Client Sample ID: GWQ31610:1510NP1-1-8
 Collection Date: 3/16/2010 3:10:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|--------------------|----|-----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Bromodichloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| Bromoform | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| Bromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| Carbon disulfide | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| Carbon tetrachloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| Chlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| Chloroethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| Chloroform | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| Chloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| cis-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| cis-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| Dibromochloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| Dibromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| Dichlorodifluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| Ethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| Hexachlorobutadiene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| Isopropylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| m,p-Xylene | U | 0.3 | 2.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| Methyl tert-butyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| Methylene chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| Naphthalene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| n-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| n-Propylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| o-Xylene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| sec-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| Styrene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| tert-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| Tetrachloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| Toluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| trans-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| trans-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| Trichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| Trichlorofluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 25-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 1003155
Project: Rowe
Lab ID: 1003155-07A

Client Sample ID: GWQ31610:1510NP1-1-8
Collection Date: 3/16/2010 3:10:00 PM
Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|-----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Vinyl acetate | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| Vinyl chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 12:49:00 AM |
| Surr: 4-Bromofluorobenzene | 99.9 | 0 | 60-130 | | %REC | 1 | 3/24/2010 12:49:00 AM |
| Surr: Dibromofluoromethane | 99.2 | 0 | 63-127 | | %REC | 1 | 3/24/2010 12:49:00 AM |
| Surr: Toluene-d8 | 105 | 0 | 61-128 | | %REC | 1 | 3/24/2010 12:49:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 25-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-07B

Client Sample ID: GWQ31610:1510NP1-1-8
 Collection Date: 3/16/2010 3:10:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|------------|---------------|-------|--------|------|---------|----|-----------------------|
| TOTAL IRON | | | E200.7 | | SW3010A | | Analyst: JP |
| Iron | 8.15 | 0.005 | 0.0200 | | mg/L | 1 | 3/19/2010 11:25:08 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 25-Mar-10

ELAP ID : 11418

| | | | |
|-------------------|----------------------------------|--------------------------|----------------------|
| CLIENT: | Leggette Brashears & Graham Inc. | Client Sample ID: | GWQ31610:1510NP1-1-8 |
| Lab Order: | 1003155 | Collection Date: | 3/16/2010 3:10:00 PM |
| Project: | Rowe | Matrix: | LIQUID |
| Lab ID: | 1003155-07C | | |

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|----------------|---------------|-------|--------|------|---------|----|-----------------------|
| DISSOLVED IRON | | | E200.7 | | SW3005A | | Analyst: JP |
| Iron | 2.36 | 0.005 | 0.0200 | | mg/L | 1 | 3/19/2010 11:23:05 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



- | | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-08A

Client Sample ID: GWQ31610:1520NP1-1-9
 Collection Date: 3/16/2010 2:10:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| 1,1,1,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| 1,1,1-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| 1,1,2,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| 1,1,2-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| 1,1-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| 1,1-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| 1,1-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| 1,2,3-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| 1,2,3-Trichloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| 1,2,4-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| 1,2,4-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| 1,2-Dibromo-3-chloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| 1,2-Dibromoethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| 1,2-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| 1,2-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| 1,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| 1,3,5-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| 1,3-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| 1,3-dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| 1,4-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| 2,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| 2-Butanone | U | 0.3 | 3.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| 2-Chloroethyl vinyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| 2-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| 2-Hexanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| 4-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| 4-Isopropyltoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| 4-Methyl-2-pentanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| Acetone | U | 0.3 | 2.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| Benzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| Bromobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| Bromochloromethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 25-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-08A

Client Sample ID: GWQ31610:1520NP1-1-9
 Collection Date: 3/16/2010 2:10:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------|-------------|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | | Analyst: LA | |
| Bromodichloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| Bromoform | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| Bromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| Carbon disulfide | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| Carbon tetrachloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| Chlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| Chloroethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| Chloroform | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| Chloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| cis-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| cis-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| Dibromochloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| Dibromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| Dichlorodifluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| Ethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| Hexachlorobutadiene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| Isopropylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| m,p-Xylene | U | 0.3 | 2.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| Methyl tert-butyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| Methylene chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| Naphthalene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| n-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| n-Propylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| o-Xylene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| sec-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| Styrene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| tert-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| Tetrachloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| Toluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| trans-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| trans-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| Trichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| Trichlorofluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735

Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 25-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-08A

Client Sample ID: GWQ31610:1520NP1-1-9
 Collection Date: 3/16/2010 2:10:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------|-------------|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | | Analyst: LA | |
| Vinyl acetate | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| Vinyl chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/24/2010 1:16:00 AM |
| Surr: 4-Bromofluorobenzene | 102 | 0 | 60-130 | | %REC | 1 | 3/24/2010 1:16:00 AM |
| Surr: Dibromofluoromethane | 101 | 0 | 63-127 | | %REC | 1 | 3/24/2010 1:16:00 AM |
| Surr: Toluene-d8 | 100 | 0 | 61-128 | | %REC | 1 | 3/24/2010 1:16:00 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-08B

Client Sample ID: GWQ31610:1520NP1-1-9
 Collection Date: 3/16/2010 2:10:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|------------|---------------|-------|--------|------|---------|----|-----------------------|
| TOTAL IRON | | | E200.7 | | SW3010A | | Analyst: JP |
| Iron | 2.64 | 0.005 | 0.0200 | | mg/L | 1 | 3/19/2010 11:48:52 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 25-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003155
 Project: Rowe
 Lab ID: 1003155-08C

Client Sample ID: GWQ31610:1520NP1-1-9
 Collection Date: 3/16/2010 2:10:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|----------------|---------------|-------|--------|------|---------|----|-----------------------|
| DISSOLVED IRON | | | E200.7 | | SW3005A | | Analyst: JP |
| Iron | 1.84 | 0.005 | 0.0200 | | mg/L | 1 | 3/19/2010 11:27:12 AM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735

Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 25-Mar-10

CLIENT: Leggette Brashears & Graham Inc.
 Work Order: 1003155
 Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

Sample ID: V624LCS-032310YW SampType: LCS TestCode: 8260MTBE11 Units: µg/L Prep Date: RunNo: 49626
 Client ID: LCSW Batch ID: R49626 TestNo: SW8260B Analysis Date: 3/23/2010 SeqNo: 687125

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---------------------------|--------|-----|-----------|-------------|------|----------|-----------|-------------|------|----------|------|
| 1,1,1-Trichloroethane | 36 | 1.0 | 50.00 | 0 | 72.8 | 43 | 148 | | | | |
| 1,1,2,2-Tetrachloroethane | 35 | 1.0 | 50.00 | 0 | 70.1 | 32 | 148 | | | | |
| 1,1,2-Trichloroethane | 35 | 1.0 | 50.00 | 0 | 70.7 | 42 | 136 | | | | |
| 1,1-Dichloroethane | 33 | 1.0 | 50.00 | 0 | 66.0 | 40 | 150 | | | | |
| 1,1-Dichloroethene | 36 | 1.0 | 50.00 | 0 | 72.0 | 30 | 154 | | | | |
| 1,2-Dichlorobenzene | 38 | 1.0 | 50.00 | 0 | 76.8 | 40 | 129 | | | | |
| 1,2-Dichloroethane | 36 | 1.0 | 50.00 | 0 | 71.3 | 36 | 141 | | | | |
| 1,2-Dichloropropane | 35 | 1.0 | 50.00 | 0 | 70.2 | 44 | 138 | | | | |
| 1,3-Dichlorobenzene | 38 | 1.0 | 50.00 | 0 | 75.9 | 40 | 133 | | | | |
| 1,4-Dichlorobenzene | 38 | 1.0 | 50.00 | 0 | 75.7 | 40 | 135 | | | | |
| 2-Chloroethyl vinyl ether | 33 | 1.0 | 50.00 | 0 | 66.3 | 21 | 139 | | | | |
| Benzene | 32 | 1.0 | 50.00 | 0 | 64.8 | 45 | 144 | | | | |
| Bromodichloromethane | 38 | 1.0 | 50.00 | 0 | 76.2 | 35 | 136 | | | | |
| Bromoform | 36 | 1.0 | 50.00 | 0 | 72.0 | 28 | 138 | | | | |
| Bromomethane | 45 | 1.0 | 50.00 | 0 | 89.6 | 26 | 148 | | | | |
| Carbon tetrachloride | 37 | 1.0 | 50.00 | 0 | 74.9 | 45 | 141 | | | | |
| Chlorobenzene | 38 | 1.0 | 50.00 | 0 | 75.4 | 41 | 142 | | | | |
| Chloroethane | 41 | 1.0 | 50.00 | 0 | 82.3 | 36 | 143 | | | | |
| Chloroform | 32 | 1.0 | 50.00 | 0 | 64.6 | 42 | 137 | | | | |
| Chloromethane | 43 | 1.0 | 50.00 | 0 | 85.2 | 35 | 151 | | | | |
| cis-1,3-Dichloropropene | 36 | 1.0 | 50.00 | 0 | 71.3 | 42 | 130 | | | | |
| Dibromochloromethane | 35 | 1.0 | 50.00 | 0 | 69.7 | 21 | 134 | | | | |
| Ethylbenzene | 40 | 1.0 | 50.00 | 0 | 79.2 | 45 | 146 | | | | |
| Tetrachloroethene | 37 | 1.0 | 50.00 | 0 | 74.6 | 45 | 136 | | | | |
| Toluene | 37 | 1.0 | 50.00 | 0 | 73.3 | 43 | 134 | | | | |
| trans-1,2-Dichloroethene | 33 | 1.0 | 50.00 | 0 | 65.8 | 42 | 135 | | | | |
| trans-1,3-Dichloropropene | 40 | 1.0 | 50.00 | 0 | 80.7 | 37 | 133 | | | | |
| Trichloroethene | 38 | 1.0 | 50.00 | 0 | 76.3 | 43 | 140 | | | | |
| Trichlorofluoromethane | 50 | 1.0 | 50.00 | 0 | 100 | 50 | 148 | | | | |
| Vinyl chloride | 49 | 1.0 | 50.00 | 0 | 97.8 | 35 | 142 | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

CLIENT: Leggette Brashears & Graham Inc.
 Work Order: 1003155
 Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

| | | | | | | | | | | | |
|-----------------------------|------------------|----------------------|-------------|--------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Sample ID: V624LCS-032310YW | SampType: LCS | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49626 | | | | | | |
| Client ID: LCSW | Batch ID: R49626 | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 687125 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| Surr: 4-Bromofluorobenzene | 52 | | 50.00 | | 103 | 60 | 130 | | | | |
| Surr: Dibromofluoromethane | 47 | | 50.00 | | 94.8 | 63 | 127 | | | | |
| Surr: Toluene-d8 | 52 | | 50.00 | | 103 | 61 | 128 | | | | |

| | | | | | | | | | | | |
|--------------------------|------------------|----------------------|-------------|--------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Sample ID: VBLK-032310YW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49626 | | | | | | |
| Client ID: PBW | Batch ID: R49626 | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 687126 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|---------------------------------------|---|-----|--|--|--|--|--|--|--|--|---|
| 1,1,1,2-Tetrachloroethane | U | 1.0 | | | | | | | | | |
| 1,1,1-Trichloroethane | U | 1.0 | | | | | | | | | |
| 1,1,2,2-Tetrachloroethane | U | 1.0 | | | | | | | | | |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 1.0 | | | | | | | | | |
| 1,1,2-Trichloroethane | U | 1.0 | | | | | | | | | |
| 1,1-Dichloroethane | U | 1.0 | | | | | | | | | |
| 1,1-Dichloroethene | U | 1.0 | | | | | | | | | |
| 1,1-Dichloropropene | U | 1.0 | | | | | | | | | |
| 1,2,3-Trichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2,3-Trichloropropane | U | 1.0 | | | | | | | | | |
| 1,2,4-Trichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2,4-Trimethylbenzene | U | 1.0 | | | | | | | | | |
| 1,2-Dibromo-3-chloropropane | U | 1.0 | | | | | | | | | |
| 1,2-Dibromoethane | U | 1.0 | | | | | | | | | |
| 1,2-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2-Dichloroethane | U | 1.0 | | | | | | | | | |
| 1,2-Dichloropropane | U | 1.0 | | | | | | | | | |
| 1,3,5-Trimethylbenzene | U | 1.0 | | | | | | | | | |
| 1,3-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,3-dichloropropane | U | 1.0 | | | | | | | | | |
| 1,4-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 2,2-Dichloropropane | U | 1.0 | | | | | | | | | |
| 2-Butanone | U | 3.0 | | | | | | | | | C |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

CLIENT: Leggette Brashears & Graham Inc.
 Work Order: 1003155
 Project: Rowe

| Sample ID: VBLK-032310YW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49626 | | | | | | |
|--------------------------|------------------|----------------------|-------------|--------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Client ID: PBW | Batch ID: R49626 | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 687126 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|---------------------------|---|-----|--|--|--|--|--|--|--|--|--|
| 2-Chloroethyl vinyl ether | U | 1.0 | | | | | | | | | |
| 2-Chlorotoluene | U | 1.0 | | | | | | | | | |
| 2-Hexanone | U | 2.0 | | | | | | | | | |
| 4-Chlorotoluene | U | 1.0 | | | | | | | | | |
| 4-Isopropyltoluene | U | 1.0 | | | | | | | | | |
| 4-Methyl-2-pentanone | U | 2.0 | | | | | | | | | |
| Acetone | U | 2.0 | | | | | | | | | |
| Benzene | U | 1.0 | | | | | | | | | |
| Bromobenzene | U | 1.0 | | | | | | | | | |
| Bromochloromethane | U | 1.0 | | | | | | | | | |
| Bromodichloromethane | U | 1.0 | | | | | | | | | |
| Bromoform | U | 1.0 | | | | | | | | | |
| Bromomethane | U | 1.0 | | | | | | | | | |
| Carbon disulfide | U | 1.0 | | | | | | | | | |
| Carbon tetrachloride | U | 1.0 | | | | | | | | | |
| Chlorobenzene | U | 1.0 | | | | | | | | | |
| Chloroethane | U | 1.0 | | | | | | | | | |
| Chloroform | U | 1.0 | | | | | | | | | |
| Chloromethane | U | 1.0 | | | | | | | | | |
| cis-1,2-Dichloroethene | U | 1.0 | | | | | | | | | |
| cis-1,3-Dichloropropene | U | 1.0 | | | | | | | | | |
| Dibromochloromethane | U | 1.0 | | | | | | | | | |
| Dibromomethane | U | 1.0 | | | | | | | | | |
| Dichlorodifluoromethane | U | 1.0 | | | | | | | | | |
| Ethylbenzene | U | 1.0 | | | | | | | | | |
| Hexachlorobutadiene | U | 1.0 | | | | | | | | | |
| Isopropylbenzene | U | 1.0 | | | | | | | | | |
| m,p-Xylene | U | 2.0 | | | | | | | | | |
| Methyl tert-butyl ether | U | 1.0 | | | | | | | | | |
| Methylene chloride | U | 1.0 | | | | | | | | | |
| Naphthalene | U | 1.0 | | | | | | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

CLIENT: Leggettie Brashears & Graham Inc.
 Work Order: 1003155
 Project: Rowe

ANALYTICAL QC SUMMARY REPORT
 TestCode: 8260MTBE113_W

Sample ID: VBLK-032310YW SampType: MBLK TestCode: 8260MTBE11 Units: µg/L Prep Date: RunNo: 49626
 Client ID: PBW Batch ID: R49626 TestNo: SW8260B Analysis Date: 3/23/2010 SeqNo: 687126

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|----------------------------|--------|-----|-----------|-------------|------|----------|-----------|-------------|------|----------|------|
| n-Butylbenzene | U | 1.0 | | | | | | | | | |
| n-Propylbenzene | U | 1.0 | | | | | | | | | |
| o-Xylene | U | 1.0 | | | | | | | | | |
| sec-Butylbenzene | U | 1.0 | | | | | | | | | |
| Styrene | U | 1.0 | | | | | | | | | |
| tert-Butylbenzene | U | 1.0 | | | | | | | | | |
| Tetrachloroethene | U | 1.0 | | | | | | | | | |
| Toluene | U | 1.0 | | | | | | | | | |
| trans-1,2-Dichloroethene | U | 1.0 | | | | | | | | | |
| trans-1,3-Dichloropropene | U | 1.0 | | | | | | | | | |
| Trichloroethene | U | 1.0 | | | | | | | | | |
| Trichlorofluoromethane | U | 1.0 | | | | | | | | | |
| Vinyl acetate | U | 1.0 | | | | | | | | | |
| Vinyl chloride | U | 1.0 | | | | | | | | | |
| Surr: 4-Bromofluorobenzene | 51 | | 50.00 | | 102 | 60 | 130 | | | | |
| Surr: Dibromofluoromethane | 47 | | 50.00 | | 93.5 | 63 | 127 | | | | |
| Surr: Toluene-d8 | 51 | | 50.00 | | 101 | 61 | 128 | | | | |

Sample ID: V624LCS-032310YW SampType: LCS TestCode: 8260MTBE11 Units: µg/L Prep Date: RunNo: 49626
 Client ID: LCSW Batch ID: R49626A TestNo: SW8260B Analysis Date: 3/23/2010 SeqNo: 687129

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---------------------------|--------|-----|-----------|-------------|------|----------|-----------|-------------|------|----------|------|
| 1,1,1-Trichloroethane | 39 | 1.0 | 50.00 | 0 | 77.5 | 43 | 148 | | | | |
| 1,1,2,2-Tetrachloroethane | 38 | 1.0 | 50.00 | 0 | 76.7 | 32 | 148 | | | | |
| 1,1,2-Trichloroethane | 37 | 1.0 | 50.00 | 0 | 73.2 | 42 | 136 | | | | |
| 1,1-Dichloroethane | 35 | 1.0 | 50.00 | 0 | 70.6 | 40 | 150 | | | | |
| 1,1-Dichloroethene | 39 | 1.0 | 50.00 | 0 | 78.0 | 30 | 154 | | | | |
| 1,2-Dichlorobenzene | 41 | 1.0 | 50.00 | 0 | 81.1 | 40 | 129 | | | | |
| 1,2-Dichloroethane | 39 | 1.0 | 50.00 | 0 | 78.8 | 36 | 141 | | | | |
| 1,2-Dichloropropane | 41 | 1.0 | 50.00 | 0 | 81.6 | 44 | 138 | | | | |
| 1,3-Dichlorobenzene | 41 | 1.0 | 50.00 | 0 | 82.7 | 40 | 133 | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

CLIENT: Leggett Brashears & Graham Inc.
 Work Order: 1003155
 Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

| | | | | | | |
|-----------------------------|-------------------|---------------|----------------------|-------------|--------------------------|---------------|
| Sample ID: V624LCS-032310YW | Batch ID: R49626A | SampType: LCS | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49626 |
| Client ID: LCSW | | | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 687129 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|----------------------------|--------|-----|-----------|-------------|------|----------|-----------|-------------|------|----------|------|
| 1,4-Dichlorobenzene | 41 | 1.0 | 50.00 | 0 | 81.5 | 40 | 135 | | | | |
| 2-Chloroethyl vinyl ether | 33 | 1.0 | 50.00 | 0 | 65.4 | 21 | 139 | | | | |
| Benzene | 39 | 1.0 | 50.00 | 0 | 77.7 | 45 | 144 | | | | |
| Bromodichloromethane | 37 | 1.0 | 50.00 | 0 | 74.5 | 35 | 136 | | | | |
| Bromoform | 37 | 1.0 | 50.00 | 0 | 74.1 | 28 | 138 | | | | |
| Bromomethane | 32 | 1.0 | 50.00 | 0 | 63.1 | 26 | 148 | | | | |
| Carbon tetrachloride | 39 | 1.0 | 50.00 | 0 | 78.4 | 45 | 141 | | | | |
| Chlorobenzene | 41 | 1.0 | 50.00 | 0 | 81.9 | 41 | 142 | | | | |
| Chloroethane | 47 | 1.0 | 50.00 | 0 | 93.2 | 36 | 143 | | | | |
| Chloroform | 39 | 1.0 | 50.00 | 0 | 77.8 | 42 | 137 | | | | |
| Chloromethane | 40 | 1.0 | 50.00 | 0 | 79.2 | 35 | 151 | | | | |
| cis-1,3-Dichloropropene | 41 | 1.0 | 50.00 | 0 | 82.7 | 42 | 130 | | | | C |
| Dibromochloromethane | 37 | 1.0 | 50.00 | 0 | 73.9 | 21 | 134 | | | | |
| Ethylbenzene | 42 | 1.0 | 50.00 | 0 | 83.8 | 45 | 146 | | | | |
| Tetrachloroethene | 41 | 1.0 | 50.00 | 0 | 81.8 | 45 | 136 | | | | |
| Toluene | 38 | 1.0 | 50.00 | 0 | 77.0 | 43 | 134 | | | | |
| trans-1,2-Dichloroethene | 36 | 1.0 | 50.00 | 0 | 71.9 | 42 | 135 | | | | |
| trans-1,3-Dichloropropene | 38 | 1.0 | 50.00 | 0 | 76.6 | 37 | 133 | | | | |
| Trichloroethene | 41 | 1.0 | 50.00 | 0 | 81.2 | 43 | 140 | | | | |
| Trichlorofluoromethane | 52 | 1.0 | 50.00 | 0 | 104 | 50 | 148 | | | | |
| Vinyl chloride | 51 | 1.0 | 50.00 | 0 | 103 | 35 | 142 | | | | |
| Surr: 4-Bromofluorobenzene | 51 | | 50.00 | | 102 | 60 | 130 | | | | |
| Surr: Dibromofluoromethane | 48 | | 50.00 | | 96.4 | 63 | 127 | | | | |
| Surr: Toluene-d8 | 51 | | 50.00 | | 101 | 61 | 128 | | | | |

| | | | | | | |
|--------------------------|-------------------|----------------|----------------------|-------------|--------------------------|---------------|
| Sample ID: VBLK-032310YW | Batch ID: R49626A | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49626 |
| Client ID: PBW | | | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 687130 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---------------------------|--------|-----|-----------|-------------|------|----------|-----------|-------------|------|----------|------|
| 1,1,1,2-Tetrachloroethane | U | 1.0 | | | | | | | | | |
| 1,1,1-Trichloroethane | U | 1.0 | | | | | | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

CLIENT: Leggette Brashears & Graham Inc.
 Work Order: 1003155
 Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

| | | | | | |
|--------------------------|-------------------|----------------------|-------------|--------------------------|---------------|
| Sample ID: VBLK-032310YW | Samp Type: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49626 |
| Client ID: PBW | Batch ID: R49626A | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 687130 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---------------------------------------|--------|-----|-----------|-------------|------|----------|-----------|-------------|------|----------|------|
| 1,1,2,2-Tetrachloroethane | U | 1.0 | | | | | | | | | |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 1.0 | | | | | | | | | |
| 1,1,2-Trichloroethane | U | 1.0 | | | | | | | | | |
| 1,1-Dichloroethane | U | 1.0 | | | | | | | | | |
| 1,1-Dichloroethene | U | 1.0 | | | | | | | | | |
| 1,1-Dichloropropene | U | 1.0 | | | | | | | | | |
| 1,2,3-Trichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2,3-Trichloropropane | U | 1.0 | | | | | | | | | |
| 1,2,4-Trichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2,4-Trimethylbenzene | U | 1.0 | | | | | | | | | |
| 1,2-Dibromo-3-chloropropane | U | 1.0 | | | | | | | | | |
| 1,2-Dibromoethane | U | 1.0 | | | | | | | | | |
| 1,2-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2-Dichloroethane | U | 1.0 | | | | | | | | | |
| 1,2-Dichloropropane | U | 1.0 | | | | | | | | | |
| 1,3,5-Trimethylbenzene | U | 1.0 | | | | | | | | | |
| 1,3-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,3-dichloropropane | U | 1.0 | | | | | | | | | |
| 1,4-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 2,2-Dichloropropane | U | 1.0 | | | | | | | | | |
| 2-Butanone | U | 3.0 | | | | | | | | | |
| 2-Chloroethyl vinyl ether | U | 1.0 | | | | | | | | | |
| 2-Chlorotoluene | U | 1.0 | | | | | | | | | |
| 2-Hexanone | U | 2.0 | | | | | | | | | |
| 4-Chlorotoluene | U | 1.0 | | | | | | | | | |
| 4-Isopropyltoluene | U | 1.0 | | | | | | | | | |
| 4-Methyl-2-pentanone | U | 2.0 | | | | | | | | | |
| Acetone | U | 2.0 | | | | | | | | | |
| Benzene | U | 1.0 | | | | | | | | | |
| Bromobenzene | U | 1.0 | | | | | | | | | |
| Bromochloromethane | U | 1.0 | | | | | | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or anal
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

CLIENT: Leggett Brashears & Graham Inc.
Work Order: 1003155
Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

| | | | | | | | | | | | |
|--------------------------|-------------------|----------------------|-------------|--------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Sample ID: VBLK-032310YW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49626 | | | | | | |
| Client ID: PBW | Batch ID: R49626A | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 687130 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|---------------------------|---|-----|--|--|--|--|--|--|--|--|--|
| Bromodichloromethane | U | 1.0 | | | | | | | | | |
| Bromoform | U | 1.0 | | | | | | | | | |
| Bromomethane | U | 1.0 | | | | | | | | | |
| Carbon disulfide | U | 1.0 | | | | | | | | | |
| Carbon tetrachloride | U | 1.0 | | | | | | | | | |
| Chlorobenzene | U | 1.0 | | | | | | | | | |
| Chloroethane | U | 1.0 | | | | | | | | | |
| Chloroform | U | 1.0 | | | | | | | | | |
| Chloromethane | U | 1.0 | | | | | | | | | |
| cis-1,2-Dichloroethene | U | 1.0 | | | | | | | | | |
| cis-1,3-Dichloropropene | U | 1.0 | | | | | | | | | |
| Dibromochloromethane | U | 1.0 | | | | | | | | | |
| Dibromomethane | U | 1.0 | | | | | | | | | |
| Dichlorodifluoromethane | U | 1.0 | | | | | | | | | |
| Ethylbenzene | U | 1.0 | | | | | | | | | |
| Hexachlorobutadiene | U | 1.0 | | | | | | | | | |
| Isopropylbenzene | U | 1.0 | | | | | | | | | |
| m,p-Xylene | U | 2.0 | | | | | | | | | |
| Methyl tert-butyl ether | U | 1.0 | | | | | | | | | |
| Methylene chloride | U | 1.0 | | | | | | | | | |
| Naphthalene | U | 1.0 | | | | | | | | | |
| n-Butylbenzene | U | 1.0 | | | | | | | | | |
| n-Propylbenzene | U | 1.0 | | | | | | | | | |
| o-Xylene | U | 1.0 | | | | | | | | | |
| sec-Butylbenzene | U | 1.0 | | | | | | | | | |
| Styrene | U | 1.0 | | | | | | | | | |
| tert-Butylbenzene | U | 1.0 | | | | | | | | | |
| Tetrachloroethene | U | 1.0 | | | | | | | | | |
| Toluene | U | 1.0 | | | | | | | | | |
| trans-1,2-Dichloroethene | U | 1.0 | | | | | | | | | |
| trans-1,3-Dichloropropene | U | 1.0 | | | | | | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or anal
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 1003155
Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

| | | | | | | | | | | | |
|---------------------------------|--------------------------|-----------------------------|--------------------|---------------------------------|----------------------|----------|-----------|-------------|------|----------|------|
| Sample ID: VBLK-032310YW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49626 | | | | | | |
| Client ID: PBW | Batch ID: R49626A | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 687130 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|----------------------------|----|-----|-------|--|------|----|-----|--|--|--|--|
| Trichloroethene | U | 1.0 | | | | | | | | | |
| Trichlorofluoromethane | U | 1.0 | | | | | | | | | |
| Vinyl acetate | U | 1.0 | | | | | | | | | |
| Vinyl chloride | U | 1.0 | | | | | | | | | |
| Surr: 4-Bromofluorobenzene | 51 | | 50.00 | | 102 | 60 | 130 | | | | |
| Surr: Dibromofluoromethane | 49 | | 50.00 | | 98.1 | 63 | 127 | | | | |
| Surr: Toluene-d8 | 50 | | 50.00 | | 100 | 61 | 128 | | | | |

| | | | | | | | | | | | |
|------------------------------------|--------------------------|-----------------------------|--------------------|---------------------------------|----------------------|----------|-----------|-------------|------|----------|------|
| Sample ID: V624LCS-032310aY | SampType: LCS | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49626 | | | | | | |
| Client ID: LCSW | Batch ID: R49626B | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 687133 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|---------------------------|----|-----|-------|---|------|----|-----|--|--|--|--|
| 1,1,1-Trichloroethane | 41 | 1.0 | 50.00 | 0 | 81.8 | 43 | 148 | | | | |
| 1,1,2,2-Tetrachloroethane | 38 | 1.0 | 50.00 | 0 | 75.3 | 32 | 148 | | | | |
| 1,1,2-Trichloroethane | 37 | 1.0 | 50.00 | 0 | 73.2 | 42 | 136 | | | | |
| 1,1-Dichloroethane | 36 | 1.0 | 50.00 | 0 | 71.4 | 40 | 150 | | | | |
| 1,1-Dichloroethene | 40 | 1.0 | 50.00 | 0 | 80.5 | 30 | 154 | | | | |
| 1,2-Dichlorobenzene | 40 | 1.0 | 50.00 | 0 | 79.6 | 40 | 129 | | | | |
| 1,2-Dichloroethane | 40 | 1.0 | 50.00 | 0 | 79.3 | 36 | 141 | | | | |
| 1,2-Dichloropropane | 41 | 1.0 | 50.00 | 0 | 81.9 | 44 | 138 | | | | |
| 1,3-Dichlorobenzene | 40 | 1.0 | 50.00 | 0 | 79.4 | 40 | 133 | | | | |
| 1,4-Dichlorobenzene | 39 | 1.0 | 50.00 | 0 | 77.8 | 40 | 135 | | | | |
| 2-Chloroethyl vinyl ether | 33 | 1.0 | 50.00 | 0 | 65.8 | 21 | 139 | | | | |
| Benzene | 39 | 1.0 | 50.00 | 0 | 78.9 | 45 | 144 | | | | |
| Bromodichloromethane | 36 | 1.0 | 50.00 | 0 | 72.2 | 35 | 136 | | | | |
| Bromoform | 36 | 1.0 | 50.00 | 0 | 71.0 | 28 | 138 | | | | |
| Bromomethane | 35 | 1.0 | 50.00 | 0 | 69.8 | 26 | 148 | | | | |
| Carbon tetrachloride | 42 | 1.0 | 50.00 | 0 | 83.3 | 45 | 141 | | | | |
| Chlorobenzene | 40 | 1.0 | 50.00 | 0 | 79.1 | 41 | 142 | | | | |
| Chloroethane | 49 | 1.0 | 50.00 | 0 | 97.7 | 36 | 143 | | | | |
| Chloroform | 39 | 1.0 | 50.00 | 0 | 77.1 | 42 | 137 | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

CLIENT: Leggett Brashears & Graham Inc.
 Work Order: 1003155
 Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

| | | | | | |
|-----------------------------|-------------------|----------------------|-------------|--------------------------|---------------|
| Sample ID: V624LCS-032310aY | SampType: LCS | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49626 |
| Client ID: LCSW | Batch ID: R49626B | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 687133 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|----------------------------|--------|-----|-----------|-------------|------|----------|-----------|-------------|------|----------|------|
| Chloromethane | 42 | 1.0 | 50.00 | 0 | 84.1 | 35 | 151 | | | | |
| cis-1,3-Dichloropropene | 39 | 1.0 | 50.00 | 0 | 78.6 | 42 | 130 | | | | |
| Dibromochloromethane | 36 | 1.0 | 50.00 | 0 | 72.1 | 21 | 134 | | | | |
| Ethylbenzene | 41 | 1.0 | 50.00 | 0 | 82.2 | 45 | 146 | | | | |
| Tetrachloroethene | 41 | 1.0 | 50.00 | 0 | 81.2 | 45 | 136 | | | | |
| Toluene | 38 | 1.0 | 50.00 | 0 | 75.7 | 43 | 134 | | | | |
| trans-1,2-Dichloroethene | 36 | 1.0 | 50.00 | 0 | 72.4 | 42 | 135 | | | | |
| trans-1,3-Dichloropropene | 37 | 1.0 | 50.00 | 0 | 74.4 | 37 | 133 | | | | |
| Trichloroethene | 40 | 1.0 | 50.00 | 0 | 79.1 | 43 | 140 | | | | |
| Trichlorofluoromethane | 55 | 1.0 | 50.00 | 0 | 109 | 50 | 148 | | | | |
| Vinyl chloride | 54 | 1.0 | 50.00 | 0 | 108 | 35 | 142 | | | | |
| Surr: 4-Bromofluorobenzene | 50 | | 50.00 | | 99.3 | 60 | 130 | | | | |
| Surr: Dibromofluoromethane | 50 | | 50.00 | | 101 | 63 | 127 | | | | |
| Surr: Toluene-d8 | 50 | | 50.00 | | 99.8 | 61 | 128 | | | | |

| | | | | | |
|---------------------------|-------------------|----------------------|-------------|--------------------------|---------------|
| Sample ID: VBLK-032310aYW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49626 |
| Client ID: PBW | Batch ID: R49626B | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 687134 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---------------------------------------|--------|-----|-----------|-------------|------|----------|-----------|-------------|------|----------|------|
| 1,1,1,2-Tetrachloroethane | U | 1.0 | | | | | | | | | |
| 1,1,1-Trichloroethane | U | 1.0 | | | | | | | | | |
| 1,1,2,2-Tetrachloroethane | U | 1.0 | | | | | | | | | |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 1.0 | | | | | | | | | |
| 1,1,2-Trichloroethane | U | 1.0 | | | | | | | | | |
| 1,1-Dichloroethane | U | 1.0 | | | | | | | | | |
| 1,1-Dichloroethene | U | 1.0 | | | | | | | | | |
| 1,1-Dichloropropene | U | 1.0 | | | | | | | | | |
| 1,2,3-Trichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2,3-Trichloropropane | U | 1.0 | | | | | | | | | |
| 1,2,4-Trichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2,4-Trimethylbenzene | U | 1.0 | | | | | | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

CLIENT: Leggette Brashears & Graham Inc.
 Work Order: 1003155
 Project: Rowe

| | | | | | | | | | | | |
|---------------------------|-------------------|----------------------|-------------|--------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Sample ID: VBLK-032310aYW | Samp Type: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49626 | | | | | | |
| Client ID: PBW | Batch ID: R49626B | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 687134 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|-----------------------------|---|-----|--|--|--|--|--|--|--|--|--|
| 1,2-Dibromo-3-chloropropane | U | 1.0 | | | | | | | | | |
| 1,2-Dibromoethane | U | 1.0 | | | | | | | | | |
| 1,2-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2-Dichloroethane | U | 1.0 | | | | | | | | | |
| 1,2-Dichloropropane | U | 1.0 | | | | | | | | | |
| 1,3,5-Trimethylbenzene | U | 1.0 | | | | | | | | | |
| 1,3-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,3-dichloropropane | U | 1.0 | | | | | | | | | |
| 1,4-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 2,2-Dichloropropane | U | 1.0 | | | | | | | | | |
| 2-Butanone | U | 3.0 | | | | | | | | | |
| 2-Chloroethyl vinyl ether | U | 1.0 | | | | | | | | | |
| 2-Chlorotoluene | U | 1.0 | | | | | | | | | |
| 2-Hexanone | U | 2.0 | | | | | | | | | |
| 4-Chlorotoluene | U | 1.0 | | | | | | | | | |
| 4-Isopropyltoluene | U | 1.0 | | | | | | | | | |
| 4-Methyl-2-pentanone | U | 2.0 | | | | | | | | | |
| Acetone | U | 2.0 | | | | | | | | | |
| Benzene | U | 1.0 | | | | | | | | | |
| Bromobenzene | U | 1.0 | | | | | | | | | |
| Bromochloromethane | U | 1.0 | | | | | | | | | |
| Bromodichloromethane | U | 1.0 | | | | | | | | | |
| Bromoform | U | 1.0 | | | | | | | | | |
| Bromomethane | U | 1.0 | | | | | | | | | |
| Carbon disulfide | U | 1.0 | | | | | | | | | |
| Carbon tetrachloride | U | 1.0 | | | | | | | | | |
| Chlorobenzene | U | 1.0 | | | | | | | | | |
| Chloroethane | U | 1.0 | | | | | | | | | |
| Chloroform | U | 1.0 | | | | | | | | | |
| Chloromethane | U | 1.0 | | | | | | | | | |
| cis-1,2-Dichloroethene | U | 1.0 | | | | | | | | | |

Qualifiers: C Calibration %RSD/%d exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or anal
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

CLIENT: Leggett Brashears & Graham Inc.
Work Order: 1003155
Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

| Sample ID: VBLK-032310aYW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49626 | | | | | | |
|----------------------------------|--------------------------|-----------------------------|--------------------|---------------------------------|----------------------|----------|-----------|-------------|------|----------|------|
| Client ID: PBW | Batch ID: R49626B | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 687134 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|----------------------------|----|-----|-------|--|-----|----|--|-----|--|--|--|
| cis-1,3-Dichloropropene | U | 1.0 | | | | | | | | | |
| Dibromochloromethane | U | 1.0 | | | | | | | | | |
| Dibromomethane | U | 1.0 | | | | | | | | | |
| Dichlorodifluoromethane | U | 1.0 | | | | | | | | | |
| Ethylbenzene | U | 1.0 | | | | | | | | | |
| Hexachlorobutadiene | U | 1.0 | | | | | | | | | |
| Isopropylbenzene | U | 1.0 | | | | | | | | | |
| m,p-Xylene | U | 2.0 | | | | | | | | | |
| Methyl tert-butyl ether | U | 1.0 | | | | | | | | | |
| Methylene chloride | U | 1.0 | | | | | | | | | |
| Naphthalene | U | 1.0 | | | | | | | | | |
| n-Butylbenzene | U | 1.0 | | | | | | | | | |
| n-Propylbenzene | U | 1.0 | | | | | | | | | |
| o-Xylene | U | 1.0 | | | | | | | | | |
| sec-Butylbenzene | U | 1.0 | | | | | | | | | |
| Styrene | U | 1.0 | | | | | | | | | |
| tert-Butylbenzene | U | 1.0 | | | | | | | | | |
| Tetrachloroethene | U | 1.0 | | | | | | | | | |
| Toluene | U | 1.0 | | | | | | | | | |
| trans-1,2-Dichloroethene | U | 1.0 | | | | | | | | | |
| trans-1,3-Dichloropropene | U | 1.0 | | | | | | | | | |
| Trichloroethene | U | 1.0 | | | | | | | | | |
| Trichlorofluoromethane | U | 1.0 | | | | | | | | | |
| Vinyl acetate | U | 1.0 | | | | | | | | | |
| Vinyl chloride | U | 1.0 | | | | | | | | | |
| Surr: 4-Bromofluorobenzene | 53 | | 50.00 | | 105 | 60 | | 130 | | | |
| Surr: Dibromofluoromethane | 50 | | 50.00 | | 100 | 63 | | 127 | | | |
| Surr: Toluene-d8 | 50 | | 50.00 | | 101 | 61 | | 128 | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analyte
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

CLIENT: Leggette Brashears & Graham Inc.
 Work Order: 1003155
 Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

| Sample ID: V624LCS-032310aY | SampType: LCS | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49626 | | | | | | |
|-----------------------------|-------------------|----------------------|-------------|--------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Client ID: LCSW | Batch ID: R49626C | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 687137 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| 1,1,1-Trichloroethane | 38 | 1.0 | 50.00 | 0 | 75.8 | 43 | 148 | | | | |
| 1,1,1,2-Tetrachloroethane | 38 | 1.0 | 50.00 | 0 | 75.7 | 32 | 148 | | | | |
| 1,1,1,2-Trichloroethane | 36 | 1.0 | 50.00 | 0 | 72.5 | 42 | 136 | | | | |
| 1,1-Dichloroethane | 34 | 1.0 | 50.00 | 0 | 68.8 | 40 | 150 | | | | |
| 1,1-Dichloroethene | 40 | 1.0 | 50.00 | 0 | 79.9 | 30 | 154 | | | | |
| 1,2-Dichlorobenzene | 39 | 1.0 | 50.00 | 0 | 78.9 | 40 | 129 | | | | |
| 1,2-Dichloroethane | 38 | 1.0 | 50.00 | 0 | 76.7 | 36 | 141 | | | | |
| 1,2-Dichloropropane | 36 | 1.0 | 50.00 | 0 | 71.3 | 44 | 138 | | | | |
| 1,3-Dichlorobenzene | 38 | 1.0 | 50.00 | 0 | 76.6 | 40 | 133 | | | | |
| 1,4-Dichlorobenzene | 39 | 1.0 | 50.00 | 0 | 77.6 | 40 | 135 | | | | |
| 2-Chloroethyl vinyl ether | 38 | 1.0 | 50.00 | 0 | 75.1 | 21 | 139 | | | | |
| Benzene | 33 | 1.0 | 50.00 | 0 | 66.5 | 45 | 144 | | | | |
| Bromodichloromethane | 39 | 1.0 | 50.00 | 0 | 78.3 | 35 | 136 | | | | |
| Bromoform | 38 | 1.0 | 50.00 | 0 | 75.1 | 28 | 138 | | | | |
| Bromomethane | 51 | 1.0 | 50.00 | 0 | 102 | 26 | 148 | | | | |
| Carbon tetrachloride | 40 | 1.0 | 50.00 | 0 | 79.0 | 45 | 141 | | | | |
| Chlorobenzene | 38 | 1.0 | 50.00 | 0 | 76.9 | 41 | 142 | | | | |
| Chloroethane | 46 | 1.0 | 50.00 | 0 | 91.7 | 36 | 143 | | | | |
| Chloroform | 33 | 1.0 | 50.00 | 0 | 66.3 | 42 | 137 | | | | |
| Chloromethane | 47 | 1.0 | 50.00 | 0 | 95.0 | 35 | 151 | | | | |
| cis-1,3-Dichloropropene | 36 | 1.0 | 50.00 | 0 | 71.6 | 42 | 130 | | | | |
| Dibromochloromethane | 37 | 1.0 | 50.00 | 0 | 73.6 | 21 | 134 | | | | |
| Ethylbenzene | 40 | 1.0 | 50.00 | 0 | 80.5 | 45 | 146 | | | | |
| Tetrachloroethene | 38 | 1.0 | 50.00 | 0 | 75.6 | 45 | 136 | | | | |
| Toluene | 37 | 1.0 | 50.00 | 0 | 74.7 | 43 | 134 | | | | |
| trans-1,2-Dichloroethene | 33 | 1.0 | 50.00 | 0 | 66.5 | 42 | 135 | | | | |
| trans-1,3-Dichloropropene | 41 | 1.0 | 50.00 | 0 | 82.9 | 37 | 133 | | | | |
| Trichloroethene | 39 | 1.0 | 50.00 | 0 | 77.6 | 43 | 140 | | | | |
| Trichlorofluoromethane | 56 | 1.0 | 50.00 | 0 | 112 | 50 | 148 | | | | |
| Vinyl chloride | 55 | 1.0 | 50.00 | 0 | 110 | 35 | 142 | | | | |
| Surr: 4-Bromofluorobenzene | 51 | | 50.00 | | 103 | 60 | 130 | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 1003155
Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

| | | | | | | | | | | | |
|-----------------------------|-------------------|----------------------|-------------|--------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Sample ID: V624LCS-032310aY | SampType: LCS | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49626 | | | | | | |
| Client ID: LCSW | Batch ID: R49626C | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 687137 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| Surr: Dibromofluoromethane | 48 | | 50.00 | | 95.9 | 63 | 127 | | | | |
| Surr: Toluene-d8 | 51 | | 50.00 | | 102 | 61 | 128 | | | | |

| | | | | | | | | | | | |
|---------------------------|-------------------|----------------------|-------------|--------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Sample ID: VBLK-032310aYW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49626 | | | | | | |
| Client ID: PBW | Batch ID: R49626C | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 687138 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|---------------------------------------|---|-----|--|--|--|--|--|--|--|--|--|
| 1,1,1,2-Tetrachloroethane | U | 1.0 | | | | | | | | | |
| 1,1,1-Trichloroethane | U | 1.0 | | | | | | | | | |
| 1,1,2,2-Tetrachloroethane | U | 1.0 | | | | | | | | | |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 1.0 | | | | | | | | | |
| 1,1,2-Trichloroethane | U | 1.0 | | | | | | | | | |
| 1,1-Dichloroethane | U | 1.0 | | | | | | | | | |
| 1,1-Dichloroethene | U | 1.0 | | | | | | | | | |
| 1,1-Dichloropropene | U | 1.0 | | | | | | | | | |
| 1,2,3-Trichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2,3-Trichloropropane | U | 1.0 | | | | | | | | | |
| 1,2,4-Trichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2,4-Trimethylbenzene | U | 1.0 | | | | | | | | | |
| 1,2-Dibromo-3-chloropropane | U | 1.0 | | | | | | | | | |
| 1,2-Dibromoethane | U | 1.0 | | | | | | | | | |
| 1,2-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2-Dichloroethane | U | 1.0 | | | | | | | | | |
| 1,2-Dichloropropane | U | 1.0 | | | | | | | | | |
| 1,3,5-Trimethylbenzene | U | 1.0 | | | | | | | | | |
| 1,3-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,3-dichloropropane | U | 1.0 | | | | | | | | | |
| 1,4-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 2,2-Dichloropropane | U | 1.0 | | | | | | | | | |
| 2-Butanone | U | 3.0 | | | | | | | | | |
| 2-Chloroethyl vinyl ether | U | 1.0 | | | | | | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analyte
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

CLIENT: Leggette Brashears & Graham Inc.
 Work Order: 1003155
 Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

| Sample ID: VBLK-032310aYW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49626 | | | | | | |
|---------------------------|-------------------|----------------------|-------------|--------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Client ID: PBW | Batch ID: R49626C | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 687138 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|-------------------------|---|-----|--|--|--|--|--|--|--|--|--|
| 2-Chlorotoluene | U | 1.0 | | | | | | | | | |
| 2-Hexanone | U | 2.0 | | | | | | | | | |
| 4-Chlorotoluene | U | 1.0 | | | | | | | | | |
| 4-Isopropyltoluene | U | 1.0 | | | | | | | | | |
| 4-Methyl-2-pentanone | U | 2.0 | | | | | | | | | |
| Acetone | U | 2.0 | | | | | | | | | |
| Benzene | U | 1.0 | | | | | | | | | |
| Bromobenzene | U | 1.0 | | | | | | | | | |
| Bromochloromethane | U | 1.0 | | | | | | | | | |
| Bromodichloromethane | U | 1.0 | | | | | | | | | |
| Bromoform | U | 1.0 | | | | | | | | | |
| Bromomethane | U | 1.0 | | | | | | | | | |
| Carbon disulfide | U | 1.0 | | | | | | | | | |
| Carbon tetrachloride | U | 1.0 | | | | | | | | | |
| Chlorobenzene | U | 1.0 | | | | | | | | | |
| Chloroethane | U | 1.0 | | | | | | | | | |
| Chloroform | U | 1.0 | | | | | | | | | |
| Chloromethane | U | 1.0 | | | | | | | | | |
| cis-1,2-Dichloroethene | U | 1.0 | | | | | | | | | |
| cis-1,3-Dichloropropene | U | 1.0 | | | | | | | | | |
| Dibromochloromethane | U | 1.0 | | | | | | | | | |
| Dibromomethane | U | 1.0 | | | | | | | | | |
| Dichlorodifluoromethane | U | 1.0 | | | | | | | | | |
| Ethylbenzene | U | 1.0 | | | | | | | | | |
| Hexachlorobutadiene | U | 1.0 | | | | | | | | | |
| Isopropylbenzene | U | 1.0 | | | | | | | | | |
| m,p-Xylene | U | 2.0 | | | | | | | | | |
| Methyl tert-butyl ether | U | 1.0 | | | | | | | | | |
| Methylene chloride | U | 1.0 | | | | | | | | | |
| Naphthalene | U | 1.0 | | | | | | | | | |
| n-Butylbenzene | U | 1.0 | | | | | | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analyte
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

CLIENT: Leggette Brashears & Graham Inc.
 Work Order: 1003155
 Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

| Sample ID: VBLK-032310aYW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49626 | | | | | | |
|---------------------------|-------------------|----------------------|-------------|--------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Client ID: PBW | Batch ID: R49626C | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 687138 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|----------------------------|----|-----|-------|--|------|----|-----|--|--|--|--|
| n-Propylbenzene | U | 1.0 | | | | | | | | | |
| o-Xylene | U | 1.0 | | | | | | | | | |
| sec-Butylbenzene | U | 1.0 | | | | | | | | | |
| Styrene | U | 1.0 | | | | | | | | | |
| tert-Butylbenzene | U | 1.0 | | | | | | | | | |
| Tetrachloroethene | U | 1.0 | | | | | | | | | |
| Toluene | U | 1.0 | | | | | | | | | |
| trans-1,2-Dichloroethene | U | 1.0 | | | | | | | | | |
| trans-1,3-Dichloropropene | U | 1.0 | | | | | | | | | |
| Trichloroethene | U | 1.0 | | | | | | | | | |
| Trichlorofluoromethane | U | 1.0 | | | | | | | | | |
| Vinyl acetate | U | 1.0 | | | | | | | | | |
| Vinyl chloride | U | 1.0 | | | | | | | | | |
| Surr: 4-Bromofluorobenzene | 50 | | 50.00 | | 100 | 60 | 130 | | | | |
| Surr: Dibromofluoromethane | 48 | | 50.00 | | 95.5 | 63 | 127 | | | | |
| Surr: Toluene-d8 | 52 | | 50.00 | | 103 | 61 | 128 | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 1003155
Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: FE_D

| | | | | | | | | | | | |
|------------------------|-----------------|----------------|-------------|--------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Sample ID: PBW-031810A | SampType: MBLK | TestCode: FE_D | Units: mg/L | Prep Date: 3/18/2010 | RunNo: 49534 | | | | | | |
| Client ID: PBW | Batch ID: 28439 | TestNo: E200.7 | SW3005A | Analysis Date: 3/19/2010 | SeqNo: 685808 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| Iron | U | 0.0200 | | | | | | | | | |

| | | | | | | | | | | | |
|-------------------------|-----------------|----------------|-------------|--------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Sample ID: LCSW-031810A | SampType: LCS | TestCode: FE_D | Units: mg/L | Prep Date: 3/18/2010 | RunNo: 49534 | | | | | | |
| Client ID: LCSW | Batch ID: 28439 | TestNo: E200.7 | SW3005A | Analysis Date: 3/19/2010 | SeqNo: 685809 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| Iron | 2.00 | 0.0200 | 2.000 | 0 | 100 | 68 | 122 | | | | |

Qualifiers:

| | | | | | |
|----|---|-----|--------------------------------------|-----|--|
| C | Calibration %RSD/%D exceeded for non-CCC analytes | E | Value above quantitation range | H | Holding times for preparation or analy |
| J | Analyte detected below quantitation limits | LOD | Limit of Detection | LOQ | Limit of Quantitation |
| ND | Not Detected at the Reporting Limit | R | RPD outside accepted recovery limits | S | Spike Recovery outside accepted reco |

ANALYTICAL QC SUMMARY REPORT

CLIENT: Leggett Brashears & Graham Inc.
Work Order: 1003155
Project: Rowe

TestCode: FE_T

| | | | | | |
|-------------------------------|------------------------|-----------------------|--------------------|---------------------------------|----------------------|
| Sample ID: PBW-031810B | SampType: MBLK | TestCode: FE_T | Units: mg/L | Prep Date: 3/18/2010 | RunNo: 49534 |
| Client ID: PBW | Batch ID: 28440 | TestNo: E200.7 | SW3010A | Analysis Date: 3/19/2010 | SeqNo: 685734 |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC |
| Iron | U | 0.0200 | | | |
| | | | | LowLimit | HighLimit |
| | | | | RPD Ref Val | RPD Limit |
| | | | | | Qual |

| | | | | | |
|--------------------------------|------------------------|-----------------------|--------------------|---------------------------------|----------------------|
| Sample ID: LCSW-031810B | SampType: LCS | TestCode: FE_T | Units: mg/L | Prep Date: 3/18/2010 | RunNo: 49534 |
| Client ID: LCSW | Batch ID: 28440 | TestNo: E200.7 | SW3010A | Analysis Date: 3/19/2010 | SeqNo: 685735 |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC |
| Iron | 2.08 | 0.0200 | 2.000 | 0 | 104 |
| | | | | LowLimit | HighLimit |
| | | | | RPD Ref Val | RPD Limit |
| | | | | | Qual |

| | | | | | |
|-----------------------------------|------------------------|-----------------------|--------------------|---------------------------------|----------------------|
| Sample ID: 1003155-08B-MS | SampType: MS | TestCode: FE_T | Units: mg/L | Prep Date: 3/18/2010 | RunNo: 49534 |
| Client ID: GWQ31610:1520NP | Batch ID: 28440 | TestNo: E200.7 | SW3010A | Analysis Date: 3/19/2010 | SeqNo: 685764 |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC |
| Iron | 3.64 | 0.0200 | 1.000 | 2.644 | 99.7 |
| | | | | LowLimit | HighLimit |
| | | | | RPD Ref Val | RPD Limit |
| | | | | | Qual |

| | | | | | |
|-----------------------------------|------------------------|-----------------------|--------------------|---------------------------------|----------------------|
| Sample ID: 1003155-08B-MSD | SampType: MSD | TestCode: FE_T | Units: mg/L | Prep Date: 3/18/2010 | RunNo: 49534 |
| Client ID: GWQ31610:1520NP | Batch ID: 28440 | TestNo: E200.7 | SW3010A | Analysis Date: 3/19/2010 | SeqNo: 685765 |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC |
| Iron | 3.63 | 0.0200 | 1.000 | 2.644 | 99.0 |
| | | | | LowLimit | HighLimit |
| | | | | RPD Ref Val | RPD Limit |
| | | | | | Qual |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

APPENDIX II

Friday, March 26, 2010

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555

FAX (203) 926-9140

RE: Rowe

Order No.: 1003154

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 4 sample(s) on 3/17/2010 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The results reported herein relate only to the items tested or to the samples as received by the laboratory. This report may not be reproduced, except in full, without the approval of American Analytical Laboratories, LLC and is not considered complete without a cover page and chain of custody documentation. The limits (LOQ) provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report or the data is qualified. This package has been reviewed by American Analytical Laboratories' QA Department/Laboratory Director to comply with NELAC standards prior to report submittal. This report consists of 27 pages.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe
Lab Order: 1003154

Work Order Sample Summary

| Lab Sample ID | Client Sample ID | Date Collected | Date Received |
|----------------------|-------------------------|-----------------------|----------------------|
| 1003154-01A | WQ31610:1530FRW-1 | 3/16/2010 3:30:00 PM | 3/17/2010 |
| 1003154-02A | WQ31610:1535FRW-2 | 3/16/2010 3:35:00 PM | 3/17/2010 |
| 1003154-03A | WQ31610:1540FRW-3 | 3/16/2010 3:40:00 PM | 3/17/2010 |
| 1003154-04A | WQ31610:1545FRW-4 | 3/16/2010 3:45:00 PM | 3/17/2010 |

American Analytical Laboratories, LLC.

Sample Receipt Checklist

Client Name LBG CT

Date and Time Receive 3/17/2010

Work Order Numbe 1003154

RcptNo: 1

Received by LB

COC_ID:

CoolerID:

Checklist completed b

Signature: You Br Date: 03/17/10

Reviewed by

Initials: CBN Date: 3/18/10

Matrix

Carrier name Lab Courier

- Shipping container/cooler in good condition? Yes [checked] No [] Not Presen []
Custody seals intact on shipping container/cooler? Yes [] No [] Not Presen [checked]
Custody seals intact on sample bottles? Yes [] No [] Not Presen [checked]
Chain of custody present? Yes [checked] No []
Chain of custody signed when relinquished and received? Yes [checked] No []
Chain of custody agrees with sample labels? Yes [checked] No []
Samples in proper container/bottle? Yes [checked] No []
Sample containers intact? Yes [checked] No []
Sufficient sample volume for indicated test? Yes [checked] No []
All samples received within holding time? Yes [checked] No []
Container/Temp Blank temperature in compliance? Yes [checked] No []
Water - VOA vials have zero headspace? No VOA vials submitted [] Yes [checked] No []
Water - pH acceptable upon receipt? Yes [checked] No [] N/A []

Adjusted _____ Checked b _____

Any No and/or NA (not applicable) response must be detailed in the comments section b

Client contacted _____ Date contacted: _____ Person contacted _____

Contacted by: _____ Regarding _____

Comments: cooler with ice. 3.4 degreese C

Corrective Action _____

American Analytical Laboratories, LLC.

Date: 26-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003154
 Project: Rowe
 Lab ID: 1003154-01A

Client Sample ID: WQ31610:1530FRW-1
 Collection Date: 3/16/2010 3:30:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| 1,1,1,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| 1,1,1-Trichloroethane | 4.6 | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| 1,1,2,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| 1,1,2-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| 1,1-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| 1,1-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| 1,1-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| 1,2,3-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| 1,2,3-Trichloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| 1,2,4-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| 1,2,4-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| 1,2-Dibromo-3-chloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| 1,2-Dibromoethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| 1,2-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| 1,2-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| 1,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| 1,3,5-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| 1,3-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| 1,3-dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| 1,4-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| 2,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| 2-Butanone | U | 0.3 | 3.0 | C | µg/L | 1 | 3/23/2010 3:10:00 PM |
| 2-Chloroethyl vinyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| 2-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| 2-Hexanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| 4-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| 4-Isopropyltoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| 4-Methyl-2-pentanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| Acetone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| Benzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| Bromobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| Bromochloromethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 26-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003154
 Project: Rowe
 Lab ID: 1003154-01A

Client Sample ID: WQ31610:1530FRW-1
 Collection Date: 3/16/2010 3:30:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------|-------------|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | | Analyst: LA | |
| Bromodichloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| Bromoform | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| Bromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| Carbon disulfide | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| Carbon tetrachloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| Chlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| Chloroethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| Chloroform | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| Chloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| cis-1,2-Dichloroethene | 8.3 | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| cis-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| Dibromochloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| Dibromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| Dichlorodifluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| Ethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| Hexachlorobutadiene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| Isopropylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| m,p-Xylene | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| Methyl tert-butyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| Methylene chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| Naphthalene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| n-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| n-Propylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| o-Xylene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| sec-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| Styrene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| tert-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| Tetrachloroethene | 160 | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| Toluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| trans-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| trans-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| Trichloroethene | 1.2 | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| Trichlorofluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735

Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 26-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003154
 Project: Rowe
 Lab ID: 1003154-01A

Client Sample ID: WQ31610:1530FRW-1
 Collection Date: 3/16/2010 3:30:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------|-------------|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | | Analyst: LA | |
| Vinyl acetate | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| Vinyl chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:10:00 PM |
| Surr: 4-Bromofluorobenzene | 105 | 0 | 60-130 | | %REC | 1 | 3/23/2010 3:10:00 PM |
| Surr: Dibromofluoromethane | 92.7 | 0 | 63-127 | | %REC | 1 | 3/23/2010 3:10:00 PM |
| Surr: Toluene-d8 | 99.4 | 0 | 61-128 | | %REC | 1 | 3/23/2010 3:10:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 26-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003154
 Project: Rowe
 Lab ID: 1003154-02A

Client Sample ID: WQ31610:1535FRW-2
 Collection Date: 3/16/2010 3:35:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------|-------------|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | | Analyst: LA | |
| 1,1,1,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| 1,1,1-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| 1,1,2,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| 1,1,2-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| 1,1-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| 1,1-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| 1,1-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| 1,2,3-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| 1,2,3-Trichloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| 1,2,4-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| 1,2,4-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| 1,2-Dibromo-3-chloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| 1,2-Dibromoethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| 1,2-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| 1,2-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| 1,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| 1,3,5-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| 1,3-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| 1,3-dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| 1,4-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| 2,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| 2-Butanone | U | 0.3 | 3.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| 2-Chloroethyl vinyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| 2-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| 2-Hexanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| 4-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| 4-Isopropyltoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| 4-Methyl-2-pentanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| Acetone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| Benzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| Bromobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| Bromochloromethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735

Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 26-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003154
 Project: Rowe
 Lab ID: 1003154-02A

Client Sample ID: WQ31610:1535FRW-2
 Collection Date: 3/16/2010 3:35:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Bromodichloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| Bromoform | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| Bromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| Carbon disulfide | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| Carbon tetrachloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| Chlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| Chloroethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| Chloroform | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| Chloromethane | U | 0.3 | 1.0 | C | µg/L | 1 | 3/23/2010 3:36:00 PM |
| cis-1,2-Dichloroethene | 14 | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| cis-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| Dibromochloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| Dibromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| Dichlorodifluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| Ethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| Hexachlorobutadiene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| Isopropylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| m,p-Xylene | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| Methyl tert-butyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| Methylene chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| Naphthalene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| n-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| n-Propylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| o-Xylene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| sec-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| Styrene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| tert-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| Tetrachloroethene | 33 | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| Toluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| trans-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| trans-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| Trichloroethene | 1.7 | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| Trichlorofluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 26-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003154
 Project: Rowe
 Lab ID: 1003154-02A

Client Sample ID: WQ31610:1535FRW-2
 Collection Date: 3/16/2010 3:35:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Vinyl acetate | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| Vinyl chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 3:36:00 PM |
| Surr: 4-Bromofluorobenzene | 101 | 0 | 60-130 | | %REC | 1 | 3/23/2010 3:36:00 PM |
| Surr: Dibromofluoromethane | 93.6 | 0 | 63-127 | | %REC | 1 | 3/23/2010 3:36:00 PM |
| Surr: Toluene-d8 | 102 | 0 | 61-128 | | %REC | 1 | 3/23/2010 3:36:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003154
 Project: Rowe
 Lab ID: 1003154-03A

Client Sample ID: WQ31610:1540FRW-3
 Collection Date: 3/16/2010 3:40:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| 1,1,1,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| 1,1,1-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| 1,1,2,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| 1,1,2-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| 1,1-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| 1,1-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| 1,1-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| 1,2,3-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| 1,2,3-Trichloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| 1,2,4-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| 1,2,4-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| 1,2-Dibromo-3-chloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| 1,2-Dibromoethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| 1,2-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| 1,2-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| 1,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| 1,3,5-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| 1,3-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| 1,3-dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| 1,4-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| 2,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| 2-Butanone | U | 0.3 | 3.0 | C | µg/L | 1 | 3/23/2010 4:02:00 PM |
| 2-Chloroethyl vinyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| 2-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| 2-Hexanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| 4-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| 4-Isopropyltoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| 4-Methyl-2-pentanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| Acetone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| Benzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| Bromobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| Bromochloromethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003154
 Project: Rowe
 Lab ID: 1003154-03A

Client Sample ID: WQ31610:1540FRW-3
 Collection Date: 3/16/2010 3:40:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Bromodichloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| Bromoform | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| Bromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| Carbon disulfide | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| Carbon tetrachloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| Chlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| Chloroethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| Chloroform | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| Chloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| cis-1,2-Dichloroethene | 19 | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| cis-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| Dibromochloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| Dibromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| Dichlorodifluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| Ethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| Hexachlorobutadiene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| Isopropylbenzene | 1.5 | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| m,p-Xylene | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| Methyl tert-butyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| Methylene chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| Naphthalene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| n-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| n-Propylbenzene | 0.83 | 0.3 | 1.0 | J | µg/L | 1 | 3/23/2010 4:02:00 PM |
| o-Xylene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| sec-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| Styrene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| tert-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| Tetrachloroethene | 190 | 3 | 10 | | µg/L | 10 | 3/24/2010 5:12:00 PM |
| Toluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| trans-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| trans-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| Trichloroethene | 3.2 | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| Trichlorofluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 26-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003154
 Project: Rowe
 Lab ID: 1003154-03A

Client Sample ID: WQ31610:1540FRW-3
 Collection Date: 3/16/2010 3:40:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------|-------------|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | | Analyst: LA | |
| Vinyl acetate | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| Vinyl chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:02:00 PM |
| Surr: 4-Bromofluorobenzene | 99.5 | 0 | 60-130 | | %REC | 10 | 3/24/2010 5:12:00 PM |
| Surr: 4-Bromofluorobenzene | 103 | 0 | 60-130 | | %REC | 1 | 3/23/2010 4:02:00 PM |
| Surr: Dibromofluoromethane | 93.4 | 0 | 63-127 | | %REC | 1 | 3/23/2010 4:02:00 PM |
| Surr: Dibromofluoromethane | 101 | 0 | 63-127 | | %REC | 10 | 3/24/2010 5:12:00 PM |
| Surr: Toluene-d8 | 104 | 0 | 61-128 | | %REC | 1 | 3/23/2010 4:02:00 PM |
| Surr: Toluene-d8 | 103 | 0 | 61-128 | | %REC | 10 | 3/24/2010 5:12:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735
 Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| LOD | Limit of Detection | LOQ Limit of Quantitation |
| ND | Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| U | Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 26-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003154
 Project: Rowe
 Lab ID: 1003154-04A

Client Sample ID: WQ31610:1545FRW-4
 Collection Date: 3/16/2010 3:45:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------|--------------------|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | | Analyst: LA | |
| 1,1,1,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| 1,1,1-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| 1,1,2,2-Tetrachloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| 1,1,2-Trichloro-1,2,2-trifluoroethan | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| 1,1,2-Trichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| 1,1-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| 1,1-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| 1,1-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| 1,2,3-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| 1,2,3-Trichloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| 1,2,4-Trichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| 1,2,4-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| 1,2-Dibromo-3-chloropropane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| 1,2-Dibromoethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| 1,2-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| 1,2-Dichloroethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| 1,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| 1,3,5-Trimethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| 1,3-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| 1,3-dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| 1,4-Dichlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| 2,2-Dichloropropane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| 2-Butanone | U | 0.3 | 3.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| 2-Chloroethyl vinyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| 2-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| 2-Hexanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| 4-Chlorotoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| 4-Isopropyltoluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| 4-Methyl-2-pentanone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| Acetone | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| Benzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| Bromobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| Bromochloromethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735

Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 26-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003154
 Project: Rowe
 Lab ID: 1003154-04A

Client Sample ID: WQ31610:1545FRW-4
 Collection Date: 3/16/2010 3:45:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------------|----|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | Analyst: LA | | |
| Bromodichloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| Bromoform | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| Bromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| Carbon disulfide | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| Carbon tetrachloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| Chlorobenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| Chloroethane | U | 0.4 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| Chloroform | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| Chloromethane | U | 0.3 | 1.0 | C | µg/L | 1 | 3/23/2010 4:30:00 PM |
| cis-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| cis-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| Dibromochloromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| Dibromomethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| Dichlorodifluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| Ethylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| Hexachlorobutadiene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| Isopropylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| m,p-Xylene | U | 0.3 | 2.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| Methyl tert-butyl ether | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| Methylene chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| Naphthalene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| n-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| n-Propylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| o-Xylene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| sec-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| Styrene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| tert-Butylbenzene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| Tetrachloroethene | 5.3 | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| Toluene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| trans-1,2-Dichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| trans-1,3-Dichloropropene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| Trichloroethene | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| Trichlorofluoromethane | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735

Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

American Analytical Laboratories, LLC.

Date: 26-Mar-10

ELAP ID : 11418

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 1003154
 Project: Rowe
 Lab ID: 1003154-04A

Client Sample ID: WQ31610:1545FRW-4
 Collection Date: 3/16/2010 3:45:00 PM
 Matrix: LIQUID

Certificate of Results

| Analyses | Sample Result | LOD | LOQ | Qual | Units | DF | Date/Time Analyzed |
|---|---------------|-----|----------------|------|-------|-------------|----------------------|
| VOLATILE SW-846 8260 + MTBE & FREON113 | | | SW8260B | | | Analyst: LA | |
| Vinyl acetate | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| Vinyl chloride | U | 0.3 | 1.0 | | µg/L | 1 | 3/23/2010 4:30:00 PM |
| Surr: 4-Bromofluorobenzene | 103 | 0 | 60-130 | | %REC | 1 | 3/23/2010 4:30:00 PM |
| Surr: Dibromofluoromethane | 96.2 | 0 | 63-127 | | %REC | 1 | 3/23/2010 4:30:00 PM |
| Surr: Toluene-d8 | 104 | 0 | 61-128 | | %REC | 1 | 3/23/2010 4:30:00 PM |

American Analytical Laboratories, LLC., 56 Toledo Street, Farmingdale, NY, Zip - 11735

Tel - 6314546100 Fax - 6314548027 www.American-Analytical.com



| | | |
|--------------------|---|---|
| Qualifiers: | * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| | C Calibration %RSD/%D exceeded for non-CCC analytes | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | J Analyte detected below quantitation limits |
| | LOD Limit of Detection | LOQ Limit of Quantitation |
| | ND Not Detected at the Reporting Limit | S Spike Recovery outside accepted recovery limits |
| | U Indicates the compound was analyzed but not detected. | |

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 1003154
Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

| | | | | | |
|-----------------------------|------------------|----------------------|-------------|--------------------------|---------------|
| Sample ID: V624LCS-032310YW | SampType: LCS | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49625 |
| Client ID: LCSW | Batch ID: R49625 | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 687115 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---------------------------|--------|-----|-----------|-------------|------|----------|-----------|-------------|------|----------|------|
| 1,1,1-Trichloroethane | 39 | 1.0 | 50.00 | 0 | 77.5 | 43 | 148 | | | | |
| 1,1,2,2-Tetrachloroethane | 38 | 1.0 | 50.00 | 0 | 76.7 | 32 | 148 | | | | |
| 1,1,2-Trichloroethane | 37 | 1.0 | 50.00 | 0 | 73.2 | 42 | 136 | | | | |
| 1,1-Dichloroethane | 35 | 1.0 | 50.00 | 0 | 70.6 | 40 | 150 | | | | |
| 1,1-Dichloroethene | 39 | 1.0 | 50.00 | 0 | 78.0 | 30 | 154 | | | | |
| 1,2-Dichlorobenzene | 41 | 1.0 | 50.00 | 0 | 81.1 | 40 | 129 | | | | |
| 1,2-Dichloroethane | 39 | 1.0 | 50.00 | 0 | 78.8 | 36 | 141 | | | | |
| 1,2-Dichloropropane | 41 | 1.0 | 50.00 | 0 | 81.6 | 44 | 138 | | | | |
| 1,3-Dichlorobenzene | 41 | 1.0 | 50.00 | 0 | 82.7 | 40 | 133 | | | | |
| 1,4-Dichlorobenzene | 41 | 1.0 | 50.00 | 0 | 81.5 | 40 | 135 | | | | |
| 2-Chloroethyl vinyl ether | 33 | 1.0 | 50.00 | 0 | 65.4 | 21 | 139 | | | | |
| Benzene | 39 | 1.0 | 50.00 | 0 | 77.7 | 45 | 144 | | | | |
| Bromodichloromethane | 37 | 1.0 | 50.00 | 0 | 74.5 | 35 | 136 | | | | |
| Bromoform | 37 | 1.0 | 50.00 | 0 | 74.1 | 28 | 138 | | | | |
| Bromomethane | 32 | 1.0 | 50.00 | 0 | 63.1 | 26 | 148 | | | | |
| Carbon tetrachloride | 39 | 1.0 | 50.00 | 0 | 78.4 | 45 | 141 | | | | |
| Chlorobenzene | 41 | 1.0 | 50.00 | 0 | 81.9 | 41 | 142 | | | | |
| Chloroethane | 47 | 1.0 | 50.00 | 0 | 93.2 | 36 | 143 | | | | |
| Chloroform | 39 | 1.0 | 50.00 | 0 | 77.8 | 42 | 137 | | | | |
| Chloromethane | 40 | 1.0 | 50.00 | 0 | 79.2 | 35 | 151 | | | | |
| cis-1,3-Dichloropropene | 41 | 1.0 | 50.00 | 0 | 82.7 | 42 | 130 | | | | C |
| Dibromochloromethane | 37 | 1.0 | 50.00 | 0 | 73.9 | 21 | 134 | | | | |
| Ethylbenzene | 42 | 1.0 | 50.00 | 0 | 83.8 | 45 | 146 | | | | |
| Tetrachloroethene | 41 | 1.0 | 50.00 | 0 | 81.8 | 45 | 136 | | | | |
| Toluene | 38 | 1.0 | 50.00 | 0 | 77.0 | 43 | 134 | | | | |
| trans-1,2-Dichloroethene | 36 | 1.0 | 50.00 | 0 | 71.9 | 42 | 135 | | | | |
| trans-1,3-Dichloropropene | 38 | 1.0 | 50.00 | 0 | 76.6 | 37 | 133 | | | | |
| Trichloroethene | 41 | 1.0 | 50.00 | 0 | 81.2 | 43 | 140 | | | | |
| Trichlorofluoromethane | 52 | 1.0 | 50.00 | 0 | 104 | 50 | 148 | | | | |
| Vinyl chloride | 51 | 1.0 | 50.00 | 0 | 103 | 35 | 142 | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analyte
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

CLIENT: Leggett Brashears & Graham Inc.
 Work Order: 1003154
 Project: Rowe

| | | | | | | | | | | | |
|-----------------------------|------------------|----------------------|-------------|--------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Sample ID: V624LCS-032310YW | SampType: LCS | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49625 | | | | | | |
| Client ID: LCSW | Batch ID: R49625 | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 687115 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| Surr: 4-Bromofluorobenzene | 51 | | 50.00 | | 102 | 60 | 130 | | | | |
| Surr: Dibromofluoromethane | 48 | | 50.00 | | 96.4 | 63 | 127 | | | | |
| Surr: Toluene-d8 | 51 | | 50.00 | | 101 | 61 | 128 | | | | |

| | | | | | | | | | | | |
|--------------------------|------------------|----------------------|-------------|--------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Sample ID: VBLK-032310YW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49625 | | | | | | |
| Client ID: PBW | Batch ID: R49625 | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 687116 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|---------------------------------------|---|-----|--|--|--|--|--|--|--|--|--|
| 1,1,1,2-Tetrachloroethane | U | 1.0 | | | | | | | | | |
| 1,1,1-Trichloroethane | U | 1.0 | | | | | | | | | |
| 1,1,2,2-Tetrachloroethane | U | 1.0 | | | | | | | | | |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 1.0 | | | | | | | | | |
| 1,1,2-Trichloroethane | U | 1.0 | | | | | | | | | |
| 1,1-Dichloroethane | U | 1.0 | | | | | | | | | |
| 1,1-Dichloroethene | U | 1.0 | | | | | | | | | |
| 1,1-Dichloropropene | U | 1.0 | | | | | | | | | |
| 1,2,3-Trichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2,3-Trichloropropane | U | 1.0 | | | | | | | | | |
| 1,2,4-Trichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2,4-Trimethylbenzene | U | 1.0 | | | | | | | | | |
| 1,2-Dibromo-3-chloropropane | U | 1.0 | | | | | | | | | |
| 1,2-Dibromoethane | U | 1.0 | | | | | | | | | |
| 1,2-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2-Dichloroethane | U | 1.0 | | | | | | | | | |
| 1,2-Dichloropropane | U | 1.0 | | | | | | | | | |
| 1,3,5-Trimethylbenzene | U | 1.0 | | | | | | | | | |
| 1,3-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,3-dichloropropane | U | 1.0 | | | | | | | | | |
| 1,4-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 2,2-Dichloropropane | U | 1.0 | | | | | | | | | |
| 2-Butanone | U | 3.0 | | | | | | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analysis
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

CLIENT: Leggette Brashears & Graham Inc.
 Work Order: 1003154
 Project: Rowe

| Sample ID: VBLK-032310YW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49625 | | | | | | |
|--------------------------|------------------|----------------------|-------------|--------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Client ID: PBW | Batch ID: R49625 | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 687116 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|---------------------------|---|-----|--|--|--|--|--|--|--|--|--|
| 2-Chloroethyl vinyl ether | U | 1.0 | | | | | | | | | |
| 2-Chlorotoluene | U | 1.0 | | | | | | | | | |
| 2-Hexanone | U | 2.0 | | | | | | | | | |
| 4-Chlorotoluene | U | 1.0 | | | | | | | | | |
| 4-Isopropyltoluene | U | 1.0 | | | | | | | | | |
| 4-Methyl-2-pentanone | U | 2.0 | | | | | | | | | |
| Acetone | U | 2.0 | | | | | | | | | |
| Benzene | U | 1.0 | | | | | | | | | |
| Bromobenzene | U | 1.0 | | | | | | | | | |
| Bromochloromethane | U | 1.0 | | | | | | | | | |
| Bromodichloromethane | U | 1.0 | | | | | | | | | |
| Bromoform | U | 1.0 | | | | | | | | | |
| Bromomethane | U | 1.0 | | | | | | | | | |
| Carbon disulfide | U | 1.0 | | | | | | | | | |
| Carbon tetrachloride | U | 1.0 | | | | | | | | | |
| Chlorobenzene | U | 1.0 | | | | | | | | | |
| Chloroethane | U | 1.0 | | | | | | | | | |
| Chloroform | U | 1.0 | | | | | | | | | |
| Chloromethane | U | 1.0 | | | | | | | | | |
| cis-1,2-Dichloroethene | U | 1.0 | | | | | | | | | |
| cis-1,3-Dichloropropene | U | 1.0 | | | | | | | | | |
| Dibromochloromethane | U | 1.0 | | | | | | | | | |
| Dibromomethane | U | 1.0 | | | | | | | | | |
| Dichlorodifluoromethane | U | 1.0 | | | | | | | | | |
| Ethylbenzene | U | 1.0 | | | | | | | | | |
| Hexachlorobutadiene | U | 1.0 | | | | | | | | | |
| Isopropylbenzene | U | 1.0 | | | | | | | | | |
| m,p-Xylene | U | 2.0 | | | | | | | | | |
| Methyl tert-butyl ether | U | 1.0 | | | | | | | | | |
| Methylene chloride | U | 1.0 | | | | | | | | | |
| Naphthalene | U | 1.0 | | | | | | | | | |

C

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analysis
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

CLIENT: Leggett Brashears & Graham Inc.
Work Order: 1003154
Project: Rowe

TestCode: 8260MTBE113_W

| Sample ID: VBLK-032310YW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49625 | | | | | | |
|---------------------------------|-------------------------|-----------------------------|--------------------|---------------------------------|----------------------|----------|-----------|-------------|------|----------|------|
| Client ID: PBW | Batch ID: R49625 | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 687116 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|----------------------------|----|-----|-------|--|------|----|-----|--|--|--|--|
| n-Butylbenzene | U | 1.0 | | | | | | | | | |
| n-Propylbenzene | U | 1.0 | | | | | | | | | |
| o-Xylene | U | 1.0 | | | | | | | | | |
| sec-Butylbenzene | U | 1.0 | | | | | | | | | |
| Styrene | U | 1.0 | | | | | | | | | |
| tert-Butylbenzene | U | 1.0 | | | | | | | | | |
| Tetrachloroethene | U | 1.0 | | | | | | | | | |
| Toluene | U | 1.0 | | | | | | | | | |
| trans-1,2-Dichloroethene | U | 1.0 | | | | | | | | | |
| trans-1,3-Dichloropropene | U | 1.0 | | | | | | | | | |
| Trichloroethene | U | 1.0 | | | | | | | | | |
| Trichlorofluoromethane | U | 1.0 | | | | | | | | | |
| Vinyl acetate | U | 1.0 | | | | | | | | | |
| Vinyl chloride | U | 1.0 | | | | | | | | | |
| Surr: 4-Bromofluorobenzene | 51 | | 50.00 | | 102 | 60 | 130 | | | | |
| Surr: Dibromofluoromethane | 49 | | 50.00 | | 98.1 | 63 | 127 | | | | |
| Surr: Toluene-d8 | 50 | | 50.00 | | 100 | 61 | 128 | | | | |

| Sample ID: V624LCS-032310YW | SampType: LCS | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49625 | | | | | | |
|------------------------------------|--------------------------|-----------------------------|--------------------|---------------------------------|----------------------|----------|-----------|-------------|------|----------|------|
| Client ID: LCSW | Batch ID: R49625A | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 687120 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|---------------------------|----|-----|-------|---|------|----|-----|--|--|--|--|
| 1,1,1-Trichloroethane | 36 | 1.0 | 50.00 | 0 | 72.8 | 43 | 148 | | | | |
| 1,1,2,2-Tetrachloroethane | 35 | 1.0 | 50.00 | 0 | 70.1 | 32 | 148 | | | | |
| 1,1,2-Trichloroethane | 35 | 1.0 | 50.00 | 0 | 70.7 | 42 | 136 | | | | |
| 1,1-Dichloroethane | 33 | 1.0 | 50.00 | 0 | 66.0 | 40 | 150 | | | | |
| 1,1-Dichloroethene | 36 | 1.0 | 50.00 | 0 | 72.0 | 30 | 154 | | | | |
| 1,2-Dichlorobenzene | 38 | 1.0 | 50.00 | 0 | 76.8 | 40 | 129 | | | | |
| 1,2-Dichloroethane | 36 | 1.0 | 50.00 | 0 | 71.3 | 36 | 141 | | | | |
| 1,2-Dichloropropane | 35 | 1.0 | 50.00 | 0 | 70.2 | 44 | 138 | | | | |
| 1,3-Dichlorobenzene | 38 | 1.0 | 50.00 | 0 | 75.9 | 40 | 133 | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 1003154
Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

| Sample ID: V624LCS-032310YW | SampType: LCS | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49625 | | | | | | |
|-----------------------------|-------------------|----------------------|-------------|--------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Client ID: LCSW | Batch ID: R49625A | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 687120 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| 1,4-Dichlorobenzene | 38 | 1.0 | 50.00 | 0 | 75.7 | 40 | 135 | | | | |
| 2-Chloroethyl vinyl ether | 33 | 1.0 | 50.00 | 0 | 66.3 | 21 | 139 | | | | |
| Benzene | 32 | 1.0 | 50.00 | 0 | 64.8 | 45 | 144 | | | | |
| Bromodichloromethane | 38 | 1.0 | 50.00 | 0 | 76.2 | 35 | 136 | | | | |
| Bromoform | 36 | 1.0 | 50.00 | 0 | 72.0 | 28 | 138 | | | | |
| Bromomethane | 45 | 1.0 | 50.00 | 0 | 89.6 | 26 | 148 | | | | |
| Carbon tetrachloride | 37 | 1.0 | 50.00 | 0 | 74.9 | 45 | 141 | | | | |
| Chlorobenzene | 38 | 1.0 | 50.00 | 0 | 75.4 | 41 | 142 | | | | |
| Chloroethane | 41 | 1.0 | 50.00 | 0 | 82.3 | 36 | 143 | | | | |
| Chloroform | 32 | 1.0 | 50.00 | 0 | 64.6 | 42 | 137 | | | | |
| Chloromethane | 43 | 1.0 | 50.00 | 0 | 85.2 | 35 | 151 | | | | |
| cis-1,3-Dichloropropene | 36 | 1.0 | 50.00 | 0 | 71.3 | 42 | 130 | | | | |
| Dibromochloromethane | 35 | 1.0 | 50.00 | 0 | 69.7 | 21 | 134 | | | | |
| Ethylbenzene | 40 | 1.0 | 50.00 | 0 | 79.2 | 45 | 146 | | | | |
| Tetrachloroethene | 37 | 1.0 | 50.00 | 0 | 74.6 | 45 | 136 | | | | |
| Toluene | 37 | 1.0 | 50.00 | 0 | 73.3 | 43 | 134 | | | | |
| trans-1,2-Dichloroethene | 33 | 1.0 | 50.00 | 0 | 65.8 | 42 | 135 | | | | |
| trans-1,3-Dichloropropene | 40 | 1.0 | 50.00 | 0 | 80.7 | 37 | 133 | | | | |
| Trichloroethene | 38 | 1.0 | 50.00 | 0 | 76.3 | 43 | 140 | | | | |
| Trichlorofluoromethane | 50 | 1.0 | 50.00 | 0 | 100 | 50 | 148 | | | | |
| Vinyl chloride | 49 | 1.0 | 50.00 | 0 | 97.8 | 35 | 142 | | | | |
| Surr: 4-Bromofluorobenzene | 52 | | 50.00 | | 103 | 60 | 130 | | | | |
| Surr: Dibromofluoromethane | 47 | | 50.00 | | 94.8 | 63 | 127 | | | | |
| Surr: Toluene-d8 | 52 | | 50.00 | | 103 | 61 | 128 | | | | |

| Sample ID: VBLK-032310YW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49625 | | | | | | |
|---------------------------|-------------------|----------------------|-------------|--------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Client ID: PBW | Batch ID: R49625A | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 687121 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| 1,1,1,2-Tetrachloroethane | U | 1.0 | | | | | | | | | |
| 1,1,1,1-Trichloroethane | U | 1.0 | | | | | | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analysis
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 1003154
Project: Rowe

TestCode: 8260MTBE113_W

| | | | | | | | | | | | |
|---------------------------------|--------------------------|-----------------------------|--------------------|---------------------------------|----------------------|----------|-----------|-------------|------|----------|------|
| Sample ID: VBLK-032310YW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49625 | | | | | | |
| Client ID: PBW | Batch ID: R49625A | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 687121 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|---------------------------------------|---|-----|--|--|--|--|--|--|--|--|---|
| 1,1,2,2-Tetrachloroethane | U | 1.0 | | | | | | | | | |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 1.0 | | | | | | | | | |
| 1,1,2-Trichloroethane | U | 1.0 | | | | | | | | | |
| 1,1-Dichloroethane | U | 1.0 | | | | | | | | | |
| 1,1-Dichloroethene | U | 1.0 | | | | | | | | | |
| 1,1-Dichloropropene | U | 1.0 | | | | | | | | | |
| 1,2,3-Trichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2,3-Trichloropropane | U | 1.0 | | | | | | | | | |
| 1,2,4-Trichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2,4-Trimethylbenzene | U | 1.0 | | | | | | | | | |
| 1,2-Dibromo-3-chloropropane | U | 1.0 | | | | | | | | | |
| 1,2-Dibromoethane | U | 1.0 | | | | | | | | | |
| 1,2-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2-Dichloroethane | U | 1.0 | | | | | | | | | |
| 1,2-Dichloropropane | U | 1.0 | | | | | | | | | |
| 1,3,5-Trimethylbenzene | U | 1.0 | | | | | | | | | |
| 1,3-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,3-dichloropropane | U | 1.0 | | | | | | | | | |
| 1,4-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 2,2-Dichloropropane | U | 1.0 | | | | | | | | | |
| 2-Butanone | U | 3.0 | | | | | | | | | |
| 2-Chloroethyl vinyl ether | U | 1.0 | | | | | | | | | C |
| 2-Chlorotoluene | U | 1.0 | | | | | | | | | |
| 2-Hexanone | U | 2.0 | | | | | | | | | |
| 4-Chlorotoluene | U | 1.0 | | | | | | | | | |
| 4-Isopropyltoluene | U | 1.0 | | | | | | | | | |
| 4-Methyl-2-pentanone | U | 2.0 | | | | | | | | | |
| Acetone | U | 2.0 | | | | | | | | | |
| Benzene | U | 1.0 | | | | | | | | | |
| Bromobenzene | U | 1.0 | | | | | | | | | |
| Bromochloromethane | U | 1.0 | | | | | | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analyte
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 1003154
Project: Rowe

TestCode: 8260MTBE113_W

| | | | | | | | | | | | |
|--------------------------|-------------------|----------------------|-------------|--------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Sample ID: VBLK-032310YW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49625 | | | | | | |
| Client ID: PBW | Batch ID: R49625A | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 687121 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|---------------------------|---|-----|--|--|--|--|--|--|--|--|--|
| Bromodichloromethane | U | 1.0 | | | | | | | | | |
| Bromoform | U | 1.0 | | | | | | | | | |
| Bromomethane | U | 1.0 | | | | | | | | | |
| Carbon disulfide | U | 1.0 | | | | | | | | | |
| Carbon tetrachloride | U | 1.0 | | | | | | | | | |
| Chlorobenzene | U | 1.0 | | | | | | | | | |
| Chloroethane | U | 1.0 | | | | | | | | | |
| Chloroform | U | 1.0 | | | | | | | | | |
| Chloromethane | U | 1.0 | | | | | | | | | |
| cis-1,2-Dichloroethene | U | 1.0 | | | | | | | | | |
| cis-1,3-Dichloropropene | U | 1.0 | | | | | | | | | |
| Dibromochloromethane | U | 1.0 | | | | | | | | | |
| Dibromomethane | U | 1.0 | | | | | | | | | |
| Dichlorodifluoromethane | U | 1.0 | | | | | | | | | |
| Ethylbenzene | U | 1.0 | | | | | | | | | |
| Hexachlorobutadiene | U | 1.0 | | | | | | | | | |
| Isopropylbenzene | U | 1.0 | | | | | | | | | |
| m,p-Xylene | U | 2.0 | | | | | | | | | |
| Methyl tert-butyl ether | U | 1.0 | | | | | | | | | |
| Methylene chloride | U | 1.0 | | | | | | | | | |
| Naphthalene | U | 1.0 | | | | | | | | | |
| n-Butylbenzene | U | 1.0 | | | | | | | | | |
| n-Propylbenzene | U | 1.0 | | | | | | | | | |
| o-Xylene | U | 1.0 | | | | | | | | | |
| sec-Butylbenzene | U | 1.0 | | | | | | | | | |
| Styrene | U | 1.0 | | | | | | | | | |
| tert-Butylbenzene | U | 1.0 | | | | | | | | | |
| Tetrachloroethene | U | 1.0 | | | | | | | | | |
| Toluene | U | 1.0 | | | | | | | | | |
| trans-1,2-Dichloroethene | U | 1.0 | | | | | | | | | |
| trans-1,3-Dichloropropene | U | 1.0 | | | | | | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

CLIENT: Leggette Brashears & Graham Inc.
 Work Order: 1003154
 Project: Rowe

| | | | | | |
|--------------------------|-------------------|----------------------|-------------|--------------------------|---------------|
| Sample ID: VBLK-032310YW | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49625 |
| Client ID: PBW | Batch ID: R49625A | TestNo: SW8260B | | Analysis Date: 3/23/2010 | SeqNo: 687121 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|----------------------------|--------|-----|-----------|-------------|------|----------|-----------|-------------|------|----------|------|
| Trichloroethene | U | 1.0 | | | | | | | | | |
| Trichlorofluoromethane | U | 1.0 | | | | | | | | | |
| Vinyl acetate | U | 1.0 | | | | | | | | | |
| Vinyl chloride | U | 1.0 | | | | | | | | | |
| Surr: 4-Bromofluorobenzene | 51 | | 50.00 | | 102 | 60 | 130 | | | | |
| Surr: Dibromofluoromethane | 47 | | 50.00 | | 93.5 | 63 | 127 | | | | |
| Surr: Toluene-d8 | 51 | | 50.00 | | 101 | 61 | 128 | | | | |

| | | | | | |
|----------------------------|-------------------|----------------------|-------------|--------------------------|---------------|
| Sample ID: V624LCS-032410W | SampType: LCS | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49625 |
| Client ID: LCSW | Batch ID: R49625B | TestNo: SW8260B | | Analysis Date: 3/24/2010 | SeqNo: 687272 |

| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
|---------------------------|--------|-----|-----------|-------------|------|----------|-----------|-------------|------|----------|------|
| 1,1,1-Trichloroethane | 40 | 1.0 | 50.00 | 0 | 80.5 | 43 | 148 | | | | |
| 1,1,2,2-Tetrachloroethane | 35 | 1.0 | 50.00 | 0 | 70.5 | 32 | 148 | | | | |
| 1,1,2-Trichloroethane | 37 | 1.0 | 50.00 | 0 | 73.8 | 42 | 136 | | | | |
| 1,1-Dichloroethane | 35 | 1.0 | 50.00 | 0 | 70.5 | 40 | 150 | | | | |
| 1,1-Dichloroethene | 43 | 1.0 | 50.00 | 0 | 86.1 | 30 | 154 | | | | |
| 1,2-Dichlorobenzene | 38 | 1.0 | 50.00 | 0 | 76.1 | 40 | 129 | | | | |
| 1,2-Dichloroethane | 41 | 1.0 | 50.00 | 0 | 81.2 | 36 | 141 | | | | |
| 1,2-Dichloropropane | 37 | 1.0 | 50.00 | 0 | 74.3 | 44 | 138 | | | | |
| 1,3-Dichlorobenzene | 38 | 1.0 | 50.00 | 0 | 75.3 | 40 | 133 | | | | |
| 1,4-Dichlorobenzene | 38 | 1.0 | 50.00 | 0 | 76.8 | 40 | 135 | | | | |
| 2-Chloroethyl vinyl ether | 37 | 1.0 | 50.00 | 0 | 74.5 | 21 | 139 | | | | |
| Benzene | 34 | 1.0 | 50.00 | 0 | 68.0 | 45 | 144 | | | | |
| Bromodichloromethane | 41 | 1.0 | 50.00 | 0 | 82.0 | 35 | 136 | | | | |
| Bromoform | 37 | 1.0 | 50.00 | 0 | 73.5 | 28 | 138 | | | | |
| Bromomethane | 55 | 1.0 | 50.00 | 0 | 110 | 26 | 148 | | | | |
| Carbon tetrachloride | 42 | 1.0 | 50.00 | 0 | 83.2 | 45 | 141 | | | | |
| Chlorobenzene | 39 | 1.0 | 50.00 | 0 | 78.1 | 41 | 142 | | | | |
| Chloroethane | 54 | 1.0 | 50.00 | 0 | 107 | 36 | 143 | | | | |
| Chloroform | 34 | 1.0 | 50.00 | 0 | 68.7 | 42 | 137 | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analyte
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

CLIENT: Leggette Brashears & Graham Inc.
 Work Order: 1003154
 Project: Rowe

| Sample ID: V624LCS-032410W | SampType: LCS | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49625 | | | | | | |
|----------------------------|-------------------|----------------------|-------------|--------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Client ID: LCSW | Batch ID: R49625B | TestNo: SW8260B | | Analysis Date: 3/24/2010 | SeqNo: 687272 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| Chloromethane | 52 | 1.0 | 50.00 | 0 | 103 | 35 | 151 | | | | |
| cis-1,3-Dichloropropene | 37 | 1.0 | 50.00 | 0 | 74.4 | 42 | 130 | | | | |
| Dibromochloromethane | 37 | 1.0 | 50.00 | 0 | 73.9 | 21 | 134 | | | | |
| Ethylbenzene | 40 | 1.0 | 50.00 | 0 | 80.3 | 45 | 146 | | | | |
| Tetrachloroethene | 38 | 1.0 | 50.00 | 0 | 76.3 | 45 | 136 | | | | |
| Toluene | 39 | 1.0 | 50.00 | 0 | 77.7 | 43 | 134 | | | | |
| trans-1,2-Dichloroethene | 36 | 1.0 | 50.00 | 0 | 71.9 | 42 | 135 | | | | |
| trans-1,3-Dichloropropene | 43 | 1.0 | 50.00 | 0 | 85.6 | 37 | 133 | | | | |
| Trichloroethene | 40 | 1.0 | 50.00 | 0 | 79.1 | 43 | 140 | | | | |
| Trichlorofluoromethane | 60 | 1.0 | 50.00 | 0 | 120 | 50 | 148 | | | | |
| Vinyl chloride | 60 | 1.0 | 50.00 | 0 | 119 | 35 | 142 | | | | |
| Surr: 4-Bromofluorobenzene | 49 | | 50.00 | | 99.0 | 60 | 130 | | | | |
| Surr: Dibromofluoromethane | 50 | | 50.00 | | 99.0 | 63 | 127 | | | | |
| Surr: Toluene-d8 | 52 | | 50.00 | | 105 | 61 | 128 | | | | |

| Sample ID: VBLK-032410W | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49625 | | | | | | |
|---------------------------------------|-------------------|----------------------|-------------|--------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Client ID: PBW | Batch ID: R49625B | TestNo: SW8260B | | Analysis Date: 3/24/2010 | SeqNo: 687273 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |
| 1,1,1,2-Tetrachloroethane | U | 1.0 | | | | | | | | | |
| 1,1,1-Trichloroethane | U | 1.0 | | | | | | | | | |
| 1,1,2,2-Tetrachloroethane | U | 1.0 | | | | | | | | | |
| 1,1,2-Trichloro-1,2,2-trifluoroethane | U | 1.0 | | | | | | | | | |
| 1,1,2-Trichloroethane | U | 1.0 | | | | | | | | | |
| 1,1-Dichloroethane | U | 1.0 | | | | | | | | | |
| 1,1-Dichloroethene | U | 1.0 | | | | | | | | | |
| 1,1-Dichloropropene | U | 1.0 | | | | | | | | | |
| 1,2,3-Trichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2,3-Trichloropropane | U | 1.0 | | | | | | | | | |
| 1,2,4-Trichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2,4-Trimethylbenzene | U | 1.0 | | | | | | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analysis
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

CLIENT: Leggett Brashears & Graham Inc.
 Work Order: 1003154
 Project: Rowe

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

| Sample ID: VBLK-032410W | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49625 | | | | | | |
|-------------------------|-------------------|----------------------|-------------|--------------------------|---------------|----------|-----------|-------------|------|----------|------|
| Client ID: PBW | Batch ID: R49625B | TestNo: SW8260B | | Analysis Date: 3/24/2010 | SeqNo: 687273 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|-----------------------------|---|-----|--|--|--|--|--|--|--|--|--|
| 1,2-Dibromo-3-chloropropane | U | 1.0 | | | | | | | | | |
| 1,2-Dibromoethane | U | 1.0 | | | | | | | | | |
| 1,2-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,2-Dichloroethane | U | 1.0 | | | | | | | | | |
| 1,2-Dichloropropane | U | 1.0 | | | | | | | | | |
| 1,3,5-Trimethylbenzene | U | 1.0 | | | | | | | | | |
| 1,3-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 1,3-dichloropropane | U | 1.0 | | | | | | | | | |
| 1,4-Dichlorobenzene | U | 1.0 | | | | | | | | | |
| 2,2-Dichloropropane | U | 1.0 | | | | | | | | | |
| 2-Butanone | U | 3.0 | | | | | | | | | |
| 2-Chloroethyl vinyl ether | U | 1.0 | | | | | | | | | |
| 2-Chlorotoluene | U | 1.0 | | | | | | | | | |
| 2-Hexanone | U | 2.0 | | | | | | | | | |
| 4-Chlorotoluene | U | 1.0 | | | | | | | | | |
| 4-Isopropyltoluene | U | 1.0 | | | | | | | | | |
| 4-Methyl-2-pentanone | U | 2.0 | | | | | | | | | |
| Acetone | U | 2.0 | | | | | | | | | |
| Benzene | U | 1.0 | | | | | | | | | |
| Bromobenzene | U | 1.0 | | | | | | | | | |
| Bromochloromethane | U | 1.0 | | | | | | | | | |
| Bromodichloromethane | U | 1.0 | | | | | | | | | |
| Bromoform | U | 1.0 | | | | | | | | | |
| Bromomethane | U | 1.0 | | | | | | | | | |
| Carbon disulfide | U | 1.0 | | | | | | | | | |
| Carbon tetrachloride | U | 1.0 | | | | | | | | | |
| Chlorobenzene | U | 1.0 | | | | | | | | | |
| Chloroethane | U | 1.0 | | | | | | | | | |
| Chloroform | U | 1.0 | | | | | | | | | |
| Chloromethane | U | 1.0 | | | | | | | | | |
| cis-1,2-Dichloroethene | U | 1.0 | | | | | | | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analy
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco

ANALYTICAL QC SUMMARY REPORT

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 1003154
Project: Rowe

TestCode: 8260MTBE113_W

| | | | | | | | | | | | |
|--------------------------------|--------------------------|-----------------------------|--------------------|---------------------------------|----------------------|----------|-----------|-------------|------|----------|------|
| Sample ID: VBLK-032410W | SampType: MBLK | TestCode: 8260MTBE11 | Units: µg/L | Prep Date: | RunNo: 49625 | | | | | | |
| Client ID: PBW | Batch ID: R49625B | TestNo: SW8260B | | Analysis Date: 3/24/2010 | SeqNo: 687273 | | | | | | |
| Analyte | Result | PQL | SPK value | SPK Ref Val | %REC | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

| | | | | | | | | | | | |
|----------------------------|----|-----|-------|--|------|----|--|-----|--|--|--|
| cis-1,3-Dichloropropene | U | 1.0 | | | | | | | | | |
| Dibromochloromethane | U | 1.0 | | | | | | | | | |
| Dibromomethane | U | 1.0 | | | | | | | | | |
| Dichlorodifluoromethane | U | 1.0 | | | | | | | | | |
| Ethylbenzene | U | 1.0 | | | | | | | | | |
| Hexachlorobutadiene | U | 1.0 | | | | | | | | | |
| Isopropylbenzene | U | 1.0 | | | | | | | | | |
| m,p-Xylene | U | 2.0 | | | | | | | | | |
| Methyl tert-butyl ether | U | 1.0 | | | | | | | | | |
| Methylene chloride | U | 1.0 | | | | | | | | | |
| Naphthalene | U | 1.0 | | | | | | | | | |
| n-Butylbenzene | U | 1.0 | | | | | | | | | |
| n-Propylbenzene | U | 1.0 | | | | | | | | | |
| o-Xylene | U | 1.0 | | | | | | | | | |
| sec-Butylbenzene | U | 1.0 | | | | | | | | | |
| Styrene | U | 1.0 | | | | | | | | | |
| tert-Butylbenzene | U | 1.0 | | | | | | | | | |
| Tetrachloroethene | U | 1.0 | | | | | | | | | |
| Toluene | U | 1.0 | | | | | | | | | |
| trans-1,2-Dichloroethene | U | 1.0 | | | | | | | | | |
| trans-1,3-Dichloropropene | U | 1.0 | | | | | | | | | |
| Trichloroethene | U | 1.0 | | | | | | | | | |
| Trichlorofluoromethane | U | 1.0 | | | | | | | | | |
| Vinyl acetate | U | 1.0 | | | | | | | | | |
| Vinyl chloride | U | 1.0 | | | | | | | | | |
| Surr: 4-Bromofluorobenzene | 50 | | 50.00 | | 100 | 60 | | 130 | | | |
| Surr: Dibromofluoromethane | 49 | | 50.00 | | 98.6 | 63 | | 127 | | | |
| Surr: Toluene-d8 | 52 | | 50.00 | | 103 | 61 | | 128 | | | |

Qualifiers: C Calibration %RSD/%D exceeded for non-CCC analytes E Value above quantitation range H Holding times for preparation or analyte
 J Analyte detected below quantitation limits LOD Limit of Detection LOQ Limit of Quantitation
 ND Not Detected at the Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted reco