



575 Broad Hollow Road, Melville, NY 11747

TEL: (631) 694-3040 FAX: (631) 420-8436

www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
Origin: Raw Well
Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Rob King

Federal ID : 5103704

Collected : 04/01/2019 08:25 AM Point S-15687

Received : 04/01/2019 10:20 AM Location Well #1-1

Collected By CLIENT

Lab No. : 7083994001

Client Sample ID.: S-15687

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	0.048		1	mg/L	0.3	04/04/2019 11:10	001 BP4N1/1
Manganese	0.010		1	mg/L	0.3	04/04/2019 11:10	001 BP4N1/1

Analytical Method:EPA 200.8

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Antimony	<0.40		1	ug/L	6	04/02/2019 10:11	001 BP4N1/1
Arsenic	<1.0		1	ug/L	10	04/02/2019 10:11	001 BP4N1/1
Barium	0.062		1	mg/L	2	04/02/2019 10:11	001 BP4N1/1
Beryllium	<0.30		1	ug/L	4	04/02/2019 10:11	001 BP4N1/1
Cadmium	<1.0		1	ug/L	5	04/02/2019 10:11	001 BP4N1/1
Chromium	<0.0070		1	mg/L	0.1	04/02/2019 10:11	001 BP4N1/1
Lead	<1.0		1	ug/L	15	04/02/2019 10:11	001 BP4N1/1
Mercury	<0.20		1	ug/L	2	04/02/2019 10:11	001 BP4N1/1
Nickel	0.0024		1	mg/L		04/02/2019 10:11	001 BP4N1/1
Selenium	<2.0		1	ug/L	50	04/02/2019 10:11	001 BP4N1/1
Silver	<0.0010		1	mg/L	0.1	04/02/2019 10:11	001 BP4N1/1
Thallium	<0.30		1	ug/L	2	04/02/2019 10:11	001 BP4N1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	3.6		10	mg/L	10	04/01/2019 8:41 PM	001 BP4U1/1
Nitrate-Nitrite (as N)	3.6		10	mg/L		04/01/2019 8:41 PM	001 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	04/01/2019 6:31 PM	001 BP4U1/1

Analytical Method:SM22 9223B Colilert

Prep Method: SM22 9223B Colilert

Prep Date: 04/01/2019 4:10 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	04/02/2019 10:10	001 SP5T1/1
Total Coliforms	Absent		1		Absent	04/02/2019 10:10	001 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 04/04/2019

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747

TEL: (631) 694-3040 FAX: (631) 420-8436

www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water

Origin: Raw Well

Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Rob King

Federal ID : 5103704

Collected : 04/01/2019 08:40 AM Point S-24848

Received : 04/01/2019 10:20 AM Location Well #1-2

Collected By CLIENT

Lab No. : 7083994002

Client Sample ID.: S-24848

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	0.24		1	mg/L	0.3	04/04/2019 11:11	002 BP4N1/1
Manganese	0.41*		1	mg/L	0.3	04/04/2019 11:11	002 BP4N1/1

Analytical Method:EPA 200.8

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Antimony	<0.40		1	ug/L	6	04/02/2019 10:14	002 BP4N1/1
Arsenic	<1.0		1	ug/L	10	04/02/2019 10:14	002 BP4N1/1
Barium	0.11		1	mg/L	2	04/02/2019 10:14	002 BP4N1/1
Beryllium	<0.30		1	ug/L	4	04/02/2019 10:14	002 BP4N1/1
Cadmium	<1.0		1	ug/L	5	04/02/2019 10:14	002 BP4N1/1
Chromium	<0.0070		1	mg/L	0.1	04/02/2019 10:14	002 BP4N1/1
Lead	<1.0		1	ug/L	15	04/02/2019 10:14	002 BP4N1/1
Mercury	<0.20		1	ug/L	2	04/02/2019 10:14	002 BP4N1/1
Nickel	0.013		1	mg/L		04/02/2019 10:14	002 BP4N1/1
Selenium	<2.0		1	ug/L	50	04/02/2019 10:14	002 BP4N1/1
Silver	<0.0010		1	mg/L	0.1	04/02/2019 10:14	002 BP4N1/1
Thallium	<0.30		1	ug/L	2	04/02/2019 10:14	002 BP4N1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	8.7		10	mg/L	10	04/01/2019 8:44 PM	002 BP4U1/1
Nitrate-Nitrite (as N)	8.7		10	mg/L		04/01/2019 8:44 PM	002 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	04/01/2019 6:33 PM	002 BP4U1/1

Analytical Method:SM22 9223B Colilert

Prep Method: SM22 9223B Colilert

Prep Date: 04/01/2019 4:10 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	04/02/2019 10:10	002 SP5T1/1
Total Coliforms	Absent		1		Absent	04/02/2019 10:10	002 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 04/04/2019

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747

TEL: (631) 694-3040 FAX: (631) 420-8436

www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
Origin: Raw Well
Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Rob King

Federal ID : 5103704

Collected : 04/01/2019 08:50 AM Point S-31636

Received : 04/01/2019 10:20 AM Location Well #1-3

Collected By CLIENT

Lab No. : 7083994003

Client Sample ID.: S-31636

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	0.10		1	mg/L	0.3	04/04/2019 11:12	003 BP4N1/1
Manganese	0.017		1	mg/L	0.3	04/04/2019 11:12	003 BP4N1/1

Analytical Method:EPA 200.8

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Antimony	<0.40		1	ug/L	6	04/02/2019 10:23	003 BP4N1/1
Arsenic	<1.0		1	ug/L	10	04/02/2019 10:23	003 BP4N1/1
Barium	0.062		1	mg/L	2	04/02/2019 10:23	003 BP4N1/1
Beryllium	<0.30		1	ug/L	4	04/02/2019 10:23	003 BP4N1/1
Cadmium	<1.0		1	ug/L	5	04/02/2019 10:23	003 BP4N1/1
Chromium	<0.0070		1	mg/L	0.1	04/02/2019 10:23	003 BP4N1/1
Lead	<1.0		1	ug/L	15	04/02/2019 10:23	003 BP4N1/1
Mercury	<0.20		1	ug/L	2	04/02/2019 10:23	003 BP4N1/1
Nickel	0.00071		1	mg/L		04/02/2019 10:23	003 BP4N1/1
Selenium	<2.0		1	ug/L	50	04/02/2019 10:23	003 BP4N1/1
Silver	<0.0010		1	mg/L	0.1	04/02/2019 10:23	003 BP4N1/1
Thallium	<0.30		1	ug/L	2	04/02/2019 10:23	003 BP4N1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	5.0		10	mg/L	10	04/01/2019 8:45 PM	003 BP4U1/1
Nitrate-Nitrite (as N)	5.0		10	mg/L		04/01/2019 8:45 PM	003 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	04/01/2019 6:34 PM	003 BP4U1/1

Analytical Method:SM22 9223B Colilert

Prep Method: SM22 9223B Colilert

Prep Date: 04/01/2019 4:10 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	04/02/2019 10:10	003 SP5T1/1
Total Coliforms	Absent		1		Absent	04/02/2019 10:10	003 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 04/04/2019

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
Origin: Raw Well
Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Rob King

Federal ID : 5103704

Collected : 04/01/2019 09:00 AM Point BLENDED

Received : 04/01/2019 10:20 AM Location

Collected By CLIENT

Lab No. : 7083994004

Client Sample ID.: BLENDED INFLUENT

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	0.098		1	mg/L	0.3	04/04/2019 11:14	004 BP4N1/1
Manganese	0.11		1	mg/L	0.3	04/04/2019 11:14	004 BP4N1/1

Analytical Method:EPA 200.8

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Antimony	<0.40		1	ug/L	6	04/02/2019 10:26	004 BP4N1/1
Arsenic	<1.0		1	ug/L	10	04/02/2019 10:26	004 BP4N1/1
Barium	0.075		1	mg/L	2	04/02/2019 10:26	004 BP4N1/1
Beryllium	<0.30		1	ug/L	4	04/02/2019 10:26	004 BP4N1/1
Cadmium	<1.0		1	ug/L	5	04/02/2019 10:26	004 BP4N1/1
Chromium	<0.0070		1	mg/L	0.1	04/02/2019 10:26	004 BP4N1/1
Lead	<1.0		1	ug/L	15	04/02/2019 10:26	004 BP4N1/1
Mercury	<0.20		1	ug/L	2	04/02/2019 10:26	004 BP4N1/1
Nickel	0.0011		1	mg/L		04/02/2019 10:26	004 BP4N1/1
Selenium	<2.0		1	ug/L	50	04/02/2019 10:26	004 BP4N1/1
Silver	<0.0010		1	mg/L	0.1	04/02/2019 10:26	004 BP4N1/1
Thallium	<0.30		1	ug/L	2	04/02/2019 10:26	004 BP4N1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	6.1		10	mg/L	10	04/01/2019 8:47 PM	004 BP4U1/1
Nitrate-Nitrite (as N)	6.1		10	mg/L		04/01/2019 8:47 PM	004 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	04/01/2019 6:36 PM	004 BP4U1/1

Analytical Method:SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 04/01/2019 4:10 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	04/02/2019 10:10	004 SP5T1/1
Total Coliforms	Absent		1		Absent	04/02/2019 10:10	004 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
ND - Not Detected at or above adjusted reporting limit.
J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).
Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 04/04/2019

Stu Murrell

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747

TEL: (631) 694-3040 FAX: (631) 420-8436

www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water

Origin: Raw Well

Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Rob King

Federal ID : 5103704

Collected : 04/01/2019 09:10 AM Point BLENDED

Received : 04/01/2019 10:20 AM Location

Collected By CLIENT

Lab No. : 7083994005

Client Sample ID.: BLENDED EFFLUENT

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	0.072		1	mg/L	0.3	04/04/2019 11:15	005 BP4N1/1
Manganese	0.18		1	mg/L	0.3	04/04/2019 11:15	005 BP4N1/1

Analytical Method:EPA 200.8

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Antimony	<0.40		1	ug/L	6	04/02/2019 10:29	005 BP4N1/1
Arsenic	1.8		1	ug/L	10	04/02/2019 10:29	005 BP4N1/1
Barium	0.041		1	mg/L	2	04/02/2019 10:29	005 BP4N1/1
Beryllium	<0.30		1	ug/L	4	04/02/2019 10:29	005 BP4N1/1
Cadmium	<1.0		1	ug/L	5	04/02/2019 10:29	005 BP4N1/1
Chromium	<0.0070		1	mg/L	0.1	04/02/2019 10:29	005 BP4N1/1
Lead	<1.0		1	ug/L	15	04/02/2019 10:29	005 BP4N1/1
Mercury	<0.20		1	ug/L	2	04/02/2019 10:29	005 BP4N1/1
Nickel	0.00069		1	mg/L		04/02/2019 10:29	005 BP4N1/1
Selenium	<2.0		1	ug/L	50	04/02/2019 10:29	005 BP4N1/1
Silver	<0.0010		1	mg/L	0.1	04/02/2019 10:29	005 BP4N1/1
Thallium	<0.30		1	ug/L	2	04/02/2019 10:29	005 BP4N1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	5.2		10	mg/L	10	04/01/2019 8:48 PM	005 BP4U1/1
Nitrate-Nitrite (as N)	5.2		10	mg/L		04/01/2019 8:48 PM	005 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	04/01/2019 6:37 PM	005 BP4U1/1

Analytical Method:SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 04/01/2019 4:10 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	04/02/2019 10:10	005 SP5T1/1
Total Coliforms	Absent		1		Absent	04/02/2019 10:10	005 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 04/04/2019

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

WorkOrder :

7083994

Laboratory Certifications

Long Island Certification IDs

575 Broad Hollow Rd, Melville, NY 11747
New York Certification #: 10478 Primary Accrediting Body
New Jersey Certification #: NY158
Pennsylvania Certification #: 68-00350
Connecticut Certification #: PH-0435
Maryland Certification #: 208
Rhode Island Certification #: LAO00340
Massachusetts Certification #: M-NY026
New Hampshire Certification #: 2987

WO#: 7083994



7083994

Sample Request Form PUBLIC WATER SUPPLIER

☐ WELL OFF LINE

☐ WELL RUN TO SYSTEM

☐ YES ☐ NO VOC'S PRESERVED WITH HCl

Date:

4-1-19

Collected By:

W Booth

Accepted By:

W Booth 10:20

Cooler Temp:

36 °C

Client Info: HAMPTON BAYS WATER DISTRICT

Name or Code: P.O. BOX 1013

Address: HAMPTON BAYS, NEW YORK 11946

(631) 728-0179

Phone #:

Attn:

Proj. # or (Name):

Bill To:

Copies To:

Sample Info:

Date/Time Collected:	Sample Type	Location	Origin	Treatment Type	Purpose	Field Readings C ₁₂ pH/Temp	Analysis	Lab No.
8:35 4-1-19	GW	WELL 1-1	RW	-	RO		PFC's, Metals, BACT, N/N	001
8:40 4-1-19	GW	WELL 1-2	RW	-	RO		PFC's, Metals, BACT, N/N	002
8:50 4-1-19	GW	WELL 1-3	RW	-	RO		PFC's, Metals, BACT, N/N	003
9:00 4-1-19	GW	BLENDED INFILTRANT	RW	-	RO		PFC's, Metals, BACT, N/N	004
9:10 4-1-19	GW	BLENDED EFFLUENT	RW	-	RO		PFC's, Metals, BACT, N/N	005
Remarks:								

Sample Types	Purpose	Origin	Treatment Types
PW - Potable Water	RO - Routine	D - Distribution	AST - Air Stripper
GW - Groundwater	RE - Resample	RW - Raw Well	GAC - Granular Activated Charcoal
SW - Surface Water	S - Special	TW - Treated Well	N - Nitrate Removal Plant
WW - Waste Water		T - Tank	FE - Iron Removal Plant
AQ - Aqueous		MW - Monitoring Well	O - Other
S - Soil		I - Influent	
		E - Effluent	



Sample Condition Upon Receipt

Client Name: Hampton Bay WL

Project

WO#: 7083994

PM: SWM Due Date: 04/09/19

CLIENT: HBW

Courier: ☐ Fed Ex ☐ UPS ☒ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other

Tracking #:

Custody Seal on Cooler/Box Present: ☐ Yes ☒ No Seals intact: ☐ Yes ☒ No

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ Ziploc ☒ None ☐ Other

Thermometer Used: TH091

Correction Factor: 0.0

Cooler Temperature (°C): 3.6

Cooler Temperature Corrected (°C): 3.6

Temperature Blank Present: ☐ Yes ☒ No

Type of Ice: Wet Blue None

☒ Samples on ice, cooling process has begun

Date/Time 5035A kits placed in freezer

Temp should be above freezing to 6.0°C

USDA Regulated Soil (☐ N/A, water sample)

Date and Initials of person examining contents: AB 4/1/19

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? ☐ YES ☒ NO

Did samples originate from a foreign source (internationally, including Hawaii and Puerto Rico)? ☐ Yes ☒ No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

				COMMENTS:
Chain of Custody Present:	☒ Yes	☐ No		1.
Chain of Custody Filled Out:	☒ Yes	☐ No		2.
Chain of Custody Relinquished:	☒ Yes	☐ No		3.
Sampler Name & Signature on COC:	☒ Yes	☐ No	☐ N/A	4.
Samples Arrived within Hold Time:	☒ Yes	☐ No		5.
Short Hold Time Analysis (<72hr):	☒ Yes	☐ No		6.
Rush Turn Around Time Requested:	☐ Yes	☒ No		7.
Sufficient Volume: (Triple volume provided for MS/MSD)	☒ Yes	☐ No		8.
Correct Containers Used:	☒ Yes	☐ No		9.
- Pace Containers Used:	☒ Yes	☐ No		
Containers Intact:	☒ Yes	☐ No		10.
Filtered volume received for Dissolved tests	☐ Yes	☐ No	☐ N/A	11. Note if sediment is visible in the dissolved container.
Sample Labels match COC:	☒ Yes	☐ No		12.
-Includes date/time/ID/Analysis Matrix SL WT OIL				
All containers needing preservation have been checked:	☒ Yes	☐ No	☐ N/A	13. ☐ HNO ₃ ☐ H ₂ SO ₄ ☐ NaOH ☐ HCl
pH paper Lot # <u>HC857466</u>				Sample #
All containers needing preservation are found to be in compliance with EPA recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, NaOH>12 Cyanide)	☒ Yes	☐ No	☐ N/A	
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water).				
Per Method, VOA pH is checked after analysis				
Samples checked for dechlorination:	☐ Yes	☐ No	☐ N/A	14. Positive for Res. Chlorine? Y N
KI starch test strips Lot #				
Residual chlorine strips Lot #				
Headspace in VOA Vials (>6mm):	☐ Yes	☐ No	☐ N/A	15.
Trip Blank Present:	☐ Yes	☐ No	☐ N/A	16.
Trip Blank Custody Seals Present	☐ Yes	☐ No	☐ N/A	
Pace Trip Blank Lot # (if applicable):				

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution: