



575 Broad Hollow Road, Melville, NY 11747

TEL: (631) 694-3040 FAX: (631) 420-8436

www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water

Origin: Raw Well

Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 07/08/2020 08:05 AM Point S-15687

Received : 07/08/2020 04:15 PM Location Well #1-1

Collected By CLIENT

Lab No. : 70137413001

Client Sample ID.: S-15687

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	<0.020		1	mg/L	0.3	07/20/2020 10:10	001 BP4N1/1
Manganese	0.092		1	mg/L	0.3	07/20/2020 10:10	001 BP4N1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	5.5		10	mg/L	10	07/09/2020 1:22 AM	001 BP4U1/1
Nitrate-Nitrite (as N)	5.5		10	mg/L		07/09/2020 1:22 AM	001 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	07/08/2020 10:58	001 BP4U1/1

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	L1,N3	1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
Benzene	<0.50		1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747

TEL: (631) 694-3040 FAX: (631) 420-8436

www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
Origin: Raw Well
Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 07/08/2020 08:05 AM Point S-15687

Received : 07/08/2020 04:15 PM Location Well #1-1

Collected By CLIENT

Lab No. : 70137413001

Client Sample ID.: S-15687

Bromochloromethane	<0.50	1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
Bromodichloromethane	<0.50	1	ug/L		07/13/2020 2:04 PM	001 VG9C1/2
Bromoform	<0.50	1	ug/L		07/13/2020 2:04 PM	001 VG9C1/2
Bromomethane	<0.50	L1 1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
Carbon tetrachloride	<0.50	1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
Chlorobenzene	<0.50	1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
Chlorodifluoromethane	<0.50	N3 1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
Chloroethane	<0.50	1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
Chloroform	<0.50	1	ug/L		07/13/2020 2:04 PM	001 VG9C1/2
Chloromethane	<0.50	1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
Dibromochloromethane	<0.50	1	ug/L		07/13/2020 2:04 PM	001 VG9C1/2
Dibromomethane	<0.50	1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
Dichlorodifluoromethane	<0.50	L1 1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
Ethylbenzene	<0.50	1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
Hexachloro-1,3-butadiene	<0.50	1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
Isopropylbenzene (Cumene)	<0.50	1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
Methyl-tert-butyl ether	<0.50	1	ug/L	10	07/13/2020 2:04 PM	001 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
Styrene	<0.50	1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
Toluene	<0.50	1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
Total Trihalomethanes (Calc.)	<0.50	1	ug/L	80	07/13/2020 2:04 PM	001 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	07/13/2020 2:04 PM	001 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	07/13/2020 2:04 PM	001 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	92%	1	%REC		07/13/2020 2:04 PM	001 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	80%	1	%REC		07/13/2020 2:04 PM	001 VG9C1/2

Analytical Method: EPA 537

Prep Method: EPA 537

Prep Date: 07/15/2020 11:03

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Perfluorobutanesulfonic acid	2.0		1	ng/L		07/23/2020 12:12	
Perfluoroheptanoic acid	9.7		1	ng/L		07/23/2020 12:12	

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Stu Murrell

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747

TEL: (631) 694-3040 FAX: (631) 420-8436

www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
Origin: Raw Well
Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 07/08/2020 08:05 AM Point S-15687

Received : 07/08/2020 04:15 PM Location Well #1-1

Collected By CLIENT

Lab No. : 70137413001

Client Sample ID.: S-15687

Perfluorohexanesulfonic acid	25.4	1	ng/L	07/23/2020 12:12
Perfluorononanoic acid	13.3	1	ng/L	07/23/2020 12:12
Perfluorooctanesulfonic acid	82.6	1	ng/L	07/23/2020 12:12
Perfluorooctanoic acid	8.3	1	ng/L	07/23/2020 12:12
Surr: 13C2-PFDA (S)	101%	1	%REC	07/23/2020 12:12
Surr: 13C2-PFHxA (S)	103%	1	%REC	07/23/2020 12:12
Surr: NEtFOSAA-d5 (S)	96%	1	%REC	07/23/2020 12:12

Analytical Method: SM22 9223B Colilert

Prep Method: SM22 9223B Colilert

Prep Date: 07/08/2020 5:52 PM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	07/09/2020 11:52	001 SP5T1/1
Total Coliforms	Absent		1		Absent	07/09/2020 11:52	001 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
Origin: Raw Well
Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 07/08/2020 07:55 AM Point S-24848

Received : 07/08/2020 04:15 PM Location Well #1-2

Collected By CLIENT

Lab No. : 70137413002

Client Sample ID.: S-24848

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	<0.020		1	mg/L	0.3	07/20/2020 10:11	002 BP4N1/1
Manganese	0.34*		1	mg/L	0.3	07/20/2020 10:11	002 BP4N1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	5.3		10	mg/L	10	07/09/2020 1:28 AM	002 BP4U1/1
Nitrate-Nitrite (as N)	5.3		10	mg/L		07/09/2020 1:28 AM	002 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	07/08/2020 11:04	002 BP4U1/1

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	L1,N3	1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
Benzene	<0.50		1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747

TEL: (631) 694-3040 FAX: (631) 420-8436

www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
Origin: Raw Well
Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 07/08/2020 07:55 AM Point S-24848

Received : 07/08/2020 04:15 PM Location Well #1-2

Collected By CLIENT

Lab No. : 70137413002

Client Sample ID.: S-24848

Bromochloromethane	<0.50	1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
Bromodichloromethane	<0.50	1	ug/L		07/13/2020 2:30 PM	002 VG9C1/2
Bromoform	<0.50	1	ug/L		07/13/2020 2:30 PM	002 VG9C1/2
Bromomethane	<0.50	L1 1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
Carbon tetrachloride	<0.50	1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
Chlorobenzene	<0.50	1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
Chlorodifluoromethane	<0.50	N3 1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
Chloroethane	<0.50	1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
Chloroform	0.52	1	ug/L		07/13/2020 2:30 PM	002 VG9C1/2
Chloromethane	<0.50	1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
Dibromochloromethane	<0.50	1	ug/L		07/13/2020 2:30 PM	002 VG9C1/2
Dibromomethane	<0.50	1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
Dichlorodifluoromethane	<0.50	L1 1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
Ethylbenzene	<0.50	1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
Hexachloro-1,3-butadiene	<0.50	1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
Isopropylbenzene (Cumene)	<0.50	1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
Methyl-tert-butyl ether	<0.50	1	ug/L	10	07/13/2020 2:30 PM	002 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
Styrene	<0.50	1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
Toluene	<0.50	1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
Total Trihalomethanes (Calc.)	0.52	1	ug/L	80	07/13/2020 2:30 PM	002 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	07/13/2020 2:30 PM	002 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	07/13/2020 2:30 PM	002 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	89%	1	%REC		07/13/2020 2:30 PM	002 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	73%	1	%REC		07/13/2020 2:30 PM	002 VG9C1/2

Analytical Method: EPA 537

Prep Method: EPA 537

Prep Date: 07/15/2020 12:37

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Perfluorobutanesulfonic acid	<1.8	1j	1	ng/L		07/21/2020 10:53	
Perfluoroheptanoic acid	5.0	1j	1	ng/L		07/21/2020 10:53	

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747

TEL: (631) 694-3040 FAX: (631) 420-8436

www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water

Origin: Raw Well

Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 07/08/2020 07:55 AM Point S-24848

Received : 07/08/2020 04:15 PM Location Well #1-2

Collected By CLIENT

Lab No. : 70137413002

Client Sample ID.: S-24848

Perfluorohexanesulfonic acid	15.1	1j	1	ng/L	07/21/2020 10:53
Perfluorononanoic acid	12.8	1j	1	ng/L	07/21/2020 10:53
Perfluorooctanesulfonic acid	27.7	1j	1	ng/L	07/21/2020 10:53
Perfluorooctanoic acid	6.1	1j	1	ng/L	07/21/2020 10:53
Surr: 13C2-PFDA (S)	86%		1	%REC	07/21/2020 10:53
Surr: 13C2-PFHxA (S)	90%		1	%REC	07/21/2020 10:53
Surr: NEtFOSAA-d5 (S)	79%		1	%REC	07/21/2020 10:53

Analytical Method: SM22 9223B Colilert

Prep Method: SM22 9223B Colilert

Prep Date: 07/08/2020 5:52 PM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	07/09/2020 11:52	002 SP5T1/1
Total Coliforms	Absent		1		Absent	07/09/2020 11:52	002 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
Origin: Raw Well
Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 07/08/2020 07:20 AM Point S-31636

Received : 07/08/2020 04:15 PM Location Well #1-3

Collected By CLIENT

Lab No. : 70137413003

Client Sample ID.: S-31636

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	<0.020		1	mg/L	0.3	07/20/2020 10:12	003 BP4N1/1
Manganese	0.015		1	mg/L	0.3	07/20/2020 10:12	003 BP4N1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	6.3		10	mg/L	10	07/09/2020 1:29 AM	003 BP4U1/1
Nitrate-Nitrite (as N)	6.3		10	mg/L		07/09/2020 1:29 AM	003 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	07/08/2020 11:05	003 BP4U1/1

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	L1,N3	1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
Benzene	<0.50		1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
Origin: Raw Well
Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 07/08/2020 07:20 AM Point S-31636

Received : 07/08/2020 04:15 PM Location Well #1-3

Collected By CLIENT

Lab No. : 70137413003

Client Sample ID.: S-31636

Bromochloromethane	<0.50	1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
Bromodichloromethane	<0.50	1	ug/L		07/13/2020 2:56 PM	003 VG9C1/2
Bromoform	<0.50	1	ug/L		07/13/2020 2:56 PM	003 VG9C1/2
Bromomethane	<0.50	L1 1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
Carbon tetrachloride	<0.50	1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
Chlorobenzene	<0.50	1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
Chlorodifluoromethane	<0.50	N3 1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
Chloroethane	<0.50	1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
Chloroform	0.51	1	ug/L		07/13/2020 2:56 PM	003 VG9C1/2
Chloromethane	<0.50	1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
Dibromochloromethane	<0.50	1	ug/L		07/13/2020 2:56 PM	003 VG9C1/2
Dibromomethane	<0.50	1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
Dichlorodifluoromethane	<0.50	L1 1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
Ethylbenzene	<0.50	1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
Hexachloro-1,3-butadiene	<0.50	1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
Isopropylbenzene (Cumene)	<0.50	1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
Methyl-tert-butyl ether	<0.50	1	ug/L	10	07/13/2020 2:56 PM	003 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
Styrene	<0.50	1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
Tetrachloroethene	0.62	1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
Toluene	<0.50	1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
Total Trihalomethanes (Calc.)	0.51	1	ug/L	80	07/13/2020 2:56 PM	003 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	07/13/2020 2:56 PM	003 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	07/13/2020 2:56 PM	003 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	93%	1	%REC		07/13/2020 2:56 PM	003 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	80%	1	%REC		07/13/2020 2:56 PM	003 VG9C1/2

Analytical Method: EPA 537

Prep Method: EPA 537

Prep Date: 07/15/2020 12:37

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Perfluorobutanesulfonic acid	3.2	1j	1	ng/L		07/21/2020 9:36 PM	
Perfluoroheptanoic acid	4.7	1j	1	ng/L		07/21/2020 9:36 PM	

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747

TEL: (631) 694-3040 FAX: (631) 420-8436

www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water

Origin: Raw Well

Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 07/08/2020 07:20 AM Point S-31636

Received : 07/08/2020 04:15 PM Location Well #1-3

Collected By CLIENT

Lab No. : 70137413003

Client Sample ID.: S-31636

Perfluorohexanesulfonic acid	24.8	1j	1	ng/L	07/21/2020 9:36 PM
Perfluorononanoic acid	5.4	1j	1	ng/L	07/21/2020 9:36 PM
Perfluorooctanesulfonic acid	34.0	1j	1	ng/L	07/21/2020 9:36 PM
Perfluorooctanoic acid	5.7	1j	1	ng/L	07/21/2020 9:36 PM
Surr: 13C2-PFDA (S)	136%	S0	1	%REC	07/21/2020 9:36 PM
Surr: 13C2-PFHxA (S)	127%		1	%REC	07/21/2020 9:36 PM
Surr: NEtFOSAA-d5 (S)	133%	S0	1	%REC	07/21/2020 9:36 PM

Analytical Method: SM22 9223B Colilert

Prep Method: SM22 9223B Colilert

Prep Date: 07/08/2020 5:52 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	07/09/2020 11:52	003 SP5T1/1
Total Coliforms	Absent		1		Absent	07/09/2020 11:52	003 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
Origin: Raw Well
Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 07/08/2020 05:30 AM Point S-50970

Received : 07/08/2020 04:15 PM Location Well #2-1

Collected By CLIENT

Lab No. : 70137413004

Client Sample ID.: S-50970

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	L1,N3	1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
Benzene	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		07/13/2020 3:22 PM	004 VG9C1/2
Bromoform	<0.50		1	ug/L		07/13/2020 3:22 PM	004 VG9C1/2
Bromomethane	<0.50	L1	1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
Chlorodifluoromethane	<0.50	N3	1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
Chloroform	1.4		1	ug/L		07/13/2020 3:22 PM	004 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		07/13/2020 3:22 PM	004 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
Dichlorodifluoromethane	<0.50	L1	1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747

TEL: (631) 694-3040 FAX: (631) 420-8436

www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water

Origin: Raw Well

Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 07/08/2020 05:30 AM Point S-50970

Received : 07/08/2020 04:15 PM Location Well #2-1

Collected By CLIENT

Lab No. : 70137413004

Client Sample ID.: S-50970

Methyl-tert-butyl ether	<0.50	1	ug/L	10	07/13/2020 3:22 PM	004 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
Styrene	<0.50	1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
Toluene	<0.50	1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
Total Trihalomethanes (Calc.)	1.4	1	ug/L	80	07/13/2020 3:22 PM	004 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	07/13/2020 3:22 PM	004 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	07/13/2020 3:22 PM	004 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	85%	1	%REC		07/13/2020 3:22 PM	004 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	77%	1	%REC		07/13/2020 3:22 PM	004 VG9C1/2

Analytical Method: SM22 9223B Colilert

Prep Method: SM22 9223B Colilert

Prep Date: 07/08/2020 5:52 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	07/09/2020 11:52	004 SP5T1/1
Total Coliforms	Absent		1		Absent	07/09/2020 11:52	004 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747

TEL: (631) 694-3040 FAX: (631) 420-8436

www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water

Origin: Raw Well

Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 07/08/2020 05:40 AM Point S-74071

Received : 07/08/2020 04:15 PM Location Well #2-2

Collected By CLIENT

Lab No. : 70137413005

Client Sample ID.: S-74071

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	L1,N3	1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
Benzene	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		07/13/2020 3:48 PM	005 VG9C1/2
Bromoform	<0.50		1	ug/L		07/13/2020 3:48 PM	005 VG9C1/2
Bromomethane	<0.50	L1	1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
Chlorodifluoromethane	<0.50	N3	1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
Chloroform	0.72		1	ug/L		07/13/2020 3:48 PM	005 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		07/13/2020 3:48 PM	005 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
Dichlorodifluoromethane	<0.50	L1	1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747

TEL: (631) 694-3040 FAX: (631) 420-8436

www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water

Origin: Raw Well

Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 07/08/2020 05:40 AM Point S-74071

Received : 07/08/2020 04:15 PM Location Well #2-2

Collected By CLIENT

Lab No. : 70137413005

Client Sample ID.: S-74071

Methyl-tert-butyl ether	<0.50	1	ug/L	10	07/13/2020 3:48 PM	005 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
Styrene	<0.50	1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
Toluene	<0.50	1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
Total Trihalomethanes (Calc.)	0.72	1	ug/L	80	07/13/2020 3:48 PM	005 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	07/13/2020 3:48 PM	005 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	07/13/2020 3:48 PM	005 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	91%	1	%REC		07/13/2020 3:48 PM	005 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	77%	1	%REC		07/13/2020 3:48 PM	005 VG9C1/2

Analytical Method: SM22 9223B Colilert

Prep Method: SM22 9223B Colilert

Prep Date: 07/08/2020 5:52 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	07/09/2020 11:52	005 SP5T1/1
Total Coliforms	Absent		1		Absent	07/09/2020 11:52	005 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747

TEL: (631) 694-3040 FAX: (631) 420-8436

www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
Origin: Raw Well
Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 07/08/2020 06:37 AM Point S-58350

Received : 07/08/2020 04:15 PM Location Well #3-1

Collected By CLIENT

Lab No. : 70137413006

Client Sample ID.: S-58350

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	L1,N3	1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
Benzene	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		07/13/2020 4:14 PM	006 VG9C1/2
Bromoform	<0.50		1	ug/L		07/13/2020 4:14 PM	006 VG9C1/2
Bromomethane	<0.50	L1	1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
Chlorodifluoromethane	<0.50	N3	1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
Chloroform	4.0		1	ug/L		07/13/2020 4:14 PM	006 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		07/13/2020 4:14 PM	006 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
Dichlorodifluoromethane	<0.50	L1	1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747

TEL: (631) 694-3040 FAX: (631) 420-8436

www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
Origin: Raw Well
Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 07/08/2020 06:37 AM Point S-58350

Received : 07/08/2020 04:15 PM Location Well #3-1

Collected By CLIENT

Lab No. : 70137413006

Client Sample ID.: S-58350

Methyl-tert-butyl ether	<0.50	1	ug/L	10	07/13/2020 4:14 PM	006 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
Styrene	<0.50	1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
Toluene	<0.50	1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
Total Trihalomethanes (Calc.)	4.0	1	ug/L	80	07/13/2020 4:14 PM	006 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	07/13/2020 4:14 PM	006 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	07/13/2020 4:14 PM	006 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	93%	1	%REC		07/13/2020 4:14 PM	006 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	79%	1	%REC		07/13/2020 4:14 PM	006 VG9C1/2

Analytical Method: SM22 9223B Colilert

Prep Method: SM22 9223B Colilert

Prep Date: 07/08/2020 5:52 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	07/09/2020 11:52	006 SP5T1/1
Total Coliforms	Absent		1		Absent	07/09/2020 11:52	006 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747

TEL: (631) 694-3040 FAX: (631) 420-8436

www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
Origin: Raw Well
Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 07/08/2020 06:30 AM Point S-58351

Received : 07/08/2020 04:15 PM Location Well #3-2

Collected By CLIENT

Lab No. : 70137413007

Client Sample ID.: S-58351

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	L1,N3	1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
Benzene	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		07/13/2020 4:40 PM	007 VG9C1/2
Bromoform	<0.50		1	ug/L		07/13/2020 4:40 PM	007 VG9C1/2
Bromomethane	<0.50	L1	1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
Chlorodifluoromethane	<0.50	N3	1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
Chloroform	1.1		1	ug/L		07/13/2020 4:40 PM	007 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		07/13/2020 4:40 PM	007 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
Dichlorodifluoromethane	<0.50	L1	1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747

TEL: (631) 694-3040 FAX: (631) 420-8436

www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water

Origin: Raw Well

Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 07/08/2020 06:30 AM Point S-58351

Received : 07/08/2020 04:15 PM Location Well #3-2

Collected By CLIENT

Lab No. : 70137413007

Client Sample ID.: S-58351

Methyl-tert-butyl ether	<0.50	1	ug/L	10	07/13/2020 4:40 PM	007 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
Styrene	<0.50	1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
Toluene	<0.50	1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
Total Trihalomethanes (Calc.)	1.1	1	ug/L	80	07/13/2020 4:40 PM	007 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	07/13/2020 4:40 PM	007 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	07/13/2020 4:40 PM	007 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	89%	1	%REC		07/13/2020 4:40 PM	007 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	79%	1	%REC		07/13/2020 4:40 PM	007 VG9C1/2

Analytical Method: SM22 9223B Colilert

Prep Method: SM22 9223B Colilert

Prep Date: 07/08/2020 5:52 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	07/09/2020 11:52	007 SP5T1/1
Total Coliforms	Absent		1		Absent	07/09/2020 11:52	007 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747

TEL: (631) 694-3040 FAX: (631) 420-8436

www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water

Origin: Raw Well

Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 07/08/2020 06:45 AM Point S-58352

Received : 07/08/2020 04:15 PM Location Well #3-3

Collected By CLIENT

Lab No. : 70137413008

Client Sample ID.: S-58352

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	L1,N3	1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
Benzene	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		07/13/2020 5:06 PM	008 VG9C1/2
Bromoform	<0.50		1	ug/L		07/13/2020 5:06 PM	008 VG9C1/2
Bromomethane	<0.50	L1	1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
Chlorodifluoromethane	<0.50	N3	1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
Chloroform	1.3		1	ug/L		07/13/2020 5:06 PM	008 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		07/13/2020 5:06 PM	008 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
Dichlorodifluoromethane	<0.50	L1	1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747

TEL: (631) 694-3040 FAX: (631) 420-8436

www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
Origin: Raw Well
Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 07/08/2020 06:45 AM Point S-58352

Received : 07/08/2020 04:15 PM Location Well #3-3

Collected By CLIENT

Lab No. : 70137413008

Client Sample ID.: S-58352

Methyl-tert-butyl ether	<0.50	1	ug/L	10	07/13/2020 5:06 PM	008 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
Styrene	<0.50	1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
Toluene	<0.50	1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
Total Trihalomethanes (Calc.)	1.3	1	ug/L	80	07/13/2020 5:06 PM	008 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	07/13/2020 5:06 PM	008 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	07/13/2020 5:06 PM	008 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	83%	1	%REC		07/13/2020 5:06 PM	008 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	76%	1	%REC		07/13/2020 5:06 PM	008 VG9C1/2

Analytical Method: SM22 9223B Colilert

Prep Method: SM22 9223B Colilert

Prep Date: 07/08/2020 5:52 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	07/09/2020 11:52	008 SP5T1/1
Total Coliforms	Absent		1		Absent	07/09/2020 11:52	008 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Stu Murrell

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747

TEL: (631) 694-3040 FAX: (631) 420-8436

www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water

Origin: Raw Well

Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 07/08/2020 06:00 AM Point S-108065

Received : 07/08/2020 04:15 PM Location Well #4-1

Collected By CLIENT

Lab No. : 70137413009

Client Sample ID.: S-108065

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	0.69*		1	mg/L	0.3	07/20/2020 10:13	009 BP4N1/1
Manganese	0.11		1	mg/L	0.3	07/20/2020 10:13	009 BP4N1/1

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	L1,N3	1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
Benzene	<0.50		1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		07/13/2020 5:33 PM	009 VG9C1/2
Bromoform	<0.50		1	ug/L		07/13/2020 5:33 PM	009 VG9C1/2
Bromomethane	<0.50	L1	1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
Chlorodifluoromethane	<0.50	N3	1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
Chloroform	1.1		1	ug/L		07/13/2020 5:33 PM	009 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
Origin: Raw Well
Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 07/08/2020 06:00 AM Point S-108065

Received : 07/08/2020 04:15 PM Location Well #4-1

Collected By CLIENT

Lab No. : 70137413009

Client Sample ID.: S-108065

Dibromochloromethane	<0.50	1	ug/L		07/13/2020 5:33 PM	009 VG9C1/2
Dibromomethane	<0.50	1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
Dichlorodifluoromethane	<0.50	L1 1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
Ethylbenzene	<0.50	1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
Hexachloro-1,3-butadiene	<0.50	1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
Isopropylbenzene (Cumene)	<0.50	1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
Methyl-tert-butyl ether	<0.50	1	ug/L	10	07/13/2020 5:33 PM	009 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
Styrene	<0.50	1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
Toluene	<0.50	1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
Total Trihalomethanes (Calc.)	1.1	1	ug/L	80	07/13/2020 5:33 PM	009 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	07/13/2020 5:33 PM	009 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	07/13/2020 5:33 PM	009 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	89%	1	%REC		07/13/2020 5:33 PM	009 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	83%	1	%REC		07/13/2020 5:33 PM	009 VG9C1/2

Analytical Method: SM22 9223B Colilert		Prep Method: SM22 9223B Colilert		Prep Date: 07/08/2020 5:52 PM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:
E.coli	Absent		1		Absent	07/09/2020 11:52
Total Coliforms	Absent		1		Absent	07/09/2020 11:52

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
ND - Not Detected at or above adjusted reporting limit.
J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
U - Indicates the compound was analyzed for, but not detected
See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).
Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747

TEL: (631) 694-3040 FAX: (631) 420-8436

www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
Origin: Raw Well
Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 07/08/2020 06:10 AM Point S-108066

Received : 07/08/2020 04:15 PM Location Well #4-2

Collected By CLIENT

Lab No. : 70137413010

Client Sample ID.: S-108066

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	1.2*		1	mg/L	0.3	07/20/2020 10:16	010 BP4N1/1
Manganese	0.14		1	mg/L	0.3	07/20/2020 10:16	010 BP4N1/1

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	L1,N3	1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
Benzene	<0.50		1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		07/13/2020 5:59 PM	010 VG9C1/2
Bromoform	<0.50		1	ug/L		07/13/2020 5:59 PM	010 VG9C1/2
Bromomethane	<0.50	L1	1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
Chlorodifluoromethane	<0.50	N3	1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
Chloroform	0.74		1	ug/L		07/13/2020 5:59 PM	010 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
Origin: Raw Well
Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 07/08/2020 06:10 AM Point S-108066

Received : 07/08/2020 04:15 PM Location Well #4-2

Collected By CLIENT

Lab No. : 70137413010

Client Sample ID.: S-108066

Dibromochloromethane	<0.50	1	ug/L		07/13/2020 5:59 PM	010 VG9C1/2
Dibromomethane	<0.50	1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
Dichlorodifluoromethane	<0.50	L1 1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
Ethylbenzene	<0.50	1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
Hexachloro-1,3-butadiene	<0.50	1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
Isopropylbenzene (Cumene)	<0.50	1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
Methyl-tert-butyl ether	<0.50	1	ug/L	10	07/13/2020 5:59 PM	010 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
Styrene	<0.50	1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
Toluene	<0.50	1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
Total Trihalomethanes (Calc.)	0.74	1	ug/L	80	07/13/2020 5:59 PM	010 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	07/13/2020 5:59 PM	010 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	07/13/2020 5:59 PM	010 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	88%	1	%REC		07/13/2020 5:59 PM	010 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	80%	1	%REC		07/13/2020 5:59 PM	010 VG9C1/2

Analytical Method: SM22 9223B Colilert		Prep Method: SM22 9223B Colilert		Prep Date: 07/08/2020 5:52 PM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:
E.coli	Absent		1		Absent	07/09/2020 11:52
Total Coliforms	Absent		1		Absent	07/09/2020 11:52

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
ND - Not Detected at or above adjusted reporting limit.
J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
U - Indicates the compound was analyzed for, but not detected
See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).
Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747

TEL: (631) 694-3040 FAX: (631) 420-8436

www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
Origin: Raw Well
Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 07/08/2020 05:15 AM Point S-127163

Received : 07/08/2020 04:15 PM Location Well #5-1

Collected By CLIENT

Lab No. : 70137413011

Client Sample ID.: S-127163

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	L1,N3	1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
Benzene	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		07/13/2020 6:25 PM	011 VG9C1/2
Bromoform	<0.50		1	ug/L		07/13/2020 6:25 PM	011 VG9C1/2
Bromomethane	<0.50	L1	1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
Chlorodifluoromethane	<0.50	N3	1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
Chloroform	0.86		1	ug/L		07/13/2020 6:25 PM	011 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		07/13/2020 6:25 PM	011 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
Dichlorodifluoromethane	<0.50	L1	1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Stu Murrell

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747

TEL: (631) 694-3040 FAX: (631) 420-8436

www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
Origin: Raw Well
Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 07/08/2020 05:15 AM Point S-127163

Received : 07/08/2020 04:15 PM Location Well #5-1

Collected By CLIENT

Lab No. : 70137413011

Client Sample ID.: S-127163

Methyl-tert-butyl ether	<0.50	1	ug/L	10	07/13/2020 6:25 PM	011 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
Styrene	<0.50	1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
Toluene	<0.50	1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
Total Trihalomethanes (Calc.)	0.86	1	ug/L	80	07/13/2020 6:25 PM	011 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	07/13/2020 6:25 PM	011 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	07/13/2020 6:25 PM	011 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	84%	1	%REC		07/13/2020 6:25 PM	011 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	78%	1	%REC		07/13/2020 6:25 PM	011 VG9C1/2

Analytical Method: SM22 9223B Colilert

Prep Method: SM22 9223B Colilert

Prep Date: 07/08/2020 5:52 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	07/09/2020 11:52	011 SP5T1/1
Total Coliforms	Absent		1		Absent	07/09/2020 11:52	011 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
Origin: Raw Well
Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 07/08/2020 07:45 AM Point BLEND INF

Received : 07/08/2020 04:15 PM Location

Collected By CLIENT

Lab No. : 70137413012

Client Sample ID.: BLEND INF

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	<0.020		1	mg/L	0.3	07/20/2020 10:18	012 BP4N1/1
Manganese	0.12		1	mg/L	0.3	07/20/2020 10:18	012 BP4N1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	6.6		10	mg/L	10	07/09/2020 1:30 AM	012 BP4U1/1
Nitrate-Nitrite (as N)	6.6		10	mg/L		07/09/2020 1:30 AM	012 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	07/08/2020 11:19	012 BP4U1/1

Analytical Method:EPA 537

Prep Method: EPA 537

Prep Date: 07/15/2020 12:37

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Perfluorobutanesulfonic acid	2.5	1j	1	ng/L		07/21/2020 10:33	
Perfluoroheptanoic acid	5.5	1j	1	ng/L		07/21/2020 10:33	
Perfluorohexanesulfonic acid	22.4	1j	1	ng/L		07/21/2020 10:33	
Perfluorononanoic acid	10.2	1j	1	ng/L		07/21/2020 10:33	
Perfluorooctanesulfonic acid	46.7	1j	1	ng/L		07/21/2020 10:33	
Perfluorooctanoic acid	6.8	1j	1	ng/L		07/21/2020 10:33	
Surr: 13C2-PFDA (S)	89%		1	%REC		07/21/2020 10:33	
Surr: 13C2-PFHxA (S)	89%		1	%REC		07/21/2020 10:33	
Surr: NETFOSAA-d5 (S)	82%		1	%REC		07/21/2020 10:33	

Analytical Method:SM22 9223B Colilert

Prep Method: SM22 9223B Colilert

Prep Date: 07/08/2020 5:52 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	07/09/2020 11:52	012 SP5T1/1
Total Coliforms	Absent		1		Absent	07/09/2020 11:52	012 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 07/28/2020

Stu Murrell

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Laboratory Results

Results for the samples and analytes requested
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
Origin: Treated Well
Routine

Treatment

Other

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 07/08/2020 07:35 AM Point BLEND EFF

Received : 07/08/2020 04:15 PM Location

Collected By CLIENT

Lab No. : 70137413013

Client Sample ID.: BLEND EFF

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	<0.020		1	mg/L	0.3	07/20/2020 10:21	013 BP4N1/1
Manganese	<0.010		1	mg/L	0.3	07/20/2020 10:21	013 BP4N1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	5.5		10	mg/L	10	07/09/2020 1:31 AM	013 BP4U1/1
Nitrate-Nitrite (as N)	5.5		10	mg/L		07/09/2020 1:31 AM	013 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	07/08/2020 11:13	013 BP4U1/1

Analytical Method:EPA 537

Prep Method: EPA 537

Prep Date: 07/15/2020 12:37

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Perfluorobutanesulfonic acid	<1.9	1j	1	ng/L		07/21/2020 10:14	
Perfluoroheptanoic acid	<1.9	1j	1	ng/L		07/21/2020 10:14	
Perfluorohexanesulfonic acid	<1.9	1j	1	ng/L		07/21/2020 10:14	
Perfluorononanoic acid	<1.9	1j	1	ng/L		07/21/2020 10:14	
Perfluorooctanesulfonic acid	<1.9	1j	1	ng/L		07/21/2020 10:14	
Perfluorooctanoic acid	<1.9	1j	1	ng/L		07/21/2020 10:14	
Surr: 13C2-PFDA (S)	92%		1	%REC		07/21/2020 10:14	
Surr: 13C2-PFHxA (S)	87%		1	%REC		07/21/2020 10:14	
Surr: NETFOSAA-d5 (S)	81%		1	%REC		07/21/2020 10:14	

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 07/28/2020



Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747

TEL: (631) 694-3040 FAX: (631) 420-8436

www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water

Origin: Treated Well

Routine

Treatment

Other

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 07/08/2020 06:12 AM Point BLEND EFF 4-1,4-2

Received : 07/08/2020 04:15 PM Location

Collected By CLIENT

Lab No. : 70137413014

Client Sample ID.: BLEND EFF 4-1,4-2

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	1.1*		1	mg/L	0.3	07/20/2020 10:22	014 BP4N1/1
Manganese	0.12		1	mg/L	0.3	07/20/2020 10:22	014 BP4N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 07/28/2020

Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

WorkOrder :

70137413

Laboratory Certifications

Pace Analytical Services Ormond Beach

8 East Tower Circle, Ormond Beach, FL 32174
Alaska DEC- CS/UST/LUST
Alabama Certification #: 41320
Arizona Certification# AZ0819
Colorado Certification: FL NELAC Reciprocity
Connecticut Certification #: PH-0216
Delaware Certification: FL NELAC Reciprocity
Florida Certification #: E83079
Georgia Certification #: 955
Guam Certification: FL NELAC Reciprocity
Hawaii Certification: FL NELAC Reciprocity
Illinois Certification #: 200068
Indiana Certification: FL NELAC Reciprocity
Kansas Certification #: E-10383
Kentucky Certification #: 90050
Louisiana Certification #: FL NELAC Reciprocity
Louisiana Environmental Certificate #: 05007
Maryland Certification: #346
Michigan Certification #: 9911
Mississippi Certification: FL NELAC Reciprocity
Missouri Certification #: 236
Montana Certification #: Cert 0074
Nebraska Certification: NE-OS-28-14
New Hampshire Certification #: 2958
New Jersey Certification #: FL022
New York Certification #: 11608
North Carolina Environmental Certificate #: 667
North Carolina Certification #: 12710
North Dakota Certification #: R-216
Ohio DEP 87780
Oklahoma Certification #: D9947
Pennsylvania Certification #: 68-00547
Puerto Rico Certification #: FL01264
South Carolina Certification: #96042001
Tennessee Certification #: TN02974
Texas Certification: FL NELAC Reciprocity
US Virgin Islands Certification: FL NELAC Reciprocity
Virginia Environmental Certification #: 460165
West Virginia Certification #: 9962C
Wisconsin Certification #: 399079670
Wyoming (EPA Region 8): FL NELAC Reciprocity

Pace Analytical Services Long Island

WorkOrder :

70137413

Laboratory Certifications

Pace Analytical Services Long Island

575 Broad Hollow Rd, Melville, NY 11747

New York Certification #: 10478 Primary Accrediting Body

New Jersey Certification #: NY158

Pennsylvania Certification #: 68-00350

Connecticut Certification #: PH-0435

Maryland Certification #: 208

Rhode Island Certification #: LAO00340

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

WorkOrder :


70137413

Qualifiers

L1 - Analyte recovery in the laboratory control sample (LCS) was above QC limits. Results for this analyte in associated samples may be biased high.

N3 - Accreditation is not offered by the relevant laboratory accrediting body for this parameter.

WO#: 70137413



70137413

1-800-420-0430

Sample Request Form PUBLIC WATER SUPPLIER

☐ WELL OFF LINE

Date: 7-8-20

Collected By: W Booth

Accepted By: Ed Dammann

Cooler Temp: 4.2 °C

☒ WELL RUN TO SYSTEM ALL

Wells

☒ YES ☐ NO VOC'S PRESERVED WITH HCl

Back 1615

Client Info: HAMPTON BAYS WATER DISTRICT

Name or Code: P.O. BOX 1013

Address: HAMPTON BAYS, NEW YORK 11946

(631) 728-0179

Phone #: _____
Attn: _____
Proj. # or (Name): _____
Bill To: _____
Copies To: _____

Sample Types	Purpose	Origin	Treatment Types
PW - Potable Water	RO - Routine	D - Distribution	AST - Air Stripper
GW - Groundwater	RE - Resample	RW - Raw Well	GAC - Granular Activated Charcoal
SW - Surface Water	S - Special	TW - Treated Well	N - Nitrate Removal Plant
WW - Waste Water		T - Tank	FE - Iron Removal Plant
AQ - Aqueous		MW - Monitoring Well	O - Other
S - Soil		I - Influent	
		E - Effluent	

Sample Info:

Date/Time Collected:	Sample Type	Location	Origin	Treatment Type	Purpose	Field Readings Cl ₂ pH/Temp	Analysis	Lab No.
8:05 7-8-20	GW	S-15687	RW	-	RO		BACT, POC, NIN, ILM, PFC	001
7:55 7-8-20	GW	S-24848	RW	-	RO		BACT, POC, NIN, ILM, PFC	002
7:20 7-8-20	GW	S-31636	RW	-	RO		BACT, POC, NIN, ILM, PFC	003
5:30 7-8-20	GW	S-51970	RW	-	RO		BACT, POC	004
5:40 7-8-20	GW	S-74071	RW	-	RO		BACT, POC	005
6:37 7-8-20	GW	S-58350	RW	-	RO		BACT, POC	006
6:30 7-8-20	GW	S-58351	RW	-	RO		BACT, POC	007
6:45 7-8-20	GW	S-58353	RW	-	RO		BACT, POC	008
6:00 7-8-20	GW	S-108065	RW	-	RO		BACT, POC	009
6:10 7-8-20	GW	S-108066	RW	-	RO		BACT, POC	010
5:15 7-8-20	GW	S-127163	RW	-	RO		BACT, POC	011
7:45 7-8-20	GW	BLEND INF	RW	-	RO		BACT, NIN, ILM, PFC	012
7:35 7-8-20	PW	BLEND EFF	D	-	RO	1.08 7.10	BACT, NIN, ILM, PFC	013
6:12 7-8-20	PW	BLEND EFF	D	-	RO	.90 7.69	ILM	014



Sample Condition Upon Receipt

Client Name: HBW

Project

WO#: 70137413

PM: KMM

Due Date: 07/14/20

CLIENT: HBW

Courier: ☐ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☒ Pace ☐ Other

Tracking #:

Custody Seal on Cooler/Box Present: ☒ Yes ☐ No Seals intact: ☒ Yes ☐ No

Temperature Blank Present: ☐ Yes ☒ No

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ Ziploc ☒ None ☐ Other

Type of Ice: Wet Blue None

Thermometer Used: TH091 Correction Factor: +0.4

☒ Samples on ice, cooling process has begun

Cooler Temperature (°C): 4.2 Cooler Temperature Corrected (°C): 4.6

Date/Time 5035A kits placed in freezer

Temp should be above freezing to 6.0°C

USDA Regulated Soil (☐ N/A, water sample)

Date and Initials of person examining contents: CD 7/8/20

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? ☐ YES ☒ NO

Did samples originate from a foreign source (internationally, including Hawaii and Puerto Rico)? ☐ Yes ☒ No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

		COMMENTS:
Chain of Custody Present:	☒ Yes ☐ No	1.
Chain of Custody Filled Out:	☒ Yes ☐ No	2.
Chain of Custody Relinquished:	☒ Yes ☐ No	3.
Sampler Name & Signature on COC:	☒ Yes ☐ No ☐ N/A	4.
Samples Arrived within Hold Time:	☒ Yes ☐ No	5.
Short Hold Time Analysis (<72hr):	☒ Yes ☐ No	6.
Rush Turn Around Time Requested:	☐ Yes ☒ No	7.
Sufficient Volume: (Triple volume provided for MS/MSD)	☒ Yes ☐ No	8.
Correct Containers Used:	☒ Yes ☐ No	9.
-Pace Containers Used:	☒ Yes ☐ No	
Containers Intact:	☒ Yes ☐ No	10.
Filtered volume received for Dissolved tests	☐ Yes ☐ No ☒ N/A	11. Note if sediment is visible in the dissolved container.
Sample Labels match COC:	☒ Yes ☐ No	12. RECEIVED I/m bottles for well 4-1 and well 4-2. But not noted on COC.
-Includes date/time//D/Analysis Matrix SL WT OIL		
All containers needing preservation have been checked	☒ Yes ☐ No ☐ N/A	13. ☐ HNO ₃ ☐ H ₂ SO ₄ ☐ NaOH ☐ HCl
pH paper Lot # <u>Heauser</u>		Sample #
All containers needing preservation are found to be in compliance with EPA recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, NAOH>12 Cyanide) Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis	☒ Yes ☐ No ☐ N/A	Initial when completed: Lot # of added preservative: Date/Time preservative added
Samples checked for dechlorination:	☐ Yes ☐ No ☒ N/A	14. Positive for Res. Chlorine? Y N
KI starch test strips Lot #		
Residual chlorine strips Lot #		
Headspace in VOA Vials (>6mm):	☐ Yes ☒ No ☐ N/A	15.
Trip Blank Present:	☐ Yes ☐ No ☒ N/A	16.
Trip Blank Custody Seals Present	☐ Yes ☐ No ☒ N/A	
Pace Trip Blank Lot # (if applicable):		

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Correct print # used for

Date/Time:

Comments/ Resolution:

well 2-1, 5097D