



Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Repeat

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Supt. McCuen

Lab No. : 70149521001
Client Sample ID.: S-58350

Federal ID : 5103704
 Collected : 10/14/2020 06:55 AM Point S-58350
 Received : 10/14/2020 04:34 PM Location Well #3-1
 Collected By CLIENT

<u>Analytical Method: EPA 531.1</u>							
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
3-Hydroxycarbofuran	<1.0		1	ug/L	50	10/21/2020 6:46 PM	001 DG6M1/2
Aldicarb	<0.50		1	ug/L	3	10/21/2020 6:46 PM	001 DG6M1/2
Aldicarb sulfone	<0.80		1	ug/L	2	10/21/2020 6:46 PM	001 DG6M1/2
Aldicarb sulfoxide	<0.50		1	ug/L	4	10/21/2020 6:46 PM	001 DG6M1/2
Carbaryl	<1.0		1	ug/L	50	10/21/2020 6:46 PM	001 DG6M1/2
Carbofuran	<0.90		1	ug/L	40	10/21/2020 6:46 PM	001 DG6M1/2
Methomyl	<1.0		1	ug/L	50	10/21/2020 6:46 PM	001 DG6M1/2
Oxamyl	<1.0		1	ug/L	50	10/21/2020 6:46 PM	001 DG6M1/2

<u>Analytical Method: EPA 547</u>							
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Glyphosate	<6.0		1	ug/L	50	10/22/2020 1:21 AM	001 DG6T1/1

<u>Analytical Method: EPA 549.2</u>		<u>Prep Method: EPA 549.2</u>		<u>Prep Date: 10/19/2020 10:33</u>			
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Diquat	<0.40		1	ug/L	20	10/20/2020 12:13	001 AP1S1/1

Qualifiers:
 DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 10/28/2020



Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Repeat

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Supt. McCuen

Lab No. : 70149521002
Client Sample ID.: S-58351

Federal ID : 5103704
 Collected : 10/14/2020 06:45 AM Point S-58351
 Received : 10/14/2020 04:34 PM Location Well #3-2
 Collected By CLIENT

Analytical Method:EPA 531.1

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
3-Hydroxycarbofuran	<1.0		1	ug/L	50	10/21/2020 7:35 PM	002 DG6M1/2
Aldicarb	<0.50		1	ug/L	3	10/21/2020 7:35 PM	002 DG6M1/2
Aldicarb sulfone	<0.80		1	ug/L	2	10/21/2020 7:35 PM	002 DG6M1/2
Aldicarb sulfoxide	<0.50		1	ug/L	4	10/21/2020 7:35 PM	002 DG6M1/2
Carbaryl	<1.0		1	ug/L	50	10/21/2020 7:35 PM	002 DG6M1/2
Carbofuran	<0.90		1	ug/L	40	10/21/2020 7:35 PM	002 DG6M1/2
Methomyl	<1.0		1	ug/L	50	10/21/2020 7:35 PM	002 DG6M1/2
Oxamyl	<1.0		1	ug/L	50	10/21/2020 7:35 PM	002 DG6M1/2

Analytical Method:EPA 547

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Glyphosate	<6.0		1	ug/L	50	10/22/2020 1:06 AM	002 DG6T1/1

Analytical Method:EPA 549.2

Prep Method: EPA 549.2

Prep Date: 10/19/2020 10:33

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Diquat	<0.40		1	ug/L	20	10/20/2020 12:06	002 AP1S1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 10/28/2020



Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Repeat

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Supt. McCuen

Lab No. : 70149521003
Client Sample ID.: S-58352

Federal ID : 5103704
 Collected : 10/14/2020 07:02 AM Point S-58352
 Received : 10/14/2020 04:34 PM Location Well #3-3
 Collected By CLIENT

Analytical Method: EPA 531.1

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
3-Hydroxycarbofuran	<1.0		1	ug/L	50	10/21/2020 8:23 PM	003 DG6M1/2
Aldicarb	<0.50		1	ug/L	3	10/21/2020 8:23 PM	003 DG6M1/2
Aldicarb sulfone	<0.80		1	ug/L	2	10/21/2020 8:23 PM	003 DG6M1/2
Aldicarb sulfoxide	<0.50		1	ug/L	4	10/21/2020 8:23 PM	003 DG6M1/2
Carbaryl	<1.0		1	ug/L	50	10/21/2020 8:23 PM	003 DG6M1/2
Carbofuran	<0.90		1	ug/L	40	10/21/2020 8:23 PM	003 DG6M1/2
Methomyl	<1.0		1	ug/L	50	10/21/2020 8:23 PM	003 DG6M1/2
Oxamyl	<1.0		1	ug/L	50	10/21/2020 8:23 PM	003 DG6M1/2

Analytical Method: EPA 547

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Glyphosate	<6.0		1	ug/L	50	10/22/2020 1:37 AM	003 DG6T1/1

Analytical Method: EPA 549.2

Prep Method: EPA 549.2

Prep Date: 10/19/2020 10:33

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Diquat	<0.40		1	ug/L	20	10/20/2020 12:21	003 AP1S1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 10/28/2020



Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Repeat

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Supt. McCuen

Lab No. : 70149521004
Client Sample ID.: S-108065

Federal ID : 5103704
 Collected : 10/14/2020 06:20 AM Point S-108065
 Received : 10/14/2020 04:34 PM Location Well #4-1
 Collected By CLIENT

Analytical Method:EPA 531.1

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
3-Hydroxycarbofuran	<1.0		1	ug/L	50	10/21/2020 9:12 PM	004 DG6M1/2
Aldicarb	<0.50		1	ug/L	3	10/21/2020 9:12 PM	004 DG6M1/2
Aldicarb sulfone	<0.80		1	ug/L	2	10/21/2020 9:12 PM	004 DG6M1/2
Aldicarb sulfoxide	<0.50		1	ug/L	4	10/21/2020 9:12 PM	004 DG6M1/2
Carbaryl	<1.0		1	ug/L	50	10/21/2020 9:12 PM	004 DG6M1/2
Carbofuran	<0.90		1	ug/L	40	10/21/2020 9:12 PM	004 DG6M1/2
Methomyl	<1.0		1	ug/L	50	10/21/2020 9:12 PM	004 DG6M1/2
Oxamyl	<1.0		1	ug/L	50	10/21/2020 9:12 PM	004 DG6M1/2

Analytical Method:EPA 547

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Glyphosate	<6.0		1	ug/L	50	10/22/2020 12:34	004 DG6T1/1

Analytical Method:EPA 549.2

Prep Method: EPA 549.2

Prep Date: 10/19/2020 10:33

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Diquat	<0.40		1	ug/L	20	10/20/2020 11:50	004 AP1S1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 10/28/2020



Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Repeat

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946
Attn To : Supt. McCuen

Lab No. : 70149521005
Client Sample ID.: S-108066

Federal ID : 5103704
 Collected : 10/14/2020 06:25 AM Point S-108066
 Received : 10/14/2020 04:34 PM Location Well #4-2
 Collected By CLIENT

Analytical Method: EPA 531.1

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
3-Hydroxycarbofuran	<1.0		1	ug/L	50	10/21/2020 10:01	005 DG6M1/2
Aldicarb	<0.50		1	ug/L	3	10/21/2020 10:01	005 DG6M1/2
Aldicarb sulfone	<0.80		1	ug/L	2	10/21/2020 10:01	005 DG6M1/2
Aldicarb sulfoxide	<0.50		1	ug/L	4	10/21/2020 10:01	005 DG6M1/2
Carbaryl	<1.0		1	ug/L	50	10/21/2020 10:01	005 DG6M1/2
Carbofuran	<0.90		1	ug/L	40	10/21/2020 10:01	005 DG6M1/2
Methomyl	<1.0		1	ug/L	50	10/21/2020 10:01	005 DG6M1/2
Oxamyl	<1.0		1	ug/L	50	10/21/2020 10:01	005 DG6M1/2

Analytical Method: EPA 547

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Glyphosate	<6.0		1	ug/L	50	10/22/2020 12:50	005 DG9T1/1

Analytical Method: EPA 549.2

Prep Method: EPA 549.2

Prep Date: 10/19/2020 10:33

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Diquat	<0.40		1	ug/L	20	10/20/2020 11:58	005 AP1S1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 10/28/2020

WorkOrder :
 70149521

Laboratory Certifications

Pace Analytical Services Ormond Beach

8 East Tower Circle, Ormond Beach, FL 32174
 Alaska DEC- CS/UST/LUST
 Alabama Certification #: 41320
 Arizona Certification# AZ0819
 Colorado Certification: FL NELAC Reciprocity
 Connecticut Certification #: PH-0216
 Delaware Certification: FL NELAC Reciprocity
 Florida Certification #: E83079
 Georgia Certification #: 955
 Guam Certification: FL NELAC Reciprocity
 Hawaii Certification: FL NELAC Reciprocity
 Illinois Certification #: 200068
 Indiana Certification: FL NELAC Reciprocity
 Kansas Certification #: E-10383
 Kentucky Certification #: 90050
 Louisiana Certification #: FL NELAC Reciprocity
 Louisiana Environmental Certificate #: 05007
 Maryland Certification: #346
 Michigan Certification #: 9911
 Mississippi Certification: FL NELAC Reciprocity
 Missouri Certification #: 236
 Montana Certification #: Cert 0074
 Nebraska Certification: NE-OS-28-14
 New Hampshire Certification #: 2958
 New Jersey Certification #: FL022
 New York Certification #: 11608
 North Carolina Environmental Certificate #: 667
 North Carolina Certification #: 12710
 North Dakota Certification #: R-216
 Ohio DEP 87780
 Oklahoma Certification #: D9947
 Pennsylvania Certification #: 68-00547
 Puerto Rico Certification #: FL01264
 South Carolina Certification: #96042001
 Tennessee Certification #: TN02974
 Texas Certification: FL NELAC Reciprocity
 US Virgin Islands Certification: FL NELAC Reciprocity
 Virginia Environmental Certification #: 460165
 West Virginia Certification #: 9962C
 Wisconsin Certification #: 399079670
 Wyoming (EPA Region 8): FL NELAC Reciprocity

Pace Analytical Services Long Island

All parameters are reported to meet the NYS ELAP required detection limits (RDL) for drinking water analyses. For the analytes listed below, the reporting limit is below the laboratory verified limit of quantification (LOQ) but greater than the method detection limit (MDL); values are estimated.

Method	Method	Unit	MDL*	RDL	LOQ
505	Toxaphene	ug/L	0.57	1	2.5
505	Chlordane	ug/L	0.096	0.2	0.5
525.2	Simazine	ug/L	0.031	0.07	0.1
525.2	Benzo(a)pyrene	ug/L	0.017	0.02	0.1
549.2	Diquat	ug/L	0.165	0.4	1

* Determined annually; subject to change but must always be below the RDL and LOQ.

WorkOrder :
 70149521

Laboratory Certifications

Pace Analytical Services Long Island

575 Broad Hollow Rd, Melville, NY 11747
 New York Certification #: 10478 Primary Accrediting Body
 New Jersey Certification #: NY158
 Pennsylvania Certification #: 68-00350
 Connecticut Certification #: PH-0435
 Maryland Certification #: 208
 Rhode Island Certification #: LAO00340
 Massachusetts Certification #: M-NY026
 New Hampshire Certification #: 2987

All parameters are reported to meet the NYS ELAP required detection limits (RDL) for drinking water analyses. For the analytes listed below, the reporting limit is below the laboratory verified limit of quantification (LOQ) but greater than the method detection limit (MDL); values are estimated.

Method	Method	Unit	MDL*	RDL	LOQ
505	Toxaphene	ug/L	0.57	1	2.5
505	Chlordane	ug/L	0.096	0.2	0.5
525.2	Simazine	ug/L	0.031	0.07	0.1
525.2	Benzo(a)pyrene	ug/L	0.017	0.02	0.1
549.2	Diquat	ug/L	0.165	0.4	1

* Determined annually; subject to change but must always be below the RDL and LOQ.

Duro Analytical
WO# : 70149521

 70149521

Client info:
 Name or Code: HAMPTON BAYS WATER DISTRICT
 Address: PO BOX 1013
HAMPTON BAYS, NEW YORK 11946
(631) 728-0179
 Phone #: _____
 Attn: _____
 Proj. # or (Name): _____
 Bill To: _____
 Copies To: _____

Sample Info:

Date/Time Collected:	Sample Type	Location	Origin	Treatment Type	Purpose	Field Readings Cl ₂ pH/Temp	Analysis	Lab No.
6:55 10-14-20	GW	WELL 3-1	RW	-	RE		SOC - 549, 547	001
6:45 10-14-20	GW	WELL 3-2	RW	-	RE		SOC - 549 - 547	002
7:02 10-14-20	GW	WELL 3-3	RW	-	RE		SOC - 549 - 547	003
6:20 10-14-20	GW	WELL 4-1	RW	-	RE		SOC - 549, 547	004
6:25 10-14-20	GW	WELL 4-2	RW	-	RE		SOC - 549, 547	005
Remarks:								

**Sample Request Form
 PUBLIC WATER SUPPLIER**

Date: 10-14-20
 Collected By: JW Booth
 Accepted By: JW Booth 13:41 10/14/20
 Cooler Temp: 7.4 °C

Del. by: [Signature] 16:34 10/14/20
 WELL OFF LINE 3-3, 4-2
Blow Off
 WELL RUN TO SYSTEM

Sample Types	Purpose	Origin	Treatment Types
PW - Potable Water	RO - Routine	D - Distribution	AST - Air Stripper
GW - Groundwater	RE - Resample	RW - Raw Well	GAC - Granular Activated Charcoal
SW - Surface Water	S - Special	TW - Treated Well	N - Nitrate Removal Plant
WW - Waste Water		T - Tank	FE - Iron Removal Plant
AQ - Aqueous		MW - Monitoring Well	O - Other
S - Soil		I - Influent	
		E - Effluent	

YES NO VOC'S PRESERVED WITH HCl



Sample Condition Upon Receipt

WO#: 70149521
PM: KMM **Due Date: 10/28/20**
CLIENT: HBW

Client Name: Hampton Bay WV

Courier: Fed Ex UPS USPS Client Commercial Pace Other

Tracking #: _____
 Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No
 Packing Material: Bubble Wrap Bubble Bags Ziploc None Other
 Thermometer Used: TH091 ✓ Correction Factor: -0.2
 Cooler Temperature (°C): 7.4 Cooler Temperature Corrected (°C): 7.2

Temperature Blank Present: Yes No
 Type of Ice: Wet Blue None
 Samples on ice, cooling process has begun
 Date/Time 5035A kits placed in freezer ✓

Temp should be above freezing to 6.0°C
 USDA Regulated Soil (N/A, water sample)

Date and Initials of person examining contents: 10/14/20 E11

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? YES NO

Did samples originate from a foreign source (internationally, including Hawaii and Puerto Rico)? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

				COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		5.
Short Hold Time Analysis (<72hr):	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No		6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No		7.
Sufficient Volume: (Triple volume provided for MS/MSD):	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		
Containers Intact:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		10.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No		12. <u>Bottles given for 531 analysis; not noted on COCs</u>
-Includes date/time/ID/Analysis Matrix SL WT OIL				
All containers needing preservation have been checked	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot #				Sample #
All containers needing preservation are found to be in compliance with EPA recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH > 9 Sulfide, NAOH > 12 Cyanide)	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	Initial when completed: _____ Lot # of added preservative: _____ Date/Time preservative added: _____
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis				
Samples checked for dechlorination:	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
KI starch test strips Lot #				
Residual chlorine strips Lot #				
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	15.
Trip Blank Present:	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	16.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable): _____				

Client Notification/ Resolution: _____ Field Data Required? Y / N
 Person Contacted: _____ Date/Time: _____
 Comments/ Resolution: _____