



# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

### Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

Hampton Bays Water District  
 P.O. Box 1013  
 Hampton Bays, NY 11946

Lab No. : 70162147001  
 Client Sample ID.: S-50970

Attn To : Supt. McCuen  
 Federal ID : 5103704  
 Collected : 02/10/2021 08:40 AM Point S-50970  
 Received : 02/10/2021 05:00 PM Location Well #2-1  
 Collected By CLIENT

Analytical Method:EPA 522		Prep Method: EPA 522			Prep Date: 02/17/2021 12:38		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,4-Dioxane (p-Dioxane)	0.056		1	ug/L	1	02/17/2021 11:26	001 AG2R1/2
Surr: 1,4-Dioxane-d8 (S)	109%		1	%REC		02/17/2021 11:26	001 AG2R1/2

Analytical Method:EPA 537.1		Prep Method: EPA 537.1			Prep Date: 02/17/2021 7:17 AM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Perfluorobutanesulfonic acid	<1.9		1	ng/L		02/23/2021 12:46	001 BP3T1/2
Perfluoroheptanoic acid	<1.9		1	ng/L		02/23/2021 12:46	001 BP3T1/2
Perfluorohexanesulfonic acid	<1.9		1	ng/L		02/23/2021 12:46	001 BP3T1/2
Perfluorononanoic acid	<1.9		1	ng/L		02/23/2021 12:46	001 BP3T1/2
Perfluorooctanesulfonic acid	<1.9		1	ng/L	10	02/23/2021 12:46	001 BP3T1/2
Perfluorooctanoic acid	<1.9		1	ng/L	10	02/23/2021 12:46	001 BP3T1/2
Surr: 13C2-PFDA (S)	102%		1	%REC		02/23/2021 12:46	001 BP3T1/2
Surr: 13C2-PFHxA (S)	111%		1	%REC		02/23/2021 12:46	001 BP3T1/2
Surr: HFPO-DAS (S)	86%		1	%REC		02/23/2021 12:46	001 BP3T1/2

Analytical Method:SM22 9223B Colilert		Prep Method: SM22 9223B Colilert			Prep Date: 02/10/2021 6:12 PM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	02/11/2021 12:15	001 SP5T1/1
Total Coliforms	Absent		1		Absent	02/11/2021 12:15	001 SP5T1/1

**Qualifiers:**

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 02/23/2021



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
 www.pacelabs.com

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

### Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

Hampton Bays Water District  
 P.O. Box 1013  
 Hampton Bays, NY 11946

Lab No. : 70162147002  
 Client Sample ID.: S-74071

Attn To : Supt. McCuen  
 Federal ID : 5103704  
 Collected : 02/10/2021 09:00 AM Point S-74071  
 Received : 02/10/2021 05:00 PM Location Well #2-2  
 Collected By CLIENT

Analytical Method: EPA 522		Prep Method: EPA 522			Prep Date: 02/17/2021 12:38		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,4-Dioxane (p-Dioxane)	0.078		1	ug/L	1	02/17/2021 11:46	002 AG2R1/2
Surr: 1,4-Dioxane-d8 (S)	106%		1	%REC		02/17/2021 11:46	002 AG2R1/2

Analytical Method: EPA 537.1		Prep Method: EPA 537.1			Prep Date: 02/17/2021 7:17 AM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Perfluorobutanesulfonic acid	<1.9		1	ng/L		02/23/2021 1:04 AM	002 BP3T1/2
Perfluoroheptanoic acid	<1.9		1	ng/L		02/23/2021 1:04 AM	002 BP3T1/2
Perfluorohexanesulfonic acid	<1.9		1	ng/L		02/23/2021 1:04 AM	002 BP3T1/2
Perfluorononanoic acid	<1.9		1	ng/L		02/23/2021 1:04 AM	002 BP3T1/2
Perfluorooctanesulfonic acid	<1.9		1	ng/L	10	02/23/2021 1:04 AM	002 BP3T1/2
Perfluorooctanoic acid	<1.9		1	ng/L	10	02/23/2021 1:04 AM	002 BP3T1/2
Surr: 13C2-PFDA (S)	101%		1	%REC		02/23/2021 1:04 AM	002 BP3T1/2
Surr: 13C2-PFHxA (S)	112%		1	%REC		02/23/2021 1:04 AM	002 BP3T1/2
Surr: HFPO-DAS (S)	94%		1	%REC		02/23/2021 1:04 AM	002 BP3T1/2

Analytical Method: SM22 9223B Colilert		Prep Method: SM22 9223B Colilert			Prep Date: 02/10/2021 6:12 PM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	02/11/2021 12:15	002 SP5T1/1
Total Coliforms	Absent		1		Absent	02/11/2021 12:15	002 SP5T1/1

### Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 02/23/2021



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
 www.pacelabs.com

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

### Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

Hampton Bays Water District  
 P.O. Box 1013  
 Hampton Bays, NY 11946

Lab No. : 70162147003  
 Client Sample ID.: S-127163

Attn To : Supt. McCuen  
 Federal ID : 5103704  
 Collected : 02/10/2021 08:10 AM Point S-127163  
 Received : 02/10/2021 05:00 PM Location Well #5-1  
 Collected By CLIENT

Analytical Method:EPA 522		Prep Method: EPA 522			Prep Date: 02/17/2021 12:38		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,4-Dioxane (p-Dioxane)	0.023		1	ug/L	1	02/18/2021 12:23	003 AG2R1/2
Surr: 1,4-Dioxane-d8 (S)	105%		1	%REC		02/18/2021 12:23	003 AG2R1/2

Analytical Method:EPA 537.1		Prep Method: EPA 537.1			Prep Date: 02/17/2021 7:17 AM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Perfluorobutanesulfonic acid	<1.9		1	ng/L		02/22/2021 10:55	003 BP3T1/2
Perfluoroheptanoic acid	<1.9		1	ng/L		02/22/2021 10:55	003 BP3T1/2
Perfluorohexanesulfonic acid	<1.9		1	ng/L		02/22/2021 10:55	003 BP3T1/2
Perfluorononanoic acid	<1.9		1	ng/L		02/22/2021 10:55	003 BP3T1/2
Perfluorooctanesulfonic acid	4.5		1	ng/L	10	02/22/2021 10:55	003 BP3T1/2
Perfluorooctanoic acid	<1.9		1	ng/L	10	02/22/2021 10:55	003 BP3T1/2
Surr: 13C2-PFDA (S)	108%		1	%REC		02/22/2021 10:55	003 BP3T1/2
Surr: 13C2-PFHxA (S)	109%		1	%REC		02/22/2021 10:55	003 BP3T1/2
Surr: HFPO-DAS (S)	93%		1	%REC		02/22/2021 10:55	003 BP3T1/2

Analytical Method:SM22 9223B Colilert		Prep Method: SM22 9223B Colilert			Prep Date: 02/10/2021 6:12 PM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	02/11/2021 12:15	003 SP5T1/1
Total Coliforms	Absent		1		Absent	02/11/2021 12:15	003 SP5T1/1

**Qualifiers:**

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 02/23/2021



# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

### Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

Hampton Bays Water District  
 P.O. Box 1013  
 Hampton Bays, NY 11946

Lab No. : 70162147004  
 Client Sample ID.: S-58351

Attn To : Supt. McCuen  
 Federal ID : 5103704  
 Collected : 02/10/2021 09:15 AM Point S-58351  
 Received : 02/10/2021 05:00 PM Location Well #3-2  
 Collected By CLIENT

Sample Comments:  
 RUN TO WASTE

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Perfluorobutanesulfonic acid	<1.8		1	ng/L		02/23/2021 1:23 AM	004 BP3T1/2
Perfluoroheptanoic acid	2.3		1	ng/L		02/23/2021 1:23 AM	004 BP3T1/2
Perfluorohexanesulfonic acid	6.9		1	ng/L		02/23/2021 1:23 AM	004 BP3T1/2
Perfluorononanoic acid	17.7		1	ng/L		02/23/2021 1:23 AM	004 BP3T1/2
Perfluorooctanesulfonic acid	9.2		1	ng/L	10	02/23/2021 1:23 AM	004 BP3T1/2
Perfluorooctanoic acid	2.9		1	ng/L	10	02/23/2021 1:23 AM	004 BP3T1/2
Surr: 13C2-PFDA (S)	100%		1	%REC		02/23/2021 1:23 AM	004 BP3T1/2
Surr: 13C2-PFHxA (S)	109%		1	%REC		02/23/2021 1:23 AM	004 BP3T1/2
Surr: HFPO-DAS (S)	93%		1	%REC		02/23/2021 1:23 AM	004 BP3T1/2

### Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 02/23/2021



# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

### Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

Hampton Bays Water District  
 P.O. Box 1013  
 Hampton Bays, NY 11946

Lab No. : 70162147005  
 Client Sample ID.: S-58352

Attn To : Supt. McCuen  
 Federal ID : 5103704  
 Collected : 02/10/2021 09:35 AM Point S-58352  
 Received : 02/10/2021 05:00 PM Location Well #3-3  
 Collected By CLIENT

**Sample Comments:**  
 RUN TO WASTE

Analytical Method: EPA 537.1		Prep Method: EPA 537.1			Prep Date: 02/17/2021 7:17 AM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Perfluorobutanesulfonic acid	3.6		1	ng/L		02/23/2021 1:41 AM	005 BP3T1/2
Perfluoroheptanoic acid	<1.9		1	ng/L		02/23/2021 1:41 AM	005 BP3T1/2
Perfluorohexanesulfonic acid	<1.9		1	ng/L		02/23/2021 1:41 AM	005 BP3T1/2
Perfluorononanoic acid	7.0		1	ng/L		02/23/2021 1:41 AM	005 BP3T1/2
Perfluorooctanesulfonic acid	<1.9		1	ng/L	10	02/23/2021 1:41 AM	005 BP3T1/2
Perfluorooctanoic acid	<1.9		1	ng/L	10	02/23/2021 1:41 AM	005 BP3T1/2
Surr: 13C2-PFDA (S)	102%		1	%REC		02/23/2021 1:41 AM	005 BP3T1/2
Surr: 13C2-PFHxA (S)	104%		1	%REC		02/23/2021 1:41 AM	005 BP3T1/2
Surr: HFPO-DAS (S)	83%		1	%REC		02/23/2021 1:41 AM	005 BP3T1/2

**Qualifiers:**

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 02/23/2021

**WorkOrder :**  
70162147

## Laboratory Certifications

---

### **Pace Analytical Services Ormond Beach**

8 East Tower Circle, Ormond Beach, FL 32174  
Alaska DEC- CS/UST/LUST  
Alabama Certification #: 41320  
Arizona Certification# AZ0819  
Colorado Certification: FL NELAC Reciprocity  
Connecticut Certification #: PH-0216  
Delaware Certification: FL NELAC Reciprocity  
Florida Certification #: E83079  
Georgia Certification #: 955  
Guam Certification: FL NELAC Reciprocity  
Hawaii Certification: FL NELAC Reciprocity  
Illinois Certification #: 200068  
Indiana Certification: FL NELAC Reciprocity  
Kansas Certification #: E-10383  
Kentucky Certification #: 90050  
Louisiana Certification #: FL NELAC Reciprocity  
Louisiana Environmental Certificate #: 05007  
Maryland Certification: #346  
Michigan Certification #: 9911  
Mississippi Certification: FL NELAC Reciprocity  
Missouri Certification #: 236  
Montana Certification #: Cert 0074  
Nebraska Certification: NE-OS-28-14  
New Hampshire Certification #: 2958  
New Jersey Certification #: FL022  
New York Certification #: 11608  
North Carolina Environmental Certificate #: 667  
North Carolina Certification #: 12710  
North Dakota Certification #: R-216  
Ohio DEP 87780  
Oklahoma Certification #: D9947  
Pennsylvania Certification #: 68-00547  
Puerto Rico Certification #: FL01264  
South Carolina Certification: #96042001  
Tennessee Certification #: TN02974  
Texas Certification: FL NELAC Reciprocity  
US Virgin Islands Certification: FL NELAC Reciprocity  
Virginia Environmental Certification #: 460165  
West Virginia Certification #: 9962C  
Wisconsin Certification #: 399079670  
Wyoming (EPA Region 8): FL NELAC Reciprocity

### **Pace Analytical Services Long Island**

**WorkOrder :**  
70162147

## Laboratory Certifications

---

**Pace Analytical Services Long Island**

Delaware Certification # NY10478  
Virginia Certification # 460302  
575 Broad Hollow Rd, Melville, NY 11747  
New York Certification #: 10478 Primary Accrediting Body  
New Jersey Certification #: NY158  
Pennsylvania Certification #: 68-00350  
Connecticut Certification #: PH-0435  
Maryland Certification #: 208  
Rhode Island Certification #: LAO00340  
Massachusetts Certification #: M-NY026  
New Hampshire Certification #: 2987

# Sample Request Form PUBLIC WATER SUPPLIER

WO#: 70162147



70162147

Date: 2-10-21

Collected By: W Booth

Accepted By: [Signature]

Cooler Temp: 3.7 °C

WELL OFF LINE 3-1, 3-2, 3-3

WELL RUN TO SYSTEM

YES  NO VOC'S PRESERVED WITH HCl

**Client Info:**

Name or Code: HAMPTON BAYS WATER DISTRICT  
 Address: PO BOX 1013  
 HAMPTON BAYS, NEW YORK 11946  
 (631) 728-0179  
 Phone #: \_\_\_\_\_  
 Attn: \_\_\_\_\_  
 Proj. # or (Name): \_\_\_\_\_  
 Bill To: \_\_\_\_\_  
 Copies To: \_\_\_\_\_

Sample Types	Purpose	Origin	Treatment Types
PW - Potable Water	RO - Routine	D - Distribution	AST - Air Stripper
GW - Groundwater	RE - Resample	RW - Raw Well	GAC - Granular Activated Charcoal
SW - Surface Water	S - Special	TW - Treated Well	N - Nitrate Removal Plant
WW - Waste Water		T - Tank	FE - Iron Removal Plant
AQ - Aqueous		MW - Monitoring Well	O - Other
S - Soil		I - Influent	
		E - Effluent	

**Sample Info:**

Date/Time Collected:	Sample Type	Location	Origin	Treatment Type	Purpose	Field Readings Cl <sub>2</sub> pH/Temp	Analysis	Lab No.
8:40 2-10-21	GW	Well 2-1	RW	-	RO		BACT, PFC, 1-4, DIOX	
9:00 2-10-21	GW	Well 2-2	RW	-	RO		BACT, PFC, 1-4 DIOX	
8:10 2-10-21	GW	Well 5-1	RW	-	RO		BACT, PFC, 1-4 DIOX	
9:15 2-10-21	GW	Well 3-2	RW	-	RO		PFC	
9:35 2-10-21	GW	Well 3-3	RW	-	RO		PFC	

Remarks: Wells 3-2 + 3-3 Run to Waste.



Sample Condition Upon Receipt

WO#: 70162147

Client Name: HBW

Project **PM: KMM** Due Date: **02/19/21**  
**CLIENT: HBW**

Courier:  Fed Ex  UPS  USPS  Client  Commercial  Pace  Other

Tracking #: \_\_\_\_\_

Custody Seal on Cooler/Box Present:  Yes  No Seals intact:  Yes  No

Packing Material:  Bubble Wrap  Bubble Bags  Ziploc  None  Other

Thermometer Used: TH091 Correction Factor: -0.2

Cooler Temperature(°C): 3.7 Cooler Temperature Corrected(°C): 3.5

Temp should be above freezing to 6.0°C

USDA Regulated Soil (  N/A, water sample)

Temperature Blank Present:  Yes  No

Type of Ice:  Wet  Blue  None

Samples on ice, cooling process has begun

Date/Time 5035A kits placed in freezer \_\_\_\_\_

Date and Initials of person examining contents: Ad 2/10/21

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)?  Yes  No

Did samples originate from a foreign source including Hawaii and Puerto Rico)?  Yes  No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

		COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished:	<input type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr):	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used:	<input type="checkbox"/> Yes <input type="checkbox"/> No	10.
Containers Intact:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID, Matrix: SL <u>WT</u> OIL		
All containers needing preservation have been checked?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	13. <input type="checkbox"/> HNO <sub>3</sub> <input type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot #		Sample #
All containers needing preservation are found to be in compliance with method recommendation?		
(HNO <sub>3</sub> , H <sub>2</sub> SO <sub>4</sub> , HCl, NaOH>9 Sulfide, NAOH>12 Cyanide)	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water).		
Per Method, VOA pH is checked after analysis		Initial when completed: Lot # of added preservative: Date/Time preservative added:
Samples checked for dechlorination:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
KI starch test strips Lot #		
Residual chlorine strips Lot #		
SM 4500 CN samples checked for sulfide?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15.
Lead Acetate Strips Lot #		
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Trip Blank Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	17.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable): _____		

Client Notification/ Resolution: \_\_\_\_\_

Field Data Required? Y / N

Person Contacted: \_\_\_\_\_

Date/Time: \_\_\_\_\_

Comments/ Resolution: \_\_\_\_\_