



Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70183738001
Client Sample ID.: S-15687

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 08/11/2021 07:25 AM Point S-15687
 Received : 08/11/2021 04:40 PM Location Well #1-1
 Collected By CLIENT

Analytical Method:EPA 200.7

| <u>Parameter(s)</u> | <u>Results</u> | <u>Qualifier</u> | <u>D.F.</u> | <u>Units</u> | <u>Limit</u> | <u>Analyzed:</u> | <u>Container:</u> |
|---------------------|----------------|------------------|-------------|--------------|--------------|------------------|-------------------|
| Iron | 0.029 | | 1 | mg/L | 0.3 | 08/16/2021 10:53 | 001 BP4N1/1 |
| Manganese | <0.010 | | 1 | mg/L | 0.3 | 08/16/2021 10:53 | 001 BP4N1/1 |

Analytical Method:EPA 353.2

| <u>Parameter(s)</u> | <u>Results</u> | <u>Qualifier</u> | <u>D.F.</u> | <u>Units</u> | <u>Limit</u> | <u>Analyzed:</u> | <u>Container:</u> |
|------------------------|----------------|------------------|-------------|--------------|--------------|--------------------|-------------------|
| Nitrate as N | 4.0 | | 5 | mg/L | 10 | 08/12/2021 2:03 AM | 001 BP4U1/1 |
| Nitrate-Nitrite (as N) | 4.0 | | 5 | mg/L | | 08/12/2021 2:03 AM | 001 BP4U1/1 |

Analytical Method:EPA 353.2

| <u>Parameter(s)</u> | <u>Results</u> | <u>Qualifier</u> | <u>D.F.</u> | <u>Units</u> | <u>Limit</u> | <u>Analyzed:</u> | <u>Container:</u> |
|---------------------|----------------|------------------|-------------|--------------|--------------|------------------|-------------------|
| Nitrite as N | <0.050 | | 1 | mg/L | 1 | 08/12/2021 12:03 | 001 BP4U1/1 |

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 08/17/2021



Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70183738002
Client Sample ID.: S-24848

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 08/11/2021 07:20 AM Point S-24848
 Received : 08/11/2021 04:40 PM Location Well #1-2
 Collected By CLIENT

Analytical Method:EPA 200.7

| <u>Parameter(s)</u> | <u>Results</u> | <u>Qualifier</u> | <u>D.F.</u> | <u>Units</u> | <u>Limit</u> | <u>Analyzed:</u> | <u>Container:</u> |
|---------------------|----------------|------------------|-------------|--------------|--------------|------------------|-------------------|
| Iron | 0.068 | | 1 | mg/L | 0.3 | 08/16/2021 10:55 | 002 BP4N1/1 |
| Manganese | 0.014 | | 1 | mg/L | 0.3 | 08/16/2021 10:55 | 002 BP4N1/1 |

Analytical Method:EPA 353.2

| <u>Parameter(s)</u> | <u>Results</u> | <u>Qualifier</u> | <u>D.F.</u> | <u>Units</u> | <u>Limit</u> | <u>Analyzed:</u> | <u>Container:</u> |
|------------------------|----------------|------------------|-------------|--------------|--------------|--------------------|-------------------|
| Nitrate as N | 8.4 | | 5 | mg/L | 10 | 08/12/2021 2:08 AM | 002 BP4U1/1 |
| Nitrate-Nitrite (as N) | 8.4 | | 5 | mg/L | | 08/12/2021 2:08 AM | 002 BP4U1/1 |

Analytical Method:EPA 353.2

| <u>Parameter(s)</u> | <u>Results</u> | <u>Qualifier</u> | <u>D.F.</u> | <u>Units</u> | <u>Limit</u> | <u>Analyzed:</u> | <u>Container:</u> |
|---------------------|----------------|------------------|-------------|--------------|--------------|------------------|-------------------|
| Nitrite as N | <0.050 | | 1 | mg/L | 1 | 08/12/2021 12:07 | 002 BP4U1/1 |

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 08/17/2021



Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70183738003
Client Sample ID.: S-31636

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 08/11/2021 06:50 AM Point S-31636
 Received : 08/11/2021 04:40 PM Location Well #1-3
 Collected By CLIENT

Analytical Method:EPA 200.7

| <u>Parameter(s)</u> | <u>Results</u> | <u>Qualifier</u> | <u>D.F.</u> | <u>Units</u> | <u>Limit</u> | <u>Analyzed:</u> | <u>Container:</u> |
|---------------------|----------------|------------------|-------------|--------------|--------------|------------------|-------------------|
| Iron | <0.020 | | 1 | mg/L | 0.3 | 08/16/2021 10:56 | 003 BP4N1/1 |
| Manganese | 0.013 | | 1 | mg/L | 0.3 | 08/16/2021 10:56 | 003 BP4N1/1 |

Analytical Method:EPA 353.2

| <u>Parameter(s)</u> | <u>Results</u> | <u>Qualifier</u> | <u>D.F.</u> | <u>Units</u> | <u>Limit</u> | <u>Analyzed:</u> | <u>Container:</u> |
|------------------------|----------------|------------------|-------------|--------------|--------------|--------------------|-------------------|
| Nitrate as N | 4.3 | | 5 | mg/L | 10 | 08/12/2021 2:09 AM | 003 BP4U1/1 |
| Nitrate-Nitrite (as N) | 4.3 | | 5 | mg/L | | 08/12/2021 2:09 AM | 003 BP4U1/1 |

Analytical Method:EPA 353.2

| <u>Parameter(s)</u> | <u>Results</u> | <u>Qualifier</u> | <u>D.F.</u> | <u>Units</u> | <u>Limit</u> | <u>Analyzed:</u> | <u>Container:</u> |
|---------------------|----------------|------------------|-------------|--------------|--------------|------------------|-------------------|
| Nitrite as N | <0.050 | | 1 | mg/L | 1 | 08/12/2021 12:08 | 003 BP4U1/1 |

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 08/17/2021



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70183738004
Client Sample ID.: S-108065

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 08/11/2021 06:05 AM Point S-108065
 Received : 08/11/2021 04:40 PM Location Well #4-1
 Collected By CLIENT

Analytical Method:EPA 200.7

| <u>Parameter(s)</u> | <u>Results</u> | <u>Qualifier</u> | <u>D.F.</u> | <u>Units</u> | <u>Limit</u> | <u>Analyzed:</u> | <u>Container:</u> |
|---------------------|----------------|------------------|-------------|--------------|--------------|------------------|-------------------|
| Iron | 0.65* | | 1 | mg/L | 0.3 | 08/16/2021 10:58 | 004 BP4N1/1 |
| Manganese | 0.11 | | 1 | mg/L | 0.3 | 08/16/2021 10:58 | 004 BP4N1/1 |

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 08/17/2021



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
 P.O. Box 1013
 Hampton Bays, NY 11946

Lab No. : 70183738005
 Client Sample ID.: S-108066

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 08/11/2021 06:15 AM Point S-108066
 Received : 08/11/2021 04:40 PM Location Well #4-2
 Collected By CLIENT

Analytical Method:EPA 200.7

| Parameter(s) | Results | Qualifier | D.F. | Units | Limit | Analyzed: | Container: |
|--------------|---------|-----------|------|-------|-------|------------------|-------------|
| Iron | 0.97* | | 1 | mg/L | 0.3 | 08/16/2021 11:00 | 005 BP4N1/1 |
| Manganese | 0.12 | | 1 | mg/L | 0.3 | 08/16/2021 11:00 | 005 BP4N1/1 |

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 08/17/2021



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70183738006
Client Sample ID.: S-127163

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 08/11/2021 05:15 AM Point S-127163
 Received : 08/11/2021 04:40 PM Location Well #5-1
 Collected By CLIENT

Analytical Method:EPA 200.7

| <u>Parameter(s)</u> | <u>Results</u> | <u>Qualifier</u> | <u>D.F.</u> | <u>Units</u> | <u>Limit</u> | <u>Analyzed:</u> | <u>Container:</u> |
|---------------------|----------------|------------------|-------------|--------------|--------------|------------------|-------------------|
| Iron | <0.020 | | 1 | mg/L | 0.3 | 08/16/2021 11:05 | 006 BP4N1/1 |
| Manganese | 0.010 | | 1 | mg/L | 0.3 | 08/16/2021 11:05 | 006 BP4N1/1 |

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 08/17/2021



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70183738007
Client Sample ID.: BLEND INF GAC MAIN PLANT

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 08/11/2021 07:00 AM Point BLEND INF
 Received : 08/11/2021 04:40 PM Location MAIN PLANT
 Collected By CLIENT

Analytical Method:EPA 200.7

| Parameter(s) | Results | Qualifier | D.F. | Units | Limit | Analyzed: | Container: |
|--------------|---------|-----------|------|-------|-------|------------------|-------------|
| Iron | <0.020 | | 1 | mg/L | 0.3 | 08/16/2021 11:07 | 007 BP4N1/1 |
| Manganese | 0.014 | | 1 | mg/L | 0.3 | 08/16/2021 11:07 | 007 BP4N1/1 |

Analytical Method:EPA 353.2

| Parameter(s) | Results | Qualifier | D.F. | Units | Limit | Analyzed: | Container: |
|------------------------|---------|-----------|------|-------|-------|--------------------|-------------|
| Nitrate as N | 4.2 | | 5 | mg/L | 10 | 08/12/2021 2:10 AM | 007 BP4U1/1 |
| Nitrate-Nitrite (as N) | 4.2 | | 5 | mg/L | | 08/12/2021 2:10 AM | 007 BP4U1/1 |

Analytical Method:EPA 353.2

| Parameter(s) | Results | Qualifier | D.F. | Units | Limit | Analyzed: | Container: |
|--------------|---------|-----------|------|-------|-------|------------------|-------------|
| Nitrite as N | <0.050 | | 1 | mg/L | 1 | 08/12/2021 12:09 | 007 BP4U1/1 |

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 08/17/2021



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
 www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
 P.O. Box 1013
 Hampton Bays, NY 11946

Lab No. : 70183738008
 Client Sample ID.: BLEND EFF GAC MAIN PLANT

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 08/11/2021 07:07 AM Point BLEND EFF
 Received : 08/11/2021 04:40 PM Location MAIN PLANT
 Collected By CLIENT

Analytical Method:EPA 200.7

| Parameter(s) | Results | Qualifier | D.F. | Units | Limit | Analyzed: | Container: |
|--------------|---------|-----------|------|-------|-------|------------------|-------------|
| Iron | <0.020 | | 1 | mg/L | 0.3 | 08/16/2021 11:09 | 008 BP4N1/1 |
| Manganese | <0.010 | | 1 | mg/L | 0.3 | 08/16/2021 11:09 | 008 BP4N1/1 |

Analytical Method:EPA 353.2

| Parameter(s) | Results | Qualifier | D.F. | Units | Limit | Analyzed: | Container: |
|------------------------|---------|-----------|------|-------|-------|--------------------|-------------|
| Nitrate as N | 4.2 | | 5 | mg/L | 10 | 08/12/2021 2:11 AM | 008 BP4U1/1 |
| Nitrate-Nitrite (as N) | 4.2 | | 5 | mg/L | | 08/12/2021 2:11 AM | 008 BP4U1/1 |

Analytical Method:EPA 353.2

| Parameter(s) | Results | Qualifier | D.F. | Units | Limit | Analyzed: | Container: |
|--------------|---------|-----------|------|-------|-------|------------------|-------------|
| Nitrite as N | <0.050 | | 1 | mg/L | 1 | 08/12/2021 12:10 | 008 BP4U1/1 |

Analytical Method:SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 08/11/2021 6:00 PM

| Parameter(s) | Results | Qualifier | D.F. | Units | Limit | Analyzed: | Container: |
|-----------------|---------|-----------|------|-------|--------|------------------|-------------|
| E.coli | Absent | | 1 | | Absent | 08/12/2021 12:00 | 008 SP5T1/1 |
| Total Coliforms | Absent | | 1 | | Absent | 08/12/2021 12:00 | 008 SP5T1/1 |

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 08/17/2021



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Distribution
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70183738009
Client Sample ID.: BLEND EFF PLANT #4

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 08/11/2021 06:07 AM Point PLANT 4 BLEND
 Received : 08/11/2021 04:40 PM Location PLANT 4
 Collected By CLIENT

Analytical Method:EPA 200.7

| <u>Parameter(s)</u> | <u>Results</u> | <u>Qualifier</u> | <u>D.F.</u> | <u>Units</u> | <u>Limit</u> | <u>Analyzed:</u> | <u>Container:</u> |
|---------------------|----------------|------------------|-------------|--------------|--------------|------------------|-------------------|
| Iron | 0.75* | | 1 | mg/L | 0.3 | 08/16/2021 11:11 | 009 BP4N1/1 |
| Manganese | 0.11 | | 1 | mg/L | 0.3 | 08/16/2021 11:11 | 009 BP4N1/1 |

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 08/17/2021



575 Broad Hollow Road, Melville, NY 11747
TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

WorkOrder :
70183738

Laboratory Certifications

Pace Analytical Services Long Island

575 Broad Hollow Rd, Melville, NY 11747
Connecticut Certification #: PH-0435
Delaware Certification # NY 10478
Maryland Certification #: 208
Massachusetts Certification #: M-NY026
New Hampshire Certification #: 2987
New Jersey Certification #: NY158
New York Certification #: 10478 Primary Accrediting Body
Pennsylvania Certification #: 68-00350
Rhode Island Certification #: LAO00340
Virginia Certification # 460302

WO#: 70183738



70183738

Client Info:

Name or Code: HAMPTON BAYS WATER DISTRICT
 Address: P.O. BOX 1013
HAMPTON BAYS, NEW YORK 11946
(631) 728-0479
 Phone #: _____
 Attn: _____
 Proj. # or (Name): _____
 Bill To: _____
 Copies To: _____

**Sample Request Form
PUBLIC WATER SUPPLIER**

Date: 8-11-21
 Collected By: PC Booth
 Accepted By: PC Booth 8/11/21
 Cooler Temp: 2.1 °C 132.5

*Return to Lab
8/11/21 1635*

- WELL OFF LINE
- WELL RUN TO SYSTEM
- YES NO VOC'S PRESERVED WITH HCl

| Sample Types | Purpose | Origin | Treatment Types |
|--------------------|---------------|----------------------|-----------------------------------|
| PW - Potable Water | RO - Routine | D - Distribution | AST - Air Stripper |
| GW - Groundwater | RE - Resample | RW - Raw Well | GAC - Granular Activated Charcoal |
| SW - Surface Water | S - Special | TW - Treated Well | N - Nitrate Removal Plant |
| WW - Waste Water | | T - Tank | FE - Iron Removal Plant |
| AQ - Aqueous | | MW - Monitoring Well | O - Other |
| S - Soil | | I - Influent | |
| | | E - Effluent | |

Sample Info:

| Date/Time Collected: | Sample Type | Location | Origin | Treatment Type | Purpose | Field Readings Cl ₂ | Field Readings pH/Temp | Analysis | Lab No. |
|----------------------|-------------|---------------------|--------|----------------|---------|--------------------------------|------------------------|----------------------|---------|
| 7:25 8-11-21 | GW | Well 1-1 | RW | - | RO | | | N/N, I/m | |
| 7:20 8-11-21 | GW | Well 1-2 | RW | - | RO | | | N/N, I/m | |
| 6:50 8-11-21 | GW | Well 1-3 | RW | - | RO | | | N/N, I/m | |
| 6:05 8-11-21 | GW | Well 4-1 | RW | - | RO | | | I/m | |
| 6:15 8-11-21 | GW | Well 4-2 | RW | - | RO | | | I/m | |
| 5:15 8-11-21 | GW | Well 5-1 | RW | - | RO | | | I/m | |
| 7:00 8-11-21 | GW | BEND INF GAC PLANT | RW | - | RO | | | N/N, I/m | |
| 7:07 8-11-21 | GW | BLEND EFF GAC PLANT | RW | - | RO | | | N/N, I/m, BACT NO CL | |
| 6:07 8-11-21 | PW | BLEND EFF PLANT #4 | D | - | RO | .52 | 7.87 | I/m | |

Remarks:



Sample Condition Upon Rec

WO#: 70183738

Client Name: HBW

Project: PM: KMM Due Date: 08/17/21 CLIENT: HBW

Courier: Fed Ex UPS USPS Client Commercial Pace Other

Tracking #: Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No

Packing Material: Bubble Wrap Bubble Bags Ziploc None Other

Thermometer Used: TH091 Correction Factor: +0.0

Cooler Temperature: 2.1 Cooler Temperature Corrected: 2.1

Temp should be above freezing to 6.0°C USDA Regulated Soil (N/A, water sample)

Temperature Blank Present: Yes No Type of Ice: Wet Blue None Samples on ice, cooling process has begun Date/Time 5035A kits placed in freezer

Date and Initials of person examining contents: 8/11/21 1635

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes No

Did samples originate from a foreign source including Hawaii and Puerto Rico? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

Table with 17 rows and 3 columns: Field Name, Yes/No/N/A, and Comments. Includes fields like Chain of Custody Present, Filtered volume received for Dissolved tests, and Samples checked for dechlorination.

Client Notification/ Resolution: Field Data Required? Y / N Date/Time:

Person Contacted: Comments/ Resolution:

PM [Project Manager] review is documented electronically in LIMS.