



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**  
**P.O. Box 1013**  
**Hampton Bays, NY 11946**

**Lab No. : 70222008001**  
**Client Sample ID.: S-15687**

**Attn To : Supt. McCuen**  
 Federal ID : 5103704  
 Collected : 07/13/2022 07:45 AM Point S-15687  
 Received : 07/13/2022 05:45 PM Location Well #1-1  
 Collected By CLIENT

Analytical Method: EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3,L1	1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
4-Chlorotoluene	<0.50	L2	1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
Benzene	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		07/24/2022 4:56 PM	001 VG9C1/2
Bromoform	<0.50		1	ug/L		07/24/2022 4:56 PM	001 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
Chlorodifluoromethane	<0.50	N3,L1	1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
Chloroethane	<0.50	L1	1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
Chloroform	0.62		1	ug/L		07/24/2022 4:56 PM	001 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		07/24/2022 4:56 PM	001 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected  
 See qualifiers page for additional qualifier definitions.

*Kimberley Mack*

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**  
**P.O. Box 1013**  
**Hampton Bays, NY 11946**

**Lab No. : 70222008001**  
**Client Sample ID.: S-15687**

**Attn To : Supt. McCuen**

Federal ID : 5103704

Collected : 07/13/2022 07:45 AM Point S-15687

Received : 07/13/2022 05:45 PM Location Well #1-1

Collected By CLIENT

Parameter	Result	Qualifier	D.F.	Units	Limit	Analyzed	Container
Methyl-tert-butyl ether	<0.50	1		ug/L	10	07/24/2022 4:56 PM	001 VG9C1/2
Methylene Chloride	<0.50	1		ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
Styrene	<0.50	1		ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
Tetrachloroethene	<0.50	1		ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
Toluene	<0.50	1		ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
Total Trihalomethanes (Calc.)	0.62	1		ug/L	80	07/24/2022 4:56 PM	001 VG9C1/2
Trichloroethene	<0.50	1		ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
Trichlorofluoromethane	<0.50	1		ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
Vinyl chloride	<0.50	1		ug/L	2	07/24/2022 4:56 PM	001 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1		ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1		ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
m&p-Xylene	<0.50	1		ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
n-Butylbenzene	<0.50	1		ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
n-Propylbenzene	<0.50	1		ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
o-Xylene	<0.50	1		ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
p-Isopropyltoluene	<0.50	1		ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
sec-Butylbenzene	<0.50	1		ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
tert-Butylbenzene	<0.50	1		ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1		ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1		ug/L	5	07/24/2022 4:56 PM	001 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	119%	1		%REC		07/24/2022 4:56 PM	001 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	114%	1		%REC		07/24/2022 4:56 PM	001 VG9C1/2

Analytical Method: SM22 9223B Colilert

Prep Method: SM22 9223B Colilert

Prep Date: 07/13/2022 6:15 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed	Container
E.coli	Absent		1		Absent	07/14/2022 12:15	001 SP5T1/1
Total Coliforms	Absent		1		Absent	07/14/2022 12:15	001 SP5T1/1

**Qualifiers:**

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected  
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**  
**P.O. Box 1013**  
**Hampton Bays, NY 11946**

**Lab No. : 70222008002**  
**Client Sample ID.: S-24848**

**Attn To :** Supt. McCuen  
 Federal ID : 5103704  
 Collected : 07/13/2022 08:00 AM Point S-24848  
 Received : 07/13/2022 05:45 PM Location Well #1-2  
 Collected By CLIENT

Analytical Method: EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3,L1	1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
4-Chlorotoluene	<0.50	L2	1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
Benzene	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		07/24/2022 5:22 PM	002 VG9C1/2
Bromoform	<0.50		1	ug/L		07/24/2022 5:22 PM	002 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
Chlorodifluoromethane	<0.50	N3,L1	1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
Chloroethane	<0.50	L1	1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
Chloroform	<0.50		1	ug/L		07/24/2022 5:22 PM	002 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		07/24/2022 5:22 PM	002 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected  
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**  
**P.O. Box 1013**  
**Hampton Bays, NY 11946**

**Lab No. : 70222008002**  
**Client Sample ID.: S-24848**

**Attn To :** Supt. McCuen  
**Federal ID :** 5103704  
**Collected :** 07/13/2022 08:00 AM **Point** S-24848  
**Received :** 07/13/2022 05:45 PM **Location** Well #1-2  
**Collected By** CLIENT

Parameter	Result	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Methyl-tert-butyl ether	<0.50	1		ug/L	10	07/24/2022 5:22 PM	002 VG9C1/2
Methylene Chloride	<0.50	1		ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
Styrene	<0.50	1		ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
Tetrachloroethene	<0.50	1		ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
Toluene	<0.50	1		ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
Total Trihalomethanes (Calc.)	<0.50	1		ug/L	80	07/24/2022 5:22 PM	002 VG9C1/2
Trichloroethene	<0.50	1		ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
Trichlorofluoromethane	<0.50	1		ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
Vinyl chloride	<0.50	1		ug/L	2	07/24/2022 5:22 PM	002 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1		ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1		ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
m&p-Xylene	<0.50	1		ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
n-Butylbenzene	<0.50	1		ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
n-Propylbenzene	<0.50	1		ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
o-Xylene	<0.50	1		ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
p-Isopropyltoluene	<0.50	1		ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
sec-Butylbenzene	<0.50	1		ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
tert-Butylbenzene	<0.50	1		ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1		ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1		ug/L	5	07/24/2022 5:22 PM	002 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	117%	1		%REC		07/24/2022 5:22 PM	002 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	119%	1		%REC		07/24/2022 5:22 PM	002 VG9C1/2

Analytical Method: SM22 9223B Colilert

Prep Method: SM22 9223B Colilert

Prep Date: 07/13/2022 6:15 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	07/14/2022 12:15	002 SP5T1/1
Total Coliforms	Absent		1		Absent	07/14/2022 12:15	002 SP5T1/1

**Qualifiers:**

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected  
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**

**P.O. Box 1013**

**Hampton Bays, NY 11946**

**Attn To : Supt. McCuen**

Federal ID : 5103704

Collected : 07/13/2022 08:15 AM Point S-31636

Received : 07/13/2022 05:45 PM Location Well #1-3

Collected By CLIENT

**Lab No. : 70222008003**

**Client Sample ID.: S-31636**

Analytical Method: EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3,L1	1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
4-Chlorotoluene	<0.50	L2	1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
Benzene	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
Bromoform	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
Chlorodifluoromethane	<0.50	N3,L1	1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
Chloroethane	<0.50	L1	1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
Chloroform	2.8		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**  
**P.O. Box 1013**  
**Hampton Bays, NY 11946**

**Lab No. : 70222008003**  
**Client Sample ID.: S-31636**

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 07/13/2022 08:15 AM Point S-31636

Received : 07/13/2022 05:45 PM Location Well #1-3

Collected By CLIENT

Parameter	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Methyl-tert-butyl ether	<0.50	1		ug/L	10	07/24/2022 5:48 PM	003 VG9C1/2
Methylene Chloride	<0.50	1		ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
Styrene	<0.50	1		ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
Tetrachloroethene	<0.50	1		ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
Toluene	<0.50	1		ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
Total Trihalomethanes (Calc.)	2.8	1		ug/L	80	07/24/2022 5:48 PM	003 VG9C1/2
Trichloroethene	<0.50	1		ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
Trichlorofluoromethane	<0.50	1		ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
Vinyl chloride	<0.50	1		ug/L	2	07/24/2022 5:48 PM	003 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1		ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1		ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
m&p-Xylene	<0.50	1		ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
n-Butylbenzene	<0.50	1		ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
n-Propylbenzene	<0.50	1		ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
o-Xylene	<0.50	1		ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
p-Isopropyltoluene	<0.50	1		ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
sec-Butylbenzene	<0.50	1		ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
tert-Butylbenzene	<0.50	1		ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1		ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1		ug/L	5	07/24/2022 5:48 PM	003 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	121%	1		%REC		07/24/2022 5:48 PM	003 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	123%	1		%REC		07/24/2022 5:48 PM	003 VG9C1/2

Analytical Method: SM22 9223B Colilert

Prep Method: SM22 9223B Colilert

Prep Date: 07/13/2022 6:15 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent	1			Absent	07/14/2022 12:15	003 SP5T1/1
Total Coliforms	Absent	1			Absent	07/14/2022 12:15	003 SP5T1/1

### Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

### Sample Information:

Type: Drinking Water  
 Origin: Effluent  
 Routine

**Hampton Bays Water District**

**P.O. Box 1013**

**Hampton Bays, NY 11946**

**Attn To : Supt. McCuen**

Federal ID : 5103704

Collected : 07/13/2022 08:30 AM Point GAC EFFLUENT

Received : 07/13/2022 05:45 PM Location GAC EFFLUENT

Collected By CLIENT

**Lab No. : 70222008004**

**Client Sample ID.: GAC EFFLUENT**

<u>Analytical Method:</u> SM22 9223B Colilert		<u>Prep Method:</u> SM22 9223B Colilert			<u>Prep Date:</u> 07/13/2022 6:15 PM		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	07/14/2022 12:15	004 SP5T1/1
Total Coliforms	Absent		1		Absent	07/14/2022 12:15	004 SP5T1/1

**Qualifiers:**

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 07/26/2022

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

### Sample Information:

Type: Drinking Water  
 Origin: Effluent  
 Routine

**Hampton Bays Water District**  
**P.O. Box 1013**  
**Hampton Bays, NY 11946**

**Lab No. : 70222008005**  
**Client Sample ID.: GAC EFFLUENT**

**Attn To :** Supt. McCuen  
 Federal ID : 5103704  
 Collected : 07/13/2022 08:45 AM Point GAC EFFLUENT  
 Received : 07/13/2022 05:45 PM Location GAC EFFLUENT  
 Collected By CLIENT

<u>Analytical Method:</u> EPA 522		<u>Prep Method:</u> EPA 522			<u>Prep Date:</u> 07/20/2022 2:38 PM		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
1,4-Dioxane (p-Dioxane)	0.082		1	ug/L	1	07/21/2022 4:41 AM	005 AG2R1/1
Surr: 1,4-Dioxane-d8 (S)	95%		1	%REC		07/21/2022 4:41 AM	005 AG2R1/1

**Qualifiers:**

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 07/26/2022



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**  
**P.O. Box 1013**  
**Hampton Bays, NY 11946**

**Lab No. : 70222008006**  
**Client Sample ID.: S-50970**

**Attn To :** Supt. McCuen  
 Federal ID : 5103704  
 Collected : 07/13/2022 09:05 AM Point S-50970  
 Received : 07/13/2022 05:45 PM Location Well #2-1  
 Collected By CLIENT

Analytical Method: EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3,L1	1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
4-Chlorotoluene	<0.50	L2	1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
Benzene	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
Bromoform	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
Chlorodifluoromethane	<0.50	N3,L1	1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
Chloroethane	<0.50	L1	1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
Chloroform	0.94		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected  
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**  
**P.O. Box 1013**  
**Hampton Bays, NY 11946**

**Lab No. : 70222008006**  
**Client Sample ID.: S-50970**

**Attn To :** Supt. McCuen  
**Federal ID :** 5103704  
**Collected :** 07/13/2022 09:05 AM **Point** S-50970  
**Received :** 07/13/2022 05:45 PM **Location** Well #2-1  
**Collected By** CLIENT

Parameter	Result	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Methyl-tert-butyl ether	<0.50	1		ug/L	10	07/24/2022 6:14 PM	006 VG9C1/2
Methylene Chloride	<0.50	1		ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
Styrene	<0.50	1		ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
Tetrachloroethene	<0.50	1		ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
Toluene	<0.50	1		ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
Total Trihalomethanes (Calc.)	0.94	1		ug/L	80	07/24/2022 6:14 PM	006 VG9C1/2
Trichloroethene	<0.50	1		ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
Trichlorofluoromethane	<0.50	1		ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
Vinyl chloride	<0.50	1		ug/L	2	07/24/2022 6:14 PM	006 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1		ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1		ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
m&p-Xylene	<0.50	1		ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
n-Butylbenzene	<0.50	1		ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
n-Propylbenzene	<0.50	1		ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
o-Xylene	<0.50	1		ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
p-Isopropyltoluene	<0.50	1		ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
sec-Butylbenzene	<0.50	1		ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
tert-Butylbenzene	<0.50	1		ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1		ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1		ug/L	5	07/24/2022 6:14 PM	006 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	127%	1		%REC		07/24/2022 6:14 PM	006 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	121%	1		%REC		07/24/2022 6:14 PM	006 VG9C1/2

Analytical Method: SM22 9223B Colilert

Prep Method: SM22 9223B Colilert

Prep Date: 07/13/2022 6:15 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	07/14/2022 12:15	006 SP5T1/1
Total Coliforms	Absent		1		Absent	07/14/2022 12:15	006 SP5T1/1

**Qualifiers:**

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected  
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**  
**P.O. Box 1013**  
**Hampton Bays, NY 11946**

**Lab No. : 70222008007**  
**Client Sample ID.: S-74071**

**Attn To :** Supt. McCuen  
 Federal ID : 5103704  
 Collected : 07/13/2022 09:20 AM Point S-74071  
 Received : 07/13/2022 05:45 PM Location Well #2-2  
 Collected By CLIENT

Analytical Method: EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3,L1	1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
4-Chlorotoluene	<0.50	L2	1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
Benzene	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
Bromoform	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
Chlorodifluoromethane	<0.50	N3,L1	1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
Chloroethane	<0.50	L1	1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
Chloroform	1.2		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected  
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**  
**P.O. Box 1013**  
**Hampton Bays, NY 11946**

**Lab No. : 70222008007**  
**Client Sample ID.: S-74071**

**Attn To :** Supt. McCuen  
**Federal ID :** 5103704  
**Collected :** 07/13/2022 09:20 AM **Point** S-74071  
**Received :** 07/13/2022 05:45 PM **Location** Well #2-2  
**Collected By** CLIENT

Parameter	Result	Qualifier	D.F.	Units	Limit	Analyzed	Container
Methyl-tert-butyl ether	<0.50	1		ug/L	10	07/24/2022 6:41 PM	007 VG9C1/2
Methylene Chloride	<0.50	1		ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
Styrene	<0.50	1		ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
Tetrachloroethene	<0.50	1		ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
Toluene	<0.50	1		ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
Total Trihalomethanes (Calc.)	1.2	1		ug/L	80	07/24/2022 6:41 PM	007 VG9C1/2
Trichloroethene	<0.50	1		ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
Trichlorofluoromethane	<0.50	1		ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
Vinyl chloride	<0.50	1		ug/L	2	07/24/2022 6:41 PM	007 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1		ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1		ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
m&p-Xylene	<0.50	1		ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
n-Butylbenzene	<0.50	1		ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
n-Propylbenzene	<0.50	1		ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
o-Xylene	<0.50	1		ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
p-Isopropyltoluene	<0.50	1		ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
sec-Butylbenzene	<0.50	1		ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
tert-Butylbenzene	<0.50	1		ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1		ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1		ug/L	5	07/24/2022 6:41 PM	007 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	120%	1		%REC		07/24/2022 6:41 PM	007 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	120%	1		%REC		07/24/2022 6:41 PM	007 VG9C1/2

Analytical Method: SM22 9223B Colilert

Prep Method: SM22 9223B Colilert

Prep Date: 07/13/2022 6:15 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed	Container
E.coli	Absent		1		Absent	07/14/2022 12:15	007 SP5T1/1
Total Coliforms	Absent		1		Absent	07/14/2022 12:15	007 SP5T1/1

**Qualifiers:**

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected  
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**  
**P.O. Box 1013**  
**Hampton Bays, NY 11946**

**Lab No. : 70222008008**  
**Client Sample ID.: S-58350**

**Attn To :** Supt. McCuen  
 Federal ID : 5103704  
 Collected : 07/13/2022 09:40 AM Point S-58350  
 Received : 07/13/2022 05:45 PM Location Well #3-1  
 Collected By CLIENT

Analytical Method: EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3,L1	1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
4-Chlorotoluene	<0.50	L2	1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
Benzene	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
Bromoform	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
Chlorodifluoromethane	<0.50	N3,L1	1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
Chloroethane	<0.50	L1	1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
Chloroform	2.5		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected  
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**  
**P.O. Box 1013**  
**Hampton Bays, NY 11946**

**Lab No. : 70222008008**  
**Client Sample ID.: S-58350**

**Attn To :** Supt. McCuen  
**Federal ID :** 5103704  
**Collected :** 07/13/2022 09:40 AM **Point** S-58350  
**Received :** 07/13/2022 05:45 PM **Location** Well #3-1  
**Collected By** CLIENT

Parameter	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Methyl-tert-butyl ether	<0.50	1		ug/L	10	07/24/2022 7:07 PM	008 VG9C1/2
Methylene Chloride	<0.50	1		ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
Styrene	<0.50	1		ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
Tetrachloroethene	<0.50	1		ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
Toluene	<0.50	1		ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
Total Trihalomethanes (Calc.)	2.5	1		ug/L	80	07/24/2022 7:07 PM	008 VG9C1/2
Trichloroethene	<0.50	1		ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
Trichlorofluoromethane	<0.50	1		ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
Vinyl chloride	<0.50	1		ug/L	2	07/24/2022 7:07 PM	008 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1		ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1		ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
m&p-Xylene	<0.50	1		ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
n-Butylbenzene	<0.50	1		ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
n-Propylbenzene	<0.50	1		ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
o-Xylene	<0.50	1		ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
p-Isopropyltoluene	<0.50	1		ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
sec-Butylbenzene	<0.50	1		ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
tert-Butylbenzene	<0.50	1		ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1		ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1		ug/L	5	07/24/2022 7:07 PM	008 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	115%	1		%REC		07/24/2022 7:07 PM	008 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	112%	1		%REC		07/24/2022 7:07 PM	008 VG9C1/2

Analytical Method: SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 07/13/2022 6:15 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	07/14/2022 12:15	008 SP5T1/1
Total Coliforms	Absent		1		Absent	07/14/2022 12:15	008 SP5T1/1

**Qualifiers:**

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected  
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**  
**P.O. Box 1013**  
**Hampton Bays, NY 11946**

**Lab No. : 70222008009**  
**Client Sample ID.: S-58351**

**Attn To :** Supt. McCuen  
 Federal ID : 5103704  
 Collected : 07/13/2022 09:55 AM Point S-58351  
 Received : 07/13/2022 05:45 PM Location Well #3-2  
 Collected By CLIENT

Analytical Method: EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3,L1	1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
4-Chlorotoluene	<0.50	L2	1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
Benzene	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
Bromoform	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
Chlorodifluoromethane	<0.50	N3,L1	1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
Chloroethane	<0.50	L1	1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
Chloroform	1.1		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected  
 See qualifiers page for additional qualifier definitions.

*Kimberley Mack*

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**  
**P.O. Box 1013**  
**Hampton Bays, NY 11946**

**Lab No. : 70222008009**  
**Client Sample ID.: S-58351**

**Attn To :** Supt. McCuen  
**Federal ID :** 5103704  
**Collected :** 07/13/2022 09:55 AM **Point** S-58351  
**Received :** 07/13/2022 05:45 PM **Location** Well #3-2  
**Collected By** CLIENT

Methyl-tert-butyl ether	<0.50	1	ug/L	10	07/24/2022 7:33 PM	009 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
Styrene	<0.50	1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
Toluene	<0.50	1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
Total Trihalomethanes (Calc.)	1.1	1	ug/L	80	07/24/2022 7:33 PM	009 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	07/24/2022 7:33 PM	009 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	07/24/2022 7:33 PM	009 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	121%	1	%REC		07/24/2022 7:33 PM	009 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	114%	1	%REC		07/24/2022 7:33 PM	009 VG9C1/2

Analytical Method: SM22 9223B Colilert

Prep Method: SM22 9223B Colilert

Prep Date: 07/13/2022 6:15 PM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	07/14/2022 12:15	009 SP5T1/1
Total Coliforms	Absent		1		Absent	07/14/2022 12:15	009 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected  
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**  
**P.O. Box 1013**  
**Hampton Bays, NY 11946**

**Lab No. : 70222008010**  
**Client Sample ID.: S-58352**

**Attn To : Supt. McCuen**  
 Federal ID : 5103704  
 Collected : 07/13/2022 10:10 AM Point S-58352  
 Received : 07/13/2022 05:45 PM Location Well #3-3  
 Collected By CLIENT

Analytical Method: EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3,L1	1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
4-Chlorotoluene	<0.50	L2	1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
Benzene	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
Bromoform	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
Chlorodifluoromethane	<0.50	N3,L1	1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
Chloroethane	<0.50	L1	1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
Chloroform	2.2		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected  
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**  
**P.O. Box 1013**  
**Hampton Bays, NY 11946**

**Lab No. : 70222008010**  
**Client Sample ID.: S-58352**

**Attn To :** Supt. McCuen  
**Federal ID :** 5103704  
**Collected :** 07/13/2022 10:10 AM **Point** S-58352  
**Received :** 07/13/2022 05:45 PM **Location** Well #3-3  
**Collected By** CLIENT

Parameter	Result	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Methyl-tert-butyl ether	<0.50	1		ug/L	10	07/24/2022 7:59 PM	010 VG9C1/2
Methylene Chloride	<0.50	1		ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
Styrene	<0.50	1		ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
Tetrachloroethene	<0.50	1		ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
Toluene	<0.50	1		ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
Total Trihalomethanes (Calc.)	2.2	1		ug/L	80	07/24/2022 7:59 PM	010 VG9C1/2
Trichloroethene	<0.50	1		ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
Trichlorofluoromethane	<0.50	1		ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
Vinyl chloride	<0.50	1		ug/L	2	07/24/2022 7:59 PM	010 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1		ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1		ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
m&p-Xylene	<0.50	1		ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
n-Butylbenzene	<0.50	1		ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
n-Propylbenzene	<0.50	1		ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
o-Xylene	<0.50	1		ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
p-Isopropyltoluene	<0.50	1		ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
sec-Butylbenzene	<0.50	1		ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
tert-Butylbenzene	<0.50	1		ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1		ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1		ug/L	5	07/24/2022 7:59 PM	010 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	121%	1		%REC		07/24/2022 7:59 PM	010 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	117%	1		%REC		07/24/2022 7:59 PM	010 VG9C1/2

Analytical Method: SM22 9223B Colilert

Prep Method: SM22 9223B Colilert

Prep Date: 07/13/2022 6:15 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent	1			Absent	07/14/2022 12:15	010 SP5T1/1
Total Coliforms	Absent	1			Absent	07/14/2022 12:15	010 SP5T1/1

**Qualifiers:**

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected  
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**  
**P.O. Box 1013**  
**Hampton Bays, NY 11946**

**Lab No. : 70222008011**  
**Client Sample ID.: S-108065**

**Attn To : Supt. McCuen**  
 Federal ID : 5103704  
 Collected : 07/13/2022 10:15 AM Point S-108065  
 Received : 07/13/2022 05:45 PM Location Well #4-1  
 Collected By CLIENT

Analytical Method: EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3,L1	1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
4-Chlorotoluene	<0.50	L2	1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
Benzene	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
Bromoform	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
Chlorodifluoromethane	<0.50	N3,L1	1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
Chloroethane	<0.50	L1	1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
Chloroform	1.2		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected  
 See qualifiers page for additional qualifier definitions.

*Kimberley Mack*

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**  
**P.O. Box 1013**  
**Hampton Bays, NY 11946**

**Lab No. : 70222008011**  
**Client Sample ID.: S-108065**

**Attn To :** Supt. McCuen  
**Federal ID :** 5103704  
**Collected :** 07/13/2022 10:15 AM **Point** S-108065  
**Received :** 07/13/2022 05:45 PM **Location** Well #4-1  
**Collected By** CLIENT

Parameter	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Methyl-tert-butyl ether	<0.50	1		ug/L	10	07/24/2022 8:25 PM	011 VG9C1/2
Methylene Chloride	<0.50	1		ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
Styrene	<0.50	1		ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
Tetrachloroethene	<0.50	1		ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
Toluene	<0.50	1		ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
Total Trihalomethanes (Calc.)	1.2	1		ug/L	80	07/24/2022 8:25 PM	011 VG9C1/2
Trichloroethene	<0.50	1		ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
Trichlorofluoromethane	<0.50	1		ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
Vinyl chloride	<0.50	1		ug/L	2	07/24/2022 8:25 PM	011 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1		ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1		ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
m&p-Xylene	<0.50	1		ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
n-Butylbenzene	<0.50	1		ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
n-Propylbenzene	<0.50	1		ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
o-Xylene	<0.50	1		ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
p-Isopropyltoluene	<0.50	1		ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
sec-Butylbenzene	<0.50	1		ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
tert-Butylbenzene	<0.50	1		ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1		ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1		ug/L	5	07/24/2022 8:25 PM	011 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	114%	1		%REC		07/24/2022 8:25 PM	011 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	112%	1		%REC		07/24/2022 8:25 PM	011 VG9C1/2

Analytical Method: SM22 9223B Colilert

Prep Method: SM22 9223B Colilert

Prep Date: 07/13/2022 6:15 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	07/14/2022 12:15	011 SP5T1/1
Total Coliforms	Absent		1		Absent	07/14/2022 12:15	011 SP5T1/1

**Qualifiers:**

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected  
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**  
**P.O. Box 1013**  
**Hampton Bays, NY 11946**

**Lab No. : 70222008012**  
**Client Sample ID.: S-108066**

**Attn To : Supt. McCuen**  
 Federal ID : 5103704  
 Collected : 07/13/2022 10:40 AM Point S-108066  
 Received : 07/13/2022 05:45 PM Location Well #4-2  
 Collected By CLIENT

Analytical Method: EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3,L1	1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
4-Chlorotoluene	<0.50	L2	1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
Benzene	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		07/24/2022 8:52 PM	012 VG9C1/2
Bromoform	<0.50		1	ug/L		07/24/2022 8:52 PM	012 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
Chlorodifluoromethane	<0.50	N3,L1	1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
Chloroethane	<0.50	L1	1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
Chloroform	0.79		1	ug/L		07/24/2022 8:52 PM	012 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		07/24/2022 8:52 PM	012 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected  
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**  
**P.O. Box 1013**  
**Hampton Bays, NY 11946**

**Lab No. : 70222008012**  
**Client Sample ID.: S-108066**

**Attn To :** Supt. McCuen  
**Federal ID :** 5103704  
**Collected :** 07/13/2022 10:40 AM **Point** S-108066  
**Received :** 07/13/2022 05:45 PM **Location** Well #4-2  
**Collected By** CLIENT

Methyl-tert-butyl ether	<0.50	1	ug/L	10	07/24/2022 8:52 PM	012 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
Styrene	<0.50	1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
Toluene	<0.50	1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
Total Trihalomethanes (Calc.)	0.79	1	ug/L	80	07/24/2022 8:52 PM	012 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	07/24/2022 8:52 PM	012 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	07/24/2022 8:52 PM	012 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	120%	1	%REC		07/24/2022 8:52 PM	012 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	116%	1	%REC		07/24/2022 8:52 PM	012 VG9C1/2

Analytical Method: SM22 9223B Colilert

Prep Method: SM22 9223B Colilert

Prep Date: 07/13/2022 6:15 PM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	07/14/2022 12:15	012 SP5T1/1
Total Coliforms	Absent		1		Absent	07/14/2022 12:15	012 SP5T1/1

**Qualifiers:**

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected  
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**  
**P.O. Box 1013**  
**Hampton Bays, NY 11946**

**Lab No. : 70222008013**  
**Client Sample ID.: S-127163**

**Attn To : Supt. McCuen**  
 Federal ID : 5103704  
 Collected : 07/13/2022 11:00 AM Point S-127163  
 Received : 07/13/2022 05:45 PM Location Well #5-1  
 Collected By CLIENT

Analytical Method: EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3,L1	1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
4-Chlorotoluene	<0.50	L2	1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
Benzene	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
Bromoform	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
Chlorodifluoromethane	<0.50	N3,L1	1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
Chloroethane	<0.50	L1	1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
Chloroform	1.6		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected  
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**  
**P.O. Box 1013**  
**Hampton Bays, NY 11946**

**Lab No. : 70222008013**  
**Client Sample ID.: S-127163**

**Attn To :** Supt. McCuen  
**Federal ID :** 5103704  
**Collected :** 07/13/2022 11:00 AM **Point** S-127163  
**Received :** 07/13/2022 05:45 PM **Location** Well #5-1  
**Collected By** CLIENT

Parameter	Result	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Methyl-tert-butyl ether	<0.50	1		ug/L	10	07/24/2022 9:18 PM	013 VG9C1/2
Methylene Chloride	<0.50	1		ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
Styrene	<0.50	1		ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
Tetrachloroethene	<0.50	1		ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
Toluene	<0.50	1		ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
Total Trihalomethanes (Calc.)	1.6	1		ug/L	80	07/24/2022 9:18 PM	013 VG9C1/2
Trichloroethene	<0.50	1		ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
Trichlorofluoromethane	<0.50	1		ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
Vinyl chloride	<0.50	1		ug/L	2	07/24/2022 9:18 PM	013 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1		ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1		ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
m&p-Xylene	<0.50	1		ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
n-Butylbenzene	<0.50	1		ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
n-Propylbenzene	<0.50	1		ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
o-Xylene	<0.50	1		ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
p-Isopropyltoluene	<0.50	1		ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
sec-Butylbenzene	<0.50	1		ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
tert-Butylbenzene	<0.50	1		ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1		ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1		ug/L	5	07/24/2022 9:18 PM	013 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	118%	1		%REC		07/24/2022 9:18 PM	013 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	112%	1		%REC		07/24/2022 9:18 PM	013 VG9C1/2

Analytical Method: SM22 9223B Colilert

Prep Method: SM22 9223B Colilert

Prep Date: 07/13/2022 6:15 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	07/14/2022 12:15	013 SP5T1/1
Total Coliforms	Absent		1		Absent	07/14/2022 12:15	013 SP5T1/1

**Qualifiers:**

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected  
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin:

**Hampton Bays Water District**

**P.O. Box 1013**

**Hampton Bays, NY 11946**

**Attn To : Supt. McCuen**

Federal ID : 5103704

Collected : 07/08/2022 06:13 AM Point

Received : 07/13/2022 05:45 PM Location

Collected By CLIENT

**Lab No. : 70222008014**

**Client Sample ID.: 20 QUAIL RUN**

Analytical Method:EPA 200.8

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Copper	0.077		1	mg/L	1.3	07/25/2022 3:43 PM	014 BP1N1/1
Lead	<1.0	M1	1	ug/L	15	07/25/2022 3:43 PM	014 BP1N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747  
TEL: (631) 694-3040 FAX: (631) 420-8436  
[www.pacelabs.com](http://www.pacelabs.com)

**WorkOrder :**  
70222008

## Laboratory Certifications

---

### **Pace Analytical Services Long Island**

575 Broad Hollow Rd, Melville, NY 11747  
Connecticut Certification #: PH-0435  
Delaware Certification # NY 10478  
Maryland Certification #: 208  
Massachusetts Certification #: M-NY026  
New Hampshire Certification #: 2987  
New Jersey Certification #: NY158  
New York Certification #: 10478 Primary Accrediting Body  
Pennsylvania Certification #: 68-00350  
Rhode Island Certification #: LAO00340  
Virginia Certification # 460302



575 Broad Hollow Road, Melville, NY 11747  
TEL: (631) 694-3040 FAX: (631) 420-8436  
[www.pacelabs.com](http://www.pacelabs.com)

**WorkOrder :**

70222008

**Additional Qualifiers**

---

L1 - Analyte recovery in the laboratory control sample (LCS) was above QC limits. Results for this analyte in associated samples may be biased high.

L2 - Analyte recovery in the laboratory control sample (LCS) was below QC limits. Results for this analyte in associated samples may be biased low.

M1 - Matrix spike recovery exceeded QC limits. Batch accepted based on laboratory control sample (LCS) recovery.

N3 - Accreditation is not offered by the relevant laboratory accrediting body for this parameter.

WO#: 70222008



70222008

**Client Info:**

Name or Code: HAMPTON BAYS WATER DISTRICT  
Address: P.O. BOX 1013  
HAMPTON BAYS, NEW YORK 11946  
(631) 728-0179

Phone #: \_\_\_\_\_  
Attn: \_\_\_\_\_  
Proj. # or (Name): \_\_\_\_\_  
Bill To: \_\_\_\_\_  
Copies To: \_\_\_\_\_

**Sample Info:**

Date/Time Collected:	Sample Type	Location	Origin	Treatment Type	Purpose	Field Readings Cl <sub>2</sub> pH/Temp	Analysis	Lab No.
7/13/22 7:45am	GW	Well 1-1	RW	-	RO		BACT No CC, POC	
7/13/22 8:00am	GW	Well 1-2	RW	-	RO		BACT No CC, POC	
7/13/22 8:15am	GW	Well 1-3	RW	-	RO		BACT No CC, POC	
7/13/22 8:30am	GW	GAC Effluent	E	-	RO		BACT No CC	
7/13/22 8:45am	GW	GAC Effluent	E	-	RO		1:4 Dioxene	
7/13/22 9:00am	GW	Well 2-1	RW	-	RO		BACT No CC, POC	
7/13/22 9:20am	GW	Well 2-2	RW	-	RO		BACT No CC, POC	
7/13/22 9:40am	GW	Well 3-1	RW	-	RO		BACT No CC, POC	
7/13/22 9:55am	GW	Well 3-2	RW	-	RO		BACT No CC, POC	
7/13/22 10:10am	GW	Well 3-3	RW	-	RO		BACT No CC, POC	
7/13/22 10:25am	GW	Well 4-1	RW	-	RO		BACT No CC, POC	

Remarks:

**Sample Request Form  
PUBLIC WATER SUPPLIER**

Date: 7/13/22  
Collected By: K. J. THILLY  
Accepted By: [Signature] 7/13/22  
Cooler Temp: 3.4 °C

Return to Lab  
7/13/22 1745

WELL OFF LINE

WELL RUN TO SYSTEM

YES  NO VOC'S PRESERVED WITH HCl

Sample Types	Purpose	Origin	Treatment Types
PW - Potable Water	RO - Routine	D - Distribution	AST - Air Stripper
GW - Groundwater	RE - Resample	RW - Raw Well	GAC - Granular Activated Charcoal
SW - Surface Water	S - Special	TW - Treated Well	N - Nitrate Removal Plant
WW - Waste Water		T - Tank	FE - Iron Removal Plant
AQ - Aqueous		MW - Monitoring Well	O - Other
S - Soil		I - Influent	
		E - Effluent	





Sample Condition Upon Receipt

Client Name: HBW

Project

**WO#: 70222008**  
**PM: KMM** Due Date: **07/25/22**  
**CLIENT: HBW**

Courier:  Fed Ex  UPS  USPS  Client  Commercial  Pace  Other

Tracking #:

Custody Seal on Cooler/Box Present:  Yes  No Seals intact:  Yes  No  N/A

Packing Material:  Bubble Wrap  Bubble Bags  Ziploc  None  Other

Thermometer Used: H09+ T1148 Correction Factor: + 0.1

Cooler Temperature(°C): 3.4 Cooler Temperature Corrected(°C): 3.5

Temp should be above freezing to 6.0°C

USDA Regulated Soil  N/A, water sample

Date and Initials of person examining contents: KM 7/13/22 1745

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)?  Yes  No

Did samples originate from a foreign source including Hawaii and Puerto Rico)?  Yes  No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

		COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr):	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: [Triple volume provided for I	<input type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used:	<input type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Containers Intact:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID, Matrix: <u>SL WT OIL</u>		
All containers needing preservation have been checked?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input checked="" type="checkbox"/> HNO <sub>3</sub> <input type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # <u>110251522</u>		Sample # <u>70 Quail Run</u>
All containers needing preservation are found to be in compliance with method recommendation? (HNO <sub>3</sub> , H <sub>2</sub> SO <sub>4</sub> , HCl, NaOH>9 Sulfide, NaOH>12 Cyanide)	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis		Initial when completed: <u>KM</u> Lot # of added preservative: <u>11131</u> Date/Time preservative added: <u>7/13/22 18:15</u>
Samples checked for dechlorination:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
KI starch test strips Lot #		
Residual chlorine strips Lot #		
SM 4500 CN samples checked for sulfide?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15. Positive for Sulfide? Y N
Lead Acetate Strips Lot #		
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	16.
Trip Blank Present:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	17.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable):		

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution: