



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
 P.O. Box 1013
 Hampton Bays, NY 11946

Lab No. : 70233055001
 Client Sample ID.: S-24848

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 10/12/2022 07:45 AM Point S-24848
 Received : 10/12/2022 04:20 PM Location Well #1-2
 Collected By CLIENT

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	0.026		1	mg/L	0.3	10/19/2022 12:00	001 BP3N1/1
Manganese	0.60*		1	mg/L	0.3	10/19/2022 12:00	001 BP3N1/1

Analytical Method:SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 10/12/2022 5:50 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	10/13/2022 11:50	001 SP5T1/1
Total Coliforms	Absent		1		Absent	10/13/2022 11:50	001 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 11/23/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 10/12/2022 08:00 AM Point S-31636

Received : 10/12/2022 04:20 PM Location Well #1-3

Collected By CLIENT

Lab No. : 70233055002

Client Sample ID.: S-31636

Analytical Method:EPA 200.7

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Iron	0.043		1	mg/L	0.3	10/19/2022 12:03	002 BP3N1/1
Manganese	0.023		1	mg/L	0.3	10/19/2022 12:03	002 BP3N1/1

Analytical Method:SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 10/12/2022 5:50 PM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	10/13/2022 11:50	002 SP5T1/1
Total Coliforms	Absent		1		Absent	10/13/2022 11:50	002 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 11/23/2022

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Influent
 Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 10/12/2022 08:15 AM Point BLENDED
 Received : 10/12/2022 04:20 PM Location BLENDED INFLUENT GAC
 Collected By CLIENT

Lab No. : 70233055003

Client Sample ID.: BLENDED INFLUENT GAC

Analytical Method:EPA 200.7

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Iron	<0.020		1	mg/L	0.3	10/19/2022 12:06	003 BP3N1/1
Manganese	0.14		1	mg/L	0.3	10/19/2022 12:06	003 BP3N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 11/23/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Effluent
 Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 10/12/2022 08:30 AM Point BLENDED

Received : 10/12/2022 04:20 PM Location BLENDED EFFLUENT GAC

Collected By CLIENT

Lab No. : 70233055004

Client Sample ID.: BLENDED EFFLUENT GAC

<u>Analytical Method:</u> EPA 522		<u>Prep Method:</u> EPA 522			<u>Prep Date:</u> 10/24/2022 9:46 AM		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
1,4-Dioxane (p-Dioxane)	0.052		1	ug/L	1	10/26/2022 11:44	004 AG2R1/1
Surr: 1,4-Dioxane-d8 (S)	93%		1	%REC		10/26/2022 11:44	004 AG2R1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 11/23/2022

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 10/12/2022 09:45 AM Point S-58350

Received : 10/12/2022 04:20 PM Location Well #3-1

Collected By CLIENT

Lab No. : 70233055013

Client Sample ID.: S-58350

<u>Analytical Method:</u> SM22 9223B Colilert		<u>Prep Method:</u> SM22 9223B Colilert			<u>Prep Date:</u> 10/12/2022 5:50 PM		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	10/13/2022 11:50	013 SP5T1/1
Total Coliforms	Absent		1		Absent	10/13/2022 11:50	013 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 11/23/2022

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Distribution
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70233055015
Client Sample ID.: BLENDED ENTRY POINT 3 FIELD

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 10/12/2022 09:50 AM Point BLENDED ENTRY

Received : 10/12/2022 04:20 PM Location BLENDED ENTRY POINT 3 FIELD

Collected By CLIENT

Analytical Method:EPA 200.7

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Iron	<0.020		1	mg/L	0.3	10/19/2022 12:15	015 BP3N1/1
Manganese	<0.010		1	mg/L	0.3	10/19/2022 12:15	015 BP3N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 11/23/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 10/12/2022 10:00 AM Point S-58351

Received : 10/12/2022 04:20 PM Location Well #3-2

Collected By CLIENT

Lab No. : 70233055016

Client Sample ID.: S-58351

Analytical Method:EPA 200.7

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Iron	0.23		1	mg/L	0.3	10/19/2022 12:18	016 BP3N1/1
Manganese	0.034		1	mg/L	0.3	10/19/2022 12:18	016 BP3N1/1

Analytical Method:SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 10/12/2022 5:50 PM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	10/13/2022 11:50	016 SP5T1/1
Total Coliforms	Absent		1		Absent	10/13/2022 11:50	016 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 11/23/2022

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70233055017
Client Sample ID.: S-58352

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 10/12/2022 10:15 AM Point S-58352
 Received : 10/12/2022 04:20 PM Location Well #3-3
 Collected By CLIENT

<u>Analytical Method:</u> SM22 9223B Colilert		<u>Prep Method:</u> SM22 9223B Colilert			<u>Prep Date:</u> 10/12/2022 5:50 PM		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	10/13/2022 11:50	017 SP5T1/1
Total Coliforms	Absent		1		Absent	10/13/2022 11:50	017 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 11/23/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 10/12/2022 10:40 AM Point S-127163

Received : 10/12/2022 04:20 PM Location Well #5-1

Collected By CLIENT

Lab No. : 70233055018

Client Sample ID.: S-127163

<u>Analytical Method:</u> SM22 9223B Colilert		<u>Prep Method:</u> SM22 9223B Colilert			<u>Prep Date:</u> 10/12/2022 5:50 PM		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	10/13/2022 11:50	018 SP5T1/1
Total Coliforms	Absent		1		Absent	10/13/2022 11:50	018 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 11/23/2022

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70233055020
Client Sample ID.: S-108065

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 10/12/2022 10:55 AM Point S-108065
 Received : 10/12/2022 04:20 PM Location Well #4-1
 Collected By CLIENT

Analytical Method:EPA 200.7

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Iron	1.0*		1	mg/L	0.3	10/19/2022 12:21	020 BP3N1/1
Manganese	0.12		1	mg/L	0.3	10/19/2022 12:21	020 BP3N1/1

Analytical Method:SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 10/12/2022 5:50 PM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	10/13/2022 11:50	020 SP5T1/1
Total Coliforms	Absent		1		Absent	10/13/2022 11:50	020 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 11/23/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 10/12/2022 11:05 AM Point S-108066

Received : 10/12/2022 04:20 PM Location Well #4-2

Collected By CLIENT

Lab No. : 70233055021

Client Sample ID.: S-108066

Analytical Method:EPA 200.7

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Iron	1.2*		1	mg/L	0.3	10/19/2022 12:24	021 BP3N1/1
Manganese	0.13		1	mg/L	0.3	10/19/2022 12:24	021 BP3N1/1

Analytical Method:SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 10/12/2022 5:50 PM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	10/13/2022 11:50	021 SP5T1/1
Total Coliforms	Absent		1		Absent	10/13/2022 11:50	021 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 11/23/2022

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Influent
 Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 10/12/2022 11:10 AM Point BLENDED

Received : 10/12/2022 04:20 PM Location BLENDED INFLUENT IRON PLANT

Collected By CLIENT

Lab No. : 70233055022

Client Sample ID.: BLENDED INFLUENT IRON PLANT

Analytical Method:EPA 200.7

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Iron	0.97*		1	mg/L	0.3	10/19/2022 12:27	022 BP3N1/1
Manganese	0.13		1	mg/L	0.3	10/19/2022 12:27	022 BP3N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 11/23/2022

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Effluent
 Routine

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 10/12/2022 11:15 AM Point BLENDED

Received : 10/12/2022 04:20 PM Location BLENDED EFFLUENT IRON PLANT

Collected By CLIENT

Lab No. : 70233055023

Client Sample ID.: BLENDED EFFLUENT IRON PLANT

Analytical Method:EPA 200.7

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Iron	<0.020		1	mg/L	0.3	10/19/2022 12:30	023 BP3N1/1
Manganese	<0.010		1	mg/L	0.3	10/19/2022 12:30	023 BP3N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 11/23/2022

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

WorkOrder :
70233055

Laboratory Certifications

Pace Analytical Services Long Island

575 Broad Hollow Rd, Melville, NY 11747
Connecticut Certification #: PH-0435
Delaware Certification # NY 10478
Maryland Certification #: 208
Massachusetts Certification #: M-NY026
New Hampshire Certification #: 2987
New Jersey Certification #: NY158
New York Certification #: 10478 Primary Accrediting Body
Pennsylvania Certification #: 68-00350
Rhode Island Certification #: LAO00340
Virginia Certification # 460302

NO#: 70233055



70233055

Sample Request Form PUBLIC WATER SUPPLIER

Return to Lab
10/12/22 1620

WELL OFF LINE

WELL RUN TO SYSTEM

Date: 10-12-22

Collected By: A. TUTTILL

Accepted By: *[Signature]* 10/12/22

Cooler Temp: 12.6 °C / 1730

Client Info:

Name or Code: HAMPTON BAYS WATER DISTRICT
P.O. BOX 1113
Address: HAMPTON BAYS, NEW YORK 11946
(631) 728-0179

Phone #: _____
Attn: _____
Proj. # or (Name): _____
Bill To: _____
Copies To: _____

Sample Types	Purpose	Origin	Treatment Types
PW - Potable Water	RO - Routine	D - Distribution	AST - Air Stripper
GW - Groundwater	RE - Resample	RW - Raw Well	GAC - Granular Activated Charcoal
SW - Surface Water	S - Special	TW - Treated Well	N - Nitrate Removal Plant
WW - Waste Water		T - Tank	FE - Iron Removal Plant
AQ - Aqueous		MW - Monitoring Well	O - Other
S - Soil		I - Influent	
		E - Effluent	

Sample Info:

Date/Time Collected:	Sample Type	Location	Origin	Treatment Type	Purpose	Field Readings Cl ₂ pH/Temp	Analysis	Lab No.
10/12/22 7:30 AM	GW	Well 1-1	RW	-	RO		PFC's, I/M, BACT NO CC FB	
10/12/22 7:45 AM	GW	Well 1-2	RW	-	RO		PFC's, I/M, BACT NO CC	
10/12/22 8:00 AM	GW	Well 1-3	RW	-	RO		PFC's, I/M, BACT NO CC	
10/12/22 8:15 AM	GW	Blended Influent GAC	I	-	RO		PFC's, I/M	
10/12/22 8:30 AM	GW	Blended Effluent GAC	E	-	RO		PFC's, 1.4 Diarsane	
10/12/22 8:45 AM	GW	GAC TANK A 25% North Tank	T	-	RO		PFC's	
10/12/22 8:55 AM	GW	GAC TANK A 50% North Tank	T	-	RO		PFC's	
10/12/22 9:05 AM	GW	GAC TANK A 75% North Tank	T	-	RO		PFC's	
10/12/22 9:15 AM	GW	GAC TANK A 100% North Tank	T	-	RO		PFC's	
10/12/22 9:25 AM	GW	GAC TANK B 25% South Tank	T	-	RO		PFC's	
10/12/22 9:35 AM	GW	GAC TANK B 50% South Tank	T	-	RO		PFC's	
10/12/22 9:45 AM	GW	GAC TANK B 75% South Tank	T	-	RO		PFC's	
10/12/22 10:05 AM	GW	GAC Blended Effluent	E	GAC	RO	0.00	7.68	Bact

Remarks:

10/12/22 10:05 AM GW



Pace Analytical®
www.pacelabs.com

575 Broad Hollow Rd., Melville, NY 11747
(631) 694-3040 Fax: (631) 420-8436

Sample Request Form PUBLIC WATER SUPPLIER

Date: 10-17-22
 Collected By: K. TOTHILE
 Accepted By: [Signature]
 Cooler Temp: 2.6 °C / 12.50

*Return to Lab
10/17/22 1620*

- WELL OFF LINE
 WELL RUN TO SYSTEM
 YES NO VOC'S PRESERVED WITH HCl

Client Info:
 Name or Code: HAMPTON BAYS WATER DISTRICT
 Address: P.O. BOX 1013
HAMPTON BAYS, NEW YORK 11946
(631) 728-0179
 Phone #: _____
 Attn: _____
 Proj. # or (Name): _____
 Bill To: _____
 Copies To: _____

Sample Types	Purpose	Origin	Treatment Types
PW - Potable Water	RO - Routine	D - Distribution	AST - Air Stripper
GW - Groundwater	RE - Resample	RW - Raw Well	GAC - Granular Activated Charcoal
SW - Surface Water	S - Special	TW - Treated Well	N - Nitrate Removal Plant
WW - Waste Water		T - Tank	FE - Iron Removal Plant
AQ - Aqueous		MW - Monitoring Well	O - Other
S - Soil		I - Influent	
		E - Effluent	

Sample Info:

Date/Time Collected:	Sample Type	Location	Origin	Treatment Type	Purpose	Field Readings Cl ₂ pH/Temp	Analysis	Lab No.
10/12/22 9:15AM	GW	GAC TANK B 759/SOUTH TANK	T	GAC	RO		PFCS	
10/12/22 9:30AM	GW	GAC TANK B 1000/SOUTH TANK	T	GAC	RO		PFCS	
10/12/22 9:45AM	GW	Well 3-1	PW	-	RO		PFCS, BACT NO CC, RO FB	
10/12/22 9:50AM	PW	Blended Entry Point 3 Field	D	-	RO		PFCS, F/M	
10/12/22 10:00AM	GW	Well 3-2	GW	-	RO		PFCS, F/M, BACT NO CC	
10/12/22 10:15AM	GW	Well 3-3	GW	-	RO		PFCS, BACT NO CC	
10/12/22 10:40AM	GW	Well 5-1	GW	-	RO		PFCS, BACT NO CC, FB	
10/12/22 10:55AM	GW	Well 4-1	GW	-	RO		F/M, BACT NO CC	
10/12/22 11:05AM	GW	Well 4-2	GW	-	RO		F/M, BACT NO CC	
10/12/22 11:00AM	GW	Blended Influent Iron Plant	I	FE	RO		F/M	
10/12/22 11:15AM	GW	Blended Effluent Iron Plant	E	FE	RO		F/M	

Remarks:



Sample Condition Upon Rec

WO#: 70233055

Client Name: HBW

Proj

PM: KMM

Due Date: 10/18/22

CLIENT: HBW

Courier: Fed Ex UPS USPS Client Commercial Pace Other

Tracking #:

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No N/A

Packing Material: Bubble Wrap Bubble Bags Ziploc None Other

Thermometer Used: TH148 Correction Factor: + 0.1

Cooler Temperature(°C): 2.6 Cooler Temperature Corrected(°C): 2.7

Temp should be above freezing to 6.0°C

USDA Regulated Soil (N/A, water sample)

Date and Initials of person examining contents: 10/12/22 1620

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes No

Did samples originate from a foreign source including Hawaii and Puerto Rico)? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

		COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr):	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for I)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Containers Intact:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No	12. Well 1-1 Not Received.
-Includes date/time/ID, Matrix: SL (WT) OIL		
All containers needing preservation have been checked?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # 205522		Sample #
All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, NAOH>12 Cyanide)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	Initial when completed: Lot # of added preservative: Date/Time preservative added:
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis		
Samples checked for dechlorination:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
KI starch test strips Lot #		
Residual chlorine strips Lot #		
SM 4500 CN samples checked for sulfide?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15. Positive for Sulfide? Y N
Lead Acetate Strips Lot #		
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Trip Blank Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	17.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable):		

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution:

* PM (Project Manager) review is documented electronically in LIMS.