



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
 www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
 P.O. Box 1013
 Hampton Bays, NY 11946

Lab No. : 70214442001
 Client Sample ID.: S-15687

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 05/11/2022 07:45 AM Point S-15687
 Received : 05/11/2022 03:58 PM Location Well #1-1
 Collected By CLIENT

Analytical Method: EPA 505		Prep Method: EPA 505			Prep Date: 05/16/2022 6:00 PM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Alachlor	<0.20		1	ug/L	2	05/17/2022 9:25 AM	001 DG9T1/2
Aldrin	<0.025		1	ug/L	5	05/17/2022 9:25 AM	001 DG9T1/2
Chlordane (Technical)	<0.20		1	ug/L	2	05/17/2022 9:25 AM	001 DG9T1/2
Dieldrin	<0.050		1	ug/L	5	05/17/2022 9:25 AM	001 DG9T1/2
Endrin	<0.010		1	ug/L	2	05/17/2022 9:25 AM	001 DG9T1/2
Heptachlor	<0.025		1	ug/L	0.4	05/17/2022 9:25 AM	001 DG9T1/2
Heptachlor epoxide	<0.020		1	ug/L	0.2	05/17/2022 9:25 AM	001 DG9T1/2
Hexachlorobenzene	<0.10		1	ug/L	1	05/17/2022 9:25 AM	001 DG9T1/2
Hexachlorocyclopentadiene	<0.10		1	ug/L	5	05/17/2022 9:25 AM	001 DG9T1/2
Methoxychlor	<0.10		1	ug/L	40	05/17/2022 9:25 AM	001 DG9T1/2
PCB Screen	<0.40		1	ug/L		05/17/2022 9:25 AM	001 DG9T1/2
Toxaphene	<1.0		1	ug/L	3	05/17/2022 9:25 AM	001 DG9T1/2
gamma-BHC (Lindane)	<0.020		1	ug/L	0.2	05/17/2022 9:25 AM	001 DG9T1/2
Surr: Decachlorobiphenyl (S)	143%		1	%REC		05/17/2022 9:25 AM	001 DG9T1/2
Surr: Tetrachloro-m-xylene (S)	99%		1	%REC		05/17/2022 9:25 AM	001 DG9T1/2

Analytical Method: EPA 515.3		Prep Method: EPA 515.3			Prep Date: 05/17/2022 8:05 AM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
2,4,5-TP (Silvex)	<0.13		1	ug/L	10	05/21/2022 2:32 PM	001 AG3T1/1
2,4-D	<0.10		1	ug/L	50	05/21/2022 2:32 PM	001 AG3T1/1
Dalapon	<0.70		1	ug/L	50	05/21/2022 2:32 PM	001 AG3T1/1
Dicamba	<1.0		1	ug/L	50	05/21/2022 2:32 PM	001 AG3T1/1
Dinoseb	<0.20		1	ug/L	7	05/21/2022 2:32 PM	001 AG3T1/1
Pentachlorophenol	<0.040		1	ug/L	1	05/21/2022 2:32 PM	001 AG3T1/1
Picloram	<0.10		1	ug/L	50	05/21/2022 2:32 PM	001 AG3T1/1
Surr: 2,4-DCAA (S)	118%		1	%REC		05/21/2022 2:32 PM	001 AG3T1/1

Analytical Method: EPA 525.3		Prep Method: EPA 525.3			Prep Date: 05/23/2022 9:34 AM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Atrazine	<0.10		1	ug/L	3	05/26/2022 3:02 PM	001 AG1A1/1
Benzo(a)pyrene	<0.020		1	ug/L	0.2	05/26/2022 3:02 PM	001 AG1A1/1
Butachlor	<0.20		1	ug/L	50	05/26/2022 3:02 PM	001 AG1A1/1
Metolachlor	<0.10		1	ug/L	50	05/26/2022 3:02 PM	001 AG1A1/1
Metribuzin	<0.50		1	ug/L	50	05/26/2022 3:02 PM	001 AG1A1/1
Propachlor	<0.10		1	ug/L	50	05/26/2022 3:02 PM	001 AG1A1/1
Simazine	<0.070		1	ug/L	4	05/26/2022 3:02 PM	001 AG1A1/1
bis(2-Ethylhexyl)adipate	<0.60		1	ug/L	50	05/26/2022 3:02 PM	001 AG1A1/1
bis(2-Ethylhexyl)phthalate	<0.60		1	ug/L	6	05/26/2022 3:02 PM	001 AG1A1/1
Surr: 1,3-Dimethyl-2-nitrobenzene(S)	78%		1	%REC		05/26/2022 3:02 PM	001 AG1A1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 06/08/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70214442001
Client Sample ID.: S-15687

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 05/11/2022 07:45 AM Point S-15687
 Received : 05/11/2022 03:58 PM Location Well #1-1
 Collected By CLIENT

Surr: Benzo(a)pyrene-d12 (S)	73%	1	%REC	05/26/2022 3:02 PM	001 AG1A1/1
Surr: Triphenylphosphate (S)	94%	1	%REC	05/26/2022 3:02 PM	001 AG1A1/1

Analytical Method:EPA 531.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
3-Hydroxycarbofuran	<2.0		1	ug/L	50	05/19/2022 4:02 AM	001 DG9Y1/2
Aldicarb	<2.0		1	ug/L	3	05/19/2022 4:02 AM	001 DG9Y1/2
Aldicarb sulfone	<2.0		1	ug/L	2	05/19/2022 4:02 AM	001 DG9Y1/2
Aldicarb sulfoxide	<2.0		1	ug/L	4	05/19/2022 4:02 AM	001 DG9Y1/2
Carbaryl	<2.0		1	ug/L	50	05/19/2022 4:02 AM	001 DG9Y1/2
Carbofuran	<0.90		1	ug/L	40	05/19/2022 4:02 AM	001 DG9Y1/2
Methomyl	<2.0		1	ug/L	50	05/19/2022 4:02 AM	001 DG9Y1/2
Oxamyl	<2.0		1	ug/L	50	05/19/2022 4:02 AM	001 DG9Y1/2
Surr: BDMC (S)	125%		1	%REC		05/19/2022 4:02 AM	001 DG9Y1/2

Analytical Method:EPA 547

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Glyphosate	<6.0		1	ug/L	50	05/24/2022 12:12	001 DG6T1/1

Analytical Method:EPA 548.1

Prep Method: EPA 548.1

Prep Date: 05/15/2022 8:30 AM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Endothall	<9.0		1	ug/L	50	05/18/2022 3:58 AM	001 AG3U1/1

Analytical Method:EPA 549.2

Prep Method: EPA 549.2

Prep Date: 05/16/2022 9:29 AM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Diquat	<0.40		1	ug/L	20	05/23/2022 4:48 PM	001 BP1B1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 06/08/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70214442002
Client Sample ID.: S-24848

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 05/11/2022 08:00 AM Point S-24848
 Received : 05/11/2022 03:58 PM Location Well #1-2
 Collected By CLIENT

Analytical Method: EPA 505		Prep Method: EPA 505			Prep Date: 05/16/2022 6:00 PM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Alachlor	<0.20		1	ug/L	2	05/17/2022 10:13	002 DG9T1/2
Aldrin	<0.025		1	ug/L	5	05/17/2022 10:13	002 DG9T1/2
Chlordane (Technical)	<0.20		1	ug/L	2	05/17/2022 10:13	002 DG9T1/2
Dieldrin	<0.050		1	ug/L	5	05/17/2022 10:13	002 DG9T1/2
Endrin	<0.010		1	ug/L	2	05/17/2022 10:13	002 DG9T1/2
Heptachlor	<0.025		1	ug/L	0.4	05/17/2022 10:13	002 DG9T1/2
Heptachlor epoxide	<0.020		1	ug/L	0.2	05/17/2022 10:13	002 DG9T1/2
Hexachlorobenzene	<0.10		1	ug/L	1	05/17/2022 10:13	002 DG9T1/2
Hexachlorocyclopentadiene	<0.10		1	ug/L	5	05/17/2022 10:13	002 DG9T1/2
Methoxychlor	<0.10		1	ug/L	40	05/17/2022 10:13	002 DG9T1/2
PCB Screen	<0.40		1	ug/L		05/17/2022 10:13	002 DG9T1/2
Toxaphene	<1.0		1	ug/L	3	05/17/2022 10:13	002 DG9T1/2
gamma-BHC (Lindane)	<0.020		1	ug/L	0.2	05/17/2022 10:13	002 DG9T1/2
Surr: Decachlorobiphenyl (S)	144%		1	%REC		05/17/2022 10:13	002 DG9T1/2
Surr: Tetrachloro-m-xylene (S)	102%		1	%REC		05/17/2022 10:13	002 DG9T1/2

Analytical Method: EPA 515.3		Prep Method: EPA 515.3			Prep Date: 05/17/2022 8:05 AM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
2,4,5-TP (Silvex)	<0.13		1	ug/L	10	05/21/2022 3:02 PM	002 AG3T1/1
2,4-D	<0.10		1	ug/L	50	05/21/2022 3:02 PM	002 AG3T1/1
Dalapon	<0.70		1	ug/L	50	05/21/2022 3:02 PM	002 AG3T1/1
Dicamba	<1.0		1	ug/L	50	05/21/2022 3:02 PM	002 AG3T1/1
Dinoseb	<0.20		1	ug/L	7	05/21/2022 3:02 PM	002 AG3T1/1
Pentachlorophenol	<0.040		1	ug/L	1	05/21/2022 3:02 PM	002 AG3T1/1
Picloram	<0.10		1	ug/L	50	05/21/2022 3:02 PM	002 AG3T1/1
Surr: 2,4-DCAA (S)	111%		1	%REC		05/21/2022 3:02 PM	002 AG3T1/1

Analytical Method: EPA 525.3		Prep Method: EPA 525.3			Prep Date: 05/23/2022 9:34 AM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Atrazine	<0.10		1	ug/L	3	05/27/2022 8:26 PM	002 AG1A1/1
Benzo(a)pyrene	<0.020		1	ug/L	0.2	05/27/2022 8:26 PM	002 AG1A1/1
Butachlor	<0.20		1	ug/L	50	05/27/2022 8:26 PM	002 AG1A1/1
Metolachlor	<0.10		1	ug/L	50	05/27/2022 8:26 PM	002 AG1A1/1
Metribuzin	<0.50		1	ug/L	50	05/27/2022 8:26 PM	002 AG1A1/1
Propachlor	<0.10		1	ug/L	50	05/27/2022 8:26 PM	002 AG1A1/1
Simazine	<0.070		1	ug/L	4	05/27/2022 8:26 PM	002 AG1A1/1
bis(2-Ethylhexyl)adipate	<0.60		1	ug/L	50	05/27/2022 8:26 PM	002 AG1A1/1
bis(2-Ethylhexyl)phthalate	<0.60		1	ug/L	6	05/27/2022 8:26 PM	002 AG1A1/1
Surr: 1,3-Dimethyl-2-nitrobenzene(S)	94%		1	%REC		05/27/2022 8:26 PM	002 AG1A1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70214442002
Client Sample ID.: S-24848

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 05/11/2022 08:00 AM Point S-24848
 Received : 05/11/2022 03:58 PM Location Well #1-2
 Collected By CLIENT

Surr: Benzo(a)pyrene-d12 (S)	73%	1	%REC	05/27/2022 8:26 PM	002 AG1A1/1
Surr: Triphenylphosphate (S)	102%	1	%REC	05/27/2022 8:26 PM	002 AG1A1/1

Analytical Method:EPA 531.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
3-Hydroxycarbofuran	<2.0		1	ug/L	50	05/19/2022 4:46 AM	002 DG9Y1/2
Aldicarb	<2.0		1	ug/L	3	05/19/2022 4:46 AM	002 DG9Y1/2
Aldicarb sulfone	<2.0		1	ug/L	2	05/19/2022 4:46 AM	002 DG9Y1/2
Aldicarb sulfoxide	<2.0		1	ug/L	4	05/19/2022 4:46 AM	002 DG9Y1/2
Carbaryl	<2.0		1	ug/L	50	05/19/2022 4:46 AM	002 DG9Y1/2
Carbofuran	<0.90		1	ug/L	40	05/19/2022 4:46 AM	002 DG9Y1/2
Methomyl	<2.0		1	ug/L	50	05/19/2022 4:46 AM	002 DG9Y1/2
Oxamyl	<2.0		1	ug/L	50	05/19/2022 4:46 AM	002 DG9Y1/2
Surr: BDMC (S)	117%		1	%REC		05/19/2022 4:46 AM	002 DG9Y1/2

Analytical Method:EPA 547

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Glyphosate	<6.0		1	ug/L	50	05/24/2022 1:17 AM	002 DG6T1/1

Analytical Method:EPA 548.1

Prep Method: EPA 548.1

Prep Date: 05/16/2022 2:33 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Endothall	<9.0	M1	1	ug/L	50	05/24/2022 2:22 PM	002 AG3U1/1

Analytical Method:EPA 549.2

Prep Method: EPA 549.2

Prep Date: 05/16/2022 9:29 AM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Diquat	<0.40		1	ug/L	20	05/23/2022 5:03 PM	002 BP1B1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70214442003
Client Sample ID.: S-31636

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 05/11/2022 08:15 AM Point S-31636
 Received : 05/11/2022 03:58 PM Location Well #1-3
 Collected By CLIENT

Analytical Method: EPA 505		Prep Method: EPA 505			Prep Date: 05/16/2022 6:00 PM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Alachlor	<0.20		1	ug/L	2	05/17/2022 11:26	003 DG9T1/2
Aldrin	<0.025		1	ug/L	5	05/17/2022 11:26	003 DG9T1/2
Chlordane (Technical)	<0.20		1	ug/L	2	05/17/2022 11:26	003 DG9T1/2
Dieldrin	<0.050		1	ug/L	5	05/17/2022 11:26	003 DG9T1/2
Endrin	<0.010		1	ug/L	2	05/17/2022 11:26	003 DG9T1/2
Heptachlor	<0.025		1	ug/L	0.4	05/17/2022 11:26	003 DG9T1/2
Heptachlor epoxide	<0.020		1	ug/L	0.2	05/17/2022 11:26	003 DG9T1/2
Hexachlorobenzene	<0.10		1	ug/L	1	05/17/2022 11:26	003 DG9T1/2
Hexachlorocyclopentadiene	<0.10		1	ug/L	5	05/17/2022 11:26	003 DG9T1/2
Methoxychlor	<0.10		1	ug/L	40	05/17/2022 11:26	003 DG9T1/2
PCB Screen	<0.40		1	ug/L		05/17/2022 11:26	003 DG9T1/2
Toxaphene	<1.0		1	ug/L	3	05/17/2022 11:26	003 DG9T1/2
gamma-BHC (Lindane)	<0.020		1	ug/L	0.2	05/17/2022 11:26	003 DG9T1/2
Surr: Decachlorobiphenyl (S)	147%		1	%REC		05/17/2022 11:26	003 DG9T1/2
Surr: Tetrachloro-m-xylene (S)	103%		1	%REC		05/17/2022 11:26	003 DG9T1/2

Analytical Method: EPA 515.3		Prep Method: EPA 515.3			Prep Date: 05/17/2022 8:05 AM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
2,4,5-TP (Silvex)	<0.13		1	ug/L	10	05/21/2022 3:32 PM	003 AG3T1/1
2,4-D	<0.10		1	ug/L	50	05/21/2022 3:32 PM	003 AG3T1/1
Dalapon	<0.70		1	ug/L	50	05/21/2022 3:32 PM	003 AG3T1/1
Dicamba	<1.0		1	ug/L	50	05/21/2022 3:32 PM	003 AG3T1/1
Dinoseb	<0.20		1	ug/L	7	05/21/2022 3:32 PM	003 AG3T1/1
Pentachlorophenol	<0.040		1	ug/L	1	05/21/2022 3:32 PM	003 AG3T1/1
Picloram	<0.10		1	ug/L	50	05/21/2022 3:32 PM	003 AG3T1/1
Surr: 2,4-DCAA (S)	114%		1	%REC		05/21/2022 3:32 PM	003 AG3T1/1

Analytical Method: EPA 525.3		Prep Method: EPA 525.3			Prep Date: 05/23/2022 9:34 AM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Atrazine	<0.10		1	ug/L	3	05/26/2022 4:28 PM	003 AG1A1/1
Benzo(a)pyrene	<0.020		1	ug/L	0.2	05/26/2022 4:28 PM	003 AG1A1/1
Butachlor	<0.20		1	ug/L	50	05/26/2022 4:28 PM	003 AG1A1/1
Metolachlor	<0.10		1	ug/L	50	05/26/2022 4:28 PM	003 AG1A1/1
Metribuzin	<0.50		1	ug/L	50	05/26/2022 4:28 PM	003 AG1A1/1
Propachlor	<0.10		1	ug/L	50	05/26/2022 4:28 PM	003 AG1A1/1
Simazine	<0.070		1	ug/L	4	05/26/2022 4:28 PM	003 AG1A1/1
bis(2-Ethylhexyl)adipate	<0.60		1	ug/L	50	05/26/2022 4:28 PM	003 AG1A1/1
bis(2-Ethylhexyl)phthalate	<0.60		1	ug/L	6	05/26/2022 4:28 PM	003 AG1A1/1
Surr: 1,3-Dimethyl-2-nitrobenzene(S)	88%		1	%REC		05/26/2022 4:28 PM	003 AG1A1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 06/08/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70214442003
Client Sample ID.: S-31636

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 05/11/2022 08:15 AM Point S-31636
 Received : 05/11/2022 03:58 PM Location Well #1-3
 Collected By CLIENT

Surr: Benzo(a)pyrene-d12 (S)	75%	1	%REC	05/26/2022 4:28 PM	003 AG1A1/1
Surr: Triphenylphosphate (S)	95%	1	%REC	05/26/2022 4:28 PM	003 AG1A1/1

Analytical Method:EPA 531.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
3-Hydroxycarbofuran	<2.0		1	ug/L	50	05/19/2022 5:08 AM	003 DG9Y1/2
Aldicarb	<2.0		1	ug/L	3	05/19/2022 5:08 AM	003 DG9Y1/2
Aldicarb sulfone	<2.0		1	ug/L	2	05/19/2022 5:08 AM	003 DG9Y1/2
Aldicarb sulfoxide	<2.0		1	ug/L	4	05/19/2022 5:08 AM	003 DG9Y1/2
Carbaryl	<2.0		1	ug/L	50	05/19/2022 5:08 AM	003 DG9Y1/2
Carbofuran	<0.90		1	ug/L	40	05/19/2022 5:08 AM	003 DG9Y1/2
Methomyl	<2.0		1	ug/L	50	05/19/2022 5:08 AM	003 DG9Y1/2
Oxamyl	<2.0		1	ug/L	50	05/19/2022 5:08 AM	003 DG9Y1/2
Surr: BDMC (S)	114%		1	%REC		05/19/2022 5:08 AM	003 DG9Y1/2

Analytical Method:EPA 547

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Glyphosate	<6.0		1	ug/L	50	05/24/2022 1:50 AM	003 DG6T1/1

Analytical Method:EPA 548.1

Prep Method: EPA 548.1

Prep Date: 05/16/2022 2:33 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Endothall	<9.0		1	ug/L	50	05/24/2022 2:58 PM	003 AG3U1/1

Analytical Method:EPA 549.2

Prep Method: EPA 549.2

Prep Date: 05/16/2022 9:29 AM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Diquat	<0.40		1	ug/L	20	05/23/2022 5:18 PM	003 BP1B1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 06/08/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70214442004
Client Sample ID.: S-50970

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 05/11/2022 08:35 AM Point S-50970

Received : 05/11/2022 03:58 PM Location Well #2-1

Collected By CLIENT

Analytical Method: EPA 505		Prep Method: EPA 505			Prep Date: 05/16/2022 6:00 PM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Alachlor	<0.20		1	ug/L	2	05/17/2022 11:51	004 DG9T1/2
Aldrin	<0.025		1	ug/L	5	05/17/2022 11:51	004 DG9T1/2
Chlordane (Technical)	<0.20		1	ug/L	2	05/17/2022 11:51	004 DG9T1/2
Dieldrin	<0.050		1	ug/L	5	05/17/2022 11:51	004 DG9T1/2
Endrin	<0.010		1	ug/L	2	05/17/2022 11:51	004 DG9T1/2
Heptachlor	<0.025		1	ug/L	0.4	05/17/2022 11:51	004 DG9T1/2
Heptachlor epoxide	<0.020		1	ug/L	0.2	05/17/2022 11:51	004 DG9T1/2
Hexachlorobenzene	<0.10		1	ug/L	1	05/17/2022 11:51	004 DG9T1/2
Hexachlorocyclopentadiene	<0.10		1	ug/L	5	05/17/2022 11:51	004 DG9T1/2
Methoxychlor	<0.10		1	ug/L	40	05/17/2022 11:51	004 DG9T1/2
PCB Screen	<0.40		1	ug/L		05/17/2022 11:51	004 DG9T1/2
Toxaphene	<1.0		1	ug/L	3	05/17/2022 11:51	004 DG9T1/2
gamma-BHC (Lindane)	<0.020		1	ug/L	0.2	05/17/2022 11:51	004 DG9T1/2
Surr: Decachlorobiphenyl (S)	146%		1	%REC		05/17/2022 11:51	004 DG9T1/2
Surr: Tetrachloro-m-xylene (S)	98%		1	%REC		05/17/2022 11:51	004 DG9T1/2

Analytical Method: EPA 515.3		Prep Method: EPA 515.3			Prep Date: 05/20/2022 7:30 AM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
2,4,5-TP (Silvex)	<0.13		1	ug/L	10	05/21/2022 5:31 PM	004 AG3T1/1
2,4-D	<0.10		1	ug/L	50	05/21/2022 5:31 PM	004 AG3T1/1
Dalapon	<0.70		1	ug/L	50	05/21/2022 5:31 PM	004 AG3T1/1
Dicamba	<1.0		1	ug/L	50	05/21/2022 5:31 PM	004 AG3T1/1
Dinoseb	<0.20		1	ug/L	7	05/21/2022 5:31 PM	004 AG3T1/1
Pentachlorophenol	<0.040		1	ug/L	1	05/21/2022 5:31 PM	004 AG3T1/1
Picloram	<0.10		1	ug/L	50	05/21/2022 5:31 PM	004 AG3T1/1
Surr: 2,4-DCAA (S)	98%		1	%REC		05/21/2022 5:31 PM	004 AG3T1/1

Analytical Method: EPA 525.3		Prep Method: EPA 525.3			Prep Date: 05/24/2022 2:44 PM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Atrazine	<0.10		1	ug/L	3	05/27/2022 10:01	004 AG1A1/1
Benzo(a)pyrene	<0.020		1	ug/L	0.2	05/27/2022 10:01	004 AG1A1/1
Butachlor	<0.20		1	ug/L	50	05/27/2022 10:01	004 AG1A1/1
Metolachlor	<0.10		1	ug/L	50	05/27/2022 10:01	004 AG1A1/1
Metribuzin	<0.50		1	ug/L	50	05/27/2022 10:01	004 AG1A1/1
Propachlor	<0.10		1	ug/L	50	05/27/2022 10:01	004 AG1A1/1
Simazine	<0.070		1	ug/L	4	05/27/2022 10:01	004 AG1A1/1
bis(2-Ethylhexyl)adipate	<0.60		1	ug/L	50	05/27/2022 10:01	004 AG1A1/1
bis(2-Ethylhexyl)phthalate	<0.60		1	ug/L	6	05/27/2022 10:01	004 AG1A1/1
Surr: 1,3-Dimethyl-2-nitrobenzene(S)	84%		1	%REC		05/27/2022 10:01	004 AG1A1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 06/08/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70214442004
Client Sample ID.: S-50970

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 05/11/2022 08:35 AM Point S-50970
 Received : 05/11/2022 03:58 PM Location Well #2-1
 Collected By CLIENT

Surr: Benzo(a)pyrene-d12 (S)	72%	1	%REC	05/27/2022 10:01	004 AG1A1/1
Surr: Triphenylphosphate (S)	95%	1	%REC	05/27/2022 10:01	004 AG1A1/1

Analytical Method:EPA 531.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
3-Hydroxycarbofuran	<2.0		1	ug/L	50	05/19/2022 5:31 AM	004 DG9Y1/2
Aldicarb	<2.0		1	ug/L	3	05/19/2022 5:31 AM	004 DG9Y1/2
Aldicarb sulfone	<2.0		1	ug/L	2	05/19/2022 5:31 AM	004 DG9Y1/2
Aldicarb sulfoxide	<2.0		1	ug/L	4	05/19/2022 5:31 AM	004 DG9Y1/2
Carbaryl	<2.0		1	ug/L	50	05/19/2022 5:31 AM	004 DG9Y1/2
Carbofuran	<0.90		1	ug/L	40	05/19/2022 5:31 AM	004 DG9Y1/2
Methomyl	<2.0		1	ug/L	50	05/19/2022 5:31 AM	004 DG9Y1/2
Oxamyl	<2.0		1	ug/L	50	05/19/2022 5:31 AM	004 DG9Y1/2
Surr: BDMC (S)	121%		1	%REC		05/19/2022 5:31 AM	004 DG9Y1/2

Analytical Method:EPA 547

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Glyphosate	<6.0		1	ug/L	50	05/24/2022 2:23 AM	004 DG6T1/1

Analytical Method:EPA 548.1

Prep Method: EPA 548.1

Prep Date: 05/16/2022 2:33 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Endothall	<9.0		1	ug/L	50	05/24/2022 3:35 PM	004 AG3U1/1

Analytical Method:EPA 549.2

Prep Method: EPA 549.2

Prep Date: 05/17/2022 3:55 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Diquat	<0.40		1	ug/L	20	05/20/2022 6:44 PM	004 BP1B1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 06/08/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
 www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
 P.O. Box 1013
 Hampton Bays, NY 11946

Lab No. : 70214442005
 Client Sample ID.: S-74071

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 05/11/2022 08:50 AM Point S-74071
 Received : 05/11/2022 03:58 PM Location Well #2-2
 Collected By CLIENT

Analytical Method: EPA 505		Prep Method: EPA 505			Prep Date: 05/16/2022 6:00 PM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Alachlor	<0.20		1	ug/L	2	05/17/2022 12:15	005 DG9T1/2
Aldrin	<0.025		1	ug/L	5	05/17/2022 12:15	005 DG9T1/2
Chlordane (Technical)	<0.20		1	ug/L	2	05/17/2022 12:15	005 DG9T1/2
Dieldrin	<0.050		1	ug/L	5	05/17/2022 12:15	005 DG9T1/2
Endrin	<0.010		1	ug/L	2	05/17/2022 12:15	005 DG9T1/2
Heptachlor	<0.025		1	ug/L	0.4	05/17/2022 12:15	005 DG9T1/2
Heptachlor epoxide	<0.020		1	ug/L	0.2	05/17/2022 12:15	005 DG9T1/2
Hexachlorobenzene	<0.10		1	ug/L	1	05/17/2022 12:15	005 DG9T1/2
Hexachlorocyclopentadiene	<0.10		1	ug/L	5	05/17/2022 12:15	005 DG9T1/2
Methoxychlor	<0.10		1	ug/L	40	05/17/2022 12:15	005 DG9T1/2
PCB Screen	<0.40		1	ug/L		05/17/2022 12:15	005 DG9T1/2
Toxaphene	<1.0		1	ug/L	3	05/17/2022 12:15	005 DG9T1/2
gamma-BHC (Lindane)	<0.020		1	ug/L	0.2	05/17/2022 12:15	005 DG9T1/2
Surr: Decachlorobiphenyl (S)	142%		1	%REC		05/17/2022 12:15	005 DG9T1/2
Surr: Tetrachloro-m-xylene (S)	113%		1	%REC		05/17/2022 12:15	005 DG9T1/2

Analytical Method: EPA 515.3		Prep Method: EPA 515.3			Prep Date: 05/20/2022 7:30 AM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
2,4,5-TP (Silvex)	<0.13		1	ug/L	10	05/21/2022 8:00 PM	005 AG3T1/1
2,4-D	<0.10		1	ug/L	50	05/21/2022 8:00 PM	005 AG3T1/1
Dalapon	<0.70		1	ug/L	50	05/21/2022 8:00 PM	005 AG3T1/1
Dicamba	<1.0		1	ug/L	50	05/21/2022 8:00 PM	005 AG3T1/1
Dinoseb	<0.20		1	ug/L	7	05/21/2022 8:00 PM	005 AG3T1/1
Pentachlorophenol	<0.040		1	ug/L	1	05/21/2022 8:00 PM	005 AG3T1/1
Picloram	<0.10		1	ug/L	50	05/21/2022 8:00 PM	005 AG3T1/1
Surr: 2,4-DCAA (S)	94%		1	%REC		05/21/2022 8:00 PM	005 AG3T1/1

Analytical Method: EPA 525.3		Prep Method: EPA 525.3			Prep Date: 05/24/2022 2:44 PM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Atrazine	<0.10		1	ug/L	3	05/27/2022 10:25	005 AG1A1/1
Benzo(a)pyrene	<0.020		1	ug/L	0.2	05/27/2022 10:25	005 AG1A1/1
Butachlor	<0.20		1	ug/L	50	05/27/2022 10:25	005 AG1A1/1
Metolachlor	<0.10		1	ug/L	50	05/27/2022 10:25	005 AG1A1/1
Metribuzin	<0.50		1	ug/L	50	05/27/2022 10:25	005 AG1A1/1
Propachlor	<0.10		1	ug/L	50	05/27/2022 10:25	005 AG1A1/1
Simazine	<0.070		1	ug/L	4	05/27/2022 10:25	005 AG1A1/1
bis(2-Ethylhexyl)adipate	<0.60		1	ug/L	50	05/27/2022 10:25	005 AG1A1/1
bis(2-Ethylhexyl)phthalate	<0.60		1	ug/L	6	05/27/2022 10:25	005 AG1A1/1
Surr: 1,3-Dimethyl-2-nitrobenzene(S)	87%		1	%REC		05/27/2022 10:25	005 AG1A1/1

Qualifiers:
 DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack
 Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 06/08/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70214442005
Client Sample ID.: S-74071

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 05/11/2022 08:50 AM Point S-74071
 Received : 05/11/2022 03:58 PM Location Well #2-2
 Collected By CLIENT

Surr: Benzo(a)pyrene-d12 (S)	71%	1	%REC	05/27/2022 10:25	005 AG1A1/1
Surr: Triphenylphosphate (S)	93%	1	%REC	05/27/2022 10:25	005 AG1A1/1

Analytical Method:EPA 531.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
3-Hydroxycarbofuran	<2.0		1	ug/L	50	05/19/2022 5:53 AM	005 DG9Y1/2
Aldicarb	<2.0		1	ug/L	3	05/19/2022 5:53 AM	005 DG9Y1/2
Aldicarb sulfone	<2.0		1	ug/L	2	05/19/2022 5:53 AM	005 DG9Y1/2
Aldicarb sulfoxide	<2.0		1	ug/L	4	05/19/2022 5:53 AM	005 DG9Y1/2
Carbaryl	<2.0		1	ug/L	50	05/19/2022 5:53 AM	005 DG9Y1/2
Carbofuran	<0.90		1	ug/L	40	05/19/2022 5:53 AM	005 DG9Y1/2
Methomyl	<2.0		1	ug/L	50	05/19/2022 5:53 AM	005 DG9Y1/2
Oxamyl	<2.0		1	ug/L	50	05/19/2022 5:53 AM	005 DG9Y1/2
Surr: BDMC (S)	116%		1	%REC		05/19/2022 5:53 AM	005 DG9Y1/2

Analytical Method:EPA 547

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Glyphosate	<6.0		1	ug/L	50	05/24/2022 2:55 AM	005 DG6T1/1

Analytical Method:EPA 548.1

Prep Method: EPA 548.1

Prep Date: 05/16/2022 2:33 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Endothall	<9.0		1	ug/L	50	05/24/2022 3:53 PM	005 AG3U1/1

Analytical Method:EPA 549.2

Prep Method: EPA 549.2

Prep Date: 05/17/2022 3:55 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Diquat	<0.40		1	ug/L	20	05/20/2022 7:14 PM	005 BP1B1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 06/08/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
 www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70214442006
Client Sample ID.: S-58350

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 05/11/2022 09:05 AM Point S-58350
 Received : 05/11/2022 03:58 PM Location Well #3-1
 Collected By CLIENT

Analytical Method: EPA 505		Prep Method: EPA 505			Prep Date: 05/16/2022 6:00 PM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Alachlor	<0.20		1	ug/L	2	05/17/2022 12:39	006 DG9T1/2
Aldrin	<0.025		1	ug/L	5	05/17/2022 12:39	006 DG9T1/2
Chlordane (Technical)	<0.20		1	ug/L	2	05/17/2022 12:39	006 DG9T1/2
Dieldrin	<0.050		1	ug/L	5	05/17/2022 12:39	006 DG9T1/2
Endrin	<0.010		1	ug/L	2	05/17/2022 12:39	006 DG9T1/2
Heptachlor	<0.025		1	ug/L	0.4	05/17/2022 12:39	006 DG9T1/2
Heptachlor epoxide	<0.020		1	ug/L	0.2	05/17/2022 12:39	006 DG9T1/2
Hexachlorobenzene	<0.10		1	ug/L	1	05/17/2022 12:39	006 DG9T1/2
Hexachlorocyclopentadiene	<0.10		1	ug/L	5	05/17/2022 12:39	006 DG9T1/2
Methoxychlor	<0.10		1	ug/L	40	05/17/2022 12:39	006 DG9T1/2
PCB Screen	<0.40		1	ug/L		05/17/2022 12:39	006 DG9T1/2
Toxaphene	<1.0		1	ug/L	3	05/17/2022 12:39	006 DG9T1/2
gamma-BHC (Lindane)	<0.020		1	ug/L	0.2	05/17/2022 12:39	006 DG9T1/2
Surr: Decachlorobiphenyl (S)	133%		1	%REC		05/17/2022 12:39	006 DG9T1/2
Surr: Tetrachloro-m-xylene (S)	107%		1	%REC		05/17/2022 12:39	006 DG9T1/2

Analytical Method: EPA 525.3		Prep Method: EPA 525.3			Prep Date: 05/24/2022 2:44 PM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Atrazine	<0.10		1	ug/L	3	05/27/2022 10:49	006 AG1A1/1
Benzo(a)pyrene	<0.020		1	ug/L	0.2	05/27/2022 10:49	006 AG1A1/1
Butachlor	<0.20		1	ug/L	50	05/27/2022 10:49	006 AG1A1/1
Metolachlor	<0.10		1	ug/L	50	05/27/2022 10:49	006 AG1A1/1
Metribuzin	<0.50		1	ug/L	50	05/27/2022 10:49	006 AG1A1/1
Propachlor	<0.10		1	ug/L	50	05/27/2022 10:49	006 AG1A1/1
Simazine	<0.070		1	ug/L	4	05/27/2022 10:49	006 AG1A1/1
bis(2-Ethylhexyl)adipate	<0.60		1	ug/L	50	05/27/2022 10:49	006 AG1A1/1
bis(2-Ethylhexyl)phthalate	<0.60		1	ug/L	6	05/27/2022 10:49	006 AG1A1/1
Surr: 1,3-Dimethyl-2-nitrobenzene(S)	88%		1	%REC		05/27/2022 10:49	006 AG1A1/1
Surr: Benzo(a)pyrene-d12 (S)	72%		1	%REC		05/27/2022 10:49	006 AG1A1/1
Surr: Triphenylphosphate (S)	92%		1	%REC		05/27/2022 10:49	006 AG1A1/1

Analytical Method: EPA 531.2							
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
3-Hydroxycarbofuran	<2.0		1	ug/L	50	05/19/2022 6:15 AM	006 DG9Y1/2
Aldicarb	<2.0		1	ug/L	3	05/19/2022 6:15 AM	006 DG9Y1/2
Aldicarb sulfone	<2.0		1	ug/L	2	05/19/2022 6:15 AM	006 DG9Y1/2
Aldicarb sulfoxide	<2.0		1	ug/L	4	05/19/2022 6:15 AM	006 DG9Y1/2
Carbaryl	<2.0		1	ug/L	50	05/19/2022 6:15 AM	006 DG9Y1/2
Carbofuran	<0.90		1	ug/L	40	05/19/2022 6:15 AM	006 DG9Y1/2

Qualifiers:
 DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 06/08/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70214442006
Client Sample ID.: S-58350

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 05/11/2022 09:05 AM Point S-58350
 Received : 05/11/2022 03:58 PM Location Well #3-1
 Collected By CLIENT

Methomyl	<2.0	1	ug/L	50	05/19/2022 6:15 AM	006 DG9Y1/2
Oxamyl	<2.0	1	ug/L	50	05/19/2022 6:15 AM	006 DG9Y1/2
Surr: BDMC (S)	118%	1	%REC		05/19/2022 6:15 AM	006 DG9Y1/2

Analytical Method:EPA 547

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Glyphosate	<6.0		1	ug/L	50	05/24/2022 3:28 AM	006 DG6T1/1

Analytical Method:EPA 548.1

Prep Method: EPA 548.1

Prep Date: 05/16/2022 2:33 PM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Endothall	<9.0		1	ug/L	50	05/24/2022 4:12 PM	006 AG3U1/1

Analytical Method:EPA 549.2

Prep Method: EPA 549.2

Prep Date: 05/17/2022 3:55 PM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Diquat	<0.40		1	ug/L	20	05/20/2022 7:43 PM	006 BP1B1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 06/08/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70214442007
Client Sample ID.: S-58351

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 05/11/2022 09:20 AM Point S-58351
 Received : 05/11/2022 03:58 PM Location Well #3-2
 Collected By CLIENT

Analytical Method: EPA 505		Prep Method: EPA 505			Prep Date: 05/16/2022 6:00 PM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Alachlor	<0.20		1	ug/L	2	05/17/2022 1:04 PM	007 DG9T1/2
Aldrin	<0.025		1	ug/L	5	05/17/2022 1:04 PM	007 DG9T1/2
Chlordane (Technical)	<0.20		1	ug/L	2	05/17/2022 1:04 PM	007 DG9T1/2
Dieldrin	<0.050		1	ug/L	5	05/17/2022 1:04 PM	007 DG9T1/2
Endrin	<0.010		1	ug/L	2	05/17/2022 1:04 PM	007 DG9T1/2
Heptachlor	<0.025		1	ug/L	0.4	05/17/2022 1:04 PM	007 DG9T1/2
Heptachlor epoxide	<0.020		1	ug/L	0.2	05/17/2022 1:04 PM	007 DG9T1/2
Hexachlorobenzene	<0.10		1	ug/L	1	05/17/2022 1:04 PM	007 DG9T1/2
Hexachlorocyclopentadiene	<0.10		1	ug/L	5	05/17/2022 1:04 PM	007 DG9T1/2
Methoxychlor	<0.10		1	ug/L	40	05/17/2022 1:04 PM	007 DG9T1/2
PCB Screen	<0.40		1	ug/L		05/17/2022 1:04 PM	007 DG9T1/2
Toxaphene	<1.0		1	ug/L	3	05/17/2022 1:04 PM	007 DG9T1/2
gamma-BHC (Lindane)	<0.020		1	ug/L	0.2	05/17/2022 1:04 PM	007 DG9T1/2
Surr: Decachlorobiphenyl (S)	126%		1	%REC		05/17/2022 1:04 PM	007 DG9T1/2
Surr: Tetrachloro-m-xylene (S)	98%		1	%REC		05/17/2022 1:04 PM	007 DG9T1/2

Analytical Method: EPA 515.3		Prep Method: EPA 515.3			Prep Date: 05/20/2022 7:30 AM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
2,4,5-TP (Silvex)	<0.13		1	ug/L	10	05/21/2022 9:00 PM	007 AG3T1/1
2,4-D	<0.10		1	ug/L	50	05/21/2022 9:00 PM	007 AG3T1/1
Dalapon	<0.70		1	ug/L	50	05/21/2022 9:00 PM	007 AG3T1/1
Dicamba	<1.0		1	ug/L	50	05/21/2022 9:00 PM	007 AG3T1/1
Dinoseb	<0.20		1	ug/L	7	05/21/2022 9:00 PM	007 AG3T1/1
Pentachlorophenol	<0.040		1	ug/L	1	05/21/2022 9:00 PM	007 AG3T1/1
Picloram	<0.10		1	ug/L	50	05/21/2022 9:00 PM	007 AG3T1/1
Surr: 2,4-DCAA (S)	93%		1	%REC		05/21/2022 9:00 PM	007 AG3T1/1

Analytical Method: EPA 531.2							
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
3-Hydroxycarbofuran	<2.0		1	ug/L	50	05/19/2022 6:38 AM	007 DG9Y1/2
Aldicarb	<2.0		1	ug/L	3	05/19/2022 6:38 AM	007 DG9Y1/2
Aldicarb sulfone	<2.0		1	ug/L	2	05/19/2022 6:38 AM	007 DG9Y1/2
Aldicarb sulfoxide	<2.0		1	ug/L	4	05/19/2022 6:38 AM	007 DG9Y1/2
Carbaryl	<2.0		1	ug/L	50	05/19/2022 6:38 AM	007 DG9Y1/2
Carbofuran	<0.90		1	ug/L	40	05/19/2022 6:38 AM	007 DG9Y1/2
Methomyl	<2.0		1	ug/L	50	05/19/2022 6:38 AM	007 DG9Y1/2
Oxamyl	<2.0		1	ug/L	50	05/19/2022 6:38 AM	007 DG9Y1/2
Surr: BDMC (S)	124%		1	%REC		05/19/2022 6:38 AM	007 DG9Y1/2

Qualifiers:
 DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 06/08/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70214442007
Client Sample ID.: S-58351

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 05/11/2022 09:20 AM Point S-58351
 Received : 05/11/2022 03:58 PM Location Well #3-2
 Collected By CLIENT

Analytical Method:EPA 547

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Glyphosate	<6.0		1	ug/L	50	05/24/2022 4:01 AM	007 DG6T1/1

Analytical Method:EPA 548.1

Prep Method: EPA 548.1

Prep Date: 05/16/2022 2:33 PM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Endothall	<9.0		1	ug/L	50	05/24/2022 4:31 PM	007 AG3U1/1

Analytical Method:EPA 549.2

Prep Method: EPA 549.2

Prep Date: 05/17/2022 3:55 PM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Diquat	<0.40		1	ug/L	20	05/20/2022 7:58 PM	007 BP1B1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 06/08/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70214442008
Client Sample ID.: S-58352

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 05/11/2022 09:35 AM Point S-58352
 Received : 05/11/2022 03:58 PM Location Well #3-3
 Collected By CLIENT

Analytical Method: EPA 505		Prep Method: EPA 505			Prep Date: 05/16/2022 6:00 PM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Alachlor	<0.20		1	ug/L	2	05/17/2022 1:28 PM	008 DG9T1/2
Aldrin	<0.025		1	ug/L	5	05/17/2022 1:28 PM	008 DG9T1/2
Chlordane (Technical)	<0.20		1	ug/L	2	05/17/2022 1:28 PM	008 DG9T1/2
Dieldrin	<0.050		1	ug/L	5	05/17/2022 1:28 PM	008 DG9T1/2
Endrin	<0.010		1	ug/L	2	05/17/2022 1:28 PM	008 DG9T1/2
Heptachlor	<0.025		1	ug/L	0.4	05/17/2022 1:28 PM	008 DG9T1/2
Heptachlor epoxide	<0.020		1	ug/L	0.2	05/17/2022 1:28 PM	008 DG9T1/2
Hexachlorobenzene	<0.10		1	ug/L	1	05/17/2022 1:28 PM	008 DG9T1/2
Hexachlorocyclopentadiene	<0.10		1	ug/L	5	05/17/2022 1:28 PM	008 DG9T1/2
Methoxychlor	<0.10		1	ug/L	40	05/17/2022 1:28 PM	008 DG9T1/2
PCB Screen	<0.40		1	ug/L		05/17/2022 1:28 PM	008 DG9T1/2
Toxaphene	<1.0		1	ug/L	3	05/17/2022 1:28 PM	008 DG9T1/2
gamma-BHC (Lindane)	<0.020		1	ug/L	0.2	05/17/2022 1:28 PM	008 DG9T1/2
Surr: Decachlorobiphenyl (S)	160%		1	%REC		05/17/2022 1:28 PM	008 DG9T1/2
Surr: Tetrachloro-m-xylene (S)	111%		1	%REC		05/17/2022 1:28 PM	008 DG9T1/2

Analytical Method: EPA 515.3		Prep Method: EPA 515.3			Prep Date: 05/20/2022 7:30 AM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
2,4,5-TP (Silvex)	<0.13		1	ug/L	10	05/21/2022 9:29 PM	008 AG3T1/1
2,4-D	<0.10		1	ug/L	50	05/21/2022 9:29 PM	008 AG3T1/1
Dalapon	<0.70		1	ug/L	50	05/21/2022 9:29 PM	008 AG3T1/1
Dicamba	<1.0		1	ug/L	50	05/21/2022 9:29 PM	008 AG3T1/1
Dinoseb	<0.20		1	ug/L	7	05/21/2022 9:29 PM	008 AG3T1/1
Pentachlorophenol	<0.040		1	ug/L	1	05/21/2022 9:29 PM	008 AG3T1/1
Picloram	<0.10		1	ug/L	50	05/21/2022 9:29 PM	008 AG3T1/1
Surr: 2,4-DCAA (S)	101%		1	%REC		05/21/2022 9:29 PM	008 AG3T1/1

Analytical Method: EPA 531.2							
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
3-Hydroxycarbofuran	<2.0		1	ug/L	50	05/19/2022 7:00 AM	008 DG9Y1/2
Aldicarb	<2.0		1	ug/L	3	05/19/2022 7:00 AM	008 DG9Y1/2
Aldicarb sulfone	<2.0		1	ug/L	2	05/19/2022 7:00 AM	008 DG9Y1/2
Aldicarb sulfoxide	<2.0		1	ug/L	4	05/19/2022 7:00 AM	008 DG9Y1/2
Carbaryl	<2.0		1	ug/L	50	05/19/2022 7:00 AM	008 DG9Y1/2
Carbofuran	<0.90		1	ug/L	40	05/19/2022 7:00 AM	008 DG9Y1/2
Methomyl	<2.0		1	ug/L	50	05/19/2022 7:00 AM	008 DG9Y1/2
Oxamyl	<2.0		1	ug/L	50	05/19/2022 7:00 AM	008 DG9Y1/2
Surr: BDMC (S)	118%		1	%REC		05/19/2022 7:00 AM	008 DG9Y1/2

Qualifiers:
 DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 06/08/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70214442008
Client Sample ID.: S-58352

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 05/11/2022 09:35 AM Point S-58352
 Received : 05/11/2022 03:58 PM Location Well #3-3
 Collected By CLIENT

Analytical Method:EPA 547

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Glyphosate	<6.0		1	ug/L	50	05/24/2022 4:33 AM	008 DG6T1/1

Analytical Method:EPA 548.1

Prep Method: EPA 548.1

Prep Date: 05/16/2022 2:33 PM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Endothall	<9.0		1	ug/L	50	05/26/2022 5:56 PM	008 AG3U1/1

Analytical Method:EPA 549.2

Prep Method: EPA 549.2

Prep Date: 05/17/2022 3:55 PM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Diquat	<0.40		1	ug/L	20	05/20/2022 8:13 PM	008 BP1B1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 06/08/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70214442009
Client Sample ID.: S-108065

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 05/11/2022 09:55 AM Point S-108065
 Received : 05/11/2022 03:58 PM Location Well #4-1
 Collected By CLIENT

Analytical Method: EPA 505		Prep Method: EPA 505			Prep Date: 05/16/2022 6:00 PM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Alachlor	<0.20		1	ug/L	2	05/17/2022 1:52 PM	009 DG9T1/2
Aldrin	<0.025		1	ug/L	5	05/17/2022 1:52 PM	009 DG9T1/2
Chlordane (Technical)	<0.20		1	ug/L	2	05/17/2022 1:52 PM	009 DG9T1/2
Dieldrin	<0.050		1	ug/L	5	05/17/2022 1:52 PM	009 DG9T1/2
Endrin	<0.010		1	ug/L	2	05/17/2022 1:52 PM	009 DG9T1/2
Heptachlor	<0.025		1	ug/L	0.4	05/17/2022 1:52 PM	009 DG9T1/2
Heptachlor epoxide	<0.020		1	ug/L	0.2	05/17/2022 1:52 PM	009 DG9T1/2
Hexachlorobenzene	<0.10		1	ug/L	1	05/17/2022 1:52 PM	009 DG9T1/2
Hexachlorocyclopentadiene	<0.10		1	ug/L	5	05/17/2022 1:52 PM	009 DG9T1/2
Methoxychlor	<0.10		1	ug/L	40	05/17/2022 1:52 PM	009 DG9T1/2
PCB Screen	<0.40		1	ug/L		05/17/2022 1:52 PM	009 DG9T1/2
Toxaphene	<1.0		1	ug/L	3	05/17/2022 1:52 PM	009 DG9T1/2
gamma-BHC (Lindane)	<0.020		1	ug/L	0.2	05/17/2022 1:52 PM	009 DG9T1/2
Surr: Decachlorobiphenyl (S)	114%		1	%REC		05/17/2022 1:52 PM	009 DG9T1/2
Surr: Tetrachloro-m-xylene (S)	100%		1	%REC		05/17/2022 1:52 PM	009 DG9T1/2

Analytical Method: EPA 515.3		Prep Method: EPA 515.3			Prep Date: 05/20/2022 7:30 AM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
2,4,5-TP (Silvex)	<0.13		1	ug/L	10	05/21/2022 9:59 PM	009 AG3T1/1
2,4-D	<0.10		1	ug/L	50	05/21/2022 9:59 PM	009 AG3T1/1
Dalapon	<0.70		1	ug/L	50	05/21/2022 9:59 PM	009 AG3T1/1
Dicamba	<1.0		1	ug/L	50	05/21/2022 9:59 PM	009 AG3T1/1
Dinoseb	<0.20		1	ug/L	7	05/21/2022 9:59 PM	009 AG3T1/1
Pentachlorophenol	<0.040		1	ug/L	1	05/21/2022 9:59 PM	009 AG3T1/1
Picloram	<0.10		1	ug/L	50	05/21/2022 9:59 PM	009 AG3T1/1
Surr: 2,4-DCAA (S)	91%		1	%REC		05/21/2022 9:59 PM	009 AG3T1/1

Analytical Method: EPA 525.3		Prep Method: EPA 525.3			Prep Date: 05/24/2022 2:44 PM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Atrazine	<0.10		1	ug/L	3	05/28/2022 12:24	009 AG1A1/1
Benzo(a)pyrene	<0.020		1	ug/L	0.2	05/28/2022 12:24	009 AG1A1/1
Butachlor	<0.20		1	ug/L	50	05/28/2022 12:24	009 AG1A1/1
Metolachlor	<0.10		1	ug/L	50	05/28/2022 12:24	009 AG1A1/1
Metribuzin	<0.50		1	ug/L	50	05/28/2022 12:24	009 AG1A1/1
Propachlor	<0.10		1	ug/L	50	05/28/2022 12:24	009 AG1A1/1
Simazine	<0.070		1	ug/L	4	05/28/2022 12:24	009 AG1A1/1
bis(2-Ethylhexyl)adipate	<0.60		1	ug/L	50	05/28/2022 12:24	009 AG1A1/1
bis(2-Ethylhexyl)phthalate	<0.60		1	ug/L	6	05/28/2022 12:24	009 AG1A1/1
Surr: 1,3-Dimethyl-2-nitrobenzene(S)	84%		1	%REC		05/28/2022 12:24	009 AG1A1/1

Qualifiers:
 DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Kimberley Mack
 Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70214442009
Client Sample ID.: S-108065

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 05/11/2022 09:55 AM Point S-108065
 Received : 05/11/2022 03:58 PM Location Well #4-1
 Collected By CLIENT

Surr: Benzo(a)pyrene-d12 (S)	76%	1	%REC	05/28/2022 12:24	009 AG1A1/1
Surr: Triphenylphosphate (S)	90%	1	%REC	05/28/2022 12:24	009 AG1A1/1

Analytical Method:EPA 531.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
3-Hydroxycarbofuran	<2.0		1	ug/L	50	05/19/2022 7:22 AM	009 DG9Y1/2
Aldicarb	<2.0		1	ug/L	3	05/19/2022 7:22 AM	009 DG9Y1/2
Aldicarb sulfone	<2.0		1	ug/L	2	05/19/2022 7:22 AM	009 DG9Y1/2
Aldicarb sulfoxide	<2.0		1	ug/L	4	05/19/2022 7:22 AM	009 DG9Y1/2
Carbaryl	<2.0		1	ug/L	50	05/19/2022 7:22 AM	009 DG9Y1/2
Carbofuran	<0.90		1	ug/L	40	05/19/2022 7:22 AM	009 DG9Y1/2
Methomyl	<2.0		1	ug/L	50	05/19/2022 7:22 AM	009 DG9Y1/2
Oxamyl	<2.0		1	ug/L	50	05/19/2022 7:22 AM	009 DG9Y1/2
Surr: BDMC (S)	123%		1	%REC		05/19/2022 7:22 AM	009 DG9Y1/2

Analytical Method:EPA 547

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Glyphosate	<6.0		1	ug/L	50	05/24/2022 5:06 AM	009 DG6T1/1

Analytical Method:EPA 548.1

Prep Method: EPA 548.1

Prep Date: 05/17/2022 1:38 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Endothall	<3.6	M1	1	ug/L	50	05/24/2022 8:07 PM	009 AG3U1/1

Analytical Method:EPA 549.2

Prep Method: EPA 549.2

Prep Date: 05/17/2022 3:55 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Diquat	<0.40		1	ug/L	20	05/20/2022 8:28 PM	009 BP1B1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
 www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
 P.O. Box 1013
 Hampton Bays, NY 11946

Lab No. : 70214442010
 Client Sample ID.: S-108066

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 05/11/2022 10:10 AM Point S-108066
 Received : 05/11/2022 03:58 PM Location Well #4-2
 Collected By CLIENT

Analytical Method: EPA 505		Prep Method: EPA 505			Prep Date: 05/16/2022 6:00 PM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Alachlor	<0.20		1	ug/L	2	05/17/2022 2:17 PM	010 DG9T1/2
Aldrin	<0.025		1	ug/L	5	05/17/2022 2:17 PM	010 DG9T1/2
Chlordane (Technical)	<0.20		1	ug/L	2	05/17/2022 2:17 PM	010 DG9T1/2
Dieldrin	<0.050		1	ug/L	5	05/17/2022 2:17 PM	010 DG9T1/2
Endrin	<0.010		1	ug/L	2	05/17/2022 2:17 PM	010 DG9T1/2
Heptachlor	<0.025		1	ug/L	0.4	05/17/2022 2:17 PM	010 DG9T1/2
Heptachlor epoxide	<0.020		1	ug/L	0.2	05/17/2022 2:17 PM	010 DG9T1/2
Hexachlorobenzene	<0.10		1	ug/L	1	05/17/2022 2:17 PM	010 DG9T1/2
Hexachlorocyclopentadiene	<0.10		1	ug/L	5	05/17/2022 2:17 PM	010 DG9T1/2
Methoxychlor	<0.10		1	ug/L	40	05/17/2022 2:17 PM	010 DG9T1/2
PCB Screen	<0.40		1	ug/L		05/17/2022 2:17 PM	010 DG9T1/2
Toxaphene	<1.0		1	ug/L	3	05/17/2022 2:17 PM	010 DG9T1/2
gamma-BHC (Lindane)	<0.020		1	ug/L	0.2	05/17/2022 2:17 PM	010 DG9T1/2
Surr: Decachlorobiphenyl (S)	144%		1	%REC		05/17/2022 2:17 PM	010 DG9T1/2
Surr: Tetrachloro-m-xylene (S)	89%		1	%REC		05/17/2022 2:17 PM	010 DG9T1/2

Analytical Method: EPA 515.3		Prep Method: EPA 515.3			Prep Date: 05/20/2022 7:30 AM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
2,4,5-TP (Silvex)	<0.13		1	ug/L	10	05/21/2022 10:29	010 AG3T1/1
2,4-D	<0.10		1	ug/L	50	05/21/2022 10:29	010 AG3T1/1
Dalapon	<0.70		1	ug/L	50	05/21/2022 10:29	010 AG3T1/1
Dicamba	<1.0		1	ug/L	50	05/21/2022 10:29	010 AG3T1/1
Dinoseb	<0.20		1	ug/L	7	05/21/2022 10:29	010 AG3T1/1
Pentachlorophenol	<0.040		1	ug/L	1	05/21/2022 10:29	010 AG3T1/1
Picloram	<0.10		1	ug/L	50	05/21/2022 10:29	010 AG3T1/1
Surr: 2,4-DCAA (S)	96%		1	%REC		05/21/2022 10:29	010 AG3T1/1

Analytical Method: EPA 525.3		Prep Method: EPA 525.3			Prep Date: 05/24/2022 2:44 PM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Atrazine	<0.10		1	ug/L	3	05/28/2022 12:48	010 AG1A1/1
Benzo(a)pyrene	<0.020		1	ug/L	0.2	05/28/2022 12:48	010 AG1A1/1
Butachlor	<0.20		1	ug/L	50	05/28/2022 12:48	010 AG1A1/1
Metolachlor	<0.10		1	ug/L	50	05/28/2022 12:48	010 AG1A1/1
Metribuzin	<0.50		1	ug/L	50	05/28/2022 12:48	010 AG1A1/1
Propachlor	<0.10		1	ug/L	50	05/28/2022 12:48	010 AG1A1/1
Simazine	<0.070		1	ug/L	4	05/28/2022 12:48	010 AG1A1/1
bis(2-Ethylhexyl)adipate	<0.60		1	ug/L	50	05/28/2022 12:48	010 AG1A1/1
bis(2-Ethylhexyl)phthalate	<0.60		1	ug/L	6	05/28/2022 12:48	010 AG1A1/1
Surr: 1,3-Dimethyl-2-nitrobenzene(S)	85%		1	%REC		05/28/2022 12:48	010 AG1A1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 06/08/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70214442010
Client Sample ID.: S-108066

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 05/11/2022 10:10 AM Point S-108066
 Received : 05/11/2022 03:58 PM Location Well #4-2
 Collected By CLIENT

Surr: Benzo(a)pyrene-d12 (S)	70%	1	%REC	05/28/2022 12:48	010 AG1A1/1
Surr: Triphenylphosphate (S)	92%	1	%REC	05/28/2022 12:48	010 AG1A1/1

Analytical Method:EPA 531.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
3-Hydroxycarbofuran	<2.0		1	ug/L	50	05/19/2022 7:45 AM	010 DG9Y1/2
Aldicarb	<2.0		1	ug/L	3	05/19/2022 7:45 AM	010 DG9Y1/2
Aldicarb sulfone	<2.0		1	ug/L	2	05/19/2022 7:45 AM	010 DG9Y1/2
Aldicarb sulfoxide	<2.0		1	ug/L	4	05/19/2022 7:45 AM	010 DG9Y1/2
Carbaryl	<2.0		1	ug/L	50	05/19/2022 7:45 AM	010 DG9Y1/2
Carbofuran	<0.90		1	ug/L	40	05/19/2022 7:45 AM	010 DG9Y1/2
Methomyl	<2.0		1	ug/L	50	05/19/2022 7:45 AM	010 DG9Y1/2
Oxamyl	<2.0		1	ug/L	50	05/19/2022 7:45 AM	010 DG9Y1/2
Surr: BDMC (S)	114%		1	%REC		05/19/2022 7:45 AM	010 DG9Y1/2

Analytical Method:EPA 547

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Glyphosate	<6.0		1	ug/L	50	05/24/2022 5:39 AM	010 DG6T1/1

Analytical Method:EPA 548.1

Prep Method: EPA 548.1

Prep Date: 05/17/2022 1:38 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Endothall	<3.6		1	ug/L	50	05/24/2022 8:44 PM	010 AG3U1/1

Analytical Method:EPA 549.2

Prep Method: EPA 549.2

Prep Date: 05/17/2022 3:55 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Diquat	<0.40		1	ug/L	20	05/20/2022 8:43 PM	010 BP1B1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 06/08/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
 www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
 P.O. Box 1013
 Hampton Bays, NY 11946

Lab No. : 70214442011
 Client Sample ID.: S-127163

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 05/11/2022 10:25 AM Point S-127163
 Received : 05/11/2022 03:58 PM Location Well #5-1
 Collected By CLIENT

Analytical Method: EPA 505		Prep Method: EPA 505			Prep Date: 05/16/2022 6:00 PM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Alachlor	<0.20		1	ug/L	2	05/17/2022 2:41 PM	011 DG9T1/2
Aldrin	<0.025		1	ug/L	5	05/17/2022 2:41 PM	011 DG9T1/2
Chlordane (Technical)	<0.20		1	ug/L	2	05/17/2022 2:41 PM	011 DG9T1/2
Dieldrin	<0.050		1	ug/L	5	05/17/2022 2:41 PM	011 DG9T1/2
Endrin	<0.010		1	ug/L	2	05/17/2022 2:41 PM	011 DG9T1/2
Heptachlor	<0.025		1	ug/L	0.4	05/17/2022 2:41 PM	011 DG9T1/2
Heptachlor epoxide	<0.020		1	ug/L	0.2	05/17/2022 2:41 PM	011 DG9T1/2
Hexachlorobenzene	<0.10		1	ug/L	1	05/17/2022 2:41 PM	011 DG9T1/2
Hexachlorocyclopentadiene	<0.10		1	ug/L	5	05/17/2022 2:41 PM	011 DG9T1/2
Methoxychlor	<0.10		1	ug/L	40	05/17/2022 2:41 PM	011 DG9T1/2
PCB Screen	<0.40		1	ug/L		05/17/2022 2:41 PM	011 DG9T1/2
Toxaphene	<1.0		1	ug/L	3	05/17/2022 2:41 PM	011 DG9T1/2
gamma-BHC (Lindane)	<0.020		1	ug/L	0.2	05/17/2022 2:41 PM	011 DG9T1/2
Surr: Decachlorobiphenyl (S)	126%		1	%REC		05/17/2022 2:41 PM	011 DG9T1/2
Surr: Tetrachloro-m-xylene (S)	100%		1	%REC		05/17/2022 2:41 PM	011 DG9T1/2

Analytical Method: EPA 515.3		Prep Method: EPA 515.3			Prep Date: 05/20/2022 7:30 AM		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
2,4,5-TP (Silvex)	<0.13		1	ug/L	10	05/21/2022 10:59	011 AG3T1/1
2,4-D	<0.10		1	ug/L	50	05/21/2022 10:59	011 AG3T1/1
Dalapon	<0.70		1	ug/L	50	05/21/2022 10:59	011 AG3T1/1
Dicamba	<1.0		1	ug/L	50	05/21/2022 10:59	011 AG3T1/1
Dinoseb	<0.20		1	ug/L	7	05/21/2022 10:59	011 AG3T1/1
Pentachlorophenol	<0.040		1	ug/L	1	05/21/2022 10:59	011 AG3T1/1
Picloram	<0.10		1	ug/L	50	05/21/2022 10:59	011 AG3T1/1
Surr: 2,4-DCAA (S)	98%		1	%REC		05/21/2022 10:59	011 AG3T1/1

Analytical Method: EPA 531.2							
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
3-Hydroxycarbofuran	<2.0		1	ug/L	50	05/19/2022 2:13 PM	011 DG9Y1/2
Aldicarb	<2.0		1	ug/L	3	05/19/2022 2:13 PM	011 DG9Y1/2
Aldicarb sulfone	<2.0		1	ug/L	2	05/19/2022 2:13 PM	011 DG9Y1/2
Aldicarb sulfoxide	<2.0		1	ug/L	4	05/19/2022 2:13 PM	011 DG9Y1/2
Carbaryl	<2.0		1	ug/L	50	05/19/2022 2:13 PM	011 DG9Y1/2
Carbofuran	<0.90		1	ug/L	40	05/19/2022 2:13 PM	011 DG9Y1/2
Methomyl	<2.0		1	ug/L	50	05/19/2022 2:13 PM	011 DG9Y1/2
Oxamyl	<2.0		1	ug/L	50	05/19/2022 2:13 PM	011 DG9Y1/2
Surr: BDMC (S)	108%		1	%REC		05/19/2022 2:13 PM	011 DG9Y1/2

Qualifiers:
 DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 06/08/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70214442011
Client Sample ID.: S-127163

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 05/11/2022 10:25 AM Point S-127163
 Received : 05/11/2022 03:58 PM Location Well #5-1
 Collected By CLIENT

Analytical Method:EPA 547

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Glyphosate	<6.0		1	ug/L	50	05/24/2022 6:12 AM	011 DG6T1/1

Analytical Method:EPA 548.1

Prep Method: EPA 548.1

Prep Date: 05/17/2022 1:38 PM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Endothall	<3.6		1	ug/L	50	05/24/2022 9:20 PM	011 AG3U1/1

Analytical Method:EPA 549.2

Prep Method: EPA 549.2

Prep Date: 05/17/2022 3:55 PM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Diquat	<0.40		1	ug/L	20	05/20/2022 9:13 PM	011 BP1B1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 06/08/2022



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

WorkOrder :
 70214442

Laboratory Certifications

Pace Analytical Services Ormond Beach

- 8 East Tower Circle, Ormond Beach, FL 32174
- Alaska DEC- CS/UST/LUST
- Alabama Certification #: 41320
- Colorado Certification: FL NELAC Reciprocity
- Connecticut Certification #: PH-0216
- Delaware Certification: FL NELAC Reciprocity
- Florida Certification #: E83079
- Georgia Certification #: 955
- Guam Certification: FL NELAC Reciprocity
- Hawaii Certification: FL NELAC Reciprocity
- Illinois Certification #: 200068
- Indiana Certification: FL NELAC Reciprocity
- Kansas Certification #: E-10383
- Kentucky Certification #: 90050
- Louisiana Certification #: FL NELAC Reciprocity
- Louisiana Environmental Certificate #: 05007
- Maine Certification #: FL01264
- Maryland Certification: #346
- Massachusetts Certification #: M-FL1264
- Michigan Certification #: 9911
- Mississippi Certification: FL NELAC Reciprocity
- Missouri Certification #: 236
- Montana Certification #: Cert 0074
- Nebraska Certification: NE-OS-28-14
- New Hampshire Certification #: 2958
- New Jersey Certification #: FL022
- New York Certification #: 11608
- North Carolina Environmental Certificate #: 667
- North Carolina Certification #: 12710
- North Dakota Certification #: R-216
- Ohio DEP 87780
- Oklahoma Certification #: D9947
- Pennsylvania Certification #: 68-00547
- Puerto Rico Certification #: FL01264
- South Carolina Certification: #96042001
- Tennessee Certification #: TN02974
- Texas Certification: FL NELAC Reciprocity
- US Virgin Islands Certification: FL NELAC Reciprocity
- Virginia Environmental Certification #: 460165
- West Virginia Certification #: 9962C
- Wisconsin Certification #: 399079670
- Wyoming (EPA Region 8): FL NELAC Reciprocity

All parameters are reported to meet the NYS ELAP required detection limits (RDL) for drinking water analyses. For the analytes listed below, the reporting limit is below the laboratory verified limit of quantification (LOQ) but greater than the method detection limit (MDL); values are estimated.

Method	Method	Unit	MDL*	RDL	LOQ
505	Toxaphene	ug/L	0.57	1	2.5
505	Chlordane	ug/L	0.096	0.2	0.5
525.2	Simazine	ug/L	0.031	0.07	0.1
525.2	Benzo(a)pyrene	ug/L	0.017	0.02	0.1
549.2	Diquat	ug/L	0.165	0.4	1

* Determined annually; subject to change but must always be below the RDL and LOQ.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (631) 694-3040 FAX: (631) 420-8436
www.pacelabs.com

WorkOrder :
 70214442

Laboratory Certifications

Pace Analytical Services Long Island

575 Broad Hollow Rd, Melville, NY 11747
 Connecticut Certification #: PH-0435
 Delaware Certification # NY 10478
 Maryland Certification #: 208
 Massachusetts Certification #: M-NY026
 New Hampshire Certification #: 2987
 New Jersey Certification #: NY158
 New York Certification #: 10478 Primary Accrediting Body
 Pennsylvania Certification #: 68-00350
 Rhode Island Certification #: LAO00340
 Virginia Certification # 460302

All parameters are reported to meet the NYS ELAP required detection limits (RDL) for drinking water analyses. For the analytes listed below, the reporting limit is below the laboratory verified limit of quantification (LOQ) but greater than the method detection limit (MDL); values are estimated.

Method	Method	Unit	MDL*	RDL	LOQ
505	Toxaphene	ug/L	0.57	1	2.5
505	Chlordane	ug/L	0.096	0.2	0.5
525.2	Simazine	ug/L	0.031	0.07	0.1
525.2	Benzo(a)pyrene	ug/L	0.017	0.02	0.1
549.2	Diquat	ug/L	0.165	0.4	1

* Determined annually; subject to change but must always be below the RDL and LOQ.



575 Broad Hollow Road, Melville, NY 11747

TEL: (631) 694-3040 FAX: (631) 420-8436

www.pacelabs.com

WorkOrder :

70214442

Additional Qualifiers

M1 - Matrix spike recovery exceeded QC limits. Batch accepted based on laboratory control sample (LCS) recovery.

Del. by: *Shandy* 15:58 5/11/22

Sample Request Form PUBLIC WATER SUPPLIER

Date: 5-11-22
 Collected By: K. VUTHILAL
 Accepted By: Shandy 13:03 5/11/22
 Cooler Temp: 5.8 °C

WELL OFF LINE

WELL RUN TO SYSTEM

YES NO VOC'S PRESERVED WITH HCl

Sample Types	Purpose	Origin	Treatment Types
PW - Potable Water	RO - Routine	D - Distribution	AST - Air Stripper
GW - Groundwater	RE - Resample	RW - Raw Well	GAC - Granular Activated Charcoal
SW - Surface Water	S - Special	TW - Treated Well	N - Nitrate Removal Plant
WW - Waste Water		T - Tank	FE - Iron Removal Plant
AQ - Aqueous		MW - Monitoring Well	O - Other
S - Soil		I - Influent	
		E - Effluent	

WO#: **70214442**



70214442

Client Info:
 Name or Code: HAMPTON BAYS WATER DISTRICT
P.O. BOX 1013
 Address: HAMPTON BAYS, NEW YORK 11946
(631) 728-0179
 Phone #: _____
 Attn: _____
 Proj. # or (Name): _____
 Bill To: _____
 Copies To: _____

Sample Info:

Date/Time Collected:	Sample Type	Location	Origin	Treatment Type	Purpose	Field Readings Cl ₂ pH/Temp	Analysis	Lab No.
5/11/22 7:45am	GW	Well 1-1	RW	-	RO		SOC'S	
5/11/22 8:00am	GW	Well 1-2	RW	-	RO		SOC'S	
5/11/22 8:15am	GW	Well 1-3	RW	-	RO		SOC'S	
5/11/22 8:35am	GW	Well 2-1	RW	-	RO		SOC'S	
5/11/22 8:50am	GW	Well 2-2	RW	-	RO		SOC'S	
5/11/22 9:05am	GW	Well 3-1	RW	-	RO		SOC'S	
5/11/22 9:20am	GW	Well 3-2	RW	-	RO		SOC'S	
5/11/22 9:35am	GW	Well 3-3	RW	-	RO		SOC'S	
5/11/22 9:50am	GW	Well 4-1	RW	-	RO		SOC'S	
5/11/22 10:10am	GW	Well 4-2	RW	-	RO		SOC'S	
5/11/22 10:25am	GW	Well 5-1	RW	-	RO		SOC'S	

Remarks:



Sample Condition Upon Rec

WO#: 70214442

Client Name: Hampton Bay W.D.

Project

PM: KMM Due Date: 05/25/22 CLIENT: HIBW

Courier: Fed Ex UPS USPS Client Commercial Face Other

Tracking #:

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No N/A

Packing Material: Bubble Wrap Bubble Bags Ziploc None Other

Thermometer Used: TH091 Correction Factor: + 0.1

Cooler Temperature: 5.8 Cooler Temperature Corrected: 5.9

Temp should be above freezing to 6.0°C

USDA Regulated Soil (N/A, water sample)

Date and Initials of person examining contents: 5/11/22 EJ

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes No

Did samples originate from a foreign source including Hawaii and Puerto Rico? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

Table with 17 rows and 3 columns. Columns: Question, Yes/No/N/A, and Comments. Includes questions about Chain of Custody, Sample Labels, Preservation, and Chlorine/Sulfide tests.

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution:

Only Received 1 525.3 bottle per sample

* PM (Project Manager) review is documented electronically in LIMS.