



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Distribution
 Special

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70256702001
Client Sample ID.: 6 WHITE'S LANE

Attn To : Supt. McCuen
 Federal ID : 5103704
 Collected : 05/17/2023 08:26 AM Point
 Received : 05/17/2023 03:35 PM Location
 Collected By CLIENT

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Ca Hardness as CaCO3 (SM 2340B)	<0.50		1	mg/L		05/19/2023 12:39	001 BP4N1/1
Iron	<0.020		1	mg/L	0.3	05/19/2023 12:39	001 BP4N1/1
Manganese	<0.010		1	mg/L	0.3	05/19/2023 12:39	001 BP4N1/1
Sodium	65.6		1	mg/L		05/19/2023 12:39	001 BP4N1/1
Zinc	<0.020		1	mg/L	5	05/19/2023 12:39	001 BP4N1/1

Analytical Method:EPA 200.8

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Antimony	<0.40		1	ug/L	6	05/19/2023 12:10	001 BP4N1/1
Arsenic	<1.0		1	ug/L	10	05/19/2023 12:10	001 BP4N1/1
Barium	<0.0020		1	mg/L	2	05/19/2023 12:10	001 BP4N1/1
Beryllium	<0.30		1	ug/L	4	05/19/2023 12:10	001 BP4N1/1
Cadmium	<1.0		1	ug/L	5	05/19/2023 12:10	001 BP4N1/1
Chromium	<0.0070		1	mg/L	0.1	05/19/2023 12:10	001 BP4N1/1
Lead	<1.0		1	ug/L	15	05/19/2023 12:10	001 BP4N1/1
Mercury	<0.20		1	ug/L	2	05/19/2023 12:10	001 BP4N1/1
Nickel	<0.00050		1	mg/L		05/19/2023 12:10	001 BP4N1/1
Selenium	<2.0		1	ug/L	50	05/19/2023 12:10	001 BP4N1/1
Silver	<0.0010		1	mg/L	0.1	05/19/2023 12:10	001 BP4N1/1
Thallium	<0.30		1	ug/L	2	05/19/2023 12:10	001 BP4N1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	1.9		1	mg/L	10	05/17/2023 11:23	001 BP4U1/1
Nitrate-Nitrite (as N)	1.9		1	mg/L		05/17/2023 11:23	001 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	05/17/2023 9:33 PM	001 BP4U1/1

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
1,1,1,1-Trichloroethane	<0.50		1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Distribution
 Special

Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

Lab No. : 70256702001
Client Sample ID.: 6 WHITE'S LANE

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 05/17/2023 08:26 AM Point

Received : 05/17/2023 03:35 PM Location

Collected By CLIENT

1,1-Dichloroethene	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
1,1-Dichloropropene	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
1,2,3-Trichlorobenzene	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
1,2,3-Trichloropropane	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
1,2,4-Trichlorobenzene	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
1,2,4-Trimethylbenzene	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
1,2-Dichlorobenzene	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
1,2-Dichloroethane	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
1,2-Dichloropropane	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
1,3,5-Trimethylbenzene	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
1,3-Dichlorobenzene	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
1,3-Dichloropropane	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
1,4-Dichlorobenzene	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
2,2-Dichloropropane	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
2-Chlorotoluene	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
4-Chlorotoluene	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
Benzene	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
Bromobenzene	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
Bromochloromethane	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
Bromodichloromethane	7.3	1	ug/L		05/19/2023 1:58 PM	001 VG9C1/2
Bromoform	2.6	1	ug/L		05/19/2023 1:58 PM	001 VG9C1/2
Bromomethane	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
Carbon tetrachloride	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
Chlorobenzene	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
Chlorodifluoromethane	<0.50	N3 1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
Chloroethane	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
Chloroform	8.2	1	ug/L		05/19/2023 1:58 PM	001 VG9C1/2
Chloromethane	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
Dibromochloromethane	6.6	1	ug/L		05/19/2023 1:58 PM	001 VG9C1/2
Dibromomethane	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
Dichlorodifluoromethane	<0.50	L2 1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
Ethylbenzene	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
Hexachloro-1,3-butadiene	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
Isopropylbenzene (Cumene)	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
Methyl-tert-butyl ether	<0.50	1	ug/L	10	05/19/2023 1:58 PM	001 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
Styrene	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
Toluene	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
Total Trihalomethanes (Calc.)	24.6	1	ug/L	80	05/19/2023 1:58 PM	001 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	05/19/2023 1:58 PM	001 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Distribution
 Special

Hampton Bays Water District

P.O. Box 1013

Hampton Bays, NY 11946

Attn To : Supt. McCuen

Federal ID : 5103704

Collected : 05/17/2023 08:26 AM Point

Received : 05/17/2023 03:35 PM Location

Collected By CLIENT

Lab No. : 70256702001

Client Sample ID.: 6 WHITE'S LANE

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
cis-1,2-Dichloroethene	<0.50		1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
cis-1,3-Dichloropropene	<0.50		1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
m&p-Xylene	<0.50		1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
n-Butylbenzene	<0.50		1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
n-Propylbenzene	<0.50		1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
o-Xylene	<0.50		1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
p-Isopropyltoluene	<0.50		1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
sec-Butylbenzene	<0.50		1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
tert-Butylbenzene	<0.50		1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
trans-1,2-Dichloroethene	<0.50		1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
trans-1,3-Dichloropropene	<0.50		1	ug/L	5	05/19/2023 1:58 PM	001 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	97%		1	%REC		05/19/2023 1:58 PM	001 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	99%		1	%REC		05/19/2023 1:58 PM	001 VG9C1/2

Analytical Method:Field Method

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Field Residual Chlorine	0.49	N3	1	mg/L	4	05/17/2023 8:26 AM	001 SP5T1/1

Analytical Method:SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 05/17/2023 3:40 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	05/18/2023 9:40 AM	001 SP5T1/1
Total Coliforms	Absent		1		Absent	05/18/2023 9:40 AM	001 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

WorkOrder :
70256702

Laboratory Certifications

Pace Analytical Services Long Island

575 Broad Hollow Rd, Melville, NY 11747
Connecticut Certification #: PH-0435
Delaware Certification # NY 10478
Maryland Certification #: 208
Massachusetts Certification #: M-NY026
New Hampshire Certification #: 2987
New Jersey Certification #: NY158
New York Certification #: 10478 Primary Accrediting Body
Pennsylvania Certification #: 68-00350
Rhode Island Certification #: LAO00340
Virginia Certification # 460302



575 Broad Hollow Road, Melville, NY 11747

TEL: (516) 370-6000 FAX: (516) 886-5526

www.pacelabs.com


WorkOrder :

70256702

Additional Qualifiers

L2 - Analyte recovery in the laboratory control sample (LCS) was below QC limits. Results for this analyte in associated samples may be biased low.

N3 - Accreditation is not offered by the relevant laboratory accrediting body for this parameter.



Sample Condition Upon Receipt

Client Name: Hampton Bay

Project

WO#: 70256702

Due Date: 05/30/23

PM: KMM

CLIENT: HBW

Courier: Fed-Ex UPS USPS Client Commercial Pace Other

Tracking #: _____

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No N/A

Packing Material: Bubble Wrap Bubble Bags Ziploc None Other

Thermometer Used: TH# TH148 Correction Factor: 0.3

Cooler Temperature(°C): 3.6 Cooler Temperature Corrected(°C): 3.3

Temp should be above freezing to 6.0°C

USDA Regulated Soil (N/A, water sample)

Date and Initials of person examining contents: MW 5/17/23

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes No

Did samples originate from a foreign source including Hawaii and Puerto Rico)? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

				COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		5.
Short Hold Time Analysis (<72hr):	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No		7.
Sufficient Volume: (Triple volume provided for)	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		10.
Containers Intact:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		11.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> N/A	Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		12. <u>Time of collection taken off of bottles</u>
-Includes date/time/ID; Matrix: <u>SLWT OIL</u>				
All containers needing preservation have been checked?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # <u>HC210330</u>				Sample #
All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, NAOH>12 Cyanide)	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRD/8015 (water).				
Per Method, VOA pH is checked after analysis				
Samples checked for dechlorination:	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> N/A	14.
KI starch test strips Lot #				
Residual chlorine strips Lot #				Positive for Res. Chlorine? Y N
SM 4500 CN samples checked for sulfide?	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> N/A	15.
Lead Acetate Strips Lot #				Positive for Sulfide? Y N
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	<input type="checkbox"/> N/A	16.
Trip Blank Present:	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> N/A	17.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable):				

Field Data Required? Y / N

Date/Time: _____

Client Notification/ Resolution:

Person Contacted: _____

Comments/ Resolution: _____
