



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District

PO Box 1013

Hampton Bays, NY 11946

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 07/05/2023 07:30 AM Point S-15687

Received : 07/05/2023 03:45 PM Location Well #1-1

Collected By CLIENT

Lab No. : 70262141001

Client Sample ID.: S-15687

<u>Analytical Method:</u> EPA 515.3		<u>Prep Method:</u> EPA 515.3			<u>Prep Date:</u> 07/11/2023 10:05		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
2,4,5-TP (Silvex)	<0.20		1	ug/L	10	07/13/2023 7:23 AM	001 AG3T1/1
2,4-D	<0.10		1	ug/L	50	07/13/2023 7:23 AM	001 AG3T1/1
Dalapon	<1.0		1	ug/L	50	07/13/2023 7:23 AM	001 AG3T1/1
Dicamba	<0.10		1	ug/L	50	07/13/2023 7:23 AM	001 AG3T1/1
Dinoseb	<0.20		1	ug/L	7	07/13/2023 7:23 AM	001 AG3T1/1
Pentachlorophenol	<0.040		1	ug/L	1	07/13/2023 7:23 AM	001 AG3T1/1
Picloram	<0.10		1	ug/L	50	07/13/2023 7:23 AM	001 AG3T1/1
Surr: 2,4-DCAA (S)	98%		1	%REC		07/13/2023 7:23 AM	001 AG3T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 07/17/2023

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District

PO Box 1013

Hampton Bays, NY 11946

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 07/05/2023 07:45 AM Point S-24848

Received : 07/05/2023 03:45 PM Location Well #1-2

Collected By CLIENT

Lab No. : 70262141002

Client Sample ID.: S-24848

<u>Analytical Method:</u> EPA 515.3		<u>Prep Method:</u> EPA 515.3			<u>Prep Date:</u> 07/11/2023 10:05		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
2,4,5-TP (Silvex)	<0.20		1	ug/L	10	07/13/2023 8:22 AM	002 AG3T1/1
2,4-D	<0.10		1	ug/L	50	07/13/2023 8:22 AM	002 AG3T1/1
Dalapon	<1.0		1	ug/L	50	07/13/2023 8:22 AM	002 AG3T1/1
Dicamba	<0.10		1	ug/L	50	07/13/2023 8:22 AM	002 AG3T1/1
Dinoseb	<0.20		1	ug/L	7	07/13/2023 8:22 AM	002 AG3T1/1
Pentachlorophenol	<0.040		1	ug/L	1	07/13/2023 8:22 AM	002 AG3T1/1
Picloram	<0.10		1	ug/L	50	07/13/2023 8:22 AM	002 AG3T1/1
Surr: 2,4-DCAA (S)	97%		1	%REC		07/13/2023 8:22 AM	002 AG3T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 07/17/2023

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District

PO Box 1013

Hampton Bays, NY 11946

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 07/05/2023 08:00 AM Point S-31636

Received : 07/05/2023 03:45 PM Location Well #1-3

Collected By CLIENT

Lab No. : 70262141003

Client Sample ID.: S-31636

<u>Analytical Method:</u> EPA 515.3		<u>Prep Method:</u> EPA 515.3			<u>Prep Date:</u> 07/11/2023 10:05		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
2,4,5-TP (Silvex)	<0.20		1	ug/L	10	07/13/2023 8:52 AM	003 AG3T1/1
2,4-D	<0.10		1	ug/L	50	07/13/2023 8:52 AM	003 AG3T1/1
Dalapon	<1.0		1	ug/L	50	07/13/2023 8:52 AM	003 AG3T1/1
Dicamba	<0.10		1	ug/L	50	07/13/2023 8:52 AM	003 AG3T1/1
Dinoseb	<0.20		1	ug/L	7	07/13/2023 8:52 AM	003 AG3T1/1
Pentachlorophenol	<0.040		1	ug/L	1	07/13/2023 8:52 AM	003 AG3T1/1
Picloram	<0.10		1	ug/L	50	07/13/2023 8:52 AM	003 AG3T1/1
Surr: 2,4-DCAA (S)	95%		1	%REC		07/13/2023 8:52 AM	003 AG3T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 07/17/2023

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946
Attn To : Keith Tuthill

Lab No. : 70262141004
Client Sample ID.: S-50970

Federal ID : 5103704
 Collected : 07/05/2023 08:20 AM Point S-50970
 Received : 07/05/2023 03:45 PM Location Well #2-1
 Collected By CLIENT

<u>Analytical Method:</u> EPA 515.3		<u>Prep Method:</u> EPA 515.3			<u>Prep Date:</u> 07/11/2023 10:05		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
2,4,5-TP (Silvex)	<0.20		1	ug/L	10	07/13/2023 9:22 AM	004 AG3T1/1
2,4-D	<0.10		1	ug/L	50	07/13/2023 9:22 AM	004 AG3T1/1
Dalapon	<1.0		1	ug/L	50	07/13/2023 9:22 AM	004 AG3T1/1
Dicamba	<0.10		1	ug/L	50	07/13/2023 9:22 AM	004 AG3T1/1
Dinoseb	<0.20		1	ug/L	7	07/13/2023 9:22 AM	004 AG3T1/1
Pentachlorophenol	<0.040		1	ug/L	1	07/13/2023 9:22 AM	004 AG3T1/1
Picloram	<0.10		1	ug/L	50	07/13/2023 9:22 AM	004 AG3T1/1
Surr: 2,4-DCAA (S)	91%		1	%REC		07/13/2023 9:22 AM	004 AG3T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 07/17/2023



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District

PO Box 1013

Hampton Bays, NY 11946

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 07/05/2023 08:35 AM Point S-74071

Received : 07/05/2023 03:45 PM Location Well #2-2

Collected By CLIENT

Lab No. : 70262141005

Client Sample ID.: S-74071

<u>Analytical Method:</u> EPA 515.3		<u>Prep Method:</u> EPA 515.3			<u>Prep Date:</u> 07/11/2023 10:05		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
2,4,5-TP (Silvex)	<0.20		1	ug/L	10	07/13/2023 9:51 AM	005 AG3T1/1
2,4-D	<0.10		1	ug/L	50	07/13/2023 9:51 AM	005 AG3T1/1
Dalapon	<1.0		1	ug/L	50	07/13/2023 9:51 AM	005 AG3T1/1
Dicamba	<0.10		1	ug/L	50	07/13/2023 9:51 AM	005 AG3T1/1
Dinoseb	<0.20		1	ug/L	7	07/13/2023 9:51 AM	005 AG3T1/1
Pentachlorophenol	<0.040		1	ug/L	1	07/13/2023 9:51 AM	005 AG3T1/1
Picloram	<0.10		1	ug/L	50	07/13/2023 9:51 AM	005 AG3T1/1
Surr: 2,4-DCAA (S)	102%		1	%REC		07/13/2023 9:51 AM	005 AG3T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 07/17/2023

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District

PO Box 1013

Hampton Bays, NY 11946

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 07/05/2023 08:55 AM Point S-58350

Received : 07/05/2023 03:45 PM Location Well #3-1

Collected By CLIENT

Lab No. : 70262141006

Client Sample ID.: S-58350

<u>Analytical Method:</u> EPA 515.3		<u>Prep Method:</u> EPA 515.3			<u>Prep Date:</u> 07/11/2023 10:05		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
2,4,5-TP (Silvex)	<0.20		1	ug/L	10	07/13/2023 10:21	006 AG3T1/1
2,4-D	<0.10		1	ug/L	50	07/13/2023 10:21	006 AG3T1/1
Dalapon	<1.0		1	ug/L	50	07/13/2023 10:21	006 AG3T1/1
Dicamba	<0.10		1	ug/L	50	07/13/2023 10:21	006 AG3T1/1
Dinoseb	<0.20		1	ug/L	7	07/13/2023 10:21	006 AG3T1/1
Pentachlorophenol	<0.040		1	ug/L	1	07/13/2023 10:21	006 AG3T1/1
Picloram	<0.10		1	ug/L	50	07/13/2023 10:21	006 AG3T1/1
Surr: 2,4-DCAA (S)	94%		1	%REC		07/13/2023 10:21	006 AG3T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 07/17/2023

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District

PO Box 1013

Hampton Bays, NY 11946

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 07/05/2023 09:10 AM Point S-58351

Received : 07/05/2023 03:45 PM Location Well #3-2

Collected By CLIENT

Lab No. : 70262141007

Client Sample ID.: S-58351

<u>Analytical Method:</u> EPA 515.3		<u>Prep Method:</u> EPA 515.3			<u>Prep Date:</u> 07/11/2023 10:05		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
2,4,5-TP (Silvex)	<0.20		1	ug/L	10	07/13/2023 10:51	007 AG3T1/1
2,4-D	<0.10		1	ug/L	50	07/13/2023 10:51	007 AG3T1/1
Dalapon	<1.0		1	ug/L	50	07/13/2023 10:51	007 AG3T1/1
Dicamba	<0.10		1	ug/L	50	07/13/2023 10:51	007 AG3T1/1
Dinoseb	<0.20		1	ug/L	7	07/13/2023 10:51	007 AG3T1/1
Pentachlorophenol	<0.040		1	ug/L	1	07/13/2023 10:51	007 AG3T1/1
Picloram	<0.10		1	ug/L	50	07/13/2023 10:51	007 AG3T1/1
Surr: 2,4-DCAA (S)	92%		1	%REC		07/13/2023 10:51	007 AG3T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 07/17/2023

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District

PO Box 1013

Hampton Bays, NY 11946

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 07/05/2023 09:25 AM Point S-58352

Received : 07/05/2023 03:45 PM Location Well #3-3

Collected By CLIENT

Lab No. : 70262141008

Client Sample ID.: S-58352

<u>Analytical Method:</u> EPA 515.3		<u>Prep Method:</u> EPA 515.3			<u>Prep Date:</u> 07/11/2023 10:05		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
2,4,5-TP (Silvex)	<0.20		1	ug/L	10	07/13/2023 11:21	008 AG3T1/1
2,4-D	<0.10		1	ug/L	50	07/13/2023 11:21	008 AG3T1/1
Dalapon	<1.0		1	ug/L	50	07/13/2023 11:21	008 AG3T1/1
Dicamba	<0.10		1	ug/L	50	07/13/2023 11:21	008 AG3T1/1
Dinoseb	<0.20		1	ug/L	7	07/13/2023 11:21	008 AG3T1/1
Pentachlorophenol	<0.040		1	ug/L	1	07/13/2023 11:21	008 AG3T1/1
Picloram	<0.10		1	ug/L	50	07/13/2023 11:21	008 AG3T1/1
Surr: 2,4-DCAA (S)	88%		1	%REC		07/13/2023 11:21	008 AG3T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 07/17/2023

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District

PO Box 1013

Hampton Bays, NY 11946

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 07/05/2023 09:45 AM Point S-108065

Received : 07/05/2023 03:45 PM Location Well #4-1

Collected By CLIENT

Lab No. : 70262141009

Client Sample ID.: S-108065

Analytical Method: EPA 515.3		Prep Method: EPA 515.3			Prep Date: 07/11/2023 10:05		
Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
2,4,5-TP (Silvex)	<0.20		1	ug/L	10	07/13/2023 11:51	009 AG3T1/1
2,4-D	<0.10		1	ug/L	50	07/13/2023 11:51	009 AG3T1/1
Dalapon	<1.0		1	ug/L	50	07/13/2023 11:51	009 AG3T1/1
Dicamba	<0.10		1	ug/L	50	07/13/2023 11:51	009 AG3T1/1
Dinoseb	<0.20		1	ug/L	7	07/13/2023 11:51	009 AG3T1/1
Pentachlorophenol	<0.040		1	ug/L	1	07/13/2023 11:51	009 AG3T1/1
Picloram	<0.10		1	ug/L	50	07/13/2023 11:51	009 AG3T1/1
Surr: 2,4-DCAA (S)	85%		1	%REC		07/13/2023 11:51	009 AG3T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 07/17/2023

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District

PO Box 1013

Hampton Bays, NY 11946

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 07/05/2023 10:20 AM Point S-127163

Received : 07/05/2023 03:45 PM Location Well #5-1

Collected By CLIENT

Lab No. : 70262141011

Client Sample ID.: S-127163

<u>Analytical Method:</u> EPA 515.3		<u>Prep Method:</u> EPA 515.3			<u>Prep Date:</u> 07/12/2023 12:30		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
2,4,5-TP (Silvex)	<0.20		1	ug/L	10	07/13/2023 8:16 PM	011 AG3T1/1
2,4-D	<0.10		1	ug/L	50	07/13/2023 8:16 PM	011 AG3T1/1
Dalapon	<1.0		1	ug/L	50	07/13/2023 8:16 PM	011 AG3T1/1
Dicamba	<0.10		1	ug/L	50	07/13/2023 8:16 PM	011 AG3T1/1
Dinoseb	<0.20		1	ug/L	7	07/13/2023 8:16 PM	011 AG3T1/1
Pentachlorophenol	<0.040		1	ug/L	1	07/13/2023 8:16 PM	011 AG3T1/1
Picloram	<0.10		1	ug/L	50	07/13/2023 8:16 PM	011 AG3T1/1
Surr: 2,4-DCAA (S)	93%		1	%REC		07/13/2023 8:16 PM	011 AG3T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 07/17/2023

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

WorkOrder :

70262141

Laboratory Certifications

Pace Analytical Services Ormond Beach

8 East Tower Circle, Ormond Beach, FL 32174
Alaska DEC- CS/UST/LUST
Alabama Certification #: 41320
Colorado Certification: FL NELAC Reciprocity
Connecticut Certification #: PH-0216
Delaware Certification: FL NELAC Reciprocity
DoD-ANAB #: ADE-3199
Florida Certification #: E83079
Georgia Certification #: 955
Guam Certification: FL NELAC Reciprocity
Hawaii Certification: FL NELAC Reciprocity
Illinois Certification #: 200068
Indiana Certification: FL NELAC Reciprocity
Kansas Certification #: E-10383
Kentucky Certification #: 90050
Louisiana Certification #: FL NELAC Reciprocity
Louisiana Environmental Certificate #: 05007
Maine Certification #: FL01264
Maryland Certification: #346
Massachusetts Certification #: M-FL1264
Michigan Certification #: 9911
Mississippi Certification: FL NELAC Reciprocity
Missouri Certification #: 236
Montana Certification #: Cert 0074
Nebraska Certification: NE-OS-28-14
New Hampshire Certification #: 2958
New Jersey Certification #: FL022
New York Certification #: 11608
North Carolina Environmental Certificate #: 667
North Carolina Certification #: 12710
North Dakota Certification #: R-216
Ohio DEP 87780
Oklahoma Certification #: D9947
Pennsylvania Certification #: 68-00547
Puerto Rico Certification #: FL01264
South Carolina Certification: #96042001
Tennessee Certification #: TN02974
Texas Certification: FL NELAC Reciprocity
US Virgin Islands Certification: FL NELAC Reciprocity
Virginia Environmental Certification #: 460165
West Virginia Certification #: 9962C
Wisconsin Certification #: 399079670
Wyoming (EPA Region 8): FL NELAC Reciprocity

WO#: 70262141



70262141

(11747
:36

Sample Request Form PUBLIC WATER SUPPLIER

Date: 7-5-2023

Collected By: Julia Doherty

Accepted By: Julia Doherty 7/5/23

Cooler Temp: 13.5 °C 1315

WELL OFF LINE

WELL RUN TO SYSTEM

YES NO VOC'S PRESERVED WITH HCl

Client Info:

Name or Code: HAMPTON BAYS WATER DISTRICT
Address: P.O. BOX 1013
HAMPTON BAYS, NEW YORK 11946
(631) 726-6179

Phone #: _____
Attn: _____
Proj. # or (Name): _____
Bill To: _____
Copies To: _____

Sample Info:

Date/Time Collected:	Sample Type	Location	Origin	Treatment Type	Purpose	Field Readings Cl ₂ pH/temp	Analysis	Lab No.
7/5/23 7:36	GW	Well 1-1	Rw	-	RO		Method 515	
7/5/23 7:45	GW	Well 1-2	Rw	-	RO		Method 515	
7/5/23 8:00	GW	Well 1-3	Rw	-	RO		Method 515	
7/5/23 8:20	GW	Well 2-1	Rw	-	RO		Method 515	
7/5/23 8:55	GW	Well 2-2	Rw	-	RO		Method 515	
7/5/23 8:55	GW	Well 3-1	Rw	-	RO		Method 515	
7/5/23 9:10	GW	Well 3-2	Rw	-	RO		Method 515	
7/5/23 9:25	GW	Well 3-3	Rw	-	RO		Method 515	
7/5/23 9:45	GW	Well 4-1	Rw	-	RO		Method 515	
7/5/23 10:00	GW	Well 4-2	Rw	-	RO		Method 515	
7/5/23 10:20	GW	Well 5-1	Rw	-	RO		Method 515	
Remarks:								

Sample Type	Purpose	Origin	Treatment Types
PW - Potable Water	RO - Routine	D - Distribution	AST - Air Stripper
GW - Groundwater	RE - Resample	RW - Raw Well	GAC - Granular Activated Charcoal
SW - Surface Water	S - Special	TW - Treated Well	N - Nitrate Removal Plant
WW - Waste Water		T - Tank	FE - Iron Removal Plant
AQ - Aqueous		MW - Monitoring Well	O - Other
S - Soil		I - Influent	
		E - Effluent	

WO#: 70262141

PM: KMM Due Date: 07/20/23
CLIENT: HBW

Client Name: HBW Project _____

Courier: Fed Ex UPS USPS Client Commercial Pace Other

Tracking #: _____

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No Temperature Blank Present: Yes No
 Packing Material: Bubble Wrap Bubble Bags Ziploc None Other Type of Ice: Wet Blue None

Thermometer Used: _____ Correction Factor: _____ Samples on ice, cooling process has begun
 Cooler Temperature (°C) 3.5 Cooler Temperature Corrected (°C) 3.2 Date/Time 5035A kits placed in freezer 7/15/23 1545
 Temp should be above freezing to 6.0°C

USDA Regulated Soil (N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes No

Did samples originate from a foreign source including Hawaii and Puerto Rico? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.

Date and Initials of person examining contents:

	COMMENTS:
Chain of Custody Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out: <input type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished: <input type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr): <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used: <input type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Containers Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note: if sediment is visible in the dissolved container.
Sample Labels match COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID/Analysis: Matrix: <u>SL</u> <u>WT</u> <input type="checkbox"/> OIL <input type="checkbox"/> OTHER	

Date and Initials of person checking preservation:

All containers needing preservation have been pH paper Lot #	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, NAOH>12 Cyanide)	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	Sample #
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water).		Initial when completed: _____ Lot # of added preservative: _____ Date/Time preservative added: _____
Per Method, VOA pH is checked after analysis		
Samples checked for dechlorination: KI starch test strips Lot #	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
Residual chlorine strips Lot #		15. Positive for Sulfide? Y N
SM 4500 CN samples checked for sulfide: Lead Acetate Strips Lot #	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	17.
Trip Blank Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Trip Blank Custody Seals Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	

Client Notification/ Resolution: _____ Field Data Required? Y / N

Person Contacted: _____ Date/Time: _____

Comments/ Resolution: _____

* PM (Project Manager) review is documented electronically in LIMS.