



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Distribution
 Routine

Hampton Bays Water District

PO Box 1013

Hampton Bays, NY 11946

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 08/02/2023 08:30 AM Point HB3
 Received : 08/02/2023 04:25 PM Location U.S.C.G.
 Collected By CLIENT Foster Ave.

Lab No. : 70265429001

Client Sample ID.: HB3

Analytical Method: EPA 524.2

| Parameter(s) | Results | Qualifier | D.F. | Units | Limit | Analyzed: | Container: |
|--------------------------------|---------|-----------|------|-------|-------|------------------|-------------|
| 1,1,1,2-Tetrachloroethane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| 1,1,1-Trichloroethane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| 1,1,2,2-Tetrachloroethane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| 1,1,2-Trichloroethane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| 1,1,2-Trichlorotrifluoroethane | <0.50 | N3 | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| 1,1-Dichloroethane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| 1,1-Dichloropropene | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| 1,2,3-Trichlorobenzene | <0.50 | L1 | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| 1,2,3-Trichloropropane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| 1,2,4-Trichlorobenzene | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| 1,2,4-Trimethylbenzene | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| 1,2-Dichlorobenzene | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| 1,2-Dichloroethane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| 1,2-Dichloropropane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| 1,3,5-Trimethylbenzene | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| 1,3-Dichlorobenzene | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| 1,3-Dichloropropane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| 1,4-Dichlorobenzene | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| 2,2-Dichloropropane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| 2-Chlorotoluene | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| 4-Chlorotoluene | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| Benzene | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| Bromobenzene | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| Bromochloromethane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| Bromodichloromethane | 0.69 | | 1 | ug/L | | 08/14/2023 10:26 | 001 VG9C1/2 |
| Bromoform | 0.71 | | 1 | ug/L | | 08/14/2023 10:26 | 001 VG9C1/2 |
| Bromomethane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| Carbon tetrachloride | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| Chlorobenzene | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| Chlorodifluoromethane | <0.50 | N3 | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| Chloroethane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| Chloroform | 1.6 | | 1 | ug/L | | 08/14/2023 10:26 | 001 VG9C1/2 |
| Chloromethane | <0.50 | L1 | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| Dibromochloromethane | 1.1 | | 1 | ug/L | | 08/14/2023 10:26 | 001 VG9C1/2 |
| Dibromomethane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| Dichlorodifluoromethane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| Ethylbenzene | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| Hexachloro-1,3-butadiene | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| Isopropylbenzene (Cumene) | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Distribution
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70265429001
Client Sample ID.: HB3

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 08/02/2023 08:30 AM Point HB3
 Received : 08/02/2023 04:25 PM Location U.S.C.G.
 Collected By CLIENT Foster Ave.

| | | | | | | |
|----------------------------------|-------|---|------|----|------------------|-------------|
| Methyl-tert-butyl ether | <0.50 | 1 | ug/L | 10 | 08/14/2023 10:26 | 001 VG9C1/2 |
| Methylene Chloride | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| Styrene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| Tetrachloroethene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| Toluene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| Total Trihalomethanes (Calc.) | 4.1 | 1 | ug/L | 80 | 08/14/2023 10:26 | 001 VG9C1/2 |
| Trichloroethene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| Trichlorofluoromethane | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| Vinyl chloride | <0.50 | 1 | ug/L | 2 | 08/14/2023 10:26 | 001 VG9C1/2 |
| cis-1,2-Dichloroethene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| cis-1,3-Dichloropropene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| m&p-Xylene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| n-Butylbenzene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| n-Propylbenzene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| o-Xylene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| p-Isopropyltoluene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| sec-Butylbenzene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| tert-Butylbenzene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| trans-1,2-Dichloroethene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| trans-1,3-Dichloropropene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:26 | 001 VG9C1/2 |
| Surr: 1,2-Dichlorobenzene-d4 (S) | 109% | 1 | %REC | | 08/14/2023 10:26 | 001 VG9C1/2 |
| Surr: 4-Bromofluorobenzene (S) | 93% | 1 | %REC | | 08/14/2023 10:26 | 001 VG9C1/2 |

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Distribution
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70265429002
Client Sample ID.: HB8

Attn To : Keith Tuthill
 Federal ID : 5103704
 Collected : 08/02/2023 10:00 AM Point HB8
 Received : 08/02/2023 04:25 PM Location B. McCormack
 Collected By CLIENT Bittersweet Ave.

Analytical Method: EPA 524.2

| Parameter(s) | Results | Qualifier | D.F. | Units | Limit | Analyzed: | Container: |
|--------------------------------|---------|-----------|------|-------|-------|------------------|-------------|
| 1,1,1,2-Tetrachloroethane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| 1,1,1-Trichloroethane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| 1,1,2,2-Tetrachloroethane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| 1,1,2-Trichloroethane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| 1,1,2-Trichlorotrifluoroethane | <0.50 | N3 | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| 1,1-Dichloroethane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| 1,1-Dichloropropene | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| 1,2,3-Trichlorobenzene | <0.50 | L1 | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| 1,2,3-Trichloropropane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| 1,2,4-Trichlorobenzene | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| 1,2,4-Trimethylbenzene | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| 1,2-Dichlorobenzene | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| 1,2-Dichloroethane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| 1,2-Dichloropropane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| 1,3,5-Trimethylbenzene | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| 1,3-Dichlorobenzene | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| 1,3-Dichloropropane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| 1,4-Dichlorobenzene | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| 2,2-Dichloropropane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| 2-Chlorotoluene | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| 4-Chlorotoluene | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| Benzene | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| Bromobenzene | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| Bromochloromethane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| Bromodichloromethane | <0.50 | | 1 | ug/L | | 08/14/2023 10:48 | 002 VG9C1/2 |
| Bromoform | <0.50 | | 1 | ug/L | | 08/14/2023 10:48 | 002 VG9C1/2 |
| Bromomethane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| Carbon tetrachloride | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| Chlorobenzene | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| Chlorodifluoromethane | <0.50 | N3 | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| Chloroethane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| Chloroform | 1.1 | | 1 | ug/L | | 08/14/2023 10:48 | 002 VG9C1/2 |
| Chloromethane | <0.50 | L1 | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| Dibromochloromethane | <0.50 | | 1 | ug/L | | 08/14/2023 10:48 | 002 VG9C1/2 |
| Dibromomethane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| Dichlorodifluoromethane | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| Ethylbenzene | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| Hexachloro-1,3-butadiene | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| Isopropylbenzene (Cumene) | <0.50 | | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Distribution
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70265429002
Client Sample ID.: HB8

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 08/02/2023 10:00 AM Point HB8
 Received : 08/02/2023 04:25 PM Location B. McCormack
 Collected By CLIENT Bittersweet Ave.

| | | | | | | |
|----------------------------------|-------|---|------|----|------------------|-------------|
| Methyl-tert-butyl ether | <0.50 | 1 | ug/L | 10 | 08/14/2023 10:48 | 002 VG9C1/2 |
| Methylene Chloride | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| Styrene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| Tetrachloroethene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| Toluene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| Total Trihalomethanes (Calc.) | 1.1 | 1 | ug/L | 80 | 08/14/2023 10:48 | 002 VG9C1/2 |
| Trichloroethene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| Trichlorofluoromethane | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| Vinyl chloride | <0.50 | 1 | ug/L | 2 | 08/14/2023 10:48 | 002 VG9C1/2 |
| cis-1,2-Dichloroethene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| cis-1,3-Dichloropropene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| m&p-Xylene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| n-Butylbenzene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| n-Propylbenzene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| o-Xylene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| p-Isopropyltoluene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| sec-Butylbenzene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| tert-Butylbenzene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| trans-1,2-Dichloroethene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| trans-1,3-Dichloropropene | <0.50 | 1 | ug/L | 5 | 08/14/2023 10:48 | 002 VG9C1/2 |
| Surr: 1,2-Dichlorobenzene-d4 (S) | 100% | 1 | %REC | | 08/14/2023 10:48 | 002 VG9C1/2 |
| Surr: 4-Bromofluorobenzene (S) | 95% | 1 | %REC | | 08/14/2023 10:48 | 002 VG9C1/2 |

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

WorkOrder :
70265429

Laboratory Certifications

Pace Analytical Services Long Island

575 Broad Hollow Rd, Melville, NY 11747
Connecticut Certification #: PH-0435
Delaware Certification # NY 10478
Maryland Certification #: 208
Massachusetts Certification #: M-NY026
New Hampshire Certification #: 2987
New Jersey Certification #: NY158
New York Certification #: 10478 Primary Accrediting Body
Pennsylvania Certification #: 68-00350
Rhode Island Certification #: LAO00340
Virginia Certification # 460302



575 Broad Hollow Road, Melville, NY 11747

TEL: (516) 370-6000 FAX: (516) 886-5526

www.pacelabs.com

WorkOrder :

70265429

Additional Qualifiers

L1 - Analyte recovery in the laboratory control sample (LCS) was above QC limits. Results for this analyte in associated samples may be biased high.

N3 - Accreditation is not offered by the relevant laboratory accrediting body for this parameter.

WO#: 70265429



70265429

Sample Request Form PUBLIC WATER SUPPLIER

Pay Rudy
8/2/23 1625

Date: 8/2/23

Collected By: W. S. Gregory / G. Alexander

Accepted By: Pay Rudy 8/2/23

Cooler Temp: 37 °C (W) 1255

WELL OFF LINE

WELL RUN TO SYSTEM

YES NO VOC'S PRESERVED WITH HCl

Client Info:

Name or Code: HAMPTON BAYS WATER DISTRICT

Address: P.O. BOX 1013
HAMPTON BAYS, NEW YORK 11946
(631) 726-0179

Phone #: _____

Attn: _____

Proj. # or (Name): _____

Bill To: _____

Copies To: _____

| Sample Types | Purpose | Origin | Treatment Types |
|--------------------|---------------|----------------------|-----------------------------------|
| PW - Potable Water | RO - Routine | D - Distribution | AST - Air Stripper |
| GW - Groundwater | RE - Resample | RW - Raw Well | GAC - Granular Activated Charcoal |
| SW - Surface Water | S - Special | TW - Treated Well | N - Nitrate Removal Plant |
| WW - Waste Water | | T - Tank | FE - Iron Removal Plant |
| AQ - Aqueous | | MW - Monitoring Well | O - Other |
| S - Soil | | I - Influent | |
| | | E - Effluent | |

Sample Info:

| Date/Time Collected: | Sample Type | Location | Origin | Treatment Type | Purpose | Field Readings Cl ₂ pH/Temp | Analysis | Lab No. |
|----------------------|-------------|----------|--------|----------------|---------|--|---------------------------------|---------|
| 8/2/23/800 | PW | #9 | D | - | RO | 0.62 7.86 | BACT w/CC | |
| 8/2/23/815 | PW | #2 | D | - | RO | 0.49 7.27 | BACT w/CC | |
| 8/2/23/830 | PW | #3 | D | - | RO | 0.39 7.31 | BACT w/CC <u>Charcoals, VOC</u> | 001 |
| 8/2/23/845 | PW | #4 | D | - | RO | 0.57 7.43 | BACT w/CC | |
| 8/2/23/900 | PW | #5 | D | - | RO | 0.52 7.36 | BACT w/CC | |
| 8/2/23/915 | PW | #6 | D | - | RO | 0.63 7.40 | BACT w/CC | |
| 8/2/23/930 | PW | #27 | D | - | RO | 0.48 7.33 | BACT w/CC | |
| 8/2/23/945 | PW | #7 | D | - | RO | 0.65 7.27 | BACT w/CC | |
| 8/2/23/1000 | PW | #8 | D | - | RO | 0.71 7.56 | BACT w/CC <u>Charcoals, VOC</u> | 002 |
| 8/2/23/1015 | PW | #10 | D | - | RO | 0.77 7.59 | BACT w/CC | |
| 8/2/23/1100AM | PW | #35 | D | - | RO | 0.61 7.41 | BACT w/CC | |

Remarks:

WO# : 70265429
PM: KMM Due Date: 08/15/23
CLIENT: HBW

Client Name: HBW Project # _____

Courier: Fed Ex UPS USPS Client Commercial Pace Other

Tracking #: _____

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No Temperature Blank Present: Yes No
 Packing Material: Bubble Wrap Bubble Bags Ziploc None Other Type of Ice: Wet Blue None

Thermometer Used: _____ Correction Factor: _____ Samples on ice, cooling process has begun
 Cooler Temperature (°C): 3.7 Cooler Temperature Corrected (°C): 3.3 Date/Time 5035A kits placed in freezer: 8/2/23 1625
 Temp should be above freezing to 6.0°C

USDA Regulated Soil (N/A, water sample)
 Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes No

Did samples originate from a foreign source including Hawaii and Puerto Rico)? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.
 Date and Initials of person examining contents:

| | COMMENTS: |
|---|--|
| Chain of Custody Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | 1. |
| Chain of Custody Filled Out: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | 2. |
| Chain of Custody Relinquished: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | 3. |
| Sampler Name & Signature on COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A | 4. |
| Samples Arrived within Hold Time: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | 5. |
| Short Hold Time Analysis (<72hr): <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | 6. |
| Rush Turn Around Time Requested <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | 7. |
| Sufficient Volume: (Triple volume provided for MS/MSD) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | 8. |
| Correct Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | 9. |
| -Pace Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | 10. |
| Containers Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | 10. |
| Filtered volume received for Dissolved tests <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <u>N/A</u> | 11. Note: if sediment is visible in the dissolved container. |
| Sample Labels match COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | 12. |
| -Includes date/time/ID/Analysis Matrix: <u>SL</u> <u>WT</u> <u>OIL</u> <u>OTHER</u> | |

Date and Initials of person checking preservation:

| | |
|--|--|
| All containers needing preservation have been pH paper Lot # | 13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl |
| All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH > 9 Sulfide, NAOH > 12 Cyanide) | Sample # |
| Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis | Initial when completed: Lot # of added preservative: Date/Time preservative added: |
| Samples checked for dechlorination: KI starch test strips Lot # | 14. Positive for Res. Chlorine? Y N |
| Residual chlorine strips Lot # | 15. Positive for Sulfide? Y N |
| SM 4500 CN samples checked for sul | 16. |
| Lead Acetate Strips Lot # | 17. |
| Headspace in VOA Vials (>6mm): | |
| Trip Blank Present: | |
| Trip Blank Custody Seals Present | |

Client Notification/ Resolution: _____ Field Data Required? Y / N
 Person Contacted: _____ Date/Time: _____
 Comments/ Resolution: _____

* PM (Project Manager) review is documented electronically in LIMS.