



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70275476003
Client Sample ID.: S-31636

Attn To : Keith Tuthill
 Federal ID : 5103704
 Collected : 10/25/2023 08:00 AM Point S-31636
 Received : 10/25/2023 02:00 PM Location Well #1-3
 Collected By CLIENT

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	<0.020		1	mg/L	0.3	11/02/2023 12:09	003 BP3N1/1
Manganese	0.021		1	mg/L	0.3	11/02/2023 12:09	003 BP3N1/1

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
Benzene	<0.50		1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		11/01/2023 12:37	003 VG9C1/2
Bromoform	<0.50		1	ug/L		11/01/2023 12:37	003 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
Chlorodifluoromethane	<0.50	N3	1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
Chloroform	1.6		1	ug/L		11/01/2023 12:37	003 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	11/01/2023 12:37	003 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70275476003
Client Sample ID.: S-31636

Attn To : Keith Tuthill
Federal ID : 5103704
Collected : 10/25/2023 08:00 AM **Point** S-31636
Received : 10/25/2023 02:00 PM **Location** Well #1-3
Collected By CLIENT

Dibromochloromethane	<0.50	1	ug/L		11/01/2023 12:37	003 VG9C1/2
Dibromomethane	<0.50	1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
Dichlorodifluoromethane	<0.50	1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
Ethylbenzene	<0.50	1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
Hexachloro-1,3-butadiene	<0.50	1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
Isopropylbenzene (Cumene)	<0.50	1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
Methyl-tert-butyl ether	<0.50	1	ug/L	10	11/01/2023 12:37	003 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
Styrene	<0.50	1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
Toluene	<0.50	1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
Total Trihalomethanes (Calc.)	1.6	1	ug/L	80	11/01/2023 12:37	003 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	11/01/2023 12:37	003 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	11/01/2023 12:37	003 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	80%	1	%REC		11/01/2023 12:37	003 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	88%	1	%REC		11/01/2023 12:37	003 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Influent
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70275476004
Client Sample ID.: BI GAC

Attn To : Keith Tuthill
 Federal ID : 5103704
 Collected : 10/25/2023 08:15 AM Point BI GAC
 Received : 10/25/2023 02:00 PM Location BI GAC
 Collected By CLIENT

Analytical Method:EPA 200.7

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Iron	<0.020		1	mg/L	0.3	11/02/2023 12:12	004 BP3N1/1
Manganese	0.16		1	mg/L	0.3	11/02/2023 12:12	004 BP3N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 11/03/2023



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District

PO Box 1013

Hampton Bays, NY 11946

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 10/25/2023 08:45 AM Point S-108065

Received : 10/25/2023 02:00 PM Location Well #4-1

Collected By CLIENT

Lab No. : 70275476005

Client Sample ID.: S-108065

Analytical Method:EPA 200.7

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Iron	0.77*		1	mg/L	0.3	11/02/2023 12:14	005 BP3N1/1
Manganese	0.13		1	mg/L	0.3	11/02/2023 12:14	005 BP3N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 11/03/2023

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District

PO Box 1013

Hampton Bays, NY 11946

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 10/25/2023 08:55 AM Point S-108066

Received : 10/25/2023 02:00 PM Location Well #4-2

Collected By CLIENT

Lab No. : 70275476006

Client Sample ID.: S-108066

Analytical Method:EPA 200.7

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Iron	1.2*		1	mg/L	0.3	11/02/2023 12:22	006 BP3N1/1
Manganese	0.17		1	mg/L	0.3	11/02/2023 12:22	006 BP3N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 11/03/2023

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Influent
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70275476007
Client Sample ID.: BI IRON PLANT

Attn To : Keith Tuthill
 Federal ID : 5103704
 Collected : 10/25/2023 09:05 AM Point BI IRON PLANT
 Received : 10/25/2023 02:00 PM Location BI IRON PLANT
 Collected By CLIENT

Analytical Method:EPA 200.7

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Iron	1.0*		1	mg/L	0.3	11/02/2023 12:25	007 BP3N1/1
Manganese	0.16		1	mg/L	0.3	11/02/2023 12:25	007 BP3N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 11/03/2023



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Effluent
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70275476008
Client Sample ID.: BE IRON PLANT

Attn To : Keith Tuthill
 Federal ID : 5103704
 Collected : 10/25/2023 09:15 AM Point BE IRON PLANT
 Received : 10/25/2023 02:00 PM Location BE IRON PLANT
 Collected By CLIENT

Analytical Method:EPA 200.7

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Iron	<0.020		1	mg/L	0.3	11/02/2023 12:28	008 BP3N1/1
Manganese	<0.010		1	mg/L	0.3	11/02/2023 12:28	008 BP3N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 11/03/2023



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70275476009
Client Sample ID.: S-58351

Attn To : Keith Tuthill
 Federal ID : 5103704
 Collected : 10/25/2023 09:35 AM Point S-58351
 Received : 10/25/2023 02:00 PM Location Well #3-2
 Collected By CLIENT

Analytical Method:EPA 200.7

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Iron	0.35*		1	mg/L	0.3	11/02/2023 12:31	009 BP3N1/1
Manganese	0.021		1	mg/L	0.3	11/02/2023 12:31	009 BP3N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 11/03/2023



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District

PO Box 1013

Hampton Bays, NY 11946

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 10/25/2023 09:55 AM Point BLENDED ENTRY

Received : 10/25/2023 02:00 PM Location BLENDED ENTRY POINT 3 FIELD

Collected By CLIENT

Lab No. : 70275476010

Client Sample ID.: BLENDED ENTRY POINT 3 FIELD

Analytical Method:EPA 200.7

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Iron	0.11		1	mg/L	0.3	11/02/2023 12:33	010 BP3N1/1
Manganese	0.018		1	mg/L	0.3	11/02/2023 12:33	010 BP3N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 11/03/2023

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

WorkOrder :
70275476

Laboratory Certifications

Pace Analytical Services Long Island

575 Broad Hollow Rd, Melville, NY 11747
Connecticut Certification #: PH-0435
Delaware Certification # NY 10478
Maryland Certification #: 208
Massachusetts Certification #: M-NY026
New Hampshire Certification #: 2987
New Jersey Certification #: NY158
New York Certification #: 10478 Primary Accrediting Body
Pennsylvania Certification #: 68-00350
Rhode Island Certification #: LAO00340
Virginia Certification # 460302



575 Broad Hollow Road, Melville, NY 11747

TEL: (516) 370-6000 FAX: (516) 886-5526

www.pacelabs.com

WorkOrder :

70275476

Additional Qualifiers

N3 - Accreditation is not offered by the relevant laboratory accrediting body for this parameter.

WO#: 70275476



70275476

747

Sample Request Form PUBLIC WATER SUPPLIER

Jul Maddy
10/25/23 1640

Date: 10-25-2023

Collected By: K. Tuttle

Accepted By: Jul Maddy 10/25/23

Cooler Temp: 41.5 °C

WELL OFF LINE

WELL RUN TO SYSTEM

YES NO VOC'S PRESERVED WITH HCl

Name or Code: HAMPTON BAYS WATER DISTRICT
Address: P.O. BOX 1013
HAMPTON BAYS, NEW YORK 11946
(631) 728-0179

Phone #: _____
Attn: _____
Proj. # or (Name): _____
Bill To: _____
Copies To: _____

Sample Types	Purpose	Origin	Treatment Types
PW - Potable Water	RO - Routine	D - Distribution	AST - Air Stripper
GW - Groundwater	RE - Resample	RW - Raw Well	GAC - Granular Activated Charcoal
SW - Surface Water	S - Special	TW - Treated Well	N - Nitrate Removal Plant
WW - Waste Water		T - Tank	FE - Iron Removal Plant
AQ - Aqueous		MW - Monitoring Well	O - Other
S - Soil		I - Influent	
		E - Effluent	

Sample Info:

Date/Time Collected:	Sample Type	Location	Origin	Treatment Type	Purpose	Field Readings Cl ₂ pH/Temp	Analysis	Lab No.
10/25/23/7:30am		Well 1-1	RW		RO		I/M,	
10/25/23/7:45am		Well 1-2	RW		RO		I/M,	
10/25/23/8:00am		Well 1-3	RW		RO		I/M, Voc	
10/25/23/8:15am		B. I. GAC	RW		RO		I/M,	
10/25/23/8:45am		Well 4-1	RW		RO		I/M,	
10/25/23/8:50am		Well 4-2	RW		RO		I/M,	
10/25/23/9:05am		B. I. Iron Plant	RW		RO		I/M,	
10/25/23/9:15am		B. E. Iron Plant	RW		RO		I/M,	
10/25/23/9:35am		Well 3-2	RW		RO		I/M, Suc	
10/25/23/9:55am		Blended Embury Point 3 Field	PW		RO		I/M	
Remarks:								

Client: HBW

Profile #: 5223

Work ID: FE/ML/poc 10/25

COC Page 10/25 of 10/25

Use Point Number Spreadsheet Add SCLOGFD to first sample for field charge

Multiday Project

COC Line Item	Matrix	VG9U	VG9C	VG9H	VG9S	VG9T	VG9P	VG9G	VG9A	VG9B	VG9D	VG9E	VG9F	VG9I	VG9J	VG9K	VG9L	VG9M	VG9N	VG9O	VG9P	VG9Q	VG9R	VG9S	VG9T	VG9U	VG9V	VG9W	VG9X	VG9Y	VG9Z		
1																																	
2																																	
3																																	
4																																	
5																																	
6																																	
7																																	
8																																	
9																																	
10																																	
11																																	

Container Codes	Glass	Plastic	Misc.	IOG	Matrix
VG9U	40mL unpres clear vial	AG4U	125mL unpreserved plastic	SP5T	Water
VG9C	40mL Ascorbic-HCl clear vial	AG3U	250mL unpreserved plastic	R	SL Solid
VG9H	40mL HCl clear vial	AG2U	500mL unpreserved plastic	WG2U	NAL Non-aqueous Liquid
VG9S	40mL Sulfuric clear vial	AG1U	1L unpreserved plastic	WG2U	OL Oil
DG9T	40mL Na Thiosulfate vial	AG34	1L unpreserved plastic	WG2U	WP Wipe
DG9Y	40mL Citrate-Na Thiosulfate	AG3U	250mL HNO3 plastic	WG2U	DW Drinking Water
DG9P	40mL Ascorbic/Maleic Acid 40mL	AG4E	500mL HNO3 plastic	WG2U	
DG9T	Na Thio 60mL Vial	AG3T	500mL H2SO4 plastic	WG2U	
DG9S	Ammonium Cl/CuSO4 40mL	AG1T	500mL H2SO4 plastic	WG2U	
CG1U	1L Unpres Jar (Conn Ed)	AG1H	NaOH 250mL bottle	WG2U	
WG9Q	8oz clear soil jar	AG1A	250mL Trizma	WG2U	
WG9O	4oz clear soil jar	AG1A	250mL Ammonium Acetate	WG2U	
BP3U		BP3R	250mL NH4SO4-NH4OH	BP3U	
BP1Z		BP1Z	1L NaOH, Zn Acetate	BP1Z	
BP1N		BP1N	1L HNO3 plastic	BP1N	
BP1B		BP1B	Na Thiosulfate Amber Bottle	BP1B	
BP4U		BP4U	125mL unpreserved plastic	BP4U	
BP3U		BP3U	250mL unpreserved plastic	BP3U	
BP2U		BP2U	500mL unpreserved plastic	BP2U	
BP1U		BP1U	1L unpreserved plastic	BP1U	
BP4N		BP4N	Ammonium Cl 250mL bottle	BP4N	
BP3N		BP3N	250mL H2SO4 amber glass	BP3N	
BP2N		BP2N	125mL EDA amber glass	BP2N	
BP3S		BP3S	250mL Na Thio amber glass	BP3S	
BP2S		BP2S	Na Sulfite 500mL (blue Cap)	BP2S	
BP3C		BP3C	Na Thiosulfate 1L bottle	BP3C	
BP3T		BP3T	1L HCl amber glass	BP3T	
BP3S		BP3S	(NH4Cl)	BP3S	
BP3R		BP3R	250mL NH4SO4-NH4OH	BP3R	
BP1Z		BP1Z	1L NaOH, Zn Acetate	BP1Z	
BP1N		BP1N	1L HNO3 plastic	BP1N	
BP1B		BP1B	Na Thiosulfate Amber Bottle	BP1B	
SP5T		SP5T	120mL Coliform Na Thio	SP5T	
R		R	Terracore Kit	R	
WG2U		WG2U	20z Unpreserved Jar	WG2U	
WG2U		WG2U	4oz Unpreserved Jar	WG2U	
WG2U		WG2U	8oz Unpreserved Jar	WG2U	
WG2U		WG2U	16oz Unpreserved Jar	WG2U	
ZPLC		ZPLC	Ziplock Bag	ZPLC	
TEDL		TEDL	Tedlar Bag	TEDL	
BGIH		BGIH	1L HCl Clear Glass	BGIH	
GN		GN	General	GN	
WP		WP	Wipe	WP	

* Can also be a BP4N

SOC	Description
VG9T	140mL Na Thio amber vial
DG9A	40mL Ascorbic acid/maleic Acid vials
DG9Y	Citrate/Na Thiosulfate 40mL
DG6T	Na Thiosulfate 60mL vial
DG6M	MonoChloride/Na Thio 60mL
AG3U	250mL unpres amber glass
AG3T	Na Thiosulfate 250mL bottle
BP1B	Na Thiosulfate Amber bottle
AG1T	Na Thiosulfate 1L Amber
AG1A	525.3 Chemical Blend

Sender Initials HBW

WO#: 70275476
 PM: KMM
 CLIENT: HBW
 Due Date: 10/31/23

Additional Comments

WO#: 70275476

Client Name: HBW

Project #

PM: KMM

Due Date: 10/31/23

Courier: Fed Ex UPS USPS Client Commercial Pace Other

CLIENT: HBW

Tracking #:

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No Temperature Blank Present: Yes No

Packing Material: Bubble Wrap Bubble Bags Ziploc None Other Type of Ice: Wet Blue None

Thermometer Used: TH198 Correction Factor: +0.3 Samples on ice, cooling process has begun

Cooler Temperature (°C): 4.5 Cooler Temperature Corrected (°C): 4.8 Date/Time 5035A kits placed in freezer: 10/25/23 1640

Temp should be above freezing to 6.0°C

USDA Regulated Soil (N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes No

Did samples originate from a foreign source including Hawaii and Puerto Rico? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.

Date and Initials of person examining contents: MPL 10/26

		COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr):	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Containers Intact:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note: if sediment is visible in the dissolved container,
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID/Analysis: Matrix: SL WT OIL OTHER		

Date and Initials of person checking preservation: MPL 10/26

All containers needing preservation have been pH paper Lot # 227822V	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH > 9 Sulfide > 12 Cyanide)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	Sample #
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis		Initial when completed: Lot # of added preservative: Date/Time preservative added:
Samples checked for dechlorination: KI starch test strips Lot #	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
Residual chlorine strips Lot #		
SM 4500 CN samples checked for sul	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	15. Positive for Sulfide? Y N
Lead Acetate Strips Lot #		
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	16.
Trip Blank Present:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	17.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution:

* PM (Project Manager) review is documented electronically in LIMS.