



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (516) 370-6000 FAX: (516) 886-5526  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**  
**P.O. Box 1013**  
**Hampton Bays, NY 11946**

**Lab No. : 70244997001**  
**Client Sample ID.: S-15687**

**Attn To :** Supt. McCuen  
 Federal ID : 5103704  
 Collected : 02/01/2023 07:30 AM Point S-15687  
 Received : 02/01/2023 01:15 PM Location Well #1-1  
 Collected By CLIENT

**Sample Comments:**  
 RUN TO WASTE

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	0.21		1	mg/L	0.3	02/07/2023 12:01	001 BP4N1/1
Manganese	<b>0.90*</b>		1	mg/L	0.3	02/07/2023 12:01	001 BP4N1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	6.3		5	mg/L	10	02/02/2023 11:42	001 BP4U1/1
Nitrate-Nitrite (as N)	6.4		5	mg/L		02/02/2023 11:42	001 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	02/02/2023 9:13 PM	001 BP4U1/1

Analytical Method:SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 02/01/2023 5:30 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	02/02/2023 11:30	001 SP5T1/1
Total Coliforms	Absent		1		Absent	02/02/2023 11:30	001 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 02/07/2023



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (516) 370-6000 FAX: (516) 886-5526  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**  
**P.O. Box 1013**  
**Hampton Bays, NY 11946**

**Lab No. : 70244997002**  
**Client Sample ID.: S-24848**

**Attn To :** Supt. McCuen  
 Federal ID : 5103704  
 Collected : 02/01/2023 07:45 AM Point S-24848  
 Received : 02/01/2023 01:15 PM Location Well #1-2  
 Collected By CLIENT

**Sample Comments:**  
 RUN TO WASTE

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	<b>0.71*</b>		1	mg/L	0.3	02/07/2023 12:04	002 BP4N1/1
Manganese	<b>0.77*</b>		1	mg/L	0.3	02/07/2023 12:04	002 BP4N1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	9.3		5	mg/L	10	02/02/2023 11:46	002 BP4U1/1
Nitrate-Nitrite (as N)	9.3		5	mg/L		02/02/2023 11:46	002 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	02/02/2023 9:14 PM	002 BP4U1/1

Analytical Method:SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 02/01/2023 5:30 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	02/02/2023 11:30	002 SP5T1/1
Total Coliforms	Absent		1		Absent	02/02/2023 11:30	002 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 02/07/2023



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (516) 370-6000 FAX: (516) 886-5526  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**  
**P.O. Box 1013**  
**Hampton Bays, NY 11946**

**Lab No. : 70244997003**  
**Client Sample ID.: S-31636**

**Attn To :** Supt. McCuen  
 Federal ID : 5103704  
 Collected : 02/01/2023 08:00 AM Point S-31636  
 Received : 02/01/2023 01:15 PM Location Well #1-3  
 Collected By CLIENT

**Sample Comments:**  
 RUN TO WASTE

<u>Analytical Method:</u> EPA 200.7		<u>Prep Method:</u> EPA 200.7			<u>Prep Date:</u> 02/06/2023 8:37 AM		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Iron	0.25		1	mg/L	0.3	02/06/2023 1:54 PM	003 BP4N1/1
Manganese	0.044		1	mg/L	0.3	02/06/2023 1:54 PM	003 BP4N1/1

  

<u>Analytical Method:</u> EPA 353.2		<u>Prep Method:</u> EPA 353.2			<u>Prep Date:</u> 02/02/2023 10:49		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Nitrate as N	2.7		1	mg/L	10	02/02/2023 10:49	003 BP4U1/1
Nitrate-Nitrite (as N)	2.7		1	mg/L		02/02/2023 10:49	003 BP4U1/1

  

<u>Analytical Method:</u> EPA 353.2		<u>Prep Method:</u> EPA 353.2			<u>Prep Date:</u> 02/02/2023 9:16 PM		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Nitrite as N	<0.050		1	mg/L	1	02/02/2023 9:16 PM	003 BP4U1/1

  

<u>Analytical Method:</u> SM22 9223B Colilert		<u>Prep Method:</u> SM22 9223B Colilert			<u>Prep Date:</u> 02/01/2023 5:30 PM		
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	02/02/2023 11:30	003 SP5T1/1
Total Coliforms	Absent		1		Absent	02/02/2023 11:30	003 SP5T1/1

**Qualifiers:**

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 02/07/2023



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (516) 370-6000 FAX: (516) 886-5526  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**

**P.O. Box 1013**

**Hampton Bays, NY 11946**

**Attn To : Supt. McCuen**

Federal ID : 5103704

Collected : 02/01/2023 08:15 AM Point S-50970

Received : 02/01/2023 01:15 PM Location Well #2-1

Collected By CLIENT

**Lab No. : 70244997004**

**Client Sample ID.: S-50970**

Analytical Method:EPA 353.2

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Nitrate as N	2.8		1	mg/L	10	02/02/2023 10:51	004 BP4U1/1
Nitrate-Nitrite (as N)	2.8		1	mg/L		02/02/2023 10:51	004 BP4U1/1

Analytical Method:EPA 353.2

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Nitrite as N	<0.050		1	mg/L	1	02/02/2023 9:17 PM	004 BP4U1/1

Analytical Method:SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 02/01/2023 5:30 PM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	<b>Present*</b>		1		Absent	02/02/2023 11:30	004 SP5T1/1
Total Coliforms	<b>Present*</b>		1		Absent	02/02/2023 11:30	004 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 02/07/2023



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (516) 370-6000 FAX: (516) 886-5526  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**

**P.O. Box 1013**

**Hampton Bays, NY 11946**

**Attn To : Supt. McCuen**

Federal ID : 5103704

Collected : 02/01/2023 08:30 AM Point S-58350

Received : 02/01/2023 01:15 PM Location Well #3-1

Collected By CLIENT

**Lab No. : 70244997005**

**Client Sample ID.: S-58350**

Analytical Method:EPA 353.2

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Nitrate as N	0.099		1	mg/L	10	02/02/2023 10:52	005 BP4U1/1
Nitrate-Nitrite (as N)	0.12		1	mg/L		02/02/2023 10:52	005 BP4U1/1

Analytical Method:EPA 353.2

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Nitrite as N	<0.050		1	mg/L	1	02/02/2023 9:18 PM	005 BP4U1/1

Analytical Method:SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 02/01/2023 5:30 PM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	02/02/2023 11:30	005 SP5T1/1
Total Coliforms	Absent		1		Absent	02/02/2023 11:30	005 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 02/07/2023



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (516) 370-6000 FAX: (516) 886-5526  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**  
**P.O. Box 1013**  
**Hampton Bays, NY 11946**

**Lab No. : 70244997006**  
**Client Sample ID.: S-58351**

**Attn To :** Supt. McCuen  
 Federal ID : 5103704  
 Collected : 02/01/2023 08:45 AM Point S-58351  
 Received : 02/01/2023 01:15 PM Location Well #3-2  
 Collected By CLIENT

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	0.65*		1	mg/L	0.3	02/07/2023 12:07	006 BP4N1/1
Manganese	0.16		1	mg/L	0.3	02/07/2023 12:07	006 BP4N1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	0.083		1	mg/L	10	02/02/2023 10:53	006 BP4U1/1
Nitrate-Nitrite (as N)	0.092		1	mg/L		02/02/2023 10:53	006 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	02/02/2023 9:19 PM	006 BP4U1/1

Analytical Method:SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 02/01/2023 5:30 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	02/02/2023 11:30	006 SP5T1/1
Total Coliforms	Absent		1		Absent	02/02/2023 11:30	006 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 02/07/2023



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (516) 370-6000 FAX: (516) 886-5526  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**

**P.O. Box 1013**

**Hampton Bays, NY 11946**

**Attn To : Supt. McCuen**

Federal ID : 5103704

Collected : 02/01/2023 09:00 AM Point S-58352

Received : 02/01/2023 01:15 PM Location Well #3-3

Collected By CLIENT

**Lab No. : 70244997007**

**Client Sample ID.: S-58352**

Analytical Method:EPA 353.2

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Nitrate as N	0.085		1	mg/L	10	02/02/2023 10:55	007 BP4U1/1
Nitrate-Nitrite (as N)	0.10		1	mg/L		02/02/2023 10:55	007 BP4U1/1

Analytical Method:EPA 353.2

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Nitrite as N	<0.050		1	mg/L	1	02/02/2023 9:24 PM	007 BP4U1/1

Analytical Method:SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 02/01/2023 5:30 PM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	02/02/2023 11:30	007 SP5T1/1
Total Coliforms	Absent		1		Absent	02/02/2023 11:30	007 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 02/07/2023



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (516) 370-6000 FAX: (516) 886-5526  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**

**P.O. Box 1013**

**Hampton Bays, NY 11946**

**Attn To : Supt. McCuen**

Federal ID : 5103704

Collected : 02/01/2023 09:15 AM Point S-108065

Received : 02/01/2023 01:15 PM Location Well #4-1

Collected By CLIENT

**Lab No. : 70244997008**

**Client Sample ID.: S-108065**

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	0.13		1	mg/L	0.3	02/07/2023 12:10	008 BP4N1/1
Manganese	0.043		1	mg/L	0.3	02/07/2023 12:10	008 BP4N1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	<0.050		1	mg/L	10	02/02/2023 11:00	008 BP4U1/1
Nitrate-Nitrite (as N)	<0.050		1	mg/L		02/02/2023 11:00	008 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	02/02/2023 9:25 PM	008 BP4U1/1

Analytical Method:SM22 9223B Colilert

Prep Method: SM22 9223B Colilert

Prep Date: 02/01/2023 5:30 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	02/02/2023 11:30	008 SP5T1/1
Total Coliforms	Absent		1		Absent	02/02/2023 11:30	008 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 02/07/2023



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (516) 370-6000 FAX: (516) 886-5526  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**

**P.O. Box 1013**

**Hampton Bays, NY 11946**

**Attn To : Supt. McCuen**

Federal ID : 5103704

Collected : 02/01/2023 09:30 AM Point S-108066

Received : 02/01/2023 01:15 PM Location Well #4-2

Collected By CLIENT

**Lab No. : 70244997009**

**Client Sample ID.: S-108066**

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	1.3*		1	mg/L	0.3	02/07/2023 12:12	009 BP4N1/1
Manganese	0.17		1	mg/L	0.3	02/07/2023 12:12	009 BP4N1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	0.056		1	mg/L	10	02/02/2023 11:03	009 BP4U1/1
Nitrate-Nitrite (as N)	0.073		1	mg/L		02/02/2023 11:03	009 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	02/02/2023 9:31 PM	009 BP4U1/1

Analytical Method:SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 02/01/2023 5:30 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	02/02/2023 11:30	009 SP5T1/1
Total Coliforms	Absent		1		Absent	02/02/2023 11:30	009 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 02/07/2023



575 Broad Hollow Road, Melville, NY 11747  
 TEL: (516) 370-6000 FAX: (516) 886-5526  
[www.pacelabs.com](http://www.pacelabs.com)

# Laboratory Results

Results for the samples and analytes requested  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

## Sample Information:

Type: Drinking Water  
 Origin: Raw Well  
 Routine

**Hampton Bays Water District**

**P.O. Box 1013**

**Hampton Bays, NY 11946**

**Attn To : Supt. McCuen**

Federal ID : 5103704

Collected : 02/01/2023 09:50 AM Point S-127163

Received : 02/01/2023 01:15 PM Location Well #5-1

Collected By CLIENT

**Lab No. : 70244997010**

**Client Sample ID.: S-127163**

Analytical Method:EPA 353.2

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Nitrate as N	0.95		1	mg/L	10	02/02/2023 11:07	010 BP4U1/1
Nitrate-Nitrite (as N)	0.97		1	mg/L		02/02/2023 11:07	010 BP4U1/1

Analytical Method:EPA 353.2

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Nitrite as N	<0.050		1	mg/L	1	02/02/2023 9:32 PM	010 BP4U1/1

Analytical Method:SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 02/01/2023 5:30 PM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	02/02/2023 11:30	010 SP5T1/1
Total Coliforms	Absent		1		Absent	02/02/2023 11:30	010 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.  
 ND - Not Detected at or above adjusted reporting limit.  
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range  
 U - Indicates the compound was analyzed for, but not detected

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).  
 Result(s) flagged with \* Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 02/07/2023



575 Broad Hollow Road, Melville, NY 11747  
TEL: (516) 370-6000 FAX: (516) 886-5526  
[www.pacelabs.com](http://www.pacelabs.com)

**WorkOrder :**  
70244997

## Laboratory Certifications

---

### **Pace Analytical Services Long Island**

575 Broad Hollow Rd, Melville, NY 11747  
Connecticut Certification #: PH-0435  
Delaware Certification # NY 10478  
Maryland Certification #: 208  
Massachusetts Certification #: M-NY026  
New Hampshire Certification #: 2987  
New Jersey Certification #: NY158  
New York Certification #: 10478 Primary Accrediting Body  
Pennsylvania Certification #: 68-00350  
Rhode Island Certification #: LAO00340  
Virginia Certification # 460302

# Sample Request Form PUBLIC WATER SUPPLIER

*Return to Lab  
2/1/23 1705*

Date: 2-1-23

Collected By: F. TUTTILL  
Accepted By: [Signature] 2/1/23 1315  
Cooler Temp: 4.4 °C

WELL OFF LINE  
 WELL RUN TO SYSTEM

YES  NO VOC'S PRESERVED WITH HCl

Sample Type	Purpose	Origin	Treatment Types
PW - Potable Water	RO - Routine	D - Distribution	AST - Air Stripper
GW - Groundwater	RE - Resample	RW - Raw Well	GAC - Granular Activated Charcoal
SW - Surface Water	S - Special	TW - Treated Well	N - Nitrate Removal Plant
WW - Waste Water		T - Tank	FE - Iron Removal Plant
AQ - Aqueous		MW - Monitoring Well	O - Other
S - Soil		I - Influent	
		E - Effluent	

### Sample Info:

Date/Time Collected:	Sample Type	Location	Origin	Treatment Type	Purpose	Field Readings Cl <sub>2</sub> pH/Temp	Analysis	Lab No.
2/1/23/7:30	GW	Well 1-1	RW	-	RO		BACT, I/M, N/N	
2/1/23/7:45	GW	Well 1-2	RW	-	RO		BACT, I/M, N/N	
2/1/23/8:00	GW	Well 1-3	RW	-	RO		BACT, I/M, N/N	
2/1/23/9:15	GW	Well 2-1	RW	-	RO		BACT, N/N	
2/1/23/9:30	GW	Well 3-1	RW	-	RO		BACT, N/N	
2/1/23/9:45	GW	Well 3-2	RW	-	RO		BACT, I/M, N/N	
2/1/23/9:00	GW	Well 3-3	RW	-	RO		BACT, N/N	
2/1/23/9:15	GW	Well 4-1	RW	-	RO		BACT, I/M, N/N	
2/1/23/9:30	GW	Well 4-2	RW	-	RO		BACT, I/M, N/N	
2/1/23/9:50	GW	Well 5-1	RW	-	RO		BACT, N/N	
2/1/23/10:00	PW	#20 Ramapo Road	PW	-	S	3.8 7.9	BACT, N/N, Metals, I/M	

Remarks: Main plant 1 to blowoff



Client Name: HBW

WO#: 70244997

PM: KMM Due Date: 02/07/23  
CLIENT: HBW

Courier:  Fed Ex  UPS  USPS  Client  Commercial  Face  Other  
 Tracking #: \_\_\_\_\_  
 Custody Seal on Cooler/Box Present:  Yes  No Seals intact:  Yes  No  N/A  
 Packing Material:  Bubble Wrap  Bubble Bags  Ziploc  None  Other  
 Thermometer Used: F1148 Correction Factor: + 0.1  
 Cooler Temperature(°C): 4.4 Cooler Temperature Corrected(°C): 4.5  
 Temp should be above freezing to 6.0°C  
 USDA Regulated Soil {  N/A, water sample

Temperature Blank Present:  Yes  No  
 Type of Ice: Wet Blue None  
 Samples on ice, cooling process has begun  
 Date/Time 5035A kits placed in freezer

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)?  Yes  No  
 Did samples originate from a foreign source including Hawaii and Puerto Rico?:  Yes  No  
 Date and Initials of person examining contents: 2/1/23 1705  
 If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork

		COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out:	<input type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished:	<input type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr):	<input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No <u>21</u>	6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for)	<input type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used:	<input type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used:	<input type="checkbox"/> Yes <input type="checkbox"/> No	
Containers Intact:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID, Matrix: <u>SL WT OIL</u>		
All containers needing preservation have been checked?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO <sub>3</sub> <input type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # <u>HC 293085</u>		Sample #
All containers needing preservation are found to be in compliance with method recommendation?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
(HNO <sub>3</sub> , H <sub>2</sub> SO <sub>4</sub> , HCl, NaOH>9 Sulfide, NAOH>12 Cyanide)		
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water).		Initial when completed: _____ Lot # of added preservative: _____ Date/Time preservative added: _____
Per Method, VOA pH is checked after analysis		
Samples checked for dechlorination:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
KI starch test strips Lot #		
Residual chlorine strips Lot #		
SM 4500 CN samples checked for sulfide?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15. Positive for Sulfide? Y N
Lead Acetate Strips Lot #		
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Trip Blank Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	17.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable): _____		

Client Notification/ Resolution: \_\_\_\_\_ Field Data Required? Y / N  
 Person Contacted: \_\_\_\_\_ Date/Time: \_\_\_\_\_  
 Comments/ Resolution: \_\_\_\_\_