



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70292813001
Client Sample ID.: S-15687

Attn To : Keith Tuthill
 Federal ID : 5103704
 Collected : 04/03/2024 07:30 AM Point S-15687
 Received : 04/03/2024 01:50 PM Location Well #1-1
 Collected By CLIENT

Sample Comments:
 RUN TO WASTE

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	3.2		5	mg/L	10	04/04/2024 1:19 AM	001 BP4U1/1
Nitrate-Nitrite (as N)	3.2		5	mg/L		04/04/2024 1:19 AM	001 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	04/03/2024 11:07	001 BP4U1/1

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
Benzene	<0.50		1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		04/09/2024 12:37	001 VG9C1/2
Bromoform	<0.50		1	ug/L		04/09/2024 12:37	001 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	04/09/2024 12:37	001 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70292813001
Client Sample ID.: S-15687

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 04/03/2024 07:30 AM Point S-15687

Received : 04/03/2024 01:50 PM Location Well #1-1

Collected By CLIENT

Sample Comments:

RUN TO WASTE

Carbon tetrachloride	<0.50	1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
Chlorobenzene	<0.50	1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
Chlorodifluoromethane	<0.50	N3 1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
Chloroethane	<0.50	1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
Chloroform	1.0	1	ug/L		04/09/2024 12:37	001 VG9C1/2
Chloromethane	<0.50	1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
Dibromochloromethane	<0.50	1	ug/L		04/09/2024 12:37	001 VG9C1/2
Dibromomethane	<0.50	1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
Dichlorodifluoromethane	<0.50	1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
Ethylbenzene	<0.50	1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
Hexachloro-1,3-butadiene	<0.50	1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
Isopropylbenzene (Cumene)	<0.50	1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
Methyl-tert-butyl ether	<0.50	1	ug/L	10	04/09/2024 12:37	001 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
Styrene	<0.50	1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
Toluene	<0.50	1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
Total Trihalomethanes (Calc.)	1.0	1	ug/L	80	04/09/2024 12:37	001 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	04/09/2024 12:37	001 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	04/09/2024 12:37	001 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	85%	1	%REC		04/09/2024 12:37	001 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	88%	1	%REC		04/09/2024 12:37	001 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70292813002
Client Sample ID.: S-24848

Attn To : Keith Tuthill
 Federal ID : 5103704
 Collected : 04/03/2024 07:45 AM Point S-24848
 Received : 04/03/2024 01:50 PM Location Well #1-2
 Collected By CLIENT

Sample Comments:
 RUN TO WASTE

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	5.5		5	mg/L	10	04/04/2024 12:22	002 BP4U1/1
Nitrate-Nitrite (as N)	5.5		5	mg/L		04/04/2024 12:22	002 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	04/03/2024 10:37	002 BP4U1/1

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
Benzene	<0.50		1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		04/09/2024 1:00 PM	002 VG9C1/2
Bromoform	<0.50		1	ug/L		04/09/2024 1:00 PM	002 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70292813002
Client Sample ID.: S-24848

Attn To : Keith Tuthill
 Federal ID : 5103704
 Collected : 04/03/2024 07:45 AM Point S-24848
 Received : 04/03/2024 01:50 PM Location Well #1-2
 Collected By CLIENT

Sample Comments:
 RUN TO WASTE

Carbon tetrachloride	<0.50	1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
Chlorobenzene	<0.50	1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
Chlorodifluoromethane	<0.50	N3 1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
Chloroethane	<0.50	1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
Chloroform	<0.50	1	ug/L		04/09/2024 1:00 PM	002 VG9C1/2
Chloromethane	<0.50	1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
Dibromochloromethane	<0.50	1	ug/L		04/09/2024 1:00 PM	002 VG9C1/2
Dibromomethane	<0.50	1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
Dichlorodifluoromethane	<0.50	1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
Ethylbenzene	<0.50	1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
Hexachloro-1,3-butadiene	<0.50	1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
Isopropylbenzene (Cumene)	<0.50	1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
Methyl-tert-butyl ether	<0.50	1	ug/L	10	04/09/2024 1:00 PM	002 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
Styrene	<0.50	1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
Toluene	<0.50	1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
Total Trihalomethanes (Calc.)	<0.50	1	ug/L	80	04/09/2024 1:00 PM	002 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	04/09/2024 1:00 PM	002 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	04/09/2024 1:00 PM	002 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	86%	1	%REC		04/09/2024 1:00 PM	002 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	92%	1	%REC		04/09/2024 1:00 PM	002 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70292813003
Client Sample ID.: S-31636

Attn To : Keith Tuthill
 Federal ID : 5103704
 Collected : 04/03/2024 08:00 AM Point S-31636
 Received : 04/03/2024 01:50 PM Location Well #1-3
 Collected By CLIENT

Sample Comments:
 RUN TO WASTE

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	2.8		5	mg/L	10	04/04/2024 12:23	003 BP4U1/1
Nitrate-Nitrite (as N)	2.9		5	mg/L		04/04/2024 12:23	003 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	04/03/2024 10:40	003 BP4U1/1

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
Benzene	<0.50		1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		04/09/2024 1:23 PM	003 VG9C1/2
Bromoform	<0.50		1	ug/L		04/09/2024 1:23 PM	003 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District

PO Box 1013

Hampton Bays, NY 11946

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 04/03/2024 08:00 AM Point S-31636

Received : 04/03/2024 01:50 PM Location Well #1-3

Collected By CLIENT

Sample Comments:

RUN TO WASTE

Lab No. : 70292813003

Client Sample ID.: S-31636

Carbon tetrachloride	<0.50	1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
Chlorobenzene	<0.50	1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
Chlorodifluoromethane	<0.50	N3 1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
Chloroethane	<0.50	1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
Chloroform	<0.50	1	ug/L		04/09/2024 1:23 PM	003 VG9C1/2
Chloromethane	<0.50	1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
Dibromochloromethane	<0.50	1	ug/L		04/09/2024 1:23 PM	003 VG9C1/2
Dibromomethane	<0.50	1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
Dichlorodifluoromethane	<0.50	1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
Ethylbenzene	<0.50	1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
Hexachloro-1,3-butadiene	<0.50	1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
Isopropylbenzene (Cumene)	<0.50	1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
Methyl-tert-butyl ether	<0.50	1	ug/L	10	04/09/2024 1:23 PM	003 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
Styrene	<0.50	1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
Toluene	<0.50	1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
Total Trihalomethanes (Calc.)	<0.50	1	ug/L	80	04/09/2024 1:23 PM	003 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
Vinyl chloride	<0.50	1	ug/L	2	04/09/2024 1:23 PM	003 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	04/09/2024 1:23 PM	003 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	89%	1	%REC		04/09/2024 1:23 PM	003 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	92%	1	%REC		04/09/2024 1:23 PM	003 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70292813004
Client Sample ID.: S-50970

Attn To : Keith Tuthill
 Federal ID : 5103704
 Collected : 04/03/2024 08:20 AM Point S-50970
 Received : 04/03/2024 01:50 PM Location Well #2-1
 Collected By CLIENT

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	3.2		5	mg/L	10	04/04/2024 12:51	004 BP4U1/1
Nitrate-Nitrite (as N)	3.2		5	mg/L		04/04/2024 12:51	004 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	04/03/2024 10:44	004 BP4U1/1

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
Benzene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		04/09/2024 1:46 PM	004 VG9C1/2
Bromoform	<0.50		1	ug/L		04/09/2024 1:46 PM	004 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70292813004
Client Sample ID.: S-50970

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 04/03/2024 08:20 AM Point S-50970

Received : 04/03/2024 01:50 PM Location Well #2-1

Collected By CLIENT

Chlorodifluoromethane	<0.50	N3	1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
Chloroform	1.2		1	ug/L		04/09/2024 1:46 PM	004 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		04/09/2024 1:46 PM	004 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
Methyl-tert-butyl ether	<0.50		1	ug/L	10	04/09/2024 1:46 PM	004 VG9C1/2
Methylene Chloride	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
Styrene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
Tetrachloroethene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
Toluene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
Total Trihalomethanes (Calc.)	1.2		1	ug/L	80	04/09/2024 1:46 PM	004 VG9C1/2
Trichloroethene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
Trichlorofluoromethane	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
Vinyl chloride	<0.50		1	ug/L	2	04/09/2024 1:46 PM	004 VG9C1/2
cis-1,2-Dichloroethene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
cis-1,3-Dichloropropene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
m&p-Xylene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
n-Butylbenzene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
n-Propylbenzene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
o-Xylene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
p-Isopropyltoluene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
sec-Butylbenzene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
tert-Butylbenzene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
trans-1,2-Dichloroethene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
trans-1,3-Dichloropropene	<0.50		1	ug/L	5	04/09/2024 1:46 PM	004 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	88%		1	%REC		04/09/2024 1:46 PM	004 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	93%		1	%REC		04/09/2024 1:46 PM	004 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70292813005
Client Sample ID.: S-74071

Attn To : Keith Tuthill
 Federal ID : 5103704
 Collected : 04/03/2024 08:35 AM Point S-74071
 Received : 04/03/2024 01:50 PM Location Well #2-2
 Collected By CLIENT

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	3.7		5	mg/L	10	04/04/2024 12:56	005 BP4U1/1
Nitrate-Nitrite (as N)	3.7		5	mg/L		04/04/2024 12:56	005 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	04/03/2024 10:49	005 BP4U1/1

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
Benzene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		04/09/2024 2:09 PM	005 VG9C1/2
Bromoform	<0.50		1	ug/L		04/09/2024 2:09 PM	005 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70292813005
Client Sample ID.: S-74071

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 04/03/2024 08:35 AM Point S-74071

Received : 04/03/2024 01:50 PM Location Well #2-2

Collected By CLIENT

Chlorodifluoromethane	<0.50	N3	1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
Chloroform	0.85		1	ug/L		04/09/2024 2:09 PM	005 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		04/09/2024 2:09 PM	005 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
Methyl-tert-butyl ether	<0.50		1	ug/L	10	04/09/2024 2:09 PM	005 VG9C1/2
Methylene Chloride	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
Styrene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
Tetrachloroethene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
Toluene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
Total Trihalomethanes (Calc.)	0.85		1	ug/L	80	04/09/2024 2:09 PM	005 VG9C1/2
Trichloroethene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
Trichlorofluoromethane	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
Vinyl chloride	<0.50		1	ug/L	2	04/09/2024 2:09 PM	005 VG9C1/2
cis-1,2-Dichloroethene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
cis-1,3-Dichloropropene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
m&p-Xylene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
n-Butylbenzene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
n-Propylbenzene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
o-Xylene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
p-Isopropyltoluene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
sec-Butylbenzene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
tert-Butylbenzene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
trans-1,2-Dichloroethene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
trans-1,3-Dichloropropene	<0.50		1	ug/L	5	04/09/2024 2:09 PM	005 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	91%		1	%REC		04/09/2024 2:09 PM	005 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	93%		1	%REC		04/09/2024 2:09 PM	005 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70292813006
Client Sample ID.: S-58350

Attn To : Keith Tuthill
 Federal ID : 5103704
 Collected : 04/03/2024 08:55 AM Point S-58350
 Received : 04/03/2024 01:50 PM Location Well #3-1
 Collected By CLIENT

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	0.11		1	mg/L	10	04/04/2024 1:26 AM	006 BP4U1/1
Nitrate-Nitrite (as N)	0.11		1	mg/L		04/04/2024 1:26 AM	006 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	04/03/2024 10:50	006 BP4U1/1

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
Benzene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		04/09/2024 2:32 PM	006 VG9C1/2
Bromoform	<0.50		1	ug/L		04/09/2024 2:32 PM	006 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70292813006
Client Sample ID.: S-58350

Attn To : Keith Tuthill
Federal ID : 5103704
Collected : 04/03/2024 08:55 AM **Point** S-58350
Received : 04/03/2024 01:50 PM **Location** Well #3-1
Collected By CLIENT

Chlorodifluoromethane	<0.50	N3	1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
Chloroform	2.4		1	ug/L		04/09/2024 2:32 PM	006 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		04/09/2024 2:32 PM	006 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
Methyl-tert-butyl ether	<0.50		1	ug/L	10	04/09/2024 2:32 PM	006 VG9C1/2
Methylene Chloride	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
Styrene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
Tetrachloroethene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
Toluene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
Total Trihalomethanes (Calc.)	2.4		1	ug/L	80	04/09/2024 2:32 PM	006 VG9C1/2
Trichloroethene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
Trichlorofluoromethane	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
Vinyl chloride	<0.50		1	ug/L	2	04/09/2024 2:32 PM	006 VG9C1/2
cis-1,2-Dichloroethene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
cis-1,3-Dichloropropene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
m&p-Xylene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
n-Butylbenzene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
n-Propylbenzene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
o-Xylene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
p-Isopropyltoluene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
sec-Butylbenzene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
tert-Butylbenzene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
trans-1,2-Dichloroethene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
trans-1,3-Dichloropropene	<0.50		1	ug/L	5	04/09/2024 2:32 PM	006 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	93%		1	%REC		04/09/2024 2:32 PM	006 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	91%		1	%REC		04/09/2024 2:32 PM	006 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70292813007
Client Sample ID.: S-58351

Attn To : Keith Tuthill
 Federal ID : 5103704
 Collected : 04/03/2024 09:25 AM Point S-58351
 Received : 04/03/2024 01:50 PM Location Well #3-2
 Collected By CLIENT

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	0.61		5	mg/L	10	04/04/2024 1:05 AM	007 BP4U1/1
Nitrate-Nitrite (as N)	0.61		5	mg/L		04/04/2024 1:05 AM	007 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	04/03/2024 10:53	007 BP4U1/1

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
Benzene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		04/09/2024 2:55 PM	007 VG9C1/2
Bromoform	<0.50		1	ug/L		04/09/2024 2:55 PM	007 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70292813007
Client Sample ID.: S-58351

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 04/03/2024 09:25 AM Point S-58351

Received : 04/03/2024 01:50 PM Location Well #3-2

Collected By CLIENT

Chlorodifluoromethane	<0.50	N3	1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
Chloroform	1.1		1	ug/L		04/09/2024 2:55 PM	007 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		04/09/2024 2:55 PM	007 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
Methyl-tert-butyl ether	<0.50		1	ug/L	10	04/09/2024 2:55 PM	007 VG9C1/2
Methylene Chloride	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
Styrene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
Tetrachloroethene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
Toluene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
Total Trihalomethanes (Calc.)	1.1		1	ug/L	80	04/09/2024 2:55 PM	007 VG9C1/2
Trichloroethene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
Trichlorofluoromethane	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
Vinyl chloride	<0.50		1	ug/L	2	04/09/2024 2:55 PM	007 VG9C1/2
cis-1,2-Dichloroethene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
cis-1,3-Dichloropropene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
m&p-Xylene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
n-Butylbenzene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
n-Propylbenzene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
o-Xylene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
p-Isopropyltoluene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
sec-Butylbenzene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
tert-Butylbenzene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
trans-1,2-Dichloroethene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
trans-1,3-Dichloropropene	<0.50		1	ug/L	5	04/09/2024 2:55 PM	007 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	90%		1	%REC		04/09/2024 2:55 PM	007 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	92%		1	%REC		04/09/2024 2:55 PM	007 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70292813008
Client Sample ID.: S-58352

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 04/03/2024 09:40 AM Point S-58352

Received : 04/03/2024 01:50 PM Location Well #3-3

Collected By CLIENT

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Ca Hardness as CaCO3 (SM 2340B)	5.1		1	mg/L		04/08/2024 7:48 PM	
Iron	0.048		1	mg/L	0.3	04/08/2024 7:48 PM	
Manganese	0.067		1	mg/L	0.3	04/08/2024 7:48 PM	
Sodium	17.5		1	mg/L		04/08/2024 7:48 PM	
Zinc	<0.020		1	mg/L	5	04/08/2024 7:48 PM	

Analytical Method:EPA 200.8

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Antimony	<0.40		1	ug/L	6	04/08/2024 7:48 PM	
Arsenic	<1.0		1	ug/L	10	04/08/2024 7:48 PM	
Barium	0.015		1	mg/L	2	04/08/2024 7:48 PM	
Beryllium	<0.30		1	ug/L	4	04/08/2024 7:48 PM	
Cadmium	<1.0		1	ug/L	5	04/08/2024 7:48 PM	
Chromium	<0.0070		1	mg/L	0.1	04/08/2024 7:48 PM	
Lead	<1.0		1	ug/L	15	04/08/2024 7:48 PM	
Mercury	<0.20		1	ug/L	2	04/08/2024 7:48 PM	
Nickel	0.0011		1	mg/L		04/08/2024 7:48 PM	
Selenium	<2.0		1	ug/L	50	04/08/2024 7:48 PM	
Silver	<0.0010		1	mg/L	0.1	04/08/2024 7:48 PM	
Thallium	<0.30		1	ug/L	2	04/08/2024 7:48 PM	
Zinc	21.4		1	ug/L	5000	04/08/2024 7:48 PM	

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	0.13		1	mg/L	10	04/04/2024 1:33 AM	008 BP4U1/1
Nitrate-Nitrite (as N)	0.13		1	mg/L		04/04/2024 1:33 AM	008 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	04/03/2024 10:56	008 BP4U1/1

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District

PO Box 1013

Hampton Bays, NY 11946

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 04/03/2024 09:40 AM Point S-58352

Received : 04/03/2024 01:50 PM Location Well #3-3

Collected By CLIENT

Lab No. : 70292813008

Client Sample ID.: S-58352

1,1-Dichloroethane	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
1,1-Dichloroethene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
1,1-Dichloropropene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
1,2,3-Trichlorobenzene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
1,2,3-Trichloropropane	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
1,2,4-Trichlorobenzene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
1,2,4-Trimethylbenzene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
1,2-Dichlorobenzene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
1,2-Dichloroethane	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
1,2-Dichloropropane	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
1,3,5-Trimethylbenzene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
1,3-Dichlorobenzene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
1,3-Dichloropropane	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
1,4-Dichlorobenzene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
2,2-Dichloropropane	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
2-Chlorotoluene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
4-Chlorotoluene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
Benzene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
Bromobenzene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
Bromochloromethane	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
Bromodichloromethane	<0.50	1	ug/L		04/09/2024 3:18 PM	008 VG9C1/2
Bromoform	<0.50	1	ug/L		04/09/2024 3:18 PM	008 VG9C1/2
Bromomethane	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
Carbon tetrachloride	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
Chlorobenzene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
Chlorodifluoromethane	<0.50	N3 1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
Chloroethane	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
Chloroform	0.81	1	ug/L		04/09/2024 3:18 PM	008 VG9C1/2
Chloromethane	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
Dibromochloromethane	<0.50	1	ug/L		04/09/2024 3:18 PM	008 VG9C1/2
Dibromomethane	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
Dichlorodifluoromethane	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
Ethylbenzene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
Hexachloro-1,3-butadiene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
Isopropylbenzene (Cumene)	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
Methyl-tert-butyl ether	<0.50	1	ug/L	10	04/09/2024 3:18 PM	008 VG9C1/2
Methylene Chloride	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
Styrene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
Tetrachloroethene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
Toluene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
Total Trihalomethanes (Calc.)	0.81	1	ug/L	80	04/09/2024 3:18 PM	008 VG9C1/2
Trichloroethene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
Trichlorofluoromethane	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70292813008
Client Sample ID.: S-58352

Attn To : Keith Tuthill
Federal ID : 5103704
Collected : 04/03/2024 09:40 AM **Point** S-58352
Received : 04/03/2024 01:50 PM **Location** Well #3-3
Collected By CLIENT

Vinyl chloride	<0.50	1	ug/L	2	04/09/2024 3:18 PM	008 VG9C1/2
cis-1,2-Dichloroethene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
cis-1,3-Dichloropropene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
m&p-Xylene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
n-Butylbenzene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
n-Propylbenzene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
o-Xylene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
p-Isopropyltoluene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
sec-Butylbenzene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
tert-Butylbenzene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
trans-1,2-Dichloroethene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
trans-1,3-Dichloropropene	<0.50	1	ug/L	5	04/09/2024 3:18 PM	008 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	88%	1	%REC		04/09/2024 3:18 PM	008 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	90%	1	%REC		04/09/2024 3:18 PM	008 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946
Attn To : Keith Tuthill

Lab No. : 70292813009
Client Sample ID.: S-108065

Federal ID : 5103704
 Collected : 04/03/2024 10:10 AM Point S-108065
 Received : 04/03/2024 01:50 PM Location Well #4-1
 Collected By CLIENT

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	<0.050		1	mg/L	10	04/04/2024 1:34 AM	009 BP4U1/1
Nitrate-Nitrite (as N)	<0.050		1	mg/L		04/04/2024 1:34 AM	009 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	04/03/2024 10:57	009 BP4U1/1

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
Benzene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		04/09/2024 3:41 PM	009 VG9C1/2
Bromoform	<0.50		1	ug/L		04/09/2024 3:41 PM	009 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70292813009
Client Sample ID.: S-108065

Attn To : Keith Tuthill
Federal ID : 5103704
Collected : 04/03/2024 10:10 AM **Point** S-108065
Received : 04/03/2024 01:50 PM **Location** Well #4-1
Collected By CLIENT

Chlorodifluoromethane	<0.50	N3	1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
Chloroform	1.4		1	ug/L		04/09/2024 3:41 PM	009 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		04/09/2024 3:41 PM	009 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
Methyl-tert-butyl ether	<0.50		1	ug/L	10	04/09/2024 3:41 PM	009 VG9C1/2
Methylene Chloride	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
Styrene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
Tetrachloroethene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
Toluene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
Total Trihalomethanes (Calc.)	1.4		1	ug/L	80	04/09/2024 3:41 PM	009 VG9C1/2
Trichloroethene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
Trichlorofluoromethane	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
Vinyl chloride	<0.50		1	ug/L	2	04/09/2024 3:41 PM	009 VG9C1/2
cis-1,2-Dichloroethene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
cis-1,3-Dichloropropene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
m&p-Xylene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
n-Butylbenzene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
n-Propylbenzene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
o-Xylene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
p-Isopropyltoluene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
sec-Butylbenzene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
tert-Butylbenzene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
trans-1,2-Dichloroethene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
trans-1,3-Dichloropropene	<0.50		1	ug/L	5	04/09/2024 3:41 PM	009 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	90%		1	%REC		04/09/2024 3:41 PM	009 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	90%		1	%REC		04/09/2024 3:41 PM	009 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70292813010
Client Sample ID.: S-108066

Attn To : Keith Tuthill
 Federal ID : 5103704
 Collected : 04/03/2024 10:15 AM Point S-108066
 Received : 04/03/2024 01:50 PM Location Well #4-2
 Collected By CLIENT

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	0.11		1	mg/L	10	04/04/2024 1:36 AM	010 BP4U1/1
Nitrate-Nitrite (as N)	0.11		1	mg/L		04/04/2024 1:36 AM	010 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	04/03/2024 11:03	010 BP4U1/1

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
Benzene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		04/09/2024 4:04 PM	010 VG9C1/2
Bromoform	<0.50		1	ug/L		04/09/2024 4:04 PM	010 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70292813010
Client Sample ID.: S-108066

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 04/03/2024 10:15 AM Point S-108066

Received : 04/03/2024 01:50 PM Location Well #4-2

Collected By CLIENT

Chlorodifluoromethane	<0.50	N3	1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
Chloroform	1.6		1	ug/L		04/09/2024 4:04 PM	010 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		04/09/2024 4:04 PM	010 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
Methyl-tert-butyl ether	<0.50		1	ug/L	10	04/09/2024 4:04 PM	010 VG9C1/2
Methylene Chloride	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
Styrene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
Tetrachloroethene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
Toluene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
Total Trihalomethanes (Calc.)	1.6		1	ug/L	80	04/09/2024 4:04 PM	010 VG9C1/2
Trichloroethene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
Trichlorofluoromethane	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
Vinyl chloride	<0.50		1	ug/L	2	04/09/2024 4:04 PM	010 VG9C1/2
cis-1,2-Dichloroethene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
cis-1,3-Dichloropropene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
m&p-Xylene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
n-Butylbenzene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
n-Propylbenzene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
o-Xylene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
p-Isopropyltoluene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
sec-Butylbenzene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
tert-Butylbenzene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
trans-1,2-Dichloroethene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
trans-1,3-Dichloropropene	<0.50		1	ug/L	5	04/09/2024 4:04 PM	010 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	87%		1	%REC		04/09/2024 4:04 PM	010 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	89%		1	%REC		04/09/2024 4:04 PM	010 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70292813011
Client Sample ID.: S-127163

Attn To : Keith Tuthill
 Federal ID : 5103704
 Collected : 04/03/2024 10:30 AM Point S-127163
 Received : 04/03/2024 01:50 PM Location Well #5-1
 Collected By CLIENT

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	1.2		5	mg/L	10	04/04/2024 1:13 AM	011 BP4U1/1
Nitrate-Nitrite (as N)	1.2		5	mg/L		04/04/2024 1:13 AM	011 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	04/03/2024 11:04	011 BP4U1/1

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
Benzene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		04/09/2024 4:27 PM	011 VG9C1/2
Bromoform	<0.50		1	ug/L		04/09/2024 4:27 PM	011 VG9C1/2
Bromomethane	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70292813011
Client Sample ID.: S-127163

Attn To : Keith Tuthill
Federal ID : 5103704
Collected : 04/03/2024 10:30 AM **Point** S-127163
Received : 04/03/2024 01:50 PM **Location** Well #5-1
Collected By CLIENT

Chlorodifluoromethane	<0.50	N3	1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
Chloroform	1.9		1	ug/L		04/09/2024 4:27 PM	011 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		04/09/2024 4:27 PM	011 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
Dichlorodifluoromethane	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
Methyl-tert-butyl ether	<0.50		1	ug/L	10	04/09/2024 4:27 PM	011 VG9C1/2
Methylene Chloride	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
Styrene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
Tetrachloroethene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
Toluene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
Total Trihalomethanes (Calc.)	1.9		1	ug/L	80	04/09/2024 4:27 PM	011 VG9C1/2
Trichloroethene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
Trichlorofluoromethane	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
Vinyl chloride	<0.50		1	ug/L	2	04/09/2024 4:27 PM	011 VG9C1/2
cis-1,2-Dichloroethene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
cis-1,3-Dichloropropene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
m&p-Xylene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
n-Butylbenzene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
n-Propylbenzene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
o-Xylene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
p-Isopropyltoluene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
sec-Butylbenzene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
tert-Butylbenzene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
trans-1,2-Dichloroethene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
trans-1,3-Dichloropropene	<0.50		1	ug/L	5	04/09/2024 4:27 PM	011 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	90%		1	%REC		04/09/2024 4:27 PM	011 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	92%		1	%REC		04/09/2024 4:27 PM	011 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Kimberley Mack

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

WorkOrder :
70292813

Laboratory Certifications

Pace Analytical Services Long Island

575 Broad Hollow Rd, Melville, NY 11747
Connecticut Certification #: PH-0435
Delaware Certification # NY 10478
Maryland Certification #: 208
Massachusetts Certification #: M-NY026
New Hampshire Certification #: 2987
New Jersey Certification #: NY158
New York Certification #: 10478 Primary Accrediting Body
Pennsylvania Certification #: 68-00350
Rhode Island Certification #: LAO00340
Virginia Certification # 460302



575 Broad Hollow Road, Melville, NY 11747

TEL: (516) 370-6000 FAX: (516) 886-5526

www.pacelabs.com

WorkOrder :

70292813

Additional Qualifiers

N3 - Accreditation is not offered by the relevant laboratory accrediting body for this parameter.

Sample Request Form PUBLIC WATER SUPPLIER

4/13/24 16:15

WELL OFF LINE

WELL RUN TO SYSTEM

YES NO VOC'S PRESERVED WITH HCl

Date: 4-3-2024

Collected By: K. T. THICH

Accepted By: *[Signature]* 4/3/24

Cooler Temp: 2.2 °C 1350

WO#: 70292813

Client Info:
 Name or Code: HAMPTON BAYS WATER DISTRICT
 Address: P.O. BOX 1013
HAMPTON BAYS, NEW YORK 11946
(631) 728-0179
 Phone #: _____
 Attn: _____
 Proj. # or (Name): _____
 Bill To: _____
 Copies To: _____

Sample Types	Purpose	Origin	Treatment Types
PW - Potable Water	RO - Routine	D - Distribution	AST - Air Stripper
GW - Groundwater	RE - Resample	RW - Raw Well	GAC - Granular Activated Charcoal
SW - Surface Water	S - Special	TW - Treated Well	N - Nitrate Removal Plant
WW - Waste Water		T - Tank	FE - Iron Removal Plant
AQ - Aqueous		MW - Monitoring Well	O - Other
S - Soil		I - Influent	
		E - Effluent	

Sample Info:

Date/Time Collected:	Sample Type	Location	Origin	Treatment Type	Purpose	Field Readings Cl ₂ pH/Temp	Analysis	Lab No.
4/13/24 7:30	GW	Well 1-1	RW	-	RO		N/N, POC	
4/13/24 7:45	GW	Well 1-2	RW	-	RO		N/N, POC	
4/13/24 8:00	GW	Well 1-3	RW	-	RO		N/N, POC	
4/13/24 8:20	GW	Well 2-1	RW	-	RO		N/N, POC	
4/13/24 8:35	GW	Well 2-2	RW	-	RO		N/N, POC	
4/13/24 8:55	GW	Well 3-1	RW	-	RO		N/N, POC	
4/13/24 9:10	PW	3 Gold Blended Entry Point	D	-	RO		N/N	
4/13/24 9:25	GW	Well 3-2	RW	-	RO		N/N, POC	
4/13/24 9:40	GW	Well 3-3	RW	-	RO		N/N, POC, metals	
4/13/24 10:00	GW	Well 4-1	RW	-	RO		N/N, POC	
4/13/24 10:15	GW	Well 4-2	RW	-	RO		N/N, POC	
4/13/24 10:35	GW	Well 5-1	RW	-	RO		N/N, POC	

Remarks:

Please report all analytes for well 3-3 metals, well 1-1, 1-2, 1-3, Run to waste

WO#: 70292813
 PM: KMM Due Date: 04/12/24
 CLIENT: HBW

Client Name: HBW Project: _____
 Courier: Fed Ex UPS USPS Client Commercial Pac Other

Tracking #: _____
 Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No Temperature Blank Present: Yes No
 Packing Material: Bubble Wrap Bubble Bags Ziplo None Other Type of Ice: Wet Blue None
 Thermometer Used: TH211 Correction Factor: -0.4 Samples on ice, cooling process has begun
 Cooler Temperature (°C): 2.2 Cooler Temperature Corrected (°C): 1.8 Date/Time 5035A kits placed in freezer: 4/3/24
 Temp should be above freezing to 6.0°C

USDA Regulated Soil (N/A, water sample)
 Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL; GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes No
 Did samples originate from a foreign source including Hawaii and Puerto Rico)? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.
 Date and Initials of person examining contents: MRC 4/3

	COMMENTS:
Chain of Custody Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr): <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	6.
Rush Turn Around Time Requested: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Containers Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	11. Note: if sediment is visible in the dissolved container.
Filtered volume received for Dissolved tests: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	12.
Sample Labels match COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
-Includes date/time/ID/Analysis Matrix: SL WT OIL OTHER	

Date and Initials of person checking preservation: MRC 4/3

All containers needing preservation have been pH paper Lot # <u>200623</u> <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A NAOH>12 Cyanide)	Sample #
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis	Initial when completed: _____ Lot # of added preservative: _____ Date/Time preservative added: _____
Samples checked for dechlorination: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
KI starch test strips Lot # _____	15. Positive for Sulfide? Y N
Residual chlorine strips Lot # _____	16.
SM 4500 CN samples checked for sulf: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	17.
Lead Acetate Strips Lot # _____	
Headspace in VOA Vials (>6mm): <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	
Trip Blank Present: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Trip Blank Custody Seals Present: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	

DATE AND INITIALS OF PERSON COMPLETING SECOND REVIEW: WK 4/3/24

Client Notification/ Resolution: _____
 Person Contacted: _____ Date/Time: _____
 Comments/ Resolution: _____

* PM (Project Manager) review is documented electronically in LIMS.