



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70316138001
Client Sample ID.: S-15687

Attn To : Keith Tuthill
 Federal ID : 5103704
 Collected : 10/02/2024 07:30 AM Point S-15687
 Received : 10/02/2024 04:40 PM Location Well #1-1
 Collected By CLIENT

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	<0.020		1	mg/L	0.3	10/08/2024 7:09 PM	001 BP4N1/1
Manganese	0.087		1	mg/L	0.3	10/08/2024 7:09 PM	001 BP4N1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	3.8		5	mg/L	10	10/03/2024 2:22 AM	001 BP4U1/1
Nitrate-Nitrite (as N)	3.8		5	mg/L		10/03/2024 2:22 AM	001 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	10/03/2024 12:18	001 BP4U1/1

Analytical Method:Field Method

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Field Residual Chlorine	<0.1	N3	1	mg/L	4	10/02/2024 7:30 AM	001 SP5T1/1

Analytical Method:SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 10/02/2024 5:05 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	10/03/2024 11:05	001 SP5T1/1
Total Coliforms	Absent		1		Absent	10/03/2024 11:05	001 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Michelle Cohen

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70316138002
Client Sample ID.: S-24848

Attn To : Keith Tuthill
 Federal ID : 5103704
 Collected : 10/02/2024 07:45 AM Point S-24848
 Received : 10/02/2024 04:40 PM Location Well #1-2
 Collected By CLIENT

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	<0.020		1	mg/L	0.3	10/08/2024 7:12 PM	002 BP4N1/1
Manganese	0.69*		1	mg/L	0.3	10/08/2024 7:12 PM	002 BP4N1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	5.5		5	mg/L	10	10/03/2024 2:23 AM	002 BP4U1/1
Nitrate-Nitrite (as N)	5.5		5	mg/L		10/03/2024 2:23 AM	002 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	10/03/2024 12:22	002 BP4U1/1

Analytical Method:Field Method

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Field Residual Chlorine	<0.1	N3	1	mg/L	4	10/02/2024 7:45 AM	002 SP5T1/1

Analytical Method:SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 10/02/2024 5:05 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	10/03/2024 11:05	002 SP5T1/1
Total Coliforms	Absent		1		Absent	10/03/2024 11:05	002 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Michelle Cohen

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70316138003
Client Sample ID.: S-31636

Attn To : Keith Tuthill
 Federal ID : 5103704
 Collected : 10/02/2024 08:00 AM Point S-31636
 Received : 10/02/2024 04:40 PM Location Well #1-3
 Collected By CLIENT

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	5.3		5	mg/L	10	10/03/2024 2:27 AM	003 BP4U1/1
Nitrate-Nitrite (as N)	5.3		5	mg/L		10/03/2024 2:27 AM	003 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	10/03/2024 12:23	003 BP4U1/1

Analytical Method:EPA 524.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
1,1,1,2-Tetrachloroethane	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
1,1,1-Trichloroethane	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
1,1,2,2-Tetrachloroethane	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
1,1,2-Trichloroethane	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
1,1,2-Trichlorotrifluoroethane	<0.50	N3	1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
1,1-Dichloroethane	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
1,1-Dichloroethene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
1,1-Dichloropropene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
1,2,3-Trichlorobenzene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
1,2,3-Trichloropropane	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
1,2,4-Trichlorobenzene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
1,2,4-Trimethylbenzene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
1,2-Dichlorobenzene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
1,2-Dichloroethane	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
1,2-Dichloropropane	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
1,3,5-Trimethylbenzene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
1,3-Dichlorobenzene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
1,3-Dichloropropane	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
1,4-Dichlorobenzene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
2,2-Dichloropropane	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
2-Chlorotoluene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
4-Chlorotoluene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
Benzene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
Bromobenzene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
Bromochloromethane	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
Bromodichloromethane	<0.50		1	ug/L		10/11/2024 3:54 PM	003 VG9C1/2
Bromoform	<0.50		1	ug/L		10/11/2024 3:54 PM	003 VG9C1/2
Bromomethane	<0.50	IC	1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
Carbon tetrachloride	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
Chlorobenzene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Michelle Cohen

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70316138003
Client Sample ID.: S-31636

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 10/02/2024 08:00 AM Point S-31636

Received : 10/02/2024 04:40 PM Location Well #1-3

Collected By CLIENT

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Chlorodifluoromethane	<0.50	N3	1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
Chloroethane	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
Chloroform	0.56		1	ug/L		10/11/2024 3:54 PM	003 VG9C1/2
Chloromethane	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
Dibromochloromethane	<0.50		1	ug/L		10/11/2024 3:54 PM	003 VG9C1/2
Dibromomethane	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
Dichlorodifluoromethane	<0.50	v3	1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
Ethylbenzene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
Hexachloro-1,3-butadiene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
Isopropylbenzene (Cumene)	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
Methyl-tert-butyl ether	<0.50		1	ug/L	10	10/11/2024 3:54 PM	003 VG9C1/2
Methylene Chloride	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
Styrene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
Tetrachloroethene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
Toluene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
Total Trihalomethanes (Calc.)	0.56		1	ug/L	80	10/11/2024 3:54 PM	003 VG9C1/2
Trichloroethene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
Trichlorofluoromethane	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
Vinyl chloride	<0.50		1	ug/L	2	10/11/2024 3:54 PM	003 VG9C1/2
cis-1,2-Dichloroethene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
cis-1,3-Dichloropropene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
m&p-Xylene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
n-Butylbenzene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
n-Propylbenzene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
o-Xylene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
p-Isopropyltoluene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
sec-Butylbenzene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
tert-Butylbenzene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
trans-1,2-Dichloroethene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
trans-1,3-Dichloropropene	<0.50		1	ug/L	5	10/11/2024 3:54 PM	003 VG9C1/2
Surr: 1,2-Dichlorobenzene-d4 (S)	92%		1	%REC		10/11/2024 3:54 PM	003 VG9C1/2
Surr: 4-Bromofluorobenzene (S)	88%		1	%REC		10/11/2024 3:54 PM	003 VG9C1/2

Analytical Method:Field Method

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Field Residual Chlorine	<0.1	N3	1	mg/L	4	10/02/2024 8:00 AM	003 SP5T1/1

Analytical Method:SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 10/02/2024 5:05 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	10/03/2024 11:05	003 SP5T1/1
Total Coliforms	Absent		1		Absent	10/03/2024 11:05	003 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Michelle Cohen

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Influent
 Routine

Hampton Bays Water District

PO Box 1013

Hampton Bays, NY 11946

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 10/02/2024 08:10 AM Point BLENDED
 Received : 10/02/2024 04:40 PM Location BLENDED INFLUENT GAC
 Collected By CLIENT

Lab No. : 70316138004

Client Sample ID.: BLENDED INFLUENT GAC

Analytical Method:EPA 200.7

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Iron	<0.020		1	mg/L	0.3	10/08/2024 4:08 PM	004 BP4N1/1
Manganese	0.16		1	mg/L	0.3	10/08/2024 4:08 PM	004 BP4N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected

Michelle Cohen

Test results meet the requirements of NELAC unless otherwise noted.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Date Reported: 10/14/2024



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Effluent
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70316138005
Client Sample ID.: BLENDED EFFLUENT GAC

Attn To : Keith Tuthill
 Federal ID : 5103704
 Collected : 10/02/2024 08:15 AM Point BLENDED
 Received : 10/02/2024 04:40 PM Location BLENDED EFFLUENT GAC
 Collected By CLIENT

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrate as N	4.4		5	mg/L	10	10/03/2024 2:29 AM	005 BP4U1/1
Nitrate-Nitrite (as N)	4.4		5	mg/L		10/03/2024 2:29 AM	005 BP4U1/1

Analytical Method:EPA 353.2

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Nitrite as N	<0.050		1	mg/L	1	10/03/2024 12:25	005 BP4U1/1

Analytical Method:Field Method

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Field Residual Chlorine	<0.1	N3	1	mg/L	4	10/02/2024 8:15 AM	005 SP5T1/1

Analytical Method:SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 10/02/2024 5:05 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	10/03/2024 11:05	005 SP5T1/1
Total Coliforms	Absent		1		Absent	10/03/2024 11:05	005 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Michelle Cohen

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District

PO Box 1013

Hampton Bays, NY 11946

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 10/02/2024 08:35 AM Point S-50970

Received : 10/02/2024 04:40 PM Location Well #2-1

Collected By CLIENT

Lab No. : 70316138006

Client Sample ID.: S-50970

Analytical Method:Field Method

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Field Residual Chlorine	<0.1	N3	1	mg/L	4	10/02/2024 8:35 AM	006 SP5T1/1

Analytical Method:SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 10/02/2024 5:05 PM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	10/03/2024 11:05	006 SP5T1/1
Total Coliforms	Absent		1		Absent	10/03/2024 11:05	006 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Michelle Cohen

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District

PO Box 1013

Hampton Bays, NY 11946

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 10/02/2024 08:50 AM Point S-74071

Received : 10/02/2024 04:40 PM Location Well #2-2

Collected By CLIENT

Lab No. : 70316138007

Client Sample ID.: S-74071

Analytical Method:Field Method

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Field Residual Chlorine	<0.1	N3	1	mg/L	4	10/02/2024 8:50 AM	007 SP5T1/1

Analytical Method:SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 10/02/2024 5:05 PM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	10/03/2024 11:05	007 SP5T1/1
Total Coliforms	Absent		1		Absent	10/03/2024 11:05	007 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Michelle Cohen

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District

PO Box 1013

Hampton Bays, NY 11946

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 10/02/2024 09:10 AM Point S-58350

Received : 10/02/2024 04:40 PM Location Well #3-1

Collected By CLIENT

Lab No. : 70316138008

Client Sample ID.: S-58350

Analytical Method:Field Method

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Field Residual Chlorine	<0.1	N3	1	mg/L	4	10/02/2024 9:10 AM	008 SP5T1/1

Analytical Method:SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 10/02/2024 5:05 PM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	10/03/2024 11:05	008 SP5T1/1
Total Coliforms	Absent		1		Absent	10/03/2024 11:05	008 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Michelle Cohen

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70316138009
Client Sample ID.: S-58351

Attn To : Keith Tuthill
 Federal ID : 5103704
 Collected : 10/02/2024 09:25 AM Point S-58351
 Received : 10/02/2024 04:40 PM Location Well #3-2
 Collected By CLIENT

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	<0.020		1	mg/L	0.3	10/08/2024 7:23 PM	009 BP4N1/1
Manganese	0.059		1	mg/L	0.3	10/08/2024 7:23 PM	009 BP4N1/1

Analytical Method:Field Method

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Field Residual Chlorine	<0.1	N3	1	mg/L	4	10/02/2024 9:25 AM	009 SP5T1/1

Analytical Method:SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 10/02/2024 5:05 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	10/03/2024 11:05	009 SP5T1/1
Total Coliforms	Absent		1		Absent	10/03/2024 11:05	009 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Michelle Cohen

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District

PO Box 1013

Hampton Bays, NY 11946

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 10/02/2024 09:40 AM Point S-58352

Received : 10/02/2024 04:40 PM Location Well #3-3

Collected By CLIENT

Lab No. : 70316138010

Client Sample ID.: S-58352

Analytical Method:Field Method

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Field Residual Chlorine	<0.1	N3	1	mg/L	4	10/02/2024 9:40 AM	010 SP5T1/1

Analytical Method:SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 10/02/2024 5:05 PM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	10/03/2024 11:05	010 SP5T1/1
Total Coliforms	Absent		1		Absent	10/03/2024 11:05	010 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Michelle Cohen

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District

PO Box 1013

Hampton Bays, NY 11946

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 10/02/2024 10:00 AM Point S-108065

Received : 10/02/2024 04:40 PM Location Well #4-1

Collected By CLIENT

Lab No. : 70316138011

Client Sample ID.: S-108065

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	0.57*		1	mg/L	0.3	10/08/2024 7:25 PM	011 BP3N1/1
Manganese	0.12		1	mg/L	0.3	10/08/2024 7:25 PM	011 BP3N1/1

Analytical Method:Field Method

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Field Residual Chlorine	<0.1	N3	1	mg/L	4	10/02/2024 10:00	011 SP5T1/1

Analytical Method:SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 10/02/2024 5:05 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	10/03/2024 11:05	011 SP5T1/1
Total Coliforms	Absent		1		Absent	10/03/2024 11:05	011 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Michelle Cohen

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District
PO Box 1013
Hampton Bays, NY 11946

Lab No. : 70316138012
Client Sample ID.: S-108066

Attn To : Keith Tuthill
 Federal ID : 5103704
 Collected : 10/02/2024 10:20 AM Point S-108066
 Received : 10/02/2024 04:40 PM Location Well #4-2
 Collected By CLIENT

Analytical Method:EPA 200.7

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Iron	1.4*		1	mg/L	0.3	10/08/2024 7:28 PM	012 BP4N1/1
Manganese	0.18		1	mg/L	0.3	10/08/2024 7:28 PM	012 BP4N1/1

Analytical Method:Field Method

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Field Residual Chlorine	<0.1	N3	1	mg/L	4	10/02/2024 10:20	012 SP5T1/1

Analytical Method:SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 10/02/2024 5:05 PM

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
E.coli	Absent		1		Absent	10/03/2024 11:05	012 SP5T1/1
Total Coliforms	Absent		1		Absent	10/03/2024 11:05	012 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.
 ND - Not Detected at or above adjusted reporting limit.
 J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range
 U - Indicates the compound was analyzed for, but not detected
 See qualifiers page for additional qualifier definitions.

Michelle Cohen

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Effluent
 Routine

Hampton Bays Water District

PO Box 1013

Hampton Bays, NY 11946

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 10/02/2024 10:35 AM Point BLENDED
 Received : 10/02/2024 04:40 PM Location BLENDED EFFLUENT IRON
 Collected By CLIENT

Lab No. : 70316138013

Client Sample ID.: BLENDED EFFLUENT IRON

Analytical Method:EPA 200.7

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Iron	<0.020		1	mg/L	0.3	10/08/2024 4:10 PM	013 BP4N1/1
Manganese	<0.010		1	mg/L	0.3	10/08/2024 4:10 PM	013 BP4N1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Date Reported: 10/14/2024

Michelle Cohen

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
 TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

Laboratory Results

Results for the samples and analytes requested
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the certified tests

Sample Information:

Type: Drinking Water
 Origin: Raw Well
 Routine

Hampton Bays Water District

PO Box 1013

Hampton Bays, NY 11946

Attn To : Keith Tuthill

Federal ID : 5103704

Collected : 10/02/2024 10:55 AM Point S-127163

Received : 10/02/2024 04:40 PM Location Well #5-1

Collected By CLIENT

Lab No. : 70316138014

Client Sample ID.: S-127163

Analytical Method:Field Method

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Field Residual Chlorine	<0.1	N3	1	mg/L	4	10/02/2024 10:55	014 SP5T1/1

Analytical Method:SM22 9223B Colilert Prep Method: SM22 9223B Colilert Prep Date: 10/02/2024 5:05 PM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
E.coli	Absent		1		Absent	10/03/2024 11:05	014 SP5T1/1
Total Coliforms	Absent		1		Absent	10/03/2024 11:05	014 SP5T1/1

Qualifiers:

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to changes in sample preparation, dilution of the sample aliquot, or moisture content.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit. Estimated value - below calibration range

U - Indicates the compound was analyzed for, but not detected

See qualifiers page for additional qualifier definitions.

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit Noted.

Michelle Cohen

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



575 Broad Hollow Road, Melville, NY 11747
TEL: (516) 370-6000 FAX: (516) 886-5526
www.pacelabs.com

WorkOrder :
70316138

Laboratory Certifications

Pace Analytical Services, LLC - Melville, NY

575 Broad Hollow Rd, Melville, NY 11747
Connecticut Certification #: PH-0435
Delaware Certification # NY 10478
Maryland Certification #: 208
Massachusetts Certification #: M-NY026
New Hampshire Certification #: 2987
New Jersey Certification #: NY158
New York Certification #: 10478 Primary Accrediting Body
Pennsylvania Certification #: 68-00350
Rhode Island Certification #: LAO00340



575 Broad Hollow Road, Melville, NY 11747

TEL: (516) 370-6000 FAX: (516) 886-5526

www.pacelabs.com

WorkOrder :

70316138

Additional Qualifiers

IC - The initial calibration for this compound was outside of method control limits. The result is estimated.

N3 - Accreditation is not offered by the relevant laboratory accrediting body for this parameter.

v3 - The continuing calibration verification was below the method acceptance limit. Any detection for the analyte in the associated samples may have a low bias.

WO#: 70316138



Sample Request Form PUBLIC WATER SUPPLIER

Joe Kelly
10/2/24 1640
 WELL OFF LINE

Date: 10-2-2024
Collected By: K. TUTHILL
Accepted By: Joe Kelly 10/2/24
Cooler Temp: 3.4 °C
 WELL RUN TO SYSTEM
 YES NO VOC'S PRESERVED WITH HCl

Client Info:
Name or Code: HAMPTON BAYS WATER DISTRICT
Address: P.O. BOX 1013
HAMPTON BAYS, NEW YORK 11946
(631) 728-0179
Phone #: _____
Attn: _____
Proj. # or (Name): _____
Bill To: _____
Copies To: _____

Sample Types	Purpose	Origin	Treatment Types
PW - Potable Water	RO - Routine	D - Distribution	AST - Air Stripper
GW - Groundwater	RE - Resample	RW - Raw Well	GAC - Granular Activated Charcoal
SW - Surface Water	S - Special	TW - Treated Well	N - Nitrate Removal Plant
WW - Waste Water		T - Tank	FE - Iron Removal Plant
AQ - Aqueous		MW - Monitoring Well	O - Other
S - Soil		I - Influent	
		E - Effluent	

Sample Info:

Date/Time Collected:	Sample Type	Location	Origin	Treatment Type	Purpose	Field Readings Cl ₂ pH/Temp	Analysis	Lab No.
10/2/24/7:30	GW	well 1-1	RW		RO	.00	BACT, FILM, MIN	
10/2/24/7:45	GW	well 1-2	RW		RO	.00	BACT, FILM, MIN, IRON	
10/2/24/8:00	GW	well 1-3	RW		RO	.00	BACT, MIN, POC	
10/2/24/8:10	GW	Blended Influent	I	GAC	RO		FILM	
10/2/24/8:15	GW	Blended Effluent	E	GAC	RO	.00	BACT, MIN	
10/2/24/8:35	GW	well 2-1	RW		RO	.00	BACT	
10/2/24/8:50	GW	well 2-2	RW		RO	.00	BACT	
10/2/24/9:10	GW	well 3-1	RW		RO	.00	BACT	
10/2/24/9:25	GW	well 3-2	RW		RO	.00	BACT, FILM	
10/2/24/9:40	GW	well 3-3	RW		RO	.00	BACT	
10/2/24/9:15	PW	Blended Entry Point 3	D		RO		FILM, MIN	

Remarks:

WO#: 70316138

Client Name: H13W

Project #

PM: MC1

Due Date: 10/08/24

Courier: Fed Ex UPS USPS Client Commercial Pace Other

CLIENT: HBW

Tracking #:

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No Temperature Blank Present: Yes No

Packing Material: Bubble Wrap Bubble Bags Ziploc None Other Type of Ice: Wet Blue None

Thermometer Used: T11211 Correction Factor: -0.1 Samples on ice, cooling process has begun

Cooler Temperature (°C): 3.4 Cooler Temperature Corrected (°C): 3.1 Date/Time 5035A kits placed in freezer: 10/2/24 1640

Temp should be above freezing to 5.0°C

USDA Regulated Soil (N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes No

Did samples originate from a foreign source including Hawaii and Puerto Rico? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.

Date and Initials of person examining contents: AD 10/2/24

	COMMENTS:
Chain of Custody Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr): <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	6.
Rush Turn Around Time Requested: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Containers Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	11. Note: if sediment is visible in the dissolved container.
Sample Labels match COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID/Analysis Matrix: SL <input checked="" type="checkbox"/> WT <input type="checkbox"/> OIL <input type="checkbox"/> OTHER	

Date and Initials of person checking preservation: AD 10/2/24

All containers needing preservation have been pH paper Lot # <u>200623</u> <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH > 9 Sulfide, <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A NAOH > 12 Cyanide)	Sample #
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis	Initial when completed: Lot # of added preservative: Date/Time preservative added:
Samples checked for dechlorination: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
KI starch test strips Lot #	
SM 4500 CN samples checked for sulf <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15. Positive for Sulfide? Y N
Lead Acetate Strips Lot #	
Headspace in ALK Bottle (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Headspace in VOA Vials (>6mm): <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	17.
Trip Blank Present: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	
Trip Blank Custody Seals Present: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution:

* PM (Project Manager) review (which includes the SCUR) is documented electronically in LIMS.