

March 20, 2018

Rob King
Hampton Bays Water District
P.O. Box 1013
Hampton Bays, NY 11946

RE: Project: IOC 3/7
Pace Project No.: 7044713

Dear Rob King:

Enclosed are the analytical results for sample(s) received by the laboratory on March 07, 2018. The results relate only to the samples included in this report. Results reported herein conform to the most current, applicable TNI/NELAC standards and the laboratory's Quality Assurance Manual, where applicable, unless otherwise noted in the body of the report.

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Stu Murrell
stu.murrell@pacelabs.com
(631)694-3040
Project Manager

Enclosures

cc: Warren Booth, Hampton Bays Water District
John Collins, H2M Group
Stella Michaels, Hampton Bays Water District
Paul Ponturo, H2M Group



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: IOC 3/7
Pace Project No.: 7044713

Long Island Certification IDs

575 Broad Hollow Rd, Melville, NY 11747
New York Certification #: 10478 Primary Accrediting Body
New Jersey Certification #: NY158
Pennsylvania Certification #: 68-00350
Connecticut Certification #: PH-0435

Maryland Certification #: 208
Rhode Island Certification #: LAO00340
Massachusetts Certification #: M-NY026
New Hampshire Certification #: 2987

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE SUMMARY

Project: IOC 3/7
Pace Project No.: 7044713

Lab ID	Sample ID	Matrix	Date Collected	Date Received
7044713001	HB3	Drinking Water	03/07/18 08:10	03/07/18 16:00
7044713002	HB8	Drinking Water	03/07/18 10:00	03/07/18 16:00

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE ANALYTE COUNT

Project: IOC 3/7
Pace Project No.: 7044713

Lab ID	Sample ID	Method	Analysts	Analytes Reported
7044713001	HB3	EPA 200.7	JMW	5
		EPA 200.8	SK2	12
		SM22 2120B	JHH	2
		SM22 2150B	JHH	1
		SM22 2510B	ML	1
		SM22 5540C	JHH	2
		EPA 300.0	BNK	2
		EPA 353.2	SDO	2
		EPA 353.2	SDO	1
		SM22 4500-CN-E	CPD	1
		SM22 4500-CI-E	BNK	1
		SM22 4500 NH3 H	BNK	1
		7044713002	HB8	EPA 200.7
EPA 200.8	SK2			12
SM22 2120B	JHH			2
SM22 2150B	JHH			1
SM22 2510B	ML			1
SM22 5540C	JHH			2
EPA 300.0	BNK			2
EPA 353.2	SDO			2
EPA 353.2	SDO			1
SM22 4500-CN-E	CPD			1
SM22 4500-CI-E	BNK			1
SM22 4500 NH3 H	BNK			1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: IOC 3/7

Pace Project No.: 7044713

Sample: HB3		Lab ID: 7044713001		Collected: 03/07/18 08:10	Received: 03/07/18 16:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual	
Field Chlorine and pH		Analytical Method:								
Field Temperature	20.7	deg C			1		03/07/18 08:10		N3	
Field pH	7.02	Std. Units			1		03/07/18 08:10		N3	
200.7 MET ICP, Drinking Water		Analytical Method: EPA 200.7								
Ca Hardness as CaCO3 (SM 2340B)	35.5	mg/L	0.50		1		03/08/18 13:49			
Iron	<0.020	mg/L	0.020		1		03/08/18 13:49	7439-89-6		
Manganese	<0.010	mg/L	0.010		1		03/08/18 13:49	7439-96-5		
Sodium	29.7	mg/L	0.20		1		03/08/18 13:49	7440-23-5		
Zinc	<0.020	mg/L	0.020		1		03/08/18 13:49	7440-66-6		
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8								
Antimony	<0.40	ug/L	0.40		1		03/08/18 13:54	7440-36-0		
Arsenic	<1.0	ug/L	1.0		1		03/08/18 13:54	7440-38-2		
Barium	0.027	mg/L	0.0020		1		03/08/18 13:54	7440-39-3		
Beryllium	<0.30	ug/L	0.30		1		03/08/18 13:54	7440-41-7		
Cadmium	<1.0	ug/L	1.0		1		03/08/18 13:54	7440-43-9		
Chromium	<0.0070	mg/L	0.0070		1		03/08/18 13:54	7440-47-3		
Lead	<1.0	ug/L	1.0		1		03/08/18 13:54	7439-92-1		
Mercury	<0.20	ug/L	0.20		1		03/08/18 13:54	7439-97-6		
Nickel	<0.00050	mg/L	0.00050		1		03/08/18 13:54	7440-02-0		
Selenium	<2.0	ug/L	2.0		1		03/08/18 13:54	7782-49-2		
Silver	<0.0010	mg/L	0.0010		1		03/08/18 13:54	7440-22-4		
Thallium	<0.30	ug/L	0.30		1		03/08/18 13:54	7440-28-0		
2120B W Apparent Color		Analytical Method: SM22 2120B								
Apparent Color	<5.0	units	5.0		1		03/07/18 17:59			
pH	6.0	Std. Units	0.10		1		03/07/18 17:59			
2150B Threshold Odor Number		Analytical Method: SM22 2150B								
Odor @ 60 Degrees C	No odor observed		1.0		1		03/07/18 17:50			
2510B Specific Conductance		Analytical Method: SM22 2510B								
Specific Conductance	283	umhos/cm	1.0		1		03/11/18 08:48			
5540C MBAS Surfactants		Analytical Method: SM22 5540C Preparation Method: SM22 5540C								
LAS Molecular Weight, g/mol	320				1	03/07/18 17:39	03/07/18 21:42			
MBAS, Calculated as LAS	<0.080	mg/L	0.080		1	03/07/18 17:39	03/07/18 21:42			
300.0 IC Anions 28 Days		Analytical Method: EPA 300.0								
Fluoride	<0.10	mg/L	0.10		1		03/16/18 22:34	16984-48-8		
Sulfate	12.7	mg/L	5.0		1		03/16/18 22:34	14808-79-8		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: IOC 3/7
Pace Project No.: 7044713

Sample: HB3 Lab ID: 7044713001 Collected: 03/07/18 08:10 Received: 03/07/18 16:00 Matrix: Drinking Water									
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
353.2 Nitrogen, NO2/NO3 unpres Analytical Method: EPA 353.2									
Nitrate as N	2.1	mg/L	0.50		10		03/08/18 09:24	14797-55-8	
Nitrate-Nitrite (as N)	2.1	mg/L	0.50		10		03/08/18 09:24	7727-37-9	
353.2 Nitrogen, NO2 Analytical Method: EPA 353.2									
Nitrite as N	<0.050	mg/L	0.050		1		03/08/18 07:18	14797-65-0	M1
SM 4500 CNE Cyanide, Total Analytical Method: SM22 4500-CN-E Preparation Method: SM20/22 4500-CN-C									
Cyanide	<10.0	ug/L	10.0		1	03/19/18 10:49	03/19/18 17:20	57-12-5	
4500 Chloride Analytical Method: SM22 4500-Cl-E									
Chloride	42.5	mg/L	2.0		1		03/12/18 13:33	16887-00-6	
4500 Ammonia Water Analytical Method: SM22 4500 NH3 H									
Nitrogen, Ammonia	<0.10	mg/L	0.10		1		03/13/18 14:58	7664-41-7	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: IOC 3/7
Pace Project No.: 7044713

Sample: HB8									
Lab ID: 7044713002									
Collected: 03/07/18 10:00									
Received: 03/07/18 16:00									
Matrix: Drinking Water									
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
Field Chlorine and pH									
Analytical Method:									
Field Temperature	12.5	deg C			1		03/07/18 10:00		N3
Field pH	7.08	Std. Units			1		03/07/18 10:00		N3
200.7 MET ICP, Drinking Water									
Analytical Method: EPA 200.7									
Ca Hardness as CaCO3 (SM 2340B)	43.2	mg/L	0.50		1		03/08/18 13:52		
Iron	0.022	mg/L	0.020		1		03/08/18 13:52	7439-89-6	
Manganese	<0.010	mg/L	0.010		1		03/08/18 13:52	7439-96-5	
Sodium	36.2	mg/L	0.20		1		03/08/18 13:52	7440-23-5	
Zinc	<0.020	mg/L	0.020		1		03/08/18 13:52	7440-66-6	
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Antimony	<0.40	ug/L	0.40		1		03/08/18 13:57	7440-36-0	
Arsenic	<1.0	ug/L	1.0		1		03/08/18 13:57	7440-38-2	
Barium	0.030	mg/L	0.0020		1		03/08/18 13:57	7440-39-3	
Beryllium	<0.30	ug/L	0.30		1		03/08/18 13:57	7440-41-7	
Cadmium	<1.0	ug/L	1.0		1		03/08/18 13:57	7440-43-9	
Chromium	<0.0070	mg/L	0.0070		1		03/08/18 13:57	7440-47-3	
Lead	<1.0	ug/L	1.0		1		03/08/18 13:57	7439-92-1	
Mercury	<0.20	ug/L	0.20		1		03/08/18 13:57	7439-97-6	
Nickel	<0.00050	mg/L	0.00050		1		03/08/18 13:57	7440-02-0	
Selenium	<2.0	ug/L	2.0		1		03/08/18 13:57	7782-49-2	
Silver	<0.0010	mg/L	0.0010		1		03/08/18 13:57	7440-22-4	
Thallium	<0.30	ug/L	0.30		1		03/08/18 13:57	7440-28-0	
2120B W Apparent Color									
Analytical Method: SM22 2120B									
Apparent Color	<5.0	units	5.0		1		03/07/18 18:00		
pH	6.0	Std. Units	0.10		1		03/07/18 18:00		
2150B Threshold Odor Number									
Analytical Method: SM22 2150B									
Odor @ 60 Degrees C	No odor observed		1.0		1		03/07/18 17:50		
2510B Specific Conductance									
Analytical Method: SM22 2510B									
Specific Conductance	346	umhos/cm	1.0		1		03/11/18 08:49		
5540C MBAS Surfactants									
Analytical Method: SM22 5540C Preparation Method: SM22 5540C									
LAS Molecular Weight, g/mol	320				1	03/07/18 17:39	03/07/18 21:42		
MBAS, Calculated as LAS	<0.080	mg/L	0.080		1	03/07/18 17:39	03/07/18 21:42		
300.0 IC Anions 28 Days									
Analytical Method: EPA 300.0									
Fluoride	<0.10	mg/L	0.10		1		03/16/18 22:51	16984-48-8	
Sulfate	11.8	mg/L	5.0		1		03/16/18 22:51	14808-79-8	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: IOC 3/7
Pace Project No.: 7044713

Sample: HB8 Lab ID: 7044713002 Collected: 03/07/18 10:00 Received: 03/07/18 16:00 Matrix: Drinking Water									
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
353.2 Nitrogen, NO2/NO3 unpres Analytical Method: EPA 353.2									
Nitrate as N	1.6	mg/L	0.50		10		03/08/18 09:28	14797-55-8	
Nitrate-Nitrite (as N)	1.6	mg/L	0.50		10		03/08/18 09:28	7727-37-9	
353.2 Nitrogen, NO2 Analytical Method: EPA 353.2									
Nitrite as N	<0.050	mg/L	0.050		1		03/08/18 07:22	14797-65-0	
SM 4500 CNE Cyanide, Total Analytical Method: SM22 4500-CN-E Preparation Method: SM20/22 4500-CN-C									
Cyanide	<10.0	ug/L	10.0		1	03/19/18 10:49	03/19/18 17:22	57-12-5	
4500 Chloride Analytical Method: SM22 4500-Cl-E									
Chloride	62.3	mg/L	2.0		1		03/12/18 13:33	16887-00-6	
4500 Ammonia Water Analytical Method: SM22 4500 NH3 H									
Nitrogen, Ammonia	<0.10	mg/L	0.10		1		03/13/18 14:59	7664-41-7	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: IOC 3/7
Pace Project No.: 7044713

QC Batch: 58912 Analysis Method: EPA 200.7
QC Batch Method: EPA 200.7 Analysis Description: 200.7 MET No Prep Drinking Water
Associated Lab Samples: 7044713001, 7044713002

METHOD BLANK: 270076 Matrix: Drinking Water
Associated Lab Samples: 7044713001, 7044713002

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Ca Hardness as CaCO3 (SM 2340B)	mg/L	<0.50	0.50	03/08/18 13:32	
Iron	mg/L	<0.020	0.020	03/08/18 13:32	
Manganese	mg/L	<0.010	0.010	03/08/18 13:32	
Sodium	mg/L	<0.20	0.20	03/08/18 13:32	
Zinc	mg/L	<0.020	0.020	03/08/18 13:32	

LABORATORY CONTROL SAMPLE: 270077

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Ca Hardness as CaCO3 (SM 2340B)	mg/L		62.4			
Iron	mg/L	2	2.0	101	85-115	
Manganese	mg/L	.25	0.25	101	85-115	
Sodium	mg/L	50	49.7	99	85-115	
Zinc	mg/L	1	1.0	102	85-115	

MATRIX SPIKE SAMPLE: 270079

Parameter	Units	7044684007 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Ca Hardness as CaCO3 (SM 2340B)	mg/L	52200 ug/L		114			
Iron	mg/L	<0.020	2	2.1	103	70-130	
Manganese	mg/L	<10.0 ug/L	.25	0.26	103	70-130	
Sodium	mg/L	33700 ug/L	50	82.4	97	70-130	
Zinc	mg/L	319 ug/L	1	1.3	102	70-130	

MATRIX SPIKE SAMPLE: 270081

Parameter	Units	7044684008 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Ca Hardness as CaCO3 (SM 2340B)	mg/L	51700 ug/L		114			
Iron	mg/L	<0.020	2	2.0	100	70-130	
Manganese	mg/L	<10.0 ug/L	.25	0.25	99	70-130	
Sodium	mg/L	33300 ug/L	50	82.1	98	70-130	
Zinc	mg/L	309 ug/L	1	1.3	99	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: IOC 3/7
Pace Project No.: 7044713

SAMPLE DUPLICATE: 270078

Parameter	Units	7044684007 Result	Dup Result	RPD	Max RPD	Qualifiers
Ca Hardness as CaCO ₃ (SM 2340B	mg/L	52200 ug/L	51.7	1	20	
Iron	mg/L	<0.020	<0.020		20	
Manganese	mg/L	<10.0 ug/L	<0.010		20	
Sodium	mg/L	33700 ug/L	33.4	1	20	
Zinc	mg/L	319 ug/L	0.31	2	20	

SAMPLE DUPLICATE: 270080

Parameter	Units	7044684008 Result	Dup Result	RPD	Max RPD	Qualifiers
Ca Hardness as CaCO ₃ (SM 2340B	mg/L	51700 ug/L	53.2	3	20	
Iron	mg/L	<0.020	<0.020		20	
Manganese	mg/L	<10.0 ug/L	<0.010		20	
Sodium	mg/L	33300 ug/L	34.1	2	20	
Zinc	mg/L	309 ug/L	0.31	2	20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: IOC 3/7
Pace Project No.: 7044713

QC Batch: 58922 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET No Prep Drinking Water
Associated Lab Samples: 7044713001, 7044713002

METHOD BLANK: 270102 Matrix: Water
Associated Lab Samples: 7044713001, 7044713002

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Antimony	ug/L	<0.40	0.40	03/08/18 12:40	
Arsenic	ug/L	<1.0	1.0	03/08/18 12:40	
Barium	mg/L	<0.0020	0.0020	03/08/18 12:40	
Beryllium	ug/L	<0.30	0.30	03/08/18 12:40	
Cadmium	ug/L	<1.0	1.0	03/08/18 12:40	
Chromium	mg/L	<0.0070	0.0070	03/08/18 12:40	
Lead	ug/L	<1.0	1.0	03/08/18 12:40	
Mercury	ug/L	<0.20	0.20	03/08/18 12:40	
Nickel	mg/L	<0.00050	0.00050	03/08/18 12:40	
Selenium	ug/L	<2.0	2.0	03/08/18 12:40	
Silver	mg/L	<0.0010	0.0010	03/08/18 12:40	
Thallium	ug/L	<0.30	0.30	03/08/18 12:40	

LABORATORY CONTROL SAMPLE: 270103

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Antimony	ug/L	50	50.6	101	85-115	
Arsenic	ug/L	50	50.5	101	85-115	
Barium	mg/L	.05	0.049	99	85-115	
Beryllium	ug/L	50	49.1	98	85-115	
Cadmium	ug/L	50	49.2	98	85-115	
Chromium	mg/L	.05	0.051	103	85-115	
Lead	ug/L	50	50.5	101	85-115	
Mercury	ug/L	1.5	1.5	100	85-115	
Nickel	mg/L	.05	0.049	99	85-115	
Selenium	ug/L	50	49.8	100	85-115	
Silver	mg/L	.05	0.049	98	85-115	
Thallium	ug/L	50	52.0	104	85-115	

MATRIX SPIKE SAMPLE: 270105

Parameter	Units	7044715001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Antimony	ug/L	<0.40	10	9.5	95	70-130	
Arsenic	ug/L	<1.0	4	4.0	97	70-130	
Barium	mg/L	0.021	.2	0.22	98	70-130	
Beryllium	ug/L	<0.30	5	5.0	100	70-130	
Cadmium	ug/L	<1.0	5	4.9	98	70-130	
Chromium	mg/L	<0.0070	.02	0.017	84	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: IOC 3/7
Pace Project No.: 7044713

MATRIX SPIKE SAMPLE: 270105		7044715001	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	2	2.2	97	70-130	
Mercury	ug/L	<0.20	.4	0.43	100	70-130	
Nickel	mg/L	<0.00050	.05	0.045	91	70-130	
Selenium	ug/L	<2.0	1	<2.0	103	70-130	
Silver	mg/L	<0.0010	.005	0.0032	64	70-130	M1
Thallium	ug/L	<0.30	5	5.0	99	70-130	

MATRIX SPIKE SAMPLE: 270108		7044733003	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Antimony	ug/L	<0.40	10	9.4	93	70-130	
Arsenic	ug/L	2.8	4	6.5	92	70-130	
Barium	mg/L	4.2 ug/L	.2	0.20	99	70-130	
Beryllium	ug/L	<0.30	5	5.1	101	70-130	
Cadmium	ug/L	<1.0	5	5.0	99	70-130	
Chromium	mg/L	<7.0 ug/L	.02	0.015	75	70-130	
Lead	ug/L	<1.0	2	2.0	99	70-130	
Mercury	ug/L	<0.20	.4	0.33	80	70-130	
Nickel	mg/L	<0.50 ug/L	.05	0.047	93	70-130	
Selenium	ug/L	<2.0	1	<2.0	88	70-130	
Silver	mg/L	<1.0 ug/L	.005	0.0033	65	70-130	M1
Thallium	ug/L	<0.30	5	5.1	101	70-130	

SAMPLE DUPLICATE: 270104		7044715001	Dup	RPD	Max	
Parameter	Units	Result	Result	RPD	RPD	Qualifiers
Antimony	ug/L	<0.40	<0.40		20	
Arsenic	ug/L	<1.0	<1.0		20	
Barium	mg/L	0.021	0.021	0	20	
Beryllium	ug/L	<0.30	<0.30		20	
Cadmium	ug/L	<1.0	<1.0		20	
Chromium	mg/L	<0.0070	<0.0070		20	
Lead	ug/L	<1.0	<1.0		20	
Mercury	ug/L	<0.20	<0.20		20	
Nickel	mg/L	<0.00050	<0.00050		20	
Selenium	ug/L	<2.0	<2.0		20	
Silver	mg/L	<0.0010	<0.0010		20	
Thallium	ug/L	<0.30	<0.30		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: IOC 3/7
Pace Project No.: 7044713

SAMPLE DUPLICATE: 270107

Parameter	Units	7044733003 Result	Dup Result	RPD	Max RPD	Qualifiers
Antimony	ug/L	<0.40	<0.40		20	
Arsenic	ug/L	2.8	2.8	1	20	
Barium	mg/L	4.2 ug/L	0.0043	2	20	
Beryllium	ug/L	<0.30	<0.30		20	
Cadmium	ug/L	<1.0	<1.0		20	
Chromium	mg/L	<7.0 ug/L	<0.0070		20	
Lead	ug/L	<1.0	<1.0		20	
Mercury	ug/L	<0.20	<0.20		20	
Nickel	mg/L	<0.50 ug/L	<0.00050		20	
Selenium	ug/L	<2.0	<2.0		20	
Silver	mg/L	<1.0 ug/L	<0.0010		20	
Thallium	ug/L	<0.30	<0.30		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: IOC 3/7
Pace Project No.: 7044713

QC Batch: 58821 Analysis Method: SM22 2120B
QC Batch Method: SM22 2120B Analysis Description: 2120B Color
Associated Lab Samples: 7044713001, 7044713002

METHOD BLANK: 269752 Matrix: Water
Associated Lab Samples: 7044713001, 7044713002

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Apparent Color	units	<5.0	5.0	03/07/18 17:00	

LABORATORY CONTROL SAMPLE: 269753

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Apparent Color	units	40	40.0	100	90-110	

SAMPLE DUPLICATE: 269754

Parameter	Units	7044635001 Result	Dup Result	RPD	Max RPD	Qualifiers
Apparent Color	units	5.0	5.0	0	20	
pH	Std. Units	5.0	5.0	0	10	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: IOC 3/7
Pace Project No.: 7044713

QC Batch: 58832 Analysis Method: SM22 2150B
QC Batch Method: SM22 2150B Analysis Description: 2150B Threshold Odor Number
Associated Lab Samples: 7044713001, 7044713002

METHOD BLANK: 269855 Matrix: Drinking Water
Associated Lab Samples: 7044713001, 7044713002

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Odor @ 60 Degrees C		No odor	1.0	03/07/18 17:50	

SAMPLE DUPLICATE: 269856

Parameter	Units	7044713002 Result	Dup Result	RPD	Max RPD	Qualifiers
Odor @ 60 Degrees C		No odor observed	No odor		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: IOC 3/7
Pace Project No.: 7044713

QC Batch: 59169 Analysis Method: SM22 2510B
QC Batch Method: SM22 2510B Analysis Description: 2510B Specific Conductance
Associated Lab Samples: 7044713001, 7044713002

METHOD BLANK: 271464 Matrix: Water
Associated Lab Samples: 7044713001, 7044713002

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Specific Conductance	umhos/cm	<1.0	1.0	03/11/18 08:39	

LABORATORY CONTROL SAMPLE: 271465

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Specific Conductance	umhos/cm	718	709	99	85-115	

SAMPLE DUPLICATE: 271466

Parameter	Units	7044453001 Result	Dup Result	RPD	Max RPD	Qualifiers
Specific Conductance	umhos/cm	216	216	0	20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: IOC 3/7
Pace Project No.: 7044713

QC Batch: 58829 Analysis Method: SM22 5540C
QC Batch Method: SM22 5540C Analysis Description: 5540C MBAS Surfactants
Associated Lab Samples: 7044713001, 7044713002

METHOD BLANK: 269842 Matrix: Water
Associated Lab Samples: 7044713001, 7044713002

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
LAS Molecular Weight, g/mol		320		03/07/18 18:23	
MBAS, Calculated as LAS	mg/L	<0.080	0.080	03/07/18 18:23	

LABORATORY CONTROL SAMPLE: 269843

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
LAS Molecular Weight, g/mol			320			
MBAS, Calculated as LAS	mg/L	.24	0.23	97	85-115	

MATRIX SPIKE SAMPLE: 269844

Parameter	Units	7044635001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
LAS Molecular Weight, g/mol				320			
MBAS, Calculated as LAS	mg/L	<0.080	.24	0.30	104	75-125	

SAMPLE DUPLICATE: 269845

Parameter	Units	7044635001 Result	Dup Result	RPD	Max RPD	Qualifiers
LAS Molecular Weight, g/mol		320	320			
MBAS, Calculated as LAS	mg/L	<0.080	<0.080		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: IOC 3/7
Pace Project No.: 7044713

QC Batch: 59944 Analysis Method: EPA 300.0
QC Batch Method: EPA 300.0 Analysis Description: 300.0 IC Anions
Associated Lab Samples: 7044713001, 7044713002

METHOD BLANK: 274885 Matrix: Water
Associated Lab Samples: 7044713001, 7044713002

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Fluoride	mg/L	<0.10	0.10	03/16/18 20:37	
Sulfate	mg/L	<5.0	5.0	03/16/18 20:37	

LABORATORY CONTROL SAMPLE: 274886

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Fluoride	mg/L	1	1.0	103	90-110	
Sulfate	mg/L	10	10.4	104	90-110	

MATRIX SPIKE SAMPLE: 274887

Parameter	Units	7044804002 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Fluoride	mg/L	<0.10	1	1.0	94	80-120	
Sulfate	mg/L	26.0	10	35.1	91	80-120	

SAMPLE DUPLICATE: 274888

Parameter	Units	7044804002 Result	Dup Result	RPD	Max RPD	Qualifiers
Fluoride	mg/L	<0.10	<0.10		20	
Sulfate	mg/L	26.0	24.5	6	20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: IOC 3/7
Pace Project No.: 7044713

QC Batch: 58841 Analysis Method: EPA 353.2
QC Batch Method: EPA 353.2 Analysis Description: 353.2 Nitrite, Unpres.
Associated Lab Samples: 7044713001, 7044713002

METHOD BLANK: 269868 Matrix: Water
Associated Lab Samples: 7044713001, 7044713002

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Nitrite as N	mg/L	<0.050	0.050	03/08/18 06:51	

LABORATORY CONTROL SAMPLE: 269869

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Nitrite as N	mg/L	1	1.1	106	90-110	

MATRIX SPIKE SAMPLE: 269870

Parameter	Units	7044635005 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Nitrite as N	mg/L	<0.050	.5	0.56	111	90-110	M1

MATRIX SPIKE SAMPLE: 269872

Parameter	Units	7044713001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Nitrite as N	mg/L	<0.050	.5	0.41	82	90-110	M1

SAMPLE DUPLICATE: 269871

Parameter	Units	7044635005 Result	Dup Result	RPD	Max RPD	Qualifiers
Nitrite as N	mg/L	<0.050	<0.050		20	

SAMPLE DUPLICATE: 269873

Parameter	Units	7044713001 Result	Dup Result	RPD	Max RPD	Qualifiers
Nitrite as N	mg/L	<0.050	<0.050		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: IOC 3/7
Pace Project No.: 7044713

QC Batch: 58843 Analysis Method: EPA 353.2
QC Batch Method: EPA 353.2 Analysis Description: 353.2 Nitrate, Unpres.
Associated Lab Samples: 7044713001, 7044713002

METHOD BLANK: 269880 Matrix: Water
Associated Lab Samples: 7044713001, 7044713002

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Nitrate-Nitrite (as N)	mg/L	<0.050	0.050	03/08/18 08:27	

LABORATORY CONTROL SAMPLE: 269881

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Nitrate-Nitrite (as N)	mg/L	1	1.0	104	90-110	

MATRIX SPIKE SAMPLE: 269882

Parameter	Units	7044635005 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Nitrate-Nitrite (as N)	mg/L	<0.050	.5	0.51	99	90-110	

MATRIX SPIKE SAMPLE: 269884

Parameter	Units	7044713001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Nitrate-Nitrite (as N)	mg/L	2.1	5	6.8	94	90-110	

SAMPLE DUPLICATE: 269883

Parameter	Units	7044635005 Result	Dup Result	RPD	Max RPD	Qualifiers
Nitrate-Nitrite (as N)	mg/L	<0.050	<0.050		20	

SAMPLE DUPLICATE: 269885

Parameter	Units	7044713001 Result	Dup Result	RPD	Max RPD	Qualifiers
Nitrate-Nitrite (as N)	mg/L	2.1	2.1	0	20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: IOC 3/7
Pace Project No.: 7044713

QC Batch: 60031 Analysis Method: SM22 4500-CN-E
QC Batch Method: SM20/22 4500-CN-C Analysis Description: 4500 CNE Cyanide, Total
Associated Lab Samples: 7044713001, 7044713002

METHOD BLANK: 275328 Matrix: Water
Associated Lab Samples: 7044713001, 7044713002

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Cyanide	ug/L	<10.0	10.0	03/19/18 17:19	

LABORATORY CONTROL SAMPLE: 275329

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Cyanide	ug/L	75	70.5	94	85-115	

MATRIX SPIKE SAMPLE: 275330

Parameter	Units	7044713001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Cyanide	ug/L	<10.0	100	93.4	93	75-125	

SAMPLE DUPLICATE: 275331

Parameter	Units	7044713001 Result	Dup Result	RPD	Max RPD	Qualifiers
Cyanide	ug/L	<10.0	<10.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: IOC 3/7
Pace Project No.: 7044713

QC Batch: 59247 Analysis Method: SM22 4500-Cl-E
QC Batch Method: SM22 4500-Cl-E Analysis Description: 4500 Chloride
Associated Lab Samples: 7044713001, 7044713002

METHOD BLANK: 271675 Matrix: Water
Associated Lab Samples: 7044713001, 7044713002

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Chloride	mg/L	<2.0	2.0	03/12/18 13:19	

LABORATORY CONTROL SAMPLE: 271676

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Chloride	mg/L	50	54.4	109	90-110	

MATRIX SPIKE SAMPLE: 271677

Parameter	Units	7044804002 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Chloride	mg/L	43.4	25	41.9	-6	80-120	M1

SAMPLE DUPLICATE: 271678

Parameter	Units	7044804002 Result	Dup Result	RPD	Max RPD	Qualifiers
Chloride	mg/L	43.4	65.7	41	20	D6

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: IOC 3/7
Pace Project No.: 7044713

QC Batch: 59387 Analysis Method: SM22 4500 NH3 H
QC Batch Method: SM22 4500 NH3 H Analysis Description: 4500 Ammonia
Associated Lab Samples: 7044713001, 7044713002

METHOD BLANK: 272254 Matrix: Water
Associated Lab Samples: 7044713001, 7044713002

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Nitrogen, Ammonia	mg/L	<0.10	0.10	03/13/18 14:28	

LABORATORY CONTROL SAMPLE: 272255

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Nitrogen, Ammonia	mg/L	1	1.0	102	90-110	

MATRIX SPIKE SAMPLE: 272256

Parameter	Units	7044627001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Nitrogen, Ammonia	mg/L	18.3	10	27.6	94	75-125	

SAMPLE DUPLICATE: 272257

Parameter	Units	7044627001 Result	Dup Result	RPD	Max RPD	Qualifiers
Nitrogen, Ammonia	mg/L	18.3	17.3	6	20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: IOC 3/7
Pace Project No.: 7044713

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

ANALYTE QUALIFIERS

D6 The precision between the sample and sample duplicate exceeded laboratory control limits.

M1 Matrix spike recovery exceeded QC limits. Batch accepted based on laboratory control sample (LCS) recovery.

N3 Accreditation is not offered by the relevant laboratory accrediting body for this parameter.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: IOC 3/7
Pace Project No.: 7044713

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
7044713001	HB3		58899		
7044713002	HB8		58899		
7044713001	HB3	EPA 200.7	58912		
7044713002	HB8	EPA 200.7	58912		
7044713001	HB3	EPA 200.8	58922		
7044713002	HB8	EPA 200.8	58922		
7044713001	HB3	SM22 2120B	58821		
7044713002	HB8	SM22 2120B	58821		
7044713001	HB3	SM22 2150B	58832		
7044713002	HB8	SM22 2150B	58832		
7044713001	HB3	SM22 2510B	59169		
7044713002	HB8	SM22 2510B	59169		
7044713001	HB3	SM22 5540C	58829	SM22 5540C	58835
7044713002	HB8	SM22 5540C	58829	SM22 5540C	58835
7044713001	HB3	EPA 300.0	59944		
7044713002	HB8	EPA 300.0	59944		
7044713001	HB3	EPA 353.2	58843		
7044713002	HB8	EPA 353.2	58843		
7044713001	HB3	EPA 353.2	58841		
7044713002	HB8	EPA 353.2	58841		
7044713001	HB3	SM20/22 4500-CN-C	60031	SM22 4500-CN-E	60123
7044713002	HB8	SM20/22 4500-CN-C	60031	SM22 4500-CN-E	60123
7044713001	HB3	SM22 4500-CI-E	59247		
7044713002	HB8	SM22 4500-CI-E	59247		
7044713001	HB3	SM22 4500 NH3 H	59387		
7044713002	HB8	SM22 4500 NH3 H	59387		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Sample Request Form PUBLIC WATER SUPPLIER

WELL OFF LINE

WELL RUN TO SYSTEM

Date: 3-7-18

Collected By: K TUTTLE

Accepted By: [Signature]

Cooler Temp: 3.1 °C

3/7/18

1315

Back 1600

Client Info:

Name or Code: HAMPTON BAYS WATER DISTRICT
 Address: P.O. BOX 1413
 HAMPTON BAYS, NEW YORK 11946
 (631) 728-0179

Phone #: _____
 Attn: _____
 Proj. # or (Name): _____
 Bill To: _____
 Copies To: _____

Sample Types	Purpose	Origin	Treatment Types
PW - Potable Water	RO - Routine	D - Distribution	AST - Air Stripper
GW - Groundwater	RE - Resample	RW - Raw Well	GAC - Granular Activated Charcoal
SW - Surface Water	S - Special	TW - Treated Well	N - Nitrate Removal Plant
WW - Waste Water		T - Tank	FE - Iron Removal Plant
AQ - Aqueous		MW - Monitoring Well	O - Other
S - Soil		I - Influent	
		E - Effluent	

Sample Info:

Date/Time Collected:	Sample Type	Location	Origin	Treatment Type	Purpose	Field Readings Cl ₂ pH/Temp	Analysis	Lab No.
<u>8:10AM 3-7-18</u>	<u>PW</u>	<u>#3</u>	<u>D</u>	<u>-</u>	<u>RO</u>	<u>4.0 7.02</u>	<u>I.O.C.</u>	<u>20.7°C 001</u>
<u>10:00AM 3-7-18</u>	<u>PW</u>	<u>#8</u>	<u>D</u>	<u>-</u>	<u>RO</u>	<u>8.8 7.08</u>	<u>IOC</u>	<u>12.5°C 002</u>
<u>10:15AM 3-7-18</u>	<u>PW</u>	<u>ABBIE DERWOOD 57 Homewood DR</u>	<u>D</u>	<u>-</u>	<u>S</u>	<u>.43 7.23</u>	<u>METELS</u>	

Page 26 of 27
 Remarks: _____

WO#: 7044713



1747
6



Sample Condition Upon Receipt

Client Name: HBW

Projec

WO#: 7044713

PM: SWM Due Date: 03/19/18
CLIENT: HBW

Courier: Fed Ex UPS USPS Client Commercial Pace Other

Tracking #: _____

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No

Packing Material: Bubble Wrap Bubble Bags Ziploc None Other

Thermometer Used: TH091

Correction Factor: 0.0

Cooler Temperature (°C): 3.1

Cooler Temperature Corrected (°C): 3.1

Temp should be above freezing to 6.0°C

USDA Regulated Soil: N/A, water sample

Date and Initials of person examining contents: EO 3/7/18

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? YES NO

Did samples originate from a foreign source (internationally, including Hawaii and Puerto Rico)? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

		COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr):	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Containers Intact:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID/Analysis Matrix SL/WT OIL		
All containers needing preservation have been checked	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # <u>H0613865</u>		Sample #
All containers needing preservation are found to be in compliance with EPA recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, NAOH>12 Cyanide)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	Initial when completed: Lot # of added preservative: Date/Time preservative added:
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis		
Samples checked for dechlorination:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
KI starch test strips Lot #		
Residual chlorine strips Lot #		
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15.
Trip Blank Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable):		

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted: _____

Date/Time: _____

Comments/ Resolution: _____